


TABLE 3.3.7.12-1

EXPLOSIVE GAS MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABILITY</u>	<u>ACTION</u>
1 Main Condenser Offgas Treatment System Explosive Gas Monitoring System		*	111
a. Hydrogen Monitor			

\*During main condenser offgas treatment system operation.

ACTION 111:- With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, operation of main condenser offgas treatment system may continue for up to 30 days provided that grab samples are collected at least once per 4 hours and analyzed within the following 4 hours. If the recombiner temperature remains constant and THERMAL POWER has not changed, the grab sample collection frequency may be changed to 8 hours.

CONTROLLED COPY

9209230019 920917  
PDR ADDCK 05000397  
PDR

200

200

200