

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9210080221 DOC. DATE: 92/10/01 NOTARIZED: NO DOCKET #
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397
 AUTH. NAME AUTHOR AFFILIATION
 BAKER, J.W. Washington Public Power Supply System
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards LER 92-035-01 for WNP unit 2.

DISTRIBUTION CODE: IE22T COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+8
 TITLE: 50.73/50.9 Licensee Event Report (LER), Incident Rpt, etc.

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES		
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL	
	PD5 LA		1	1		PD5 PD		1	1	
	DEAN, W.		1	1						
INTERNAL:	ACNW		2	2		ACRS		2	2	
	AEOD/DOA		1	1		AEOD/DSP/TPAB		1	1	
	AEOD/ROAB/DSP		2	2		NRR/DET/EMEB 7E		1	1	
	NRR/DLPQ/LHFB10		1	1		NRR/DLPQ/LPEB10		1	1	
	NRR/DOEA/OEAB		1	1		NRR/DREP/PRPB11		2	2	
	NRR/DST/SELB 8D		1	1		NRR/DST/SICB8H3		1	1	
	NRR/DST/SPLB8D1		1	1		NRR/DST/SRXB 8E		1	1	
	<u>REG FILE</u> 02		1	1		RES/DSIR/EIB		1	1	
	RGN5 FILE 01		1	1						
EXTERNAL:	EG&G BRYCE, J.H		2	2		L ST LOBBY WARD		1	1	
	NRC PDR		1	1		NSIC MURPHY, G.A		1	1	
	NSIC POORE, W.		1	1		NUDOCS FULL TXT		1	1	

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK.
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

A04

FULL TEXT CONVERSION REQUIRED
 TOTAL NUMBER OF COPIES REQUIRED: LTR 31 ENCL 31

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352

October 1, 1992
G02-92-232

Docket No. 50-397

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUBJECT: NUCLEAR PLANT WNP-2, OPERATING LICENSE NPF-21
LICENSEE EVENT REPORT NO. 92-035-01

REFERENCE: Letter, dated August 10, 1992, from KE Perkins (NRC) to
GC Sorensen (SS).

Transmitted herewith is Licensee Event Report No. 92-035-01 for the WNP-2 Plant. This report is submitted in response to the report requirements of 10CFR50.73 and discusses the items of reportability, corrective action taken, and action taken to preclude recurrence.

This supplement is provided in order to provide details and clarifications requested in the referenced letter. The report has been revised to include dates and times for significant occurrences, and information has been reorganized to provide a clearer understanding of circumstances and conditions involved in the event. We recognize the Staff's concern regarding the root cause stated in the original LER. Further review of the event shows that changes to the post-modification testing plan were a contributing cause for event, but were not the primary root cause of the event.

060037

9210080221 921001
PDR ADOCK 05000397
S PDR

JE 11

Document Control Desk (USNRC)


Page 2

October 1, 1992

**NUCLEAR PLANT WNP-2, OPERATING LICENSE NPF-21
LICENSEE EVENT REPORT NO. 92-035-01**

With regard to reportability classification, 10CFR50.73(a)(2)(v) and (vi) address conditions that alone could have prevented a necessary safety function. The conditions involved in this event would not have prevented closure of the Scram Discharge Volume vent and drain valves, and delay of closure for these valves would not have adversely affected operation of the scram function. General concerns expressed regarding root cause assessments will be addressed separately.

Sincerely,



J. W. Baker

WNP-2 Plant Manager (Mail Drop 927M)

JWB/RP/cgeh

Enclosure

cc: Mr. J. B. Martin, NRC - Region V
Mr. W. Ang, NRC Resident Inspector (Mail Drop 901A, 2 Copies)
INPO Records Center - Atlanta, GA
Mr. D. L. Williams, BPA (Mail Drop 399)