

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9210220272 DOC. DATE: ~~92/09/30~~ NOTARIZED: NO DOCKET #
 FAGIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397
 AUTH. NAME AUTHOR AFFILIATION
 HUTCHISON, L. Washington Public Power Supply System
 BAKER, J.W. Washington Public Power Supply System
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Sept 1992 for Washington Nuclear
 Plant 2. W/921012 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PD5 LA		3	3		PD5 PD		1	1
	DEAN, W.		1	1					
INTERNAL:	ACRS.		10	10		AEOD/DOA		1	1
	AEOD/DSP/TPAB		1	1		NRR/DLPO/LPEB10		1	1
	NRR/DOEA/OEAB		1	1		<u>REG FILE</u> 01		1	1
	RGN5		1	1					
EXTERNAL:	EG&G BRYCE, J.H		1	1		NRC PDR		1	1
	NSIC		1	1					

Cert No 118349

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK.
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 24 ENCL 24

MR



WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352-0968 • (509) 372-5000

Docket No. 50-397

October 12, 1992
GO2-92-239

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Dear Sir:

Subject: NUCLEAR PLANT NO. 2
MONTHLY OPERATING REPORT
SEPTEMBER 1992

Transmitted herewith is the Monthly Operating Report for the month of September 1992 as required by our Technical Specifications 6.9.1.6.

Very truly yours,

J.W. Baker
J.W. Baker
WNP-2 Plant Manager
(MD 927M)

LBH:bap

cc: Mr. W.H. Lovelace, NRC, Washington, DC
Mr. J.B. Martin, NRC Region V
Ms. Dottie Sherman, ANI, Hartford, CT
Mr. C. Sorensen, NRC Resident Inspector (901A)
Mr. J.T. Wheelock, INPO
Mr. F. Yost, Utility Data Institute

230002
9210220272 920930
PDR ADDCK 05000397
R PDR

Cent. No 118349
IE24
11

OPERATING DATA REPORT
WNP-2

DATE: October 1, 1992

1. DOCKET: 50-397
2. REPORTING PERIOD: Sep-92 OUTAGE + ON-LINE HOURS: 720
3. UTILITY CONTACT: Leonard Hutchison (509) 377-2486
4. LICENSED THERMAL POWER (MWt): 3323
5. NAMEPLATE RATING (GROSS MWe): 1200.9
6. DESIGN ELECTRICAL RATING (NET MWe): 1100
7. MAXIMUM DEPENDABLE CAPACITY (GROSS MWe): 1129
8. MAXIMUM DEPENDABLE CAPACITY (NET MWe): 1085
9. IF CHANGES OCCUR ABOVE SINCE LAST REPORT, GIVE REASONS: _____
None.

10. POWER TO WHICH RESTRICTED, IF ANY (NET MWe): _____
11. REASONS FOR RESTRICTIONS, IF ANY: None.

12. REPORT PERIOD HOURS MONTH YEAR CUMULATIVE
13. HOURS REACTOR CRITICAL 720.0 6,575.0 68,359.2
14. RX RESERVE SHUTDOWN HOURS 0.0 0.0 340.4
15. HOURS GENERATOR ON LINE 720.0 3,352.7 45,152.5
16. UNIT RESERVE SHUTDOWN HOURS 0.0 0.0 381.7
17. GROSS THERMAL ENERGY (MWH) 2,297,678 10,531,230 130,147,052
18. GROSS ELECTRICAL ENERGY (MWH) 786,590 3,569,210 43,425,030
19. NET ELECTRICAL ENERGY (MWH) 748,199 3,377,166 40,887,006
20. UNIT SERVICE FACTOR 100.0% 51.0% 66.1%
21. UNIT AVAILABILITY FACTOR 100.0% 51.0% 66.6%
22. UNIT CAPACITY FACTOR (MDC NET) 95.8% 47.3% 55.7%
23. UNIT CAPACITY FACTOR (DER NET) 94.5% 46.7% 55.4%
24. UNIT FORCED OUTAGE RATE 0.0% 22.4% 13.9%
25. FORCED OUTAGE HOURS 0.0 969.5 7,273.3
26. SHUTDOWNS SCHEDULED OVER THE NEXT 6 MONTHS (TYPE, DATE, DURATION):
None.

27. IF CURRENTLY SHUTDOWN ESTIMATED STARTUP DATE: _____

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO.: 50-397
UNIT: WNP-2
DATE: OCTOBER 1, 1992
COMPLETED BY: LB HUTCHISON
TELEPHONE: (509) 377-2486

MONTH: SEPTEMBER 1992

DAY AVERAGE DAILY POWER LEVEL (MWe-NET)

1.	554
2.	1032
3.	1082
4.	1088
5.	973
6.	1076
7.	1102
8.	950
9.	880
10.	955
11.	977
12.	1075
13.	1087
14.	1085
15.	1082
16.	1084

DAY AVERAGE DAILY POWER LEVEL (MWe-NET)

17.	1086
18.	1080
19.	1078
20.	1071
21.	1073
22.	1076
23.	1071
24.	1079
25.	1062
26.	1073
27.	1091
28.	1089
29.	1084
30.	1080
31.	0

INSTRUCTIONS

ON THIS FORM, LIST THE AVERAGE DAILY UNIT POWER LEVEL IN MWe-NET FOR EACH DAY IN THE REPORTING MONTH. COMPUTE TO THE NEAREST WHOLE MEGAWATT.

THESE FIGURES WILL BE USED TO PLOT A GRAPH FOR EACH REPORTING MONTH. NOTE THAT WHEN MAXIMUM DEPENDABLE CAPACITY IS USED FOR THE NET ELECTRICAL RATING OF THE UNIT, THERE MAY BE OCCASIONS WHEN THE DAILY AVERAGE POWER LEVEL EXCEEDS THE 100% LINE (OR THE RESTRICTED POWER LEVEL LINE). IN SUCH CASES, THE AVERAGE DAILY UNIT POWER OUTPUT SHEET SHOULD BE FOOTNOTED TO EXPLAIN THE APPARENT ANOMALY.

DOCKET NO.: 50-397
UNIT NAME: WNP-2
DATE: OCTOBER 1, 1992
COMPLETED BY: LB HUTCHISON
TELEPHONE: (509) 377-2486

UNIT SHUTDOWNS / REDUCTIONS

REPORT PERIOD: SEPTEMBER 1992

<u>NO.</u>	<u>DATE</u>	<u>TYPE</u>	<u>HOURS</u>	<u>REASON</u>	<u>METHOD</u>	<u>LER NO</u>	<u>SYSTEM</u>	<u>COMPONENT</u>	<u>CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE</u>
------------	-------------	-------------	--------------	---------------	---------------	---------------	---------------	------------------	--

None

SUMMARY: WNP-2 operated routinely during September with no outages or significant power reductions.

<u>TYPE</u>	<u>REASON</u>		<u>METHOD</u>	<u>SYSTEM & COMPONENT</u>
F-FORCED	A-EQUIP FAILURE	F-ADMIN	1-MANUAL	EXHIBIT F & H
S-SCHED	B-MAINT OR TEST	G-OPER ERROR	2-MANUAL SCRAM	INSTRUCTIONS FOR
	C-REFUELING	H-OTHER	3-AUTO SCRAM	PREPARATION OF
	D-REGULATORY RESTRICTION		4-CONTINUED	DATA ENTRY SHEET
	E-OPERATOR TRAINING &		5-REDUCED LOAD	LICENSEE EVENT REPORT

