

CONTROLLED COPY

REACTIVITY CONTROL SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

4.1.3.1.4 The scram discharge volume shall be determined OPERABLE by demonstrating:

- a. The scram discharge volume drain and vent valves OPERABLE, when ~~control rods are scram tested from a normal control rod configuration of less than or equal to 50% ROD DENSITY~~ at least once per 18 months, (*) by verifying that the drain and vent valves:

1. Close within 30 seconds after receipt of ~~a signal for control rods to scram~~, and *an actual or simulated scram*
2. Open when the ~~scram signal is reset~~. *actual or simulated*

- b. Proper float response by performance of a CHANNEL FUNCTIONAL TEST of the scram discharge volume scram and control rod block level instrumentation after each scram from a pressurized condition.

~~*The provisions of Specification 4.0.4 are not applicable for entry into OPERATIONAL CONDITION 2 provided the surveillance is performed within 12 hours after achieving less than or equal to 50% ROD DENSITY.~~

