

ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9305070060 DOC. DATE: ~~92/12/31~~ NOTARIZED: NO DOCKET #
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397
 AUTH. NAME AUTHOR AFFILIATION
 SORESEN, G.C. Washington Public Power Supply System
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: "WNP-2 Cooling Water Blowdown Discharges, 1992." W/930426
 ltr.

DISTRIBUTION CODE: IE25D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
 TITLE: Environmental Monitoring Rept (per Tech Specs)

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PDV LA	3 3	PDV PD	1 1
CLIFFORD, J	1 1		
INTERNAL: ACRS	1 1	NRR/DRSS/PRPB11	2 2
<u>REG FILE</u> 01	1 1	RGN5 DRSS/RPB	1 1
RGN5 FILE 02	1 1		
EXTERNAL: EG&G SIMPSON, F	2 2	NRC PDR	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 14

Er-1

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352-0968 • (509) 372-5000

April 26, 1993
G02-93-095

Docket No. 50-397

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Station P1-137
Washington, D.C. 20555


Subject: **NUCLEAR PLANT NO. 2, OPERATING LICENSE NPF-21
1992 ANNUAL ENVIRONMENTAL OPERATING REPORT**

This letter is submitted per reporting requirements of Section 5.4.1 of the WNP-2 Environmental Protection Plan (EPP; Appendix B to OL).

A summary of the effluent data reported to the State of Washington on the monthly discharge monitoring reports is attached. No design or operational changes or tests in 1992 involved an unreviewed environmental question. Also, no non-routine nonradiological reports (within the context of EPP Section 5.4.2) were required for 1992.

Please contact us if you require additional information on this report.

Sincerely,



G. C. Sorensen, Manager
Regulatory Programs (Mail Drop PE20)

Attachment: Table of 1992 effluent data

cc: JB Martin - NRC RV
JW Clifford - NRC NRR
RC Barr - NRC RI/901A
JJ Zeller - EFSEC

050040

9305070060 921231
PDR ADOCK 05000397
R PDR

TEPS
11

THE UNIVERSITY OF CHICAGO

DEPARTMENT OF THE HISTORY OF ARTS

THE UNIVERSITY OF CHICAGO
DEPARTMENT OF THE HISTORY OF ARTS
THE UNIVERSITY OF CHICAGO
DEPARTMENT OF THE HISTORY OF ARTS

WNP-2 COOLING WATER BLOWDOWN DISCHARGES, 1992

Month	Days of Discharge	pH		TRC (mg/l)	Discharge Volume (millions of gallons)		
		High	Low		Total	Ave*	Max**
Jan	31	8.5	7.9	≤0.1	111.8	3.61	5.62
Feb	26	8.5	7.8	≤0.1	95.16	3.66	5.18
Mar	15	8.6	7.4	≤0.1	45.90	3.06	5.40
Apr	25	8.7	7.0	≤0.1	77.23	3.09	6.05
May	31	8.8	7.2	≤0.1	69.65	2.25	2.27
Jun	25	8.7	7.0	≤0.1	53.58	2.14	2.27
Jul	26	8.7	7.7	≤0.1	66.02	2.54	4.10
Aug	29	8.5	6.8	≤0.1	131.0	4.52	6.48
Sep	28	8.5	7.0	≤0.1	97.67	3.49	5.83
Oct	31	8.6	7.5	≤0.1	104.5	3.37	5.94
Nov	29	8.6	7.5	≤0.1	99.18	3.42	5.94
Dec	31	8.7	7.6	≤0.1	105.0	3.39	5.62
Permit Limit		9.0	6.5	0.1		5.00	9.40

* Average daily discharge during the month.

** Maximum daily discharge during the month.

2001-2002
2001-2002