

ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9306170290 DOC. DATE: 93/06/09 NOTARIZED: YES DOCKET #
FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Power 05000397
AUTH. NAME AUTHOR AFFILIATION
PARRISH, J.V. Washington Public Power Supply System
RECIP. NAME RECIPIENT AFFILIATION
Document Control Branch (Document Control Desk)

SUBJECT: Responds to NRC Bulletin 93-002, informs that suspected matl was not used in WNP-2 primary containment therefore, no need to take actions to remove matl.

DISTRIBUTION CODE: IE11D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
TITLE: Bulletin Response (50 DKT)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PDV PD	1 1	CLIFFORD, J	1 1
INTERNAL:	AEOD/DOA	1 1	NRR/DE/EMEB	1 1
	NRR/DRPW/OGCB	1 1	NRR/DRSS/PEPB	1 1
	NRR/DSSA	1 1	NRR/PDIII-2	1 1
	NRR/SCSB	1 1	REG FILE 02	1 1
	RES/DSIR/EIB	1 1	RGN5 FILE 01	1 1
EXTERNAL:	NRC PDR	1 1	NSIC	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 14

A01

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352-0968 • (509) 372-5000

June 9, 1993
G02-93-142

Docket No. 50-397

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: **WNP-2, OPERATING LICENSE NPF-21
RESPONSE TO NRC BULLETIN NO. 93-02**

This letter provides the required response to NRC Bulletin No. 93-02: Debris Plugging of Emergency Core Cooling Suction Strainers.

Upon receipt of the subject bulletin, in response to the requested actions, the Supply System promptly determined that the Primary Containment ventilation system used no fibrous filters as part of its design. Temporary ventilation units brought into the drywell to control airborne contamination during maintenance of contaminated components are designed with enclosed filtration cartridges. As such, they cannot contribute to migration of fibrous material from the drywell to the suppression pool. The Supply System does not store fibrous materials in the drywell during normal operation. It was also determined that the Supply System uses no other temporary sources of fibrous material in the drywell that are not designed to withstand a Loss Of Coolant Accident. The preceding statements satisfy Reporting Requirement Number One of the subject bulletin.

As none of the suspect material is used in the WNP-2 Primary Containment, there was no need to take immediate, compensatory actions or to provide for removal of such material. For this reason, this letter also serves as the 30 day letter of Reporting Requirement Number Two of this bulletin.

Reporting Requirement Number Three is not applicable, as the Supply System has taken the Requested Actions of this bulletin.

Sincerely,




J. V. Parrish (Mail Drop 1023)
Assistant Managing Director, Operations

cc: BH Faulkenberry - NRC RV
NS Reynolds - Winston & Strawn
JW Clifford - NRC

DL Williams - BPA/399
NRC Site Inspector - 901A

9306170290 930609
PDR ADDCK 05000397
Q PDR




STATE OF WASHINGTON)
)
COUNTY OF BENTON)

Subject: Response to NRC Bulletin
No. 93-02

I. J. V. PARRISH, being duly sworn, subscribe to and say that I am the Assistant Managing Director, Operations for the WASHINGTON PUBLIC POWER SUPPLY SYSTEM, the applicant herein; that I have the full authority to execute this oath; that I have reviewed the foregoing; and that to the best of my knowledge, information, and belief the statements made in it are true.


DATE 9 June, 1993



J. V. Parrish, Assistant Managing Director
Operations

On this date personally appeared before me J. V. PARRISH, to me known to be the individual who executed the foregoing instrument, and acknowledged that he signed the same as his free act and deed for the uses and purposes herein mentioned.

GIVEN under my hand and seal this 9th day of June 1993.



Notary Public in and for the
STATE OF WASHINGTON

Residing at Kennewick, Washington

My Commission Expires August 9, 1995