

ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULAR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9306300063 DOC. DATE: 93/06/18 NOTARIZED: NO DOCKET #
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Power 05000397
 AUTH. NAME AUTHOR AFFILIATION
 PARRISH, J.V. Washington Public Power Supply System
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards LER 92-037-02. Rev provides updated info re C/As for manual reactor scram due to core instability. Commitment to obtain amend to TS to eliminate requirements for calculating "T" deleted. Confusion eliminated through training.

DISTRIBUTION CODE: IE22T COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 18+2
 TITLE: 50.73/50.9 Licensee Event Report (LER), Incident Rpt, etc.

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PDV LA	1 1	PDV PD	1 1
	CLIFFORD, J	1 1		
INTERNAL:	ACNW	2 2	ACRS	2 2
	AEOD/DOA	1 1	AEOD/DSP/TPAB	1 1
	AEOD/ROAB/DSP	2 2	NRR/DE/EELB	1 1
	NRR/DE/EMEB	1 1	NRR/DORS/OEAB	1 1
	NRR/DRCH/HHFB	1 1	NRR/DRCH/HICB	1 1
	NRR/DRCH/HOLB	1 1	NRR/DRIL/RPEB	1 1
	NRR/DRSS/PRPB	2 2	NRR/DSSA/SPLB	1 1
	NRR/DSSA/SRXB	1 1	REG FILE 02	1 1
	RES/DSIR/EIB	1 1	RGN5 FILE 01	1 1
EXTERNAL:	EG&G BRYCE, J.H	2 2	L ST LOBBY WARD	1 1
	NRC PDR	1 1	NSIC MURPHY, G.A	1 1
	NSIC POORE, W.	1 1	NUDOCS FULL TXT	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

FULL TEXT CONVERSION REQUIRED
 TOTAL NUMBER OF COPIES REQUIRED: LTTR 32 ENCL 32

A04

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352

June 18, 1993
G02-93-163

Docket No. 50-397

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: **NUCLEAR PLANT WNP-2, OPERATING LICENSE NPF-21
LICENSEE EVENT REPORT NO. 92-037-02**

- References:
- 1) Letter dated August 15, 1992, J.B. Martin (NRC) to A.L. Oxsen (SS), "Confirmatory Action Letter"
 - 2) Letter dated August 29, 1992, A.L. Oxsen (SS) to J.B. Martin (NRC), "Response to Confirmatory Action Letter"
 - 3) Letter dated September 14, 1992, A.L. Oxsen (SS) to J.B. Martin (NRC), "Additional Response to Confirmatory Action Letter"
 - 4) Letter dated September 14, 1992, J.W. Baker (SS) to Document Control Desk (NRC), "Licensee Event Report No. 92-037-0"
 - 5) Letter dated September 29, 1992, J.B. Martin (NRC) to A.L. Oxsen (NRC), "NRC Augmented Inspection"
 - 6) Letter dated October 30, 1992, A.L. Oxsen (SS) to J.B. Martin (NRC), "Response to NRC Augmented Inspection Team Report"
 - 7) Letter dated November 2, 1992, J.W. Baker (SS) to Document Control Desk (NRC), "Licensee Event Report No. 92-037-1"

Transmitted herewith is LER 92-037-02 for the WNP-2 Plant. This LER revision provides updated information regarding the corrective actions for the manual reactor scram due to core instability and associated reportable events. The commitment to obtain an amendment to the Technical Specifications to eliminate the requirement for calculating "T" has been deleted. The change to the Technical Specifications was proposed in order to eliminate confusion regarding this requirement. The confusion was eliminated through training and procedure revision. A Technical Specification change deleting "T" is not necessary.

250003

9306300063 930618
PDR ADOCK 05000397
S PDR


1522
11

**NUCLEAR PLANT WNP-2, OPERATING LICENSE NPF-21
LICENSEE EVENT REPORT NO. 92-037-02**

As discussed in Reference 2, the date for the installation of adjustable speed drives for the Reactor Recirculation System pumps has been moved from June of 1994 to June of 1996. Other changes in this LER reflect the completion of corrective actions.

In the response to the Notice of Violation for this event, Reference 3, the Supply System reiterated many of the corrective actions committed to in LER 92-037-01. This revision to the LER also serves to update the commitments repeated within Reference 3. To avoid future confusion, changes made to commitments that are in the LER and the NOV response will be made as revisions to the LER.

Sincerely,



J. V. Parrish (Mail Drop 1023)
Assistant Managing Director, Operations

JVP/MGE/jd

Enclosure

cc: Mr. B. H. Faulkenberry, NRC - Region V
Mr. R. Barr, NRC Resident Inspector (Mail Drop 901A, 2 Copies)
INPO Records Center - Atlanta, GA
Mr. D. L. Williams, BPA (Mail Drop 399)