

TABLE 3.6.3-1 (Continued)
PRIMARY CONTAINMENT ISOLATION VALVES

| <u>VALVE FUNCTION AND NUMBER</u> | <u>VALVE GROUP(a)</u> | <u>MAXIMUM ISOLATION TIME (Seconds)</u> |
|--|-----------------------|---|
| a. <u>Automatic Isolation Valves (Continued)</u> | | |
| Reactor Core Isolation Cooling | | |
| RCIC-V-8 | 8 | 18(j) 26 |
| RCIC-V-63 | 8 | 16(j) 22 |
| RCIC-V-76 | 8 | |
| Low Pressure Core Spray | | |
| LPCS-V-12 | 10 | 180 |
| High Pressure Core Spray | | |
| HPCS-V-23 | 11 | 180 |
| b. <u>Excess Flow Check Valves(e)</u> | | |
| Containment Atmosphere | | N.A. |
| PI-EFC-X29d | | |
| PI-EFC-X29f | | |
| PI-EFC-X30a | | |
| PI-EFC-X30f | | |
| PI-EFC-X42c | | |
| PI-EFC-X42f | | |
| PI-EFC-X61c | | |
| PI-EFC-X62b | | |
| PI-EFC-X69f | | |
| PI-EFC-X78a | | |

DELETION OF THIS PAGE REQUESTED IN PREVIOUS SUBMITTAL
 SEE: G02-93-256, DATED OCTOBER 21, 1993

CONTROLLED COPY

STATE OF WASHINGTON)
)
COUNTY OF BENTON)

Subject: Request for Amend to Tech Spec
Table 3.6.3-1, Primary Containment

I, J. V. PARRISH, being duly sworn, subscribe to and say that I am the Assistant Managing Director, Operations for the WASHINGTON PUBLIC POWER SUPPLY SYSTEM, the applicant herein; that I have the full authority to execute this oath; that I have reviewed the foregoing; and that to the best of my knowledge, information, and belief the statements made in it are true.


DATE 9 February, 1994



J. V. Parrish, Assistant Managing Director
Operations

On this date personally appeared before me J. V. PARRISH, to me known to be the individual who executed the foregoing instrument, and acknowledged that he signed the same as his free act and deed for the uses and purposes herein mentioned.

GIVEN under my hand and seal this 9 day of February, 1994.



Notary Public in and for the
STATE OF WASHINGTON

Residing at Rushland, WA

My Commission Expires Dec. 97



2007

