

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9403090305 DOC. DATE: 94/02/25 NOTARIZED: NO DOCKET #
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397
 AUTH. NAME AUTHOR AFFILIATION
 PARRISH, J.V. Washington Public Power Supply System
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: "1993 Annual Environ Operating Rept," including summary of effluent data reported to State of Washington on monthly discharge monitoring reports. No nonradiological repts within context of EPP Section 5.4.2 required for 1993.

DISTRIBUTION CODE: IE25D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
 TITLE: Environmental Monitoring Rept (per Tech Specs)

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PDV LA	3 3	PDV PD	1 1
CLIFFORD, J	1 1		
INTERNAL: ACRS	1 1	NRR/DRSS/PRPB11	2 2
REG FILE 01	1 1	RGN5 DRSS/RPB	1 1
RGN5 FILE 02	1 1		
EXTERNAL: EG&G SIMPSON, F	2 2	NRC PDR	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 14

Er-1



WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352-0968 • (509) 372-5000

February 25, 1994
G02-94-048

Docket No. 50-397

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Station P1-37
Washington, D.C. 20555

Subject: **NUCLEAR PLANT NO. 2, OPERATING LICENSE NPF-21
1993 ANNUAL ENVIRONMENTAL OPERATING REPORT**

This letter is submitted per reporting requirements of Section 5.4.1 of the WNP-2 Environmental Protection Plan (EPP; Appendix B to OL).

A summary of the effluent data reported to the State of Washington on the monthly discharge monitoring reports is attached. No design or operational changes or tests in 1993 involved an unreviewed environmental question. Also, no non-routine nonradiological reports (within the context of EPP Section 5.4.2) were required for 1993.

Please contact us if you require additional information on this report.

Sincerely,

J.V. Parrish (Mail Drop 1023)
Assistant Managing Director, Operations

Attachment: Table of 1993 effluent data

cc: KE Perkins - NRC RV
JW Clifford - NRC NRR
RC Barr - NRC RI (927N)
JJ Zeller - EFSEC

7403090305 931231
PDR ADDCK 05000397
R PDR



1025

WNP-2 COOLING WATER BLOWDOWN DISCHARGES, 1993

Month	Days of Discharge	pH		TRC (mg/l)	Discharge Volume (millions of gallons)		
		High	Low		Total	Ave*	Max**
Jan	26	8.5	7.5	≤0.1	78.58	3.02	6.05
Feb	28	8.3	7.2	≤0.1	100.2	3.58	6.02
Mar	31	8.3	7.8	≤0.1	90.09	2.93	4.10
Apr	30	8.6	7.5	≤0.1	86.30	2.88	4.75
May	23	8.8	7.0	≤0.1	60.40	2.63	5.35
Jun	26	8.8	7.0	≤0.1	60.40	2.32	4.52
Jul	31	8.5	7.5	≤0.1	118.0	3.82	6.48
Aug	30	8.4	7.5	≤0.1	85.70	2.86	4.86
Sep	30	8.6	7.7	≤0.1	72.00	2.40	4.02
Oct	31	8.4	7.8	≤0.1	70.60	2.28	3.89
Nov	30	8.5	7.6	≤0.1	62.80	2.09	4.32
Dec	31	8.3	7.6	≤0.1	117.0	3.78	6.26
Permit Limit		9.0	6.5	0.1		5.00	9.40

* Average daily discharge during the month.

** Maximum daily discharge during the month.