

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9405120207 DOC. DATE: 94/05/05 NOTARIZED: NO DOCKET #  
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Power 05000397

AUTH. NAME: PARRISH, J. V. AUTHOR AFFILIATION: Washington Public Power Supply System  
 RECIP. NAME: RECIPIENT AFFILIATION: Document Control Branch (Document Control Desk)

SUBJECT: Application for amend to license NPF-21, requesting mod of three equipment piece numbers included in Table 3.6.3-1, "Primary Containment Isolation Valves."

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3+7  
 TITLE: OR Submittal: General Distribution

### NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PDIV-3 LA	1 1	PDIV-3 PD	1 1
	CLIFFORD, J	2 2		
INTERNAL:	ACRS	6 6	NRR/DE/EELB	1 1
	NRR/DORS/OTSB	1 1	NRR/DRCH/HICB	1 1
	NRR/DRPW	1 1	NRR/DSSA/SPLB	1 1
	NRR/DSSA/SRXB	1 1	NUDOCS-ABSTRACT	1 1
	OC/LFDCB	1 0	OGC/HDS1	1 0
	<u>REG FILE</u> 01	1 1		
EXTERNAL:	NRC PDR	1 1	NSIC	1 1

### NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 22 ENCL 20

AA2



WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352-0968 • (509) 372-5000

May 5, 1994  
G02-94-107

Docket No. 50-397

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Mail Station PI-37  
Washington, D.C.

Gentlemen:

Subject: **WNP-2, OPERATING LICENSE NPF-21  
REQUEST FOR AMENDMENT TO TECHNICAL SPECIFICATION  
3/4.6.3, PRIMARY CONTAINMENT ISOLATION VALVES**

Reference: 1. Letter, GO2-93-256, JV Parrish (SS) to NRC, "Request for Amendment to Technical Specifications to Relocate Component Lists in Accordance with Generic Letter 91-08...", dated October 21, 1993.  
2. Letter, G02-94-099, JV Parrish (SS) to NRC, "NRC Inspection Report 94-02 Reply to a Notice of Violation," dated April 29, 1994.

In accordance with the Code of Federal Regulations, Title 10, Parts 50.90 and 2.101, the Supply System hereby submits a request for amendment to the WNP-2 Technical Specifications. Specifically, the Supply System is requesting modification of three equipment piece numbers (EPNs) included in Table 3.6.3-1, "Primary Containment Isolation Valves."

The following changes are requested:

<u>EXISTING EPN</u>	<u>PROPOSED EPN</u>	<u>REASON FOR CHANGE</u>
PI-EFC-X29d	PI-EFC-X29b	Conformity to existing EPN assignment. This is an administrative change only.
PI-EFCX-72f	PI-V-X72f/1	Reflect design change to be implemented during R-9 refueling outage.
PI-EFCX-73e	PI-V-X73e/1	Reflect design change to be implemented during R-9 refueling outage.

9405120207 940505  
PDR ADDCK 05000397  
PDR

A001  
1/1

TFGL38.

Page 2

**REQUEST FOR AMENDMENT TO TECHNICAL SPECIFICATION 3/4.6.3,  
PRIMARY CONTAINMENT ISOLATION VALVES**


Reference 1 previously requested relocation of Table 3.6.3-1 to a plant procedure which would be controlled pursuant to the requirements of 10CFR50.59 and Technical Specification 6.8.1.

Renaming PI-EFC-X29d is an administrative change. Excess flow check valves PI-EFCX-72f and PI-EFCX-73e will be replaced with swing check valves to conform the plant to the analyzed design basis. This replacement requires that the check valves be renamed. Replacing the existing excess flow check valves with swing check valves represents a reduced risk to public health and safety. Granting this request involves no adverse safety impact. Attachment 1 to this letter provides the requested change. Attachment 2 provides additional information.

Approval of this amendment is required to support startup following the R-9 refueling outage; therefore, staff approval is requested by June 15, 1994.

Should you have any questions or desire additional information, please contact me or H.E. Kook at (509) 377-4278.

Sincerely,



J.V. Parrish (Mail Drop 1023)  
Assistant Managing Director, Operations

JVP/LCF/bk  
Attachments

cc: LJ Callan - NRC RIV  
KE Perkins, Jr. - NRC RIV, Walnut Creek Field Office  
NS Reynolds - Winston & Strawn  
JW Clifford - NRC  
DL Williams - BPA/399  
NRC Sr. Resident Inspector - 927N



STATE OF WASHINGTON )  
COUNTY OF BENTON )

Subject: Request for Amendment to TS  
3/4.6.3, Primary Containment  
Isolation Valves

I, J. V. PARRISH, being duly sworn, subscribe to and say that I am the Assistant Managing Director, Operations for the WASHINGTON PUBLIC POWER SUPPLY SYSTEM, the applicant herein; that I have the full authority to execute this oath; that I have reviewed the foregoing; and that to the best of my knowledge, information, and belief the statements made in it are true.

DATE May 5, 1993

J. V. Parrish  
J. V. Parrish, Assistant Managing Director  
Operations

On this date personally appeared before me J. V. PARRISH, to me known to be the individual who executed the foregoing instrument, and acknowledged that he signed the same as his free act and deed for the uses and purposes herein mentioned.

GIVEN under my hand and seal this 5<sup>th</sup> day of May 1993.

Traci M. Hardy  
Notary Public in and for the  
STATE OF WASHINGTON



Residing at Kennewick, Washington

My Commission Expires August 9, 1995

