

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9405160091 DOC.DATE: 94/05/06 NOTARIZED: YES DOCKET #
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397
 AUTH.NAME AUTHOR AFFILIATION
 PARRISH, J.V. Washington Public Power Supply System
 RECIP.NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Application for amend to license NPF-21, revising TSS
 3/4.3.7.5, 3/4.4.2 & 3/4.5.1 for main steam relief valve
 position indication.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4+9
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PDIV-3 LA	1 1	PDIV-3 PD	1 1
	CLIFFORD, J	2 2		
INTERNAL:	ACRS	6 6	NRR/DE/EELB	1 1
	NRR/DORS/OTSB	1 1	NRR/DRCH/HICB	1 1
	NRR/DRPW	1 1	NRR/DSSA/SPLB	1 1
	NRR/DSSA/SRXB	1 1	NUDOCS-ABSTRACT	1 1
	OC/LEDGB	1 0	OGC/HDS1	1 0
	<u>REG FILE</u> 01	1 1		
EXTERNAL:	NRC PDR	1 1	NSIC	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 22 ENCL 20

AA2



WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352-0968 • (509) 372-5000

May 6, 1994
GO2-94-109

Docket No. 50-397

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: WNP-2, OPERATING LICENSE NPF-21 REQUEST FOR AMENDMENT TO TECHNICAL SPECIFICATIONS 3/4.3.7.5, 3/4.4.2, AND 3/4.5.1 FOR MAIN STEAM RELIEF VALVE POSITION INDICATION - SUPPLEMENTAL INFORMATION

Reference: Letter GO2-93-281, dated December 6, 1993, JV Parrish (SS) to NRC, "Request for Amendment to Technical Specifications for Main Steam Relief"

The purpose of this letter is to clarify the intent of the Supply System's request for amendment to Technical Specifications for main steam relief valve position indication submitted by the referenced letter. This request consists of proposed changes to Technical Specifications 3/4.3.7.5, "Accident Monitoring Instrumentation," 3/4.4.2, "Safety/Relief Valves," and 3/4.5.1, "Emergency Core Cooling Systems." These proposed changes require modification of Bases section 3/4.4.2. The proposed changes would clarify the operating conditions required for Safety Relief Valve (SRV) and Automatic Depressurization System SRV surveillance testing.

The current Technical Specifications and Bases are provided in Attachment 1 with the proposed changes annotated. Additional detail is provided in Attachment 2.

Granting the request involves no adverse safety impact and does not involve a significant hazards consideration.

9405160091 940506
PDR ADOCK 05000397
P. PDR

ADD 1

Page 2

**REQUEST FOR AMENDMENT TO TECHNICAL SPECIFICATIONS 3/4.3.7.5, 3/4.4.2,
AND 3/4.5.1 FOR MAIN STEAM RELIEF VALVE POSITION INDICATION -
SUPPLEMENTAL INFORMATION**

Approval of this amendment is required to support startup following the R-9 refueling outage, therefore staff approval is requested by June 15, 1994.

Should you have any questions or desire additional information regarding this matter, please call me or H. E. Kook at (509) 377-4278.

Sincerely,



J. V. Parrish (Mail Drop 1023)
Assistant Managing Director, Operations

DAS/bk
Attachments

cc: LJ Callan - NRC RIV
KE Perkins, Jr. - NRC RIV, Walnut Creek Field Office
NS Reynolds - Winston & Strawn
JW Clifford - NRC
DL Williams - BPA/399
NRC Sr. Resident Inspector - 927N

STATE OF WASHINGTON)
)
COUNTY OF BENTON)

Subject: Request for Amendment to TS
- SRV Testing Requirements


I, J. V. PARRISH, being duly sworn, subscribe to and say that I am the Assistant Managing Director, Operations for the WASHINGTON PUBLIC POWER SUPPLY SYSTEM, the applicant herein; that I have the full authority to execute this oath; that I have reviewed the foregoing; and that to the best of my knowledge, information, and belief the statements made in it are true.

DATE 6 May, 1993


J. V. Parrish, Assistant Managing Director
Operations

On this date personally appeared before me J. V. PARRISH, to me known to be the individual who executed the foregoing instrument, and acknowledged that he signed the same as his free act and deed for the uses and purposes herein mentioned.

GIVEN under my hand and seal this 6th day of May 1993.


Notary Public in and for the
STATE OF WASHINGTON



Residing at Kennewick, Washington

My Commission Expires August 9, 1995



**REQUEST FOR AMENDMENT TO TECHNICAL SPECIFICATIONS 3/4.3.7.5, 3/4.4.2,
AND 3/4.5.1 FOR MAIN STEAM RELIEF VALVE POSITION INDICATION -
SUPPLEMENTAL INFORMATION**

Attachment 1
Page 1 of 5

LIST OF AFFECTED PAGES

<u>Page</u>	<u>Section</u>	<u>Description of Change(s)</u>
3/4 3-74	Accident Monitoring Instrumentation	Revised Table 4.3.7.5-1 to include note which qualifies SRV position indicator applicability and surveillance requirements, including the exception provided by Technical Specification 4.0.4
3/4 4-7a	Safety/Relief Valves	Revised note 4.4.2.b "***" to identify that the 12-hour time limitation for performing the safety relief valve (SRV) position indicator surveillance testing starts when plant steam pressure and flow are adequate to perform the test.
3/4 5-5	Emergency Core Cooling Systems - Operating	Revised note 4.5.1.e.3.b "*" to identify that the 12-hour time limitation for performing the Automatic Depressurization System SRV surveillance testing starts when plant steam pressure and flow are adequate to perform the test.
B 3/4 4-1a	Reactor Coolant System Bases Safety/Relief Valves	Revised to include "adequate steam pressure and flow" to the description of "lower power" in describing testing of SRVs.