

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9208210215 DOC. DATE: ~~92/07/31~~ NOTARIZED: NO DOCKET #
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397
 AUTH. NAME AUTHOR AFFILIATION
 HUTCHISON, L. B. Washington Public Power Supply System
 BAKER, J. W. Washington Public Power Supply System
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Jul 1992 for WNP-2. "W/920805"
 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD5 LA	3 3	PD5 PD	1 1
DEAN, W.	1 1		
INTERNAL: ACRS	10 10	AEOD/DOA	1 1
AEOD/DSP/TPAB	1 1	NRR/DLPQ/LPEB10	1 1
NRR/DOEA/OEAB	1 1	<u>REG FILE</u> 01	1 1
RGNS	1 1		
EXTERNAL: EG&G BRYCE, J. H	1 1	NRC PDR	1 1
NSIC	1 1		

*Cont NO
1169331*

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK.
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 24 ENCL 24

MR



WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352-0968 • (509) 372-5000

Docket No. 50-397

August 5, 1992
GO2-92-186

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Dear Sir:

Subject: **NUCLEAR PLANT NO. 2**
 MONTHLY OPERATING REPORT
 JULY 1992

Transmitted herewith is the Monthly Operating Report for the month of July 1992 as required by our Technical Specifications 6.9.1.6.

Very truly yours,

J.W. Baker for

J.W. Baker
WNP-2 Plant Manager
(MD 927M)

LBH:bap

cc: Mr. W.H. Lovelace, NRC, Washington, DC
 Mr. J.B. Martin, NRC Region V
 Ms. Dottie Sherman, ANI, Hartford, CT
 Mr. C. Sorensen, NRC Resident Inspector (901A)
 Mr. J.T. Wheelock, INPO
 Mr. F. Yost, Utility Data Institute

9208210215 920731
PDR/JADOCK 05000397
R PDR

Cent No 118, 331
IE2A
11

120008

DOCKET NO.: 50-397
UNIT NAME: WNP-2
DATE: AUGUST 1, 1992
COMPLETED BY: LB HUTCHISON
TELEPHONE: (509) 377-2486

UNIT SHUTDOWNS / REDUCTIONS

REPORT PERIOD: JULY 1992

<u>NO.</u>	<u>DATE</u>	<u>TYPE</u>	<u>HOURS</u>	<u>REASON</u>	<u>METHOD</u>	<u>LER NO</u>	<u>SYSTEM</u>	<u>COMPONENT</u>	<u>CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE</u>
92-03	4/18/92	S	460.4	C	4	--	RC	FUEL XX	Concluded refueling outage R-7.
92-04	7/20/92	S	3.7	B	1	--	HA	MECFUN	Generator was removed from service for overspeed testing and turbine bypass valve testing. It was resynchronized to grid after successful completion of testing.
92-05	7/21/92	S	16.4	B	1	--	HA	TURBIN	Generator was removed from grid for torsional testing of turbine rotors. After satisfactory completion of testing, it was returned to service.

SUMMARY: WNP-2 returned to service from refueling. Subsequently, two scheduled outages for testing were completed.

<u>TYPE</u>	<u>REASON</u>	<u>METHOD</u>	<u>SYSTEM & COMPONENT</u>
F-FORCED S-SCHED	A-EQUIP FAILURE B-MAINT OR TEST C-REFUELING D-REGULATORY RESTRICTION E-OPERATOR TRAINING & LICENSE EXAM	F-ADMIN G-OPER ERROR H-OTHER	EXHIBIT F & H INSTRUCTIONS FOR PREPARATION OF DATA ENTRY SHEET LICENSEE EVENT REPORT (LER) FILE (NUREG-0161)

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO.: 50-397
UNIT: WNP-2
DATE: AUGUST 1, 1992
COMPLETED BY: LB HUTCHISON
TELEPHONE: (509) 377-2486

MONTH: JULY 1992

DAY AVERAGE DAILY POWER LEVEL (MWe-NET)

1.	0
2.	0
3.	0
4.	0
5.	0
6.	0
7.	0
8.	0
9.	0
10.	0
11.	0
12.	0
13.	0
14.	0
15.	0
16.	0

DAY AVERAGE DAILY POWER LEVEL (MWe-NET)

17.	0
18.	0
19.	0
20.	101
21.	36
22.	343
23.	613
24.	875
25.	802
26.	857
27.	1019
28.	1085
29.	1083
30.	1089
31.	1022

INSTRUCTIONS

ON THIS FORM, LIST THE AVERAGE DAILY UNIT POWER LEVEL IN MWe-NET FOR EACH DAY IN THE REPORTING MONTH. COMPUTE TO THE NEAREST WHOLE MEGAWATT.

THESE FIGURES WILL BE USED TO PLOT A GRAPH FOR EACH REPORTING MONTH. NOTE THAT WHEN MAXIMUM DEPENDABLE CAPACITY IS USED FOR THE NET ELECTRICAL RATING OF THE UNIT, THERE MAY BE OCCASIONS WHEN THE DAILY AVERAGE POWER LEVEL EXCEEDS THE 100% LINE (OR THE RESTRICTED POWER LEVEL LINE). IN SUCH CASES, THE AVERAGE DAILY UNIT POWER OUTPUT SHEET SHOULD BE FOOTNOTED TO EXPLAIN THE APPARENT ANOMALY.

OPERATING DATA REPORT
WNP-2

DATE: 01-Aug-92

1. DOCKET: 50-397
2. REPORTING PERIOD: Jul-92 OUTAGE + ON-LINE HOURS 744
3. UTILITY CONTACT: LEONARD HUTCHISON (509) 377-2486
4. LICENSED THERMAL POWER (MWt): 3323
5. NAMEPLATE RATING (GROSS MWe): 1200.9
6. DESIGN ELECTRICAL RATING (NET MWe): 1100
7. MAXIMUM DEPENDABLE CAPACITY (GROSS MWe): 1129
8. MAXIMUM DEPENDABLE CAPACITY (NET MWe): 1085

9. IF CHANGES OCCUR ABOVE SINCE LAST REPORT, GIVE REASONS:

None

10. POWER TO WHICH RESTRICTED, IF ANY (NET MWe):

11. REASONS FOR RESTRICTIONS, IF ANY:

None

	MONTH	YEAR	CUMULATIVE
12. REPORT PERIOD HOURS	744	5111	66895.2
13. HOURS REACTOR CRITICAL	362.5	2447.5	45838.2
14. RX RESERVE SHTDWN HRS	0.0	0.0	340.4
15. HRS GENERATOR ON LINE	263.5	2306.2	44106.0
16. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	381.7
17. GROSS THERMAL ENERGY (MWH)	684858	7273108	126888930
18. GROSS ELECTRICAL ENERGY (MWH)	227300	2460830	42316650
19. NET ELECTRICAL ENERGY (MWH)	207280	2330190	40588229
20. UNIT SERVICE FACTOR	35.4%	45.1%	65.9%
21. UNIT AVAILABILITY FACTOR	35.4%	45.1%	66.5%
22. UNIT CAPACITY FACTOR (MDC NET)	25.7%	42.0%	55.5%
23. UNIT CAPACITY FACTOR (DER NET)	25.3%	41.4%	55.2%
24. UNIT FORCED OUTAGE RATE	0.0%	19.3%	13.5%
25. FORCED OUTAGE HOURS	0.0	552.0	6855.8

26. SHUTDOWNS SCHEDULED OVER THE NEXT 6 MONTHS (TYPE, DATE, DURATION):

None

27. IF CURRENTLY SHUTDOWN ESTIMATED STARTUP DATE:

