

SPECIAL TEST EXCEPTIONS

3/4.10.7 INSERVICE LEAK AND HYDROSTATIC TESTING

LIMITING CONDITION FOR OPERATION

3.10.7 When conducting Reactor Vessel inservice leak or hydrostatic testing, the average reactor coolant temperature specified in Table 1.2 for OPERATIONAL CONDITION 4 may be increased above 200°F, and operation considered not to be in OPERATIONAL CONDITION 3, and the requirements of LCO 3.4.9.2, "Reactor Coolant System Cold Shutdown," may be suspended, to allow performance of an inservice leak or hydrostatic test provided the maximum reactor coolant temperature does not exceed 212°F and the following OPERATIONAL CONDITION 3 LCO's are met:

- a. LCO 3.1.3.8, "Control Rod Drive Housing Support";
- b. LCO 3.3.2, "Isolation Actuation Instrumentation," Items 2a, 2c, and 2d of Table 3.3.2-1;
- c. LCO 3.6.5.1, "Secondary Containment Integrity";
- d. LCO 3.6.5.2, "Secondary Containment Automatic Isolation Valves";
- e. LCO 3.6.5.3, "Standby Gas Treatment"; and
- f. LCO 3.8.4.3, "Motor-Operated Valves Thermal Overload Protection."

APPLICABILITY: OPERATIONAL CONDITION 4 with average reactor coolant temperature >200°F and ≤212°F

ACTION:

With the requirements of the above specification not satisfied, immediately enter the applicable condition of the affected specification or immediately suspend activities that could increase the average reactor coolant temperature or pressure and reduce the average reactor coolant temperature to ≤ 200°F within 24 hours.

SURVEILLANCE REQUIREMENTS

4.10.7 Verify applicable OPERATIONAL CONDITION 3. surveillances for specifications listed in 3.10.7 are met.

DELETION
PER THIS
SUBMITTAL