

PRIORITY 1
(ACCELERATED RIDS PROCESSING)

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9410200151 DOC. DATE: 94/10/13 NOTARIZED: NO DOCKET #
FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397
AUTH. NAME AUTHOR AFFILIATION
PARRISH, J.V. Washington Public Power Supply System
RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk) *See Reports*

SUBJECT: Forwards "WNP-2 Response To Request For Addl Info On
Emergency Classification."

DISTRIBUTION CODE: A045D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+400
TITLE: OR Submittal: Emergency Preparedness Plans, Implement'g Procedures, c

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD4-2 PD	1 1	CLIFFORD, J	1 1
INTERNAL:	FILE CENTER 01	1 1	NRR/DRSS/PEPB	1 1
	NUDOGS-ABSTRACT	1 1		
EXTERNAL:	NOAC	1 1	NRC PDR	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL
DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM
DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 7 ENCL 7

P
R
I
O
R
I
T
Y
.
1
D
O
C
U
M
E
N
T

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352-0968 • (509) 372-5000

October 13, 1994
GO2-94-235

Docket No. 50-397

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: **WNP-2 OPERATING LICENSE NPF-21
RESPONSE TO NRC REQUEST FOR ADDITIONAL INFORMATION
REGARDING WNP-2 EMERGENCY ACTION LEVELS**

- References:
- 1) Letter GO2-93-302, dated December 30, 1993, JV Parrish (SS) to RJ Pate (NRC), "WNP-2 Operating License NPF-21 WNP-2 Emergency Plan Implementing Procedures"
 - 2) Letter GI2-94-179, dated June 24, 1994, JW Clifford (NRC) to JV Parrish (SS), "Request for Additional Information (RAI Regarding Emergency Action Levels (TAC NO. M88504))"

With Reference 1, The Supply System transmitted for review a revised WNP-2 procedure on emergency classification based on NUMARC/NESP-007 Revision 2. Reference 2 requested additional information relative to that submittal. Enclosed with this letter are Supply System responses to that request along with document changes considered to be appropriate in light of the requested information.

The enclosure includes the following:

Responses to Requests for Additional Information
Supporting Information for Responses
Procedure 13.1.1, "Classifying the Emergency"
Procedure 13.1.1A, "Classifying the Emergency - Technical Bases"

170104

9410200151 941013
PDR ADDCK 05000397
PDR

ADK 11

20

1. The first part of the document is a list of names and addresses of the members of the committee.

2. The second part of the document is a list of the names and addresses of the members of the committee.

3. The third part of the document is a list of the names and addresses of the members of the committee.

4. The fourth part of the document is a list of the names and addresses of the members of the committee.

5. The fifth part of the document is a list of the names and addresses of the members of the committee.

6. The sixth part of the document is a list of the names and addresses of the members of the committee.

7. The seventh part of the document is a list of the names and addresses of the members of the committee.

8. The eighth part of the document is a list of the names and addresses of the members of the committee.

9. The ninth part of the document is a list of the names and addresses of the members of the committee.

10. The tenth part of the document is a list of the names and addresses of the members of the committee.

11. The eleventh part of the document is a list of the names and addresses of the members of the committee.

12. The twelfth part of the document is a list of the names and addresses of the members of the committee.

13. The thirteenth part of the document is a list of the names and addresses of the members of the committee.

14. The fourteenth part of the document is a list of the names and addresses of the members of the committee.


Page 2

**RESPONSE TO NRC REQUEST FOR ADDITIONAL INFORMATION
REGARDING WNP-2 EMERGENCY ACTION LEVELS**

Following NRC approval of procedure content, the Supply System will initiate the necessary actions for effective implementation of the procedure including human factors optimization, Operator and Emergency Response Organization Training, revision of the WNP-2 Emergency Preparedness Plan, and alignment of other impacted procedures.

Should you have any questions or desire additional information regarding this matter, please call me or Mr. G.J. Reed at (509) 377-8568.

Sincerely,



J. V. Parrish (Mail Drop 1023)
Assistant Managing Director, Operations

DEL/ml
Attachments

cc: LJ Callan - NRC RIV
KE Perkins, Jr. - NRC RIV, Walnut Creek Field Office
NS Reynolds - Winston & Strawn
JW Clifford - NRC
DL Williams - BPA/399
NRC Sr. Resident Inspector - 927N

5.1.7

Primary Containment Flooding

WNP-2

Revision 0

Approved

Date

CONTROLLED COPY

- IF PC level and pressure cannot be maintained below MPCWLL
- IF RPV level can be restored and maintained above -161 in. AND existing control rod pattern alone can always assure reactor shutdown
- IF RPV level can be restored and maintained above -161 in. AND existing control rod pattern alone cannot always assure reactor shutdown

B

THEN stop injection into PC from sources external to PC as required to maintain PC level and pressure below MPCWLL. (Disregard adequate core cooling)

THEN PPM 5.1.1

2 3

THEN PPM 5.1.2

5 6

Flood PC with one or more: (RPV injection paths preferred):

- HPCS with suction from CST, if available
- IF HPCS suction transfer is necessary
- THEN override the HPCS WW high level suction transfer by simultaneously closing HPCS-V-15 and opening HPCS-V-1
- RFW
- Cond
 - condensate
 - OR
 - condensate booster
- CRD
- RCIC with suction from CST, if available
- RHR/SW Crosstie, PPM 5.5.2
- Fire System, PPM 5.5.3

PPM 5.5.13 (High RPV level)

PPM 5.5.8 (Low RPV pressure)

The purpose in overriding the WW high level transfer is to use available CST inventory to flood the PC. However, if it is likely that the manual override will disturb HPCS operation and HPCS is injecting into the RPV, then the suction transfer should not be performed.

With a high WW level (+5 in. or greater), HPCS-V-15 must be off its full open seal before HPCS-V-1 can be opened.

When WW level is at or above 51 ft, WW cannot be vented through CEP-V-3A and CEP-V-4A (PPM 5.5.14, PPM 5.5.20).

WHEN 2" ABOVE DW FLOOR (503 ft) lamp on

Vent RPV with one or more, PPM 5.5.12

- MSIVs
- MSL drains
- RCIC steam line

WHEN 60" TOP ACTIVE FUEL (551 ft 10 in.) lamp on

Maintain PC level at 551 ft 10 in. with one or more: (Take suction from sources external to PC only as required)

Suction normally aligned to WW:

- LPCS
- RHR-A
- RHR-C
- RHR head spray
- RHR-B if not aligned to SW
- ECCS water leg pumps

Suction normally aligned external to PC:


- HPCS
- Cond
 - condensate
 - OR
 - condensate booster
- CRD
- RHR/SW Crosstie, PPM 5.5.2
- Fire System, PPM 5.5.3

IF RPV level reaches -161 in. THEN vent RPV only as needed to maintain RPV level above -161 in.

2 RCIC operation with pump suction aligned to the WW, when WW temp is above 140°F, may result in high turbine tube oil and bearing temps.

3 Operating the RCIC turbine below 2100 rpm may result in unstable system operation and equipment damage.

4 Elevated WW pressure may trip the RCIC turbine on high exhaust pressure.



ANSTEC
APERTURE
CARD

Also Available on
Aperture Card

© 1992 Cael Consultants, Inc. All rights reserved.

9410200151-01

ENGINEERING CALCULATION NO.

NE-02-94-57

RESPONSE OF CONTAINMENT RADIATION MONITORS

The computer print-outs associated with this calculation are available in WNP-2 files.

105

106

107

108

109

110

111

112

113

114

115

116

117

118

119

120

121

122

123

124

125

126

127

128

129

130

131

132

133

134

135

136

137

138

139

140

CALCULATION COVER SHEET

BDC Page

Equipment Piece No.

CMS-RE-27A

Project
WNP-2Page
1.000Cont'd On Page
1.100

CMS-RE-27B

Discipline

NUCLEAR

Calculation No.

NE-02-94-57

CMS-RE-27E

Quality Class

I

CMS-RE-27F

Remarks

TITLE/SUBJECT/PURPOSE

Title/Subject Response of CMS-RE-27A, 27B, 27E & 27F to NUMARC EALs
(Emergency Action Levels).

Purpose

This calculation provides response of containment LOCA monitors
CMS-RE-27A, 27B, 27E and 27F to various accident source
terms for NUMARC EALs and to provide a basis for
revision to DPM 9.3.22.

CALCULATION REVISION RECORD

REVISION NO.	STATUS/ F, P, OR S	REVISION DESCRIPTION	INITIATING DOCUMENTS	TRANSMITTAL NO.
0	F	Initial Issue	RFTS 94-08-096	15998
		Revision: incorporates correction to source volume	RFTS 94-08-096	16069

PERFORMANCE VERIFICATION RECORD

REVISION NO.	PERFORMED BY/DATE	VERIFIED BY/DATE	APPROVED BY/DATE
0	Paul J. Hayes 8/29/94	Loren Sharp 9/1/94	SR Kirkman 9/1/94
1	Paul J. Hayes 9/15/94	Loren Sharp 9/16/94	Loren Sharp 9/19/94

Study calculations shall be used only for the purpose of evaluating alternate design options or assisting the engineer in performing assessments.



CALCULATION INDEX

Page	Cont'd On Page
1.100	1.200
Calculation No.	
NE-02-94-57	
Revision No.	
0	

ITEM	PAGE NO. SEQUENCE
Calculation Cover Sheet	1.000 - <u>NA</u>
Calculation Index	1.100 - <u>NA</u>
Verification Checklist for Calculations and CMR's	1.200 - <u>NA</u> ^{1.201}
Calculation Reference List	1.300 - <u>NA</u>
Calculation Output Interface Document Revision Index	1.400 - <u>NA</u>
Calculation Output Summary	2.000 - <u>NA</u>
Calculation Method	3.000 - NA <u>3.001</u>
Sketches	4.000 - <u>None</u> ^{5.101}
Manual Calculation	5.000 - 5.043

APPENDICES:

APPENDICES		Page Count	
<u>Computer Runs</u>	Appendix A	<u>1 - 294</u>	Pages
<u></u>	Appendix B	<u>-</u>	Pages
<u></u>	Appendix C	<u>-</u>	Pages
<u></u>	Appendix D	<u>-</u>	Pages
<u>Historical / Information</u>	Appendix H	<u>N/A</u>	Pages
<u>Superseded Pages</u>	Appendix S	<u>N/A</u>	Pages
<u>Vendor Data</u>	Appendix E	<u>9</u>	Pages
<u></u>	Appendix	<u></u>	Pages
<u></u>	Appendix	<u></u>	Pages

VERIFICATION CHECKLIST FOR CALCULATIONS AND CMRs

Page

Cont'd On Page

1.200

1.201
1.200-9CS

Calculation/CMR NE-02-94-57 Revision 0 was
verified using the following methods:

☒ Checklist Below

☐ Alternate Calculations

Checklist Item

Initial

Clear statement of purpose of analysis

Methodology clearly stated and sufficiently detailed and
appropriate to proposed application

Logical consistency of analysis

- Completeness of documenting references
- Completeness of documenting and updating output interface documents

Completeness of input

Accuracy of input data

Consistency of input data with approved criteria

Completeness in stating assumptions

Validity of assumptions

Calculation sufficiently detailed

- Arithmetical accuracy

- Physical units specified and correctly used

Reasonableness of output conclusion

Supervisor independency check (if acting as Verifier)

- Did not specify analysis approach
- Did not rule out specific analysis options
- Did not establish analysis inputs

- If a computer program was used:

- Is the program appropriate for the proposed application?
- Have the program error notices been reviewed to determine if they pose any limitations for this application?
- Is the program name, revision number and date of run inscribed on the output?
- Is the program identified on the Calculation Method form? If so, is it listed in chapter 10 of the Engineering Standards Manual?

Other Elements Considered

NONE

- If a separate verifier was used for validating these functions or a portion of these functions, sign and initial below.

Based on the foregoing, the calculation is adequate for the purpose intended.

Verifier Signature(s)/Date

Verifier Initial

Steven Sharp 8/20/94

SS



VERIFICATION CHECKLIST FOR CALCULATIONS AND CMRs

Page

Cont'd On Page

1, 201
1,200⁹⁵

1.300

Calculation/CMR NE-02-94-57 Revision 1 was
verified using the following methods:

☒ Checklist Below

☐ Alternate Calculations

Checklist Item

Clear statement of purpose of analysis

Methodology clearly stated and sufficiently detailed and
appropriate to proposed application

Logical consistency of analysis

- Completeness of documenting references
- Completeness of documenting and updating output interface documents

Completeness of input

Accuracy of input data

Consistency of input data with approved criteria

Completeness in stating assumptions

Validity of assumptions

Calculation sufficiently detailed

- Arithmetical accuracy

- Physical units specified and correctly used

Reasonableness of output conclusion

Supervisor independency check (if acting as Verifier)

- Did not specify analysis approach
- Did not rule out specific analysis options
- Did not establish analysis inputs

- If a computer program was used:

- Is the program appropriate for the proposed application?
- Have the program error notices been reviewed to determine if they pose any limitations for this application?
- Is the program name, revision number and date of run inscribed on the output?
- Is the program identified on the Calculation Method form? If so, is it listed in chapter 10 of the Engineering Standards Manual?

Other Elements Considered

- If a separate verifier was used for validating these functions or a portion of these functions, sign and initial below.

Based on the foregoing, the calculation is adequate for the purpose intended.

Verifier Signature(s)/Date

Verifier Initials

[Signature] 4/16/94

QOS



CALCULATION REFERENCE LIST

Page	Cont'd On Page
1.300	1.400 2.0

Calculation No.

NE-02-94-57

Revision No.

0

[illegible]



CALCULATION OUTPUT SUMMARY

Calculation of Results

Results for each of the cases are presented below (Power uprate values in parenthesis).

Detector	4 μ Ci/gm (R/hr)	300 μ Ci/gm (R/hr)	20% Clad Damage (R/hr)	0.1% Clad Damage (R/hr)	2% Clad Damage (R/hr)	5% Clad Damage (R/hr)
CMS-RE-27A	.005	.37	51.4 (54.1)	.26 (.27)	5.1 (5.4)	12.8 (13.5)
CMS-RE-27B	.006	.43	58.4 (61.5)	.29 (.31)	5.8 (6.1)	14.6 (15.4)
CMS-RE-27E	3.3	248	18500 (19500)	92.5 (97.4)	1850 (1950)	4630 (4870)
CMS-RE-27F	2.6	197	14700 (15500)	73.3 (77.2)	1470 (1550)	3660 (3850)

Detectors CMS-RE-27E and 27F provide acceptable results for use in monitoring EAL limits for all three required levels (RCS barrier, Fuel Clad Barrier, and Containment Barrier). Detectors CMS-RE-27A and 27B will provide reasonable response somewhere between the 0.1% and 2% clad failure case. Review of historical data indicate that detector response during full power operation has been approximately:

Detector	Reading (R/hr)
CMS-RE-27A	0.4
CMS-RE-27B	0.4
CMS-RE-27E	1.0
CMS-RE-27F	1.5

The following Table presents detector response for release of RG 1.3 source term within primary containment:

Detector	100% Clad Damage (R/hr)
CMS-RE-27A	10,800 (11,370)
CMS-RE-27B	12,300 (12,950)
CMS-RE-27E	3.96e+6 (4.17e+6)
CMS-RE-27F	3.13e+6 (3.30e+6)

Conclusions

It is recommended that detectors CMS-RE-27E and 27F be used for determining EALs during an accident scenario. The following table indicates the recommended response levels for each of the required EALs:

Action Level	% Clad Failure	Detector Response (R/hr)	Classification
RCS barrier	0.1	70	Alert
Fuel Clad Barrier	5.0	3600	Site Area Emergency
Containment Barrier	20.0	14700	General Emergency

The response for detector CMS-RE-27F was selected for the EALs since it provided the lowest response to a given source. These values will provide conservative results for power uprate. The values for the action levels were rounded for operator use and readability of the instrument.



Prepared by/Date

J. Haynes 8/24/94

Verified by/Date

[Signature] 8/30/94

Analysis Method (Check appropriate boxes)

☒ Manual (As required, document source of equations in Reference List)

☒ Computer

☐ Main Frame

☐ Personal

☐ In-House Program

☐ Computer Service Bureau Program

☐ BCS

☐ CDC

☐ PCC

☐ Other _____

☒ Verified Program: Code name/Revision QAD 2

☐ Unverified Program: Document in Appendix B

Approach/Methodology

This calculation will determine response of detectors CMS-RE-27A,D,E&F to various source terms based on EALs (emergency action level). The source terms are based on (See References 7 and 9):

- 1) Tech Spec Limits of $4\mu\text{Ci/cc}$ in the coolant (I-131 equivalent)
- 2) $300\mu\text{Ci/gm}$ dose equivalent I-131 (~ 2 to 5% core damage).
- 3) 20% clad damage.

Detector response will be determined for a $1\mu\text{Ci/cc}$ source of each of 13 noble gasses and 5 halogens. Using the generated detector response for a $1\mu\text{Ci/cc}$ source within containment, the response for each of the required EAL sources will be determined:

- 1) Tech Spec limits ($4\mu\text{Ci/gm}$ I-131 equivalent) approximated by 0.1% clad failure, and $4\mu\text{Ci/cc}$ I-131 run.
- 2) $300\mu\text{Ci/gm}$ I-131 dose equivalent, approximated by 2 and 5% clad failure runs, and a $300\mu\text{Ci/gm}$ I-131 run
- 3) 20% clad failure.

REV.
BAR

Δ

v/s

[Signature]
9/16/94



Case 1 - performed for RCS barrier EALs.
and case 4 This case represents release of
reactor coolant to the containment.

Case 2, - Performed for Fuel Clad Barrier EALs.
case 5 & This case represents a release of reactor
case 6* coolant with elevated activity indicative
of fuel damage into containment,

Case 3 - Performed for Primary Containment Barrier EALs.
This case represents release of reactor
coolant to containment with a
major release of radioactivity. This
case indicates significant core
damage has occurred and may
require offsite protective actions.

Case 7 - Performed to determine detector
response to NUREG-0588 & Reg Guide 1.3
Source term for inclusion in 7PM 9.3.22.
(References 13, 14, 15)



WASHINGTON PUBLIC POWER
SUPPLY SYSTEM

MANUAL CALCULATION

PAGE

5.000

CONT'D ON
PAGE

CALCULATION NO.

NE-02-94-57

PREPARED BY / DATE

S. J. Haynes 8/24/94

VERIFIED BY / DATE

Steve Sharp 8/29/94

REVISION NO.

0

REV.
BAR

Assumptions

- 1) Piping and shielding ignored inside containment for this evaluation
- 2) Source is smeared within drywell, including sacrificial shield wall, vessel and vessel internals
- 3) Detectors CMS-RE-27A & B will be modeled along containment wall within steel sphere the thickness of containment wall. The resultant dose will be corrected to the source conc angle of the detector.
- 4) The Fuel matrix will release 2% iodines and 3% Kr & Xe during a gap release (Reference 9)
- 5) Energy groups below 40 keV were not considered since detectors CMS-RE-27A, B, E & F would not respond to γ 's below this value

⚠
2.5
min





WASHINGTON PUBLIC POWER
SUPPLY SYSTEM

MANUAL CALCULATION

PAGE 5.001 CONT'D ON PAGE

CALCULATION NO.

NE-02-94-57

PREPARED BY / DATE

S. J. Haynes 8/24/94

VERIFIED BY / DATE

[Signature] 8/30/94

REVISION NO.

0

REV.
BAR

Purpose

This calculation is performed to determine the response of detectors CMS-RE-27 A, B, E, F to source released into containment.

QAD MODEL

The QAD model developed in Reference 1 (5.01.78) will be used as the base model for this analysis. A sketch of the model is provided on the following page. Reference 1 developed a detailed model of primary containment including the RPV and SAC shell wall. The model will be modified to include accurate detector geometry within the drywell.

A. COMBINATORIAL GEOMETRY

The combinatorial geometry portion of the model is essentially identical to that in Reference 1 except that bodies 16 through 25 have been removed.


Composition input is somewhat different with the addition of Lead. Also the steel is no longer smeared throughout the drywell. Concrete is modeled as type 04 (Reference 2). Steam is modeled as water with a reduced volume % based on density ratio

for water @ 14.7psig	Temp	Density (lb/ft^3)	Ratio to 68°F
	68°F	62.325	1.0
	212°F	59.812	.9597
Steam @ 212°F		.037324	.000599

A density for lead of 1.0×10 is selected to eliminate source on the outside of the drywell model.

Material zones

The material zones are essentially the same as Ref. 1 with the exclusion of bodies 16 through 25.



1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

[illegible]



MANUAL CALCULATION

PAGE

5.003

CONT'D ON

PAGE

CALCULATION NO.

NE-02-94-57

PREPARED BY / DATE

S.T. Haynes

VERIFIED BY / DATE

John Sharp 8/30/94

REVISION NO.

0

REV.

BAR

B. Source Description

The source will be defined using an encompassing cylinder around the drywell model. (body # 15). The source strength will be adjusted using the ASI parameter to assure a correct concentration is maintained.

Model drywell volume - determine volume within drywell structure

Lower truncated cone

$$V = \pi/12 h (R^2 + Rr + r^2)$$

$$V = \pi/12 (2195.20) (1236.18^2 + 1236.18 \cdot 602.62 + 602.62^2)$$

$$V = \frac{9.09031 \times 10^9}{6.06021} \text{ cm}^3 \quad \checkmark$$

Upper Truncated cone

$$V = \pi/12 (208.28) (602.62^2 + 602.62 \cdot 482.60 + 482.60^2)$$

$$V = \frac{2.90156 \times 10^8}{1.93437 \times 10^8} \text{ cm}^3 \quad \checkmark$$

Cylinder

$$V = \pi r^2 h = \pi (482.60)^2 (332.74)$$

$$V = 2.43461 \times 10^8 \text{ cm}^3 \quad \text{—}$$




V/S
9/1/94

THE JOURNAL OF THE AMERICAN MEDICAL ASSOCIATION
PUBLISHED WEEKLY
535 N. Dearborn Ave., Chicago 10, Ill.
Subscription price: \$5.00 per year in advance
Single copies: 15¢
Entered as Second-Class Matter, May 26, 1917
Postpaid
Acceptance for mailing at special rate of postage provided for in
Act of October 3, 1917
Copyright, 1958, by American Medical Association
All rights reserved

THE JOURNAL OF THE AMERICAN MEDICAL ASSOCIATION
PUBLISHED WEEKLY
535 N. Dearborn Ave., Chicago 10, Ill.
Subscription price: \$5.00 per year in advance
Single copies: 15¢
Entered as Second-Class Matter, May 26, 1917
Postpaid
Acceptance for mailing at special rate of postage provided for in
Act of October 3, 1917
Copyright, 1958, by American Medical Association
All rights reserved



upper sphere



The volume can be determined by adding the volume of a cone in volume B to the integrated area of volume A.

$$V_B = \pi/3 w^2 h \quad \alpha = \cos^{-1}(H/r) = 60.086^\circ$$

$$w = r \sin \alpha = 418.31 \text{ cm}$$

$$V_B = \pi/3 (418.31)^2 (240.67)$$

$$V_B = 4.41002 \times 10^7 \text{ cm}^3$$

Volume A determined by integration. The volume is bounded by

$$\begin{aligned} \alpha &\leq \phi \leq \pi/2 \\ 0 &\leq \theta \leq 2\pi \\ 0 &\leq \rho \leq r \end{aligned}$$

$$V_A = \int_0^{2\pi} \int_0^{\pi/2} \int_0^r \rho^2 \sin \phi \, d\rho \, d\phi \, d\theta$$

$$V_A = \int_0^{2\pi} \int_0^{\pi/2} \frac{r^3}{3} \sin \phi \, d\phi \, d\theta = \int_0^{2\pi} \frac{r^3}{3} \cos(\alpha) \, d\theta$$

$$V_A = 2\pi r^3/3 \cos \alpha$$

$$V_A = 2\pi (482.60)^3 \cos(60.086)$$

$$V_A = 1.17398 \times 10^8 \text{ cm}^3$$

$$V_S = V_A + V_B = 1.61498 \times 10^8 \text{ cm}^3$$

$$\text{TOTAL VOLUME} = \frac{9.78543 \times 10^9}{6.658606 \times 10^9} \text{ cm}^3 = \frac{345,624.21 \text{ ft}^3}{245,700 \text{ ft}^3}$$

[Handwritten notes and signature]



MANUAL CALCULATION

PAGE

5,005

CONT'D ON
PAGE

CALCULATION NO.

NE-02-94-57

PREPARED BY / DATE

S.J. Haynes 8/29/04

VERIFIED BY / DATE

John Sharp 8/30/04

REVISION NO.

0

REV.
BAR

Source Body Volume

$$V_{SB} = \pi r^2 h = \pi (1236.18)^2 (3218.82)$$

$$V_{SB} = 1.54529 \times 10^{10} \text{ cm}^3 \quad \checkmark$$

$$\text{Ratio of Containment to Source} = \frac{1.54529 \times 10^{10}}{\frac{9.70543 \times 10^9}{6.658606 \times 10^9}}$$

$$\text{Ratio} = \frac{1.579}{2.321}$$

Δ
v12

9/16/04

Source concentration

using the same geometry model, the source for each isotope will be used to generate detector response per isotope. Using the probability per decay per gamma energy from the RADDECAY Program (Reference 4) The following pages present the data for each of the 13 noble gas isotopes and the 5 Halogen isotopes. The first data block is source strength (γ/s) and the second block is γ energy in MeV.

The source strength in the table is determined by multiplying Probability/decay \times Volume \times 1 $\mu\text{Ci/cc}$.

$$\text{Source} = (\text{Prob}) (1.54529 \times 10^{10} \text{ cm}^3) \left(\frac{2.321}{1.579} \right) (1 \mu\text{Ci/cc}) (10^{-6}) (3.7 \times 10^{10} \frac{\gamma/s}{\text{Ci}})$$

$$\text{Source} = (\text{Prob}) \left(\frac{9.02805 \times 10^{14}}{1.32705 \times 10^{15}} \right) \text{ photons/s}$$

Δ

v12

9/16/04

The following pages present a computer program which reads the RADDECAY Photon data file and outputs a file ready to read into QAD. The output follows the computer program.



WASHINGTON PUBLIC POWER
SUPPLY SYSTEM

MANUAL CALCULATION

PAGE 5.006 CONT'D ON PAGE

CALCULATION NO.
NE-02-94-57

PREPARED BY / DATE

S.J. Haynes 9/14/94

VERIFIED BY / DATE

-228 7.4 9/16/94

REVISION NO.

1

REV.
BAR

```
program qpho
dimension prob(200)
real nrg(200)
character name*7
open(unit=1,file='photon.dat',status='old')
open(unit=2,file='qpho.dat',status='unknown')
c modified following line per Rev 1 of NE-02-94-57
csjh src=9.02805e14
src=1.32705e15
99 continue
read(1,*,end=109) ndat

do 10 i=1,ndat
read(1,1000) prob(i),nrg(i),name
prob(i)=prob(i)*src
1000 format(1x,f8.2,2x,f8.2,1x,a7)
10 continue

write(2,'(a)') name

c determine if energy is above 40 keV
do 20 i=1,ndat
if (nrg(i) .lt. 0.04 ) goto 20
lz=i
goto 21
20 continue
21 continue

write(6,*) lz

write(2,1001) (prob(i), i=lz,ndat)
write(2,*) ''
write(2,1001) (nrg(i), i=lz,ndat)

1001 format(6(1pe12.4))
write(2,*) ''
goto 99
109 continue
stop
end
```

OUTPUT FILE - used for QAD source and energy group data

I-131

3.4745E+13 3.5140E+12 8.0314E+13 3.3269E+12 1.0771E+15 4.7840E+12
9.6350E+13 2.9129E+12 2.3920E+13 3.0575E+12

8.0183E-02 1.7721E-01 2.8430E-01 3.2578E-01 3.6448E-01 5.0299E-01
6.3697E-01 6.4270E-01 7.2289E-01 3.2939E-01





WASHINGTON PUBLIC POWER
SUPPLY SYSTEM

MANUAL CALCULATION

PAGE
5.007

CONT'D ON
PAGE

CALCULATION NO.
1/E-02-24-57

PREPARED BY / DATE

S.J. Haynes 9/14/94

VERIFIED BY / DATE

J. E. 7/5 9/16/94

REVISION NO.

1

REV.
BAR

I-132

3.1438E+12 1.8340E+12 2.4882E+12 1.9123E+13 9.5614E+12 1.8340E+12
6.5490E+12 3.9294E+12 6.2876E+12 6.4176E+12 7.9902E+12 2.3582E+12
1.9654E+12 5.5006E+12 6.6800E+13 2.1350E+14 6.9418E+12 1.4412E+12
1.6635E+13 1.8340E+12 5.2392E+12 2.0957E+13 1.8206E+14 3.5365E+13
5.2392E+12 1.3098E+15 6.5490E+13 6.9419E+13 4.1914E+13 2.8816E+13
1.4408E+13 5.2392E+12 1.0112E+15 1.6373E+13 5.6320E+12 3.7984E+13
7.4659E+13 7.7274E+12 1.4276E+13 1.2181E+13 5.5006E+12 2.3969E+14
7.4660E+12 6.2876E+12 3.9294E+13 1.7944E+13 3.6680E+12 1.4408E+13
2.3582E+12 1.5063E+13 2.6196E+13 1.1788E+13 1.5712E+12 3.2745E+13
9.4305E+13 1.8861E+13 1.7942E+12 3.9294E+12 1.5718E+13 1.4408E+13
3.1438E+12 2.6196E+12 1.5712E+12 2.2268E+12 4.2394E+13

1.4720E-01 1.8330E-01 2.5480E-01 2.6270E-01 2.8480E-01 3.1650E-01
3.6350E-01 3.8780E-01 4.1680E-01 4.3190E-01 4.4600E-01 4.7390E-01
4.7850E-01 4.8820E-01 5.0590E-01 5.2265E-01 5.3550E-01 5.4000E-01
5.4710E-01 6.0000E-01 6.2080E-01 6.2120E-01 6.3022E-01 6.5060E-01
6.5900E-01 6.6769E-01 6.6980E-01 6.7160E-01 7.2700E-01 7.2720E-01
7.2850E-01 7.6450E-01 7.7261E-01 7.8020E-01 7.8450E-01 8.0980E-01
8.1220E-01 8.6330E-01 8.7680E-01 9.1030E-01 9.2760E-01 9.5455E-01
9.8370E-01 1.0347E+00 1.1360E+00 1.1434E+00 1.1474E+00 1.1732E+00
1.2727E+00 1.2907E+00 1.2953E+00 1.2976E+00 1.3178E+00 1.3721E+00
1.3986E+00 1.4426E+00 1.4768E+00 1.7575E+00 1.9211E+00 2.0022E+00
2.0868E+00 2.1727E+00 2.2232E+00 2.3905E+00 1.0146E+00

I-133

4.7309E+12 1.5460E+12 1.3748E+12 1.4890E+12 2.0277E+12 4.1006E+12
2.4055E+13 1.1455E+15 7.1594E+12 8.5568E+12 1.9817E+13 6.0593E+12
2.0397E+12 1.6381E+13 5.9338E+13 2.8187E+12 7.3200E+12 1.8220E+12
1.9817E+13 3.0928E+13 1.9707E+12 8.0578E+12

2.6270E-01 2.6717E-01 3.4543E-01 3.6108E-01 4.1805E-01 4.2291E-01
5.1053E-01 5.2987E-01 6.1797E-01 6.8025E-01 7.0658E-01 7.6838E-01
8.2051E-01 8.5628E-01 8.7533E-01 9.0967E-01 1.0523E+00 1.0601E+00
1.2364E+00 1.2982E+00 1.3504E+00 5.3524E-01

I-134

4.9886E+13 9.1155E+12 1.4053E+12 3.4185E+12 9.2429E+12 3.2924E+12
2.6335E+13 1.7345E+12 6.8370E+12 6.5835E+12 9.7493E+13 8.1030E+12
5.5583E+13 1.7220E+13 4.8119E+12 1.8739E+13 3.1020E+13 1.0382E+14
1.1649E+13 2.7855E+12 1.5067E+14 1.4055E+14 3.1401E+13 1.1269E+14
1.1016E+13 2.5323E+13 1.0129E+13 5.4444E+13 6.9644E+12 1.2661E+15
9.2428E+13 2.5320E+12 8.6603E+14 1.8990E+12 5.3557E+13 4.6845E+12
6.2041E+13 2.5323E+13 2.0259E+14 9.1155E+12 9.6224E+12 1.2915E+14
4.6845E+12 1.7729E+12 4.6845E+12 2.7855E+12 7.4700E+12 1.3934E+12
1.8990E+12 5.9505E+12 2.9115E+12 2.2785E+12 2.2785E+12 3.0387E+13
1.0255E+13 1.5195E+12 6.7109E+12 5.7862E+13 3.4185E+12 5.3175E+12
3.0389E+12 3.5452E+13 7.5968E+13 2.4059E+12 2.2785E+12 2.7855E+12
3.1650E+12 2.0264E+12 1.7713E+13





WASHINGTON PUBLIC POWER
SUPPLY SYSTEM

MANUAL CALCULATION

PAGE 5.000 CONT'D ON PAGE

CALCULATION NO.
NE-02-94-57

PREPARED BY / DATE

S. J. Haynes 9/14/94

VERIFIED BY / DATE

J. E. 74 9/16/94

REVISION NO.

1

REV.
BAR

1.3540E-01 1.3903E-01 1.5198E-01 1.6248E-01 1.8847E-01 2.1700E-01
2.3547E-01 2.7880E-01 3.1981E-01 3.5108E-01 4.0545E-01 4.1100E-01
4.3335E-01 4.5892E-01 4.6550E-01 4.8888E-01 5.1440E-01 5.4083E-01
5.6552E-01 5.7075E-01 5.9536E-01 6.2179E-01 6.2796E-01 6.7734E-01
7.0665E-01 7.3074E-01 7.3918E-01 7.6668E-01 8.1638E-01 8.4702E-01
8.5729E-01 8.6400E-01 8.8409E-01 9.2260E-01 9.4786E-01 9.6690E-01
9.7467E-01 1.0403E+00 1.0726E+00 1.1001E+00 1.1032E+00 1.1362E+00
1.1591E+00 1.1640E+00 1.1900E+00 1.2390E+00 1.2695E+00 1.3224E+00
1.3360E+00 1.3526E+00 1.4143E+00 1.4282E+00 1.4314E+00 1.4552E+00
1.4700E+00 1.5055E+00 1.5415E+00 1.6138E+00 1.6292E+00 1.6443E+00
1.6552E+00 1.7415E+00 1.8068E+00 1.9259E+00 2.0206E+00 2.1599E+00
2.3124E+00 2.4674E+00 1.7872E+00

I-135

2.3160E+13 3.0748E+12 2.4418E+12 4.1005E+13 4.0249E+12 2.4683E+12
3.0748E+12 3.9865E+12 4.6699E+13 4.0249E+12 7.3280E+12 4.1762E+12
9.4538E+13 1.7092E+12 6.0368E+12 1.7092E+12 8.7320E+12 2.0118E+12
2.2785E+12 8.8462E+13 1.9362E+12 1.1770E+13 1.5946E+13 2.0503E+12
1.0517E+14 2.1262E+13 4.7839E+13 2.9880E+14 1.3669E+12 1.1580E+13
1.1959E+13 3.7967E+14 8.0486E+12 4.1762E+12 1.1466E+14 1.4238E+13
1.7086E+13 1.2643E+14 5.4292E+13 1.0213E+14 7.6690E+12 3.9108E+12
1.1541E+13 8.1255E+12 1.2643E+13 1.9837E+13

2.2050E-01 2.2972E-01 2.6426E-01 2.8845E-01 2.9027E-01 3.6185E-01
4.0303E-01 4.1483E-01 4.1763E-01 4.2993E-01 4.3374E-01 4.5163E-01
5.4656E-01 5.7597E-01 6.4985E-01 6.9013E-01 7.0792E-01 7.8548E-01
7.9771E-01 8.3680E-01 9.6146E-01 9.7196E-01 9.7261E-01 9.9509E-01
1.0388E+00 1.1016E+00 1.1240E+00 1.1315E+00 1.1599E+00 1.1690E+00
1.2405E+00 1.2604E+00 1.3679E+00 1.4484E+00 1.4576E+00 1.5028E+00
1.5664E+00 1.6780E+00 1.7065E+00 1.7912E+00 1.8307E+00 1.9273E+00
2.0459E+00 2.2555E+00 2.4087E+00 1.0734E+00

Kr-83m

2.9963E+13 6.7281E+11

1.4100E-02 3.2160E-02

Kr-85

5.7594E+12

5.1399E-01

Kr-85m

1.8564E+14 7.7765E+11 8.1162E+12 1.5699E+13 4.1205E+12 3.9957E+12
9.9898E+14 2.8001E+11

3.0487E-01 1.6900E-03 1.3336E-02 1.3395E-02 1.5000E-02 1.2985E-01
1.5118E-01 5.8128E-01





WASHINGTON PUBLIC POWER
SUPPLY SYSTEM

MANUAL CALCULATION

PAGE 5.009 CONT'D ON PAGE

CALCULATION NO. 1/E-02-32-57

PREPARED BY / DATE

S.J. Haynes 9/14/94

VERIFIED BY / DATE

J.C. S. -> L 9/14/94

REVISION NO.

REV. BAR

Kr-87

6.5689E+14 2.5291E+13 2.2334E+12 9.9847E+12 9.6563E+13 1.8393E+12
1.4912E+13 8.6046E+12 3.8100E+12 1.6416E+12 4.7296E+12 1.7079E+12
1.3801E+12 2.7195E+13 1.8393E+12 3.8427E+13 2.8253E+12 1.2350E+14
5.1894E+13 4.2041E+12 5.9770E+12 8.6245E+12

4.0258E-01 6.7387E-01 8.1425E-01 8.3637E-01 8.4543E-01 9.4664E-01
1.1754E+00 1.3380E+00 1.3825E+00 1.3899E+00 1.5312E+00 1.5780E+00
1.6112E+00 1.7405E+00 1.8426E+00 2.0119E+00 2.4085E+00 2.5548E+00
2.5581E+00 2.8114E+00 3.3085E+00 1.6201E+00

Kr-88

2.6169E+12 4.1186E+13 3.4483E+14 3.3521E+12 1.4239E+12 1.9282E+12
2.9845E+13 8.5409E+12 1.6986E+12 9.6423E+12 3.1225E+12 7.0705E+12
1.6535E+12 1.7218E+14 2.2958E+12 8.9072E+12 3.9029E+12 1.7448E+13
1.8831E+12 6.4282E+12 1.8831E+12 1.7035E+13 1.3224E+13 9.1367E+12
1.8831E+12 1.8366E+12 4.8212E+12 1.4876E+13 2.1127E+12 2.1127E+12
1.9606E+13 2.8930E+12 1.5155E+12 2.8559E+13 1.4510E+14 6.0606E+12
8.8156E+12 1.8366E+12 1.3310E+12 6.0103E+13 4.9589E+13 3.8113E+12
1.7495E+14 4.4998E+13 9.6888E+12 4.5916E+14 1.3775E+12 8.2649E+12
1.9747E+12 2.5071E+13

1.2227E-01 1.6598E-01 1.9632E-01 2.4071E-01 3.1169E-01 3.3471E-01
3.6223E-01 3.9054E-01 4.2170E-01 4.7180E-01 6.7734E-01 7.8828E-01
7.9032E-01 8.3483E-01 8.5034E-01 8.6233E-01 9.4492E-01 9.8578E-01
9.9009E-01 1.0396E+00 1.0495E+00 1.1413E+00 1.1795E+00 1.1850E+00
1.2098E+00 1.2127E+00 1.2452E+00 1.2507E+00 1.3250E+00 1.3523E+00
1.3695E+00 1.4069E+00 1.4648E+00 1.5184E+00 1.5298E+00 1.6038E+00
1.6856E+00 1.8928E+00 1.9087E+00 2.0298E+00 2.0354E+00 2.1865E+00
2.1958E+00 2.2318E+00 2.3521E+00 2.3921E+00 2.4089E+00 2.5484E+00
2.7710E+00 1.0001E+00

Kr-89

2.9195E+12 2.4152E+13 1.6455E+12 2.6541E+14 8.7585E+12 4.5385E+12
1.5659E+13 5.4940E+13 1.1943E+13 1.8313E+13 4.2200E+12 3.3972E+13
1.2740E+13 1.0616E+13 4.2731E+12 8.8116E+13 1.5128E+13 2.1233E+12
7.4846E+13 2.2029E+14 7.9623E+12 4.5385E+12 1.5128E+12 1.4067E+12
3.0788E+12 2.3621E+13 6.6087E+12 1.0351E+13 3.9281E+12 5.5736E+13
1.5128E+12 5.3082E+12 1.2209E+13 1.4863E+13 1.0086E+13 1.4598E+13
3.7954E+12 7.8561E+13 2.1233E+12 9.5282E+13 8.2277E+12 2.1764E+12
1.4067E+12 4.2731E+12 1.3005E+13 8.7585E+12 1.4332E+12 5.4144E+12
3.1318E+12 4.7508E+12 1.1943E+13 3.8750E+13 2.2029E+13 2.1233E+12
2.8399E+12 1.3005E+13 2.2029E+12 2.4418E+12 1.9110E+12 7.8827E+12
1.8048E+13 1.3271E+12 4.0608E+13 1.7517E+12 2.5745E+12 1.9640E+12
1.6721E+12 3.5034E+12 2.9726E+12 1.6190E+12 2.3621E+12 2.4949E+12
9.1301E+13 1.7517E+13 1.4863E+12 4.4058E+13 6.7945E+13 2.0171E+12
2.5214E+12 1.0882E+13 4.4854E+12 1.6986E+12 1.8579E+12 1.7517E+12
3.4503E+12 5.8125E+13 2.9726E+12 1.0086E+13 1.4067E+12 1.8579E+12
1.5659E+12 4.6447E+12 2.6010E+12 2.0967E+12 1.3801E+13 8.4931E+12
1.7517E+12 1.5659E+12 2.0702E+13 3.2380E+12 3.4769E+12 1.2474E+13
7.0068E+12 1.6986E+12 2.7072E+12 1.0616E+13 9.5548E+12 1.4332E+12
5.5736E+12 1.6455E+12 1.0086E+13 9.0239E+12 1.7517E+12 3.1849E+12



WASHINGTON PUBLIC POWER
SUPPLY SYSTEM

MANUAL CALCULATION

PAGE 5.010 CONT'D ON PAGE .

CALCULATION NO.
NE-02-94-57

PREPARED BY / DATE

S.J. Haynes 9/14/94

VERIFIED BY / DATE

CK 9/16/94

REVISION NO.

1

REV.
BAR

2.3091E+13 4.2996E+12 3.3707E+12 3.5830E+12 2.5745E+12 1.3801E+13
1.3271E+12 5.6798E+12 1.3801E+13 8.2277E+12 1.8048E+12 1.7782E+13
3.4238E+12 1.1147E+13 1.8313E+12 1.7517E+12 1.8313E+12 1.4598E+12
1.7782E+12 5.4940E+12 2.7603E+12 3.5830E+12 1.8844E+12 1.5394E+12
1.3801E+12 1.7782E+12 9.4459E+13

1.9620E-01 1.9750E-01 2.0503E-01 2.2090E-01 2.6411E-01 3.3820E-01
3.4503E-01 3.5606E-01 3.6488E-01 3.6930E-01 4.0225E-01 4.1142E-01
4.3808E-01 4.6613E-01 4.9076E-01 4.9750E-01 4.9860E-01 5.5730E-01
5.7696E-01 5.8580E-01 6.2620E-01 6.2975E-01 6.6572E-01 6.7140E-01
6.7411E-01 6.9624E-01 7.0701E-01 7.1005E-01 7.2963E-01 7.3839E-01
7.4740E-01 7.6290E-01 7.6290E-01 7.7649E-01 8.2675E-01 8.3553E-01
8.5737E-01 8.6708E-01 8.7042E-01 9.0427E-01 9.3095E-01 9.4419E-01
9.5318E-01 9.6042E-01 9.7439E-01 9.9737E-01 1.0108E+00 1.0444E+00
1.0765E+00 1.0881E+00 1.1032E+00 1.1078E+00 1.1166E+00 1.1315E+00
1.1625E+00 1.1723E+00 1.1824E+00 1.1865E+00 1.2288E+00 1.2356E+00
1.2737E+00 1.3027E+00 1.3243E+00 1.3354E+00 1.3406E+00 1.3675E+00
1.3722E+00 1.4126E+00 1.4216E+00 1.4613E+00 1.4642E+00 1.4685E+00
1.4728E+00 1.5010E+00 1.5062E+00 1.5300E+00 1.5337E+00 1.5553E+00
1.5738E+00 1.6341E+00 1.6438E+00 1.6675E+00 1.6769E+00 1.6838E+00
1.6920E+00 1.6937E+00 1.7213E+00 1.7776E+00 1.7882E+00 1.8107E+00
1.8375E+00 1.8397E+00 1.8685E+00 1.8798E+00 1.9034E+00 1.9391E+00
1.9666E+00 1.9986E+00 2.0122E+00 2.0210E+00 2.0465E+00 2.1006E+00
2.1600E+00 2.1958E+00 2.2802E+00 2.3774E+00 2.4010E+00 2.5979E+00
2.6453E+00 2.7509E+00 2.7821E+00 2.7938E+00 2.8196E+00 2.8533E+00
2.8662E+00 2.8787E+00 3.0179E+00 3.0292E+00 3.1073E+00 3.1403E+00
3.1721E+00 3.2198E+00 3.3617E+00 3.3711E+00 3.3999E+00 3.5329E+00
3.5839E+00 3.7178E+00 3.7325E+00 3.7814E+00 3.8274E+00 3.8427E+00
3.9018E+00 3.9230E+00 3.9655E+00 3.9775E+00 3.9960E+00 4.0480E+00
4.3411E+00 4.4892E+00 2.1811E+00

Xe-131m

2.6010E+13

1.6393E-01

Xe-133

2.8731E+12 4.8415E+14 9.4486E+11

7.9621E-02 8.0997E-02 1.7770E-01

Xe-133m

1.3669E+14

2.3322E-01

Xe-135

3.8299E+12 1.1930E+15 2.9235E+12 4.7482E+12 3.8415E+13 2.7775E+12

1.5820E-01 2.4979E-01 3.5839E-01 4.0799E-01 6.0819E-01 6.8433E-01

THE UNIVERSITY OF CHICAGO LIBRARY

1968

1968

THE UNIVERSITY OF CHICAGO LIBRARY

THE UNIVERSITY OF CHICAGO LIBRARY



WASHINGTON PUBLIC POWER
SUPPLY SYSTEM

MANUAL CALCULATION

PAGE

5.011

CONT'D ON
PAGE

CALCULATION NO.

NE-02-94-57

PREPARED BY / DATE

S. J. Haynes 9/14/94

VERIFIED BY / DATE

J. S. G. 9/16/94

REVISION NO.

1

REV.
BAR

Xe-135m

1.0749E+15

5.2656E-01

Xe-137

1.5487E+12 1.8327E+12 4.0740E+14 8.1481E+12 2.7297E+12 1.3974E+12
2.9739E+12 1.3443E+12 1.6296E+12 5.4183E+12 2.4033E+12 1.7451E+13

2.9800E-01 3.9335E-01 4.5549E-01 8.4895E-01 9.8225E-01 1.1193E+00
1.2732E+00 1.5768E+00 1.6125E+00 1.7834E+00 2.8498E+00 1.4906E+00

Xe-138

7.9006E+13 4.6400E+13 4.1802E+14 5.6851E+12 1.4213E+12 6.6472E+12
8.3604E+13 2.8843E+13 2.6963E+14 4.8066E+12 3.3442E+12 1.5473E+12
1.5473E+12 4.0541E+12 1.6296E+12 1.9229E+12 3.9294E+12 8.2357E+12
1.7557E+12 4.3474E+12 1.2206E+13 1.7982E+12 3.0509E+12 5.4343E+12
2.8425E+12 1.4213E+12 1.9563E+13 6.8131E+12 1.7557E+12 3.5114E+12
3.1358E+12 2.2198E+14 2.3834E+12 1.8895E+13 7.4832E+12 7.1064E+13
1.6262E+14 1.9145E+13 3.0348E+13 8.2357E+12 4.1391E+12 2.2998E+12
3.5281E+13

1.5375E-01 2.4256E-01 2.5831E-01 2.8251E-01 3.3528E-01 3.7144E-01
3.9643E-01 4.0136E-01 4.3449E-01 5.0022E-01 5.3007E-01 5.3776E-01
5.5595E-01 5.6853E-01 5.8884E-01 6.5408E-01 8.6582E-01 8.6935E-01
8.9687E-01 9.1251E-01 9.1713E-01 9.3636E-01 9.4125E-01 1.0939E+00
1.0988E+00 1.1022E+00 1.1143E+00 1.1416E+00 1.1454E+00 1.5718E+00
1.6146E+00 1.7683E+00 1.8125E+00 1.8509E+00 1.9254E+00 2.0048E+00
2.0158E+00 2.0792E+00 2.2523E+00 2.3219E+00 2.4753E+00 2.4976E+00
1.1186E+00



WASHINGTON PUBLIC POWER
SUPPLY SYSTEM

MANUAL CALCULATION

PAGE

5.012

CONT'D ON
PAGE

CALCULATION NO.

NE-02-94-57

PREPARED BY / DATE

S.J. Haynes 8/25/94

VERIFIED BY / DATE

Green Sharp 8/30/94

REVISION NO.

0

REV.
BAR

C. DETECTOR LOCATIONS

CMS-RE-27AEB

elevation - 522' = (522-501)30.48 = 640.08cm ✓

Refs PPM 11.2.10.6
M893 Sat. 3

Located 15.3" inside bioshield wall
21.2' from sac shield wall

Model detector as a point on containment wall
surrounded by 3" diameter sphere of steel
(CVI 02-213-00, 108 indicates containment shell
is ~1.5" thick near detector location).

Model dimensions


$$Z = mx + b$$

$$m = \frac{(2195.0)}{(602.62 - 1236.18)}$$

$$m = -3.4649$$

$$\text{for } Z=0, x = 1236.18$$

$$b = 4283.1971$$



$$\therefore Z = -3.4649X + 4283.197$$

$$@ Z = 640.08 \quad X = 1051.43$$

Ver. For comments
Azimuth

Detector Location

$$R = 1051.43 \text{ cm}$$

$$\theta = 0$$

$$Z = 640.08 \text{ cm}$$

$$A - 255^\circ$$

$$B - 60^\circ$$

Azimuth for detectors
is NOT important
to this model and
results, only relative
distance from sac shield
wall.

The surrounding sphere will be located
around the detector point as body # 16

CONTENTS
ORIGINAL ARTICLES
The Role of the Physician in the Management of the Patient with a Heart Disease
The Role of the Physician in the Management of the Patient with a Lung Disease
The Role of the Physician in the Management of the Patient with a Kidney Disease
The Role of the Physician in the Management of the Patient with a Liver Disease
The Role of the Physician in the Management of the Patient with a Stomach Disease
The Role of the Physician in the Management of the Patient with a Small Intestine Disease
The Role of the Physician in the Management of the Patient with a Large Intestine Disease
The Role of the Physician in the Management of the Patient with a Genitourinary Disease
The Role of the Physician in the Management of the Patient with a Gynecological Disease
The Role of the Physician in the Management of the Patient with a Dermatological Disease
The Role of the Physician in the Management of the Patient with a Neurological Disease
The Role of the Physician in the Management of the Patient with a Psychiatric Disease
The Role of the Physician in the Management of the Patient with a Systemic Disease
The Role of the Physician in the Management of the Patient with a Infectious Disease
The Role of the Physician in the Management of the Patient with a Parasitic Disease
The Role of the Physician in the Management of the Patient with a Neoplastic Disease
The Role of the Physician in the Management of the Patient with a Traumatic Disease
The Role of the Physician in the Management of the Patient with a Poisoning Disease
The Role of the Physician in the Management of the Patient with a Surgical Disease
The Role of the Physician in the Management of the Patient with a Medical Disease
The Role of the Physician in the Management of the Patient with a Miscellaneous Disease

THE JOURNAL OF THE AMERICAN MEDICAL ASSOCIATION
PUBLISHED WEEKLY
CHICAGO, ILL., MAY 1, 1935
Vol. 44, No. 19

CONTENTS

ORIGINAL ARTICLES

The Role of the Physician in the Management of the Patient with a Heart Disease

The Role of the Physician in the Management of the Patient with a Lung Disease

The Role of the Physician in the Management of the Patient with a Kidney Disease

The Role of the Physician in the Management of the Patient with a Liver Disease

The Role of the Physician in the Management of the Patient with a Stomach Disease

The Role of the Physician in the Management of the Patient with a Small Intestine Disease

The Role of the Physician in the Management of the Patient with a Large Intestine Disease

The Role of the Physician in the Management of the Patient with a Genitourinary Disease

The Role of the Physician in the Management of the Patient with a Gynecological Disease

The Role of the Physician in the Management of the Patient with a Dermatological Disease

The Role of the Physician in the Management of the Patient with a Neurological Disease

The Role of the Physician in the Management of the Patient with a Psychiatric Disease

The Role of the Physician in the Management of the Patient with a Systemic Disease

The Role of the Physician in the Management of the Patient with a Infectious Disease

The Role of the Physician in the Management of the Patient with a Parasitic Disease

The Role of the Physician in the Management of the Patient with a Neoplastic Disease

The Role of the Physician in the Management of the Patient with a Traumatic Disease

The Role of the Physician in the Management of the Patient with a Poisoning Disease

The Role of the Physician in the Management of the Patient with a Surgical Disease

The Role of the Physician in the Management of the Patient with a Medical Disease

The Role of the Physician in the Management of the Patient with a Miscellaneous Disease



MANUAL CALCULATION

PAGE

5.013

CONT'D ON
PAGE

CALCULATION NO.

NE-02-94-57

PREPARED BY / DATE

S.J. Haynes

8/24/94

VERIFIED BY / DATE

Shen Shap

8/30/94

REVISION NO.

0

REV.
BAR

Sphere location / detector location


$$V_x = 1051.43$$

$$\text{Radius} = (1.5)(2.59) = 3.81 \text{ cm}$$

$$V_y = 0.0$$

$$V_z = 640.08$$

To correct the QAD detector response to the source cone angle the source cone volume to hemisphere ratio will be used



α = source cone angle

for CMS-RE-27A $\alpha = 15^\circ$ APR 11.2.10.6

CMS-RE-27B $\alpha = 16^\circ$

$$\text{Correction Factor} = \frac{\text{Volume of cone}}{\text{Volume of sphere}}$$

$$\text{Volume of cone} = \frac{2\pi r^3}{3} (1 - \cos \frac{\alpha}{2})$$

see Reference 5
page 859

$$\text{Volume of hemisphere} = \frac{2}{3} \pi r^3$$

$$\text{Correction factor} = \frac{\frac{2}{3} \pi r^3 (1 - \cos \frac{\alpha}{2})}{\frac{2}{3} \pi r^3} = (1 - \cos \frac{\alpha}{2})$$

Detector α correction factor

CMS-RE-27A	15	0.00856	✓
CMS-RE-27B	16	0.00973	✓

Ver: For comment

when $\alpha = 180^\circ$ then $(1 - \cos \frac{\alpha}{2}) = 1$ and ratio is valid

Subscription price, Five Dollars Per Annum in Advance

Single Copies, Fifteen Cents Each

Entered as Second-Class Matter, May 26, 1917

19

Postage paid at
Chicago, Ill.

Acceptance for
special rate of postage provided
for in Act of October 3, 1917
authorized on May 1, 1935

Postage paid at
Chicago, Ill.

Postage paid at
Chicago, Ill.

Postage paid at
Chicago, Ill.

Postage paid at
Chicago, Ill.

Postage paid at
Chicago, Ill.

Postage paid at
Chicago, Ill.

Postage paid at
Chicago, Ill.

Postage paid at
Chicago, Ill.

Postage paid at
Chicago, Ill.

Postage paid at
Chicago, Ill.

Postage paid at
Chicago, Ill.

Postage paid at
Chicago, Ill.

Postage paid at
Chicago, Ill.



WASHINGTON PUBLIC POWER
SUPPLY SYSTEM

MANUAL CALCULATION

PAGE

5.04

CONT'D ON
PAGE

CALCULATION NO.

NE-02-94-57

PREPARED BY / DATE

S.J. Haynes 8/24/94

VERIFIED BY / DATE

Don Sharp 8/30/94

REVISION NO.

0

REV.
BAR

CMS-RE-27E & F

detector elevation

E - 516' 0"

M 893 S43

F - 515' 8"

distance from SAC SHIELD

E = 15'

PPM 11.2.10.06

F = 20'

Azimuth

E - 300

F - 45

Since internals are ^{not} modeled the azimuth for the detectors is not important to the results, only relative distance within containment

Δ
v/c
20.5
5/16/94

<u>detector</u>	<u>Z (cm)</u>	<u>Q</u>	<u>R</u>
CMS-RE-27E	457.2 ✓	.19635 ✓	913.77 ✓
CMS-RE-27F	447.04 ✓	.19635 ✓	1066.17 ✓

* see note on bottom of page 5.016

The following pages contain the QAD input file with the source term for I-131

note: For all cases Energies below to key are deleted since they will not contribute to detector response (see Appendix E for detector response curves).

Verifier comment *A*

Due to radial difference in placement of E and F monitors the E detector should see more of the drywell volume and result in higher values than F detectors.





WASHINGTON PUBLIC POWER
SUPPLY SYSTEM

MANUAL CALCULATION

PAGE 5.015 CONT'D ON
PAGE

CALCULATION NO.
NE-02-94-57

PREPARED BY / DATE

S.J. Haynes 9/14/94

VERIFIED BY / DATE

GC-8 J. H. 9/16/94

REVISION NO.

1

REV.
BAR

2 DRYWELL MODEL/CMS-RE-27A,27B,27E,2F (1.e-6 Ci/cc I-131 source)

* set up one source for drywell volume *****

* mat ncomp nrgy ineut nsrcc nrcvrs nflage

6 6 10 0 1 3 1

* as1 as2 as3

2 0 0.0

* CG body number for source

15

* nsopt nx ny nz ngpf ngpl ngpi

0 40 60 80 1 10 5

* source strength (data from RADDECAY probability/decay*total source)

3.4745E+13 3.5140E+12 8.0314E+13 3.3269E+12 1.0771E+15 4.7840E+12

9.6350E+13 2.9129E+12 2.3920E+13 3.0575E+12

* Combinatorial Geometry *****

0 0 WNP-2 COMPLETE DRYWELL MODEL

TRC 1 0.0 0.0 0.0 0.0 0.0 2195.20

1236.18 602.62

TRC 2 0.0 0.0 2195.20 0.0 0.0 208.28

602.62 482.60

RCC 3 0.0 0.0 2403.48 0.0 0.0 332.74

482.60

SPH 4 0.0 0.0 2736.22 482.60

RCC 5 0.0 0.0 2976.89 0.0 0.0 241.93

482.60

RCC 6 0.0 0.0 0.0 0.0 0.0 2023.11

393.70

RCC 7 0.0 0.0 0.0 0.0 0.0 2023.11

456.57

SPH 8 0.0 0.0 929.01 318.77

SPH 9 0.0 0.0 929.01 334.01

RCC 10 0.0 0.0 929.01 0.0 0.0 532.13

318.77

RCC 11 0.0 0.0 1461.14 0.0 0.0 1050.29

318.77

RCC 12 0.0 0.0 929.01 0.0 0.0 1582.42

334.01

SPH 13 0.0 0.0 2511.43 318.77

SPH 14 0.0 0.0 2511.43 334.01

RCC 15 0.0 0.0 0.0 0.0 0.0 3218.82

1236.18

SPH 16 1051.43 0.0 640.08 3.81

END

* CGC cards to describe material zones *****

air 50OR 1 -7 -12 -16

OR 2 -12

OR 3 -12 -14

OR 4 -5 -14

OR 6 -9 -12

con 50OR 7 -6

stl 50OR 9 -8 -10



WASHINGTON PUBLIC POWER

SUPPLY SYSTEM

MANUAL CALCULATION

PAGE

5.016

CONT'D ON

PAGE

CALCULATION NO.

NE-02-94-57

PREPARED BY / DATE

S.J. Haynes 9/14/99

VERIFIED BY / DATE

C.K. S. 9/16/99

REVISION NO.

1

REV.

BAR

OR 12 -10 -11
OR 14 -13 -11
OR 1 16

Rw1 50OR 8OR 10

Rs1 50OR 11OR 13

Pb 50OR 15 -1 -2 -3 -4 -5
OR 5

END

* CGD cards - not used in QAD *****

1 1 1 1 1 1

* CGE cards - composition # to zone # *****

1 2 3 4 5 6

*nbld h2o N O con. 04 Fe Pb

3 101 7 8 106 26 82

0.0 0.00086 0.00025 0.0 0.0 0.0 --- air

0.0 0.0 0.0 1.0 0.0 0.0 --- concrete

0.0 0.0 0.0 0.0 7.860 0.0 --- steel

0.9597 0.0 0.0 0.0 3.390 0.0 --- water+steel

0.000599 0.0 0.0 0.0 1.572 0.0 --- steam+steel

0.0 0.0 0.0 0.0 0.0 1.e8 --- lead

* EBAR - gamma energy groups *****

8.0183E-02 1.7721E-01 2.8430E-01 3.2578E-01 3.6448E-01 5.0299E-01

6.3697E-01 6.4270E-01 7.2289E-01 3.2939E-01

* DETECTOR locations *****

1051.43 0.0 640.08 0 - CMS-RE-27A & 27B

913.77 0.19635 457.20 0 - CMS-RE-27E

1066.17 0.19635 447.04 0 - CMS-RE-27F

NOTE: The azimuthal angle for the E&F detectors are set off of the X axis line at an angle of
0.19635 radians. This will not impact the results due to model symmetry.

MANUAL CALCULATION

PAGE

5.017

CONT'D ON
PAGE

CALCULATION NO.

NE-02-94-57

PREPARED BY / DATE

S. J. Haynes 8/24/94

VERIFIED BY / DATE

[Signature] 8/30/94

REVISION NO.

0

REV.
BAR

D. QAD RUNS

18 QAD runs will be made to determine detector response to a $1 \mu\text{Ci/cc}$ source

Once detector response is determined for a given $1 \mu\text{Ci/cc}$ source the accident source term from calculation NE-02-88-27 times a given % clad damage will be used to generate detector response

<u>ISOTOPE</u>	<u>Input Files</u> **	
I-131	I131	✓
I-132	I132a	✓
	I132b	✓
	I132c	✓
	I132d	✓
I-133	I133a	✓
	I133b	✓
I-134	I134a	✓
	I134b	✓
	I134c	✓
	I134d	✓
I-135	I135a	✓
	I135b	✓
	I135c	✓
Kr-83m*		
Kr-85	Kr85	✓
Kr-85m	Kr85m	✓
Kr-87	Kr87a	✓
	Kr87b	✓
Kr-88	Kr88a	✓
	Kr88b	✓
	Kr88c	✓

** Output files in Appendix AC input name with .out extension

* energy from Kr-83m is below detector response, no run made.



WASHINGTON PUBLIC POWER
SUPPLY SYSTEM

MANUAL CALCULATION

PAGE

5.018

CONT'D ON
PAGE

CALCULATION NO.

NE-02-94-57

PREPARED BY / DATE

S. J. Haynes

8/25/94

VERIFIED BY / DATE

John J. Haynes 8/30/94

REVISION NO.

0

REV.
BAR

ISOTOPE

INPUT FILES

Kr - 89

Kr89a ✓

Kr89b ✓

Kr89c ✓

Kr89d ✓

Kr89e ✓

Kr89f ✓

Xe - 131m

Xe131m ✓

Xe - 133

Xe133 ✓

Xe - 133m

Xe133m ✓

Xe - 135

Xe135 ✓

Xe - 135m

Xe135m ✓

Xe - 138

Xe138a ✓

Xe138b ✓

Xe138c ✓

Kr - 89

Kr89g ✓

Kr89h ✓

Xe - 137

Xe137 ✓





MANUAL CALCULATION

E. DETECTOR RESPONSE

The QAD results for each isotope energy group (R/hr including buildup) will be combined with detector response (see Appendix E for vendor data) and EALS to produce detector response.

Three spreadsheets will be used, 1 for CMS-RE-27A & 27B and the other 2 for CMS-RE-27E & 27F. The spreadsheet will take the $1 \mu\text{Ci/cc}$ source data, times the detector efficiency/energy group, and times the EAL source.

Source Term

The design basis source term from Reference 6 (NE-02-88-27) will be used for the Halogen & Noble gas source contained in the fuel matrix. For each EAL a given % of this source will be released into the containment instantaneously. The EALS are (see Reference 7):

- 1) Technical Specification reactor coolant activity limits of $4 \mu\text{Ci/cc}$ dose equivalent I-131 (approximately 0.1% clad failure)
- 2) Release of reactor coolant Noble gas and iodine inventory associated with a concentration of approximately $300 \mu\text{Ci/gm}$ dose equivalent I-131 (approximately 2-5% core damage).
- 3) 20% core damage.

The following table presents the core inventory of Halogens & Noble gas at time=0



WASHINGTON PUBLIC POWER
SUPPLY SYSTEM

MANUAL CALCULATION

PAGE

5.020

CONT'D ON
PAGE

CALCULATION NO.

NE-02-94-57

PREPARED BY / DATE

S. J. Haynes

8/26/94

VERIFIED BY / DATE

John Sharp 9/1/94

REVISION NO.

0

REV.
BAR



	<u>Isotope</u>	<u>Source (Ci)</u>
HALOGENS	I-131	2.422×10^7 ✓
	I-132	3.466×10^7 ✓
	I-133	4.747×10^7 ✓
	I-134	5.183×10^7 ✓
	I-135	4.470×10^7 ✓
NOBLE GAS	Kr-83m	9.938×10^6 ✓
	Kr-85	8.915×10^5 ✓
	Kr-85m	1.976×10^7 ✓
	Kr-87	3.671×10^7 ✓
	Kr-88	5.139×10^7 ✓
	Kr-89	6.082×10^7 ✓
	Xe-131m	9.762×10^5 ✓
	Xe-133	1.902×10^7
	Xe-133m	6.044×10^6 ✓
	Xe-135	4.723×10^7 ✓
	Xe-135m	3.905×10^7 ✓
	Xe-137	1.656×10^8 ✓
	Xe-138	1.506×10^8 ✓

1.902×10^8 *AS*

Net Free Volume Drywell = $200,540 \text{ ft}^3$ ✓ FSAR Table 6.2-1
= $5.6787 \times 10^9 \text{ cm}^3$ ✓

Volume of water in Vessel = $12,743 \text{ ft}^3$ ✓ FSAR Table 6.2-4
" Recirc Loops = 670 ft^3 ✓
Total release = $13,413 \text{ ft}^3$ ✓
= $3.7981 \times 10^8 \text{ cm}^3$ ✓

Release fraction for gap release Xe, Kr = 0.03 ✓ NUREG-1228
I = 0.02 ✓

 WASHINGTON PUBLIC POWER SUPPLY SYSTEM	MANUAL CALCULATION		PAGE 5.021	CONT'D ON PAGE
			CALCULATION NO. NE-02-94-57	
PREPARED BY / DATE S. J. Haynes 8/26/94	VERIFIED BY / DATE  8/30/94	REVISION NO. 0	REV. BAR	

CASE 1 - Technical Specification Limit $4 \mu\text{Ci/gm}$ I-131 dose equivalent

normal operating condition

$$T = 534^\circ\text{F}$$

$$P = 1035 \text{ psia}$$

$$\rho = 47.061 \frac{\text{lb}_m}{\text{ft}^3} \times 0.01602 = 0.7539 \frac{\text{gm}}{\text{cm}^3}$$

$$\text{Curies Released} = (3.7981 \times 10^8 \text{ cm}^3) (0.7539 \frac{\text{gm}}{\text{cm}^3}) (4 \mu\text{Ci/gm})$$

$$= 1.1454 \times 10^9 \mu\text{Ci I-131} \checkmark$$

$$\text{Concentration in drywell} = \frac{1.1454 \times 10^9 \mu\text{Ci}}{5.6787 \times 10^9 \text{ cm}^3} = 0.202 \frac{\mu\text{Ci}}{\text{cc}}$$

CASE 2 - $300 \mu\text{Ci/cc}$ I-131 dose equivalent

$$\text{Curies released} = (3.7981 \times 10^8 \text{ cm}^3) (0.7539 \frac{\text{gm}}{\text{cm}^3}) (300 \mu\text{Ci/gm})$$


$$= 8.5901 \times 10^{10} \text{ Ci} \checkmark$$

$$\text{Concentration in Drywell} = \frac{8.5901 \times 10^{10} \text{ Ci}}{5.6787 \times 10^9 \text{ cm}^3} = 15.1269 \frac{\mu\text{Ci}}{\text{cc}}$$

CASE 3 - 20% core damage

NUREG 1228 specifies a gap release fraction of .03 for XE & K and .02 for I

- Case 4 - 0.1% core damage
- Case 5 - 2% core damage
- Case 6 - 5% core damage

 WASHINGTON PUBLIC POWER SUPPLY SYSTEM	MANUAL CALCULATION		PAGE 5022	CONT'D ON PAGE
			CALCULATION NO. NE-02-24-57	
PREPARED BY / DATE S.J. Haynes 8/29/94	VERIFIED BY / DATE <i>Loren Sharp</i> 8/30/94	REVISION NO. 0	REV. BAR	
<p>EXCEL Spreadsheets will be created to determine detector response for each case. MathCad was used to determine detector efficiency for each of the isotope gamma energy groups. The data of detector efficiency from Appendix E was input into MathCad and used to interpolate detector efficiency for each energy group. The results were read into the EXCEL Spreadsheet.</p> <p>The following pages present the MathCad Calculation and the EXCEL Sproud Sheet results.</p> <p><u>Power Uprate</u></p> <p>Power uprate will not impact either Case 1 or Case 2. For case three the reported detector response can be increased by a factor of 1.0528 (See calculation in Reference 8)</p>				

Prepared By: S.J. Haynes 8/29/94

Page: 5.023


Verified *Longstaff* 8/30/94

j := 1..501 Number of Isotopes
 i := 1..18 Number of Data Points for Detector CMS-RE-27E&F
 k := 1..17 Number of Data Points for Detector CMS-RE-27A&B

MeV_j := Eff27EF_j := Mab_k := Eff27AB_k :=

.038	0.0	0.04	0.0
.050	.20	.061	.35
.060	.38	.070	.53
.070	.50	.080	.71
.071	.80	.090	.83
.080	.90	.100	.91
.100	1.0	.105	1.0
.120	1.02	.130	1.05
.130	1.02	.200	1.05
.150	1.0	.250	1.04
.200	.975	.300	1.01
.300	.96	.400	1.00
.400	.95	.500	.99
.6617	1.0	.6617	1.0
1.0	1.01	1.00	1.01
1.1732	1.0	2.00	1.1
2.0	.97	3.00	1.2
3.0	.9		

Detector CMS-RE-27A,B,E,F Efficiency

Energy_j := READ(mev)

vs := cspline(MeV, Eff27EF)

RES_j := interp(vs, MeV, Eff27EF, Energy_j)WRITE(r27ef) := RES_j

vs1 := cspline(Mab, Eff27AB)

RESA_j := interp(vs1, Mab, Eff27AB, Energy_j)WRITE(r27ab) := RESA_j

The following Tables are representative of the output files generated for input into the EXCEL spreadsheet calculations

Ver: Fred: *[Signature]*
8/30/94

kk := 1..10

Energy _{kk}	RES _{kk}	RESA _{kk}
0.08018	0.88417	0.71288
0.17721	0.9756	1.01957
0.2843	0.96336	1.01753
0.32578	0.95537	1.0028
0.36448	0.95096	1.00011
0.50299	0.96321	0.98982
0.63697	0.99497	0.99744
0.6427	0.9962	0.99806
0.72289	1.00909	1.00471
0.32939	0.95482	1.00223

Verified Love Sharp
9/1/94

Isotope	Photon Energy (MeV)	Probability	Drywell Concentration (uCi/cc)	Energy Group Concentration (uCi/cc)	CMS-RE-27A&B QAD Detector Response (Rad/hr)	CMS-RE-27A&B Efficiency	CMS-RE-27A&B Response (Rad/hr)
I-131	0.080183	0.026182	0.202	0.005288764	2.18E-07	0.71	8.18219E-10
I-131	0.17721	0.002648		0.000534896	1.18E-03	1.02	6.42546E-07
I-131	0.2843	0.060521		0.012225242	1.44E-01	1.02	0.001797514
I-131	0.32578	0.002507		0.000506414	8.46E-03	1.00	4.28578E-06
I-131	0.36448	0.81164		0.16395128	3.48E+00	1.00	0.570763591
I-131	0.50299	0.003605		0.00072821	3.42E-02	0.99	2.46615E-05
I-131	0.63697	0.072605		0.01466621	1.05E+00	1.00	0.015340856
I-131	0.6427	0.002195		0.00044339	3.19E-02	1.00	1.41552E-05
I-131	0.72289	0.018025		0.00364105	2.95E-01	1.00	0.001073163
I-131	0.32939	0.002304		0.000465408	7.96E-03	1.00	3.70632E-06
Sum							0.587945707

Cone Factor 0.00856 CMS-RE-27A Response = 0.005032815 Rad/hr
Cone Factor 0.00973 CMS-RE-27B Responses = 0.005720712

photon Energy (MeV)	CMS-RE-27E QAD Detector Response (Rad/hr)	CMS-RE-27F QAD Detector Response (Rad/hr)	CMS-RE-27E&F Efficiency	CMS-RE-27E Response (Rad/hr)	CMS-RE-27E Response (Rad/hr)
0.080183	1.22E-01	9.65E-02	0.88	0.000568174	0.00044921
0.17721	2.70E-02	2.13E-02	0.98	1.4135E-05	1.11832E-05
0.2843	1.16E+00	9.17E-01	0.96	0.013597599	0.010761773
0.32578	5.67E-02	4.49E-02	0.96	2.75831E-05	2.18328E-05
0.36448	2.09E+01	1.65E+01	0.95	3.248399501	2.571338097
0.50299	1.51E-01	1.20E-01	0.96	0.000105778	8.3757E-05
0.63697	3.38E+00	2.68E+00	0.99	0.049121083	0.038942879
0.6427	1.03E-01	8.17E-02	1.00	4.57091E-05	3.62365E-05
0.72289	9.44E-01	7.48E-01	1.01	0.003470787	0.002750262
0.32939	5.28E-02	4.18E-02	0.95	2.33577E-05	1.84884E-05

CMS-RE-27E
Response = 3.315373706 Rad/hr
CMS-RE-27F
Response = 2.62441372 Rad/hr

CMS-RE-27A,B,E,F Response to 100 uCi/cc Source In RPV Liquid

Calc. No: NE-02-94- rev 0
 Prepared By: S. J. Haynes 9/94
 page: 5.026

Ver: Fred Loren Sharp
9/1/94

Isotope	Photon Energy (MeV)	Probability	Drywell Concentration (uCi/cc)	Energy Group Concentration (uCi/cc)	CMS-RE-27A&B QAD Detector Response (Rad/hr)	CMS-RE-27A&B Efficiency	CMS-RE-27A&B Response (Rad/hr)
I-131	0.080183	0.026182	15.1269	0.396052496	2.18E-07	0.71	6.12729E-08
I-131	0.17721	0.002648		0.040056031	1.18E-03	1.02	4.81175E-05
I-131	0.2843	0.060521		0.915495115	1.44E-01	1.02	0.134607993
I-131	0.32578	0.002507		0.037923138	8.46E-03	1.00	0.000320944
I-131	0.36448	0.81164		12.27759712	3.48E+00	1.00	42.74199884
I-131	0.50299	0.003605		0.054532475	3.42E-02	0.99	0.001846792
I-131	0.63697	0.072605		1.098288575	1.05E+00	1.00	1.148809849
I-131	0.6427	0.002195		0.033203546	3.19E-02	1.00	0.001060023
I-131	0.72289	0.018025		0.272662373	2.95E-01	1.00	0.080364508
I-131	0.32939	0.002304		0.034852378	7.96E-03	1.00	0.00027755

Sum = 44.02869262

Cone Factor 0.00856 CMS-RE-27A Response = 0.376885609 Rad/hr
 Cone Factor 0.00973 CMS-RE-27B Responses = 0.428399179 Rad/hr

photon Energy (Mev)	CMS-RE-27E QAD Detector Response (Rad/hr)	CMS-RE-27F QAD Detector Response (Rad/hr)	CMS-RE-27E&F Efficiency	CMS-RE-27E Response (Rad/hr)	CMS-RE-27E Response (Rad/hr)
0.080183	1.22E-01	9.65E-02	0.88	0.042548078	0.0336394
0.17721	2.70E-02	2.13E-02	0.98	0.001058509	0.000837464
0.2843	1.16E+00	9.17E-01	0.96	1.018264935	0.805902293
0.32578	5.67E-02	4.49E-02	0.96	0.002065579	0.001634967
0.36448	2.09E+01	1.65E+01	0.95	243.2584872	192.5563082
0.50299	1.51E-01	1.20E-01	0.96	0.007921256	0.006272194
0.63697	3.38E+00	2.68E+00	0.99	3.678463876	2.916262588
0.6427	1.03E-01	8.17E-02	1.00	0.003422954	0.002713593
0.72289	9.44E-01	7.48E-01	1.01	0.259912135	0.205955169
0.32939	5.28E-02	4.18E-02	0.95	0.001749155	0.001384518

CMS-RE-27E
 Response = 248.2738937 Rad/hr
 CMS-RE-27F
 Response = 196.5309104 Rad/hr

Case #3- 20% Rad Failure
CMS-RE-27A,B,E,F Detector Response

Calc. No.: NE-02-94-57 rev 1
Prepared By: S. J. Haynes 1/94
page:5.027

1/18
7-25
7/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
I-131	0.080183	0.026182	2.422E+07	0.0200	4.47E-01	3.20E-07	0.71	1.015E-07	1.79E-01	1.42E-01	0.88	7.05E-02	5.58E-02
	0.17721	0.002648	2.422E+07	0.0200	4.52E-02	1.73E-03	1.02	7.975E-05	3.96E-02	3.14E-02	0.98	1.75E-03	1.39E-03
	0.2843	0.060521	2.422E+07	0.0200	1.03E+00	2.12E-01	1.02	2.231E-01	1.70E+00	1.35E+00	0.96	1.69E+00	1.34E+00
	0.32578	0.002507	2.422E+07	0.0200	4.28E-02	1.24E-02	1.00	5.321E-04	8.34E-02	6.60E-02	0.96	3.42E-03	2.71E-03
	0.36448	0.81164	2.422E+07	0.0200	1.38E+01	5.12E+00	1.00	7.085E+01	3.07E+01	2.43E+01	0.95	4.03E+02	3.19E+02
	0.50299	0.003605	2.422E+07	0.0200	6.15E-02	5.03E-02	0.99	3.061E-03	2.22E-01	1.76E-01	0.96	1.31E-02	1.04E-02
	0.63697	0.072605	2.422E+07	0.0200	1.24E+00	1.54E+00	1.00	1.904E+00	4.97E+00	3.94E+00	0.99	6.10E+00	4.83E+00
	0.6427	0.002195	2.422E+07	0.0200	3.74E-02	4.69E-02	1.00	1.757E-03	1.52E-01	1.20E-01	1.00	5.67E-03	4.50E-03
	0.72289	0.018025	2.422E+07	0.0200	3.08E-01	4.33E-01	1.00	1.333E-01	1.39E+00	1.10E+00	1.01	4.31E-01	3.41E-01
	0.32939	0.002304	2.422E+07	0.0200	3.93E-02	1.17E-02	1.00	4.602E-04	7.77E-02	6.15E-02	0.95	2.90E-03	2.30E-03
I-132	0.1472	0.002369	3.466E+07	0.0200	5.78E-02	5.60E-04	1.01	3.273E-05	2.80E-02	2.21E-02	1.01	1.63E-03	1.29E-03
	0.1833	0.001382	3.466E+07	0.0200	3.37E-02	1.07E-03	1.03	3.719E-05	2.16E-02	1.71E-02	0.97	7.08E-04	5.60E-04
	0.2548	0.001875	3.466E+07	0.0200	4.58E-02	4.65E-03	1.04	2.215E-04	4.57E-02	3.62E-02	0.97	2.03E-03	1.61E-03
	0.2627	0.01441	3.466E+07	0.0200	3.52E-01	3.93E-02	1.03	1.424E-02	3.66E-01	2.90E-01	0.97	1.25E-01	9.88E-02
	0.2848	0.007205	3.466E+07	0.0200	1.76E-01	2.54E-02	1.02	4.551E-03	2.03E-01	1.61E-01	0.96	3.43E-02	2.72E-02
	0.3165	0.001382	3.466E+07	0.0200	3.37E-02	6.45E-03	1.00	2.176E-04	4.44E-02	3.52E-02	0.96	1.44E-03	1.14E-03
	0.3635	0.004935	3.466E+07	0.0200	1.20E-01	3.09E-02	1.00	3.727E-03	1.86E-01	1.47E-01	0.95	2.13E-02	1.68E-02
	0.3878	0.002961	3.466E+07	0.0200	7.23E-02	2.13E-02	1.00	1.539E-03	1.19E-01	9.44E-02	0.95	8.19E-03	6.49E-03
	0.4168	0.004738	3.466E+07	0.0200	1.16E-01	3.90E-02	1.00	4.512E-03	2.05E-01	1.62E-01	0.95	2.25E-02	1.78E-02
	0.4319	0.004836	3.466E+07	0.0200	1.18E-01	4.22E-02	1.00	4.988E-03	2.16E-01	1.71E-01	0.95	2.42E-02	1.91E-02
	0.446	0.006021	3.466E+07	0.0200	1.47E-01	5.55E-02	1.00	8.151E-03	2.76E-01	2.18E-01	0.95	3.85E-02	3.05E-02
	0.4739	0.001777	3.466E+07	0.0200	4.34E-02	1.80E-02	0.99	7.752E-04	8.54E-02	6.76E-02	0.96	3.56E-03	2.81E-03
	0.4785	0.001481	3.466E+07	0.0200	3.62E-02	1.53E-02	0.99	5.467E-04	7.16E-02	5.67E-02	0.96	2.49E-03	1.97E-03
	0.4882	0.004145	3.466E+07	0.0200	1.01E-01	4.41E-02	0.99	4.421E-03	2.03E-01	1.61E-01	0.96	1.98E-02	1.56E-02
	0.5059	0.050337	3.466E+07	0.0200	1.23E+00	7.14E-01	0.99	8.690E-01	3.10E+00	2.46E+00	0.96	3.66E+00	2.90E+00
	0.52265	0.16088	3.466E+07	0.0200	3.93E+00	2.49E+00	0.99	9.682E+00	9.89E+00	7.83E+00	0.97	3.77E+01	2.98E+01
	0.5355	0.005231	3.466E+07	0.0200	1.28E-01	8.55E-02	0.99	1.081E-02	3.23E-01	2.56E-01	0.97	4.00E-02	3.17E-02
	0.54	0.001086	3.466E+07	0.0200	2.65E-02	1.81E-02	0.99	4.742E-04	6.71E-02	5.32E-02	0.97	1.73E-03	1.37E-03
	0.5471	0.012535	3.466E+07	0.0200	3.06E-01	2.14E-01	0.99	6.481E-02	7.77E-01	6.16E-01	0.97	2.31E-01	1.83E-01
	0.6	0.001382	3.466E+07	0.0200	3.37E-02	2.74E-02	0.99	9.143E-04	9.02E-02	7.15E-02	0.99	3.01E-03	2.39E-03
	0.6208	0.003948	3.466E+07	0.0200	9.64E-02	8.13E-02	1.00	7.838E-03	2.65E-01	2.10E-01	0.99	2.53E-02	2.00E-02
	0.6212	0.015792	3.466E+07	0.0200	3.86E-01	3.26E-01	1.00	1.255E-01	1.06E+00	8.40E-01	0.99	4.04E-01	3.21E-01
	0.63022	0.13719	3.466E+07	0.0200	3.35E+00	2.87E+00	1.00	9.623E+00	9.31E+00	7.38E+00	0.99	3.09E+01	2.45E+01

Case #3- 20-y Clad Failure
CMS-RE-27A,B,E, Reactor Response

Calc. No.: NE-02-94-07 rev 1
Prepared By: S. J. Haynes 5/94
page:5.028

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	0.6506	0.026649	3.466E+07	0.0200	6.51E-01	5.77E-01	1.00	3.753E-01	1.86E+00	1.47E+00	1.00	1.21E+00	9.59E-01
	0.659	0.003948	3.466E+07	0.0200	9.64E-02	8.66E-02	1.00	8.345E-03	2.79E-01	2.21E-01	1.00	2.69E-02	2.13E-02
	0.66769	0.987	3.466E+07	0.0200	2.41E+01	2.19E+01	1.00	5.286E+02	7.05E+01	5.59E+01	1.00	1.70E+03	1.35E+03
	0.6698	0.04935	3.466E+07	0.0200	1.20E+00	1.10E+00	1.00	1.325E+00	3.54E+00	2.80E+00	1.00	4.26E+00	3.38E+00
	0.6716	0.052311	3.466E+07	0.0200	1.28E+00	1.17E+00	1.00	1.493E+00	3.76E+00	2.98E+00	1.00	4.80E+00	3.80E+00
	0.727	0.031584	3.466E+07	0.0200	7.71E-01	7.64E-01	1.00	5.887E-01	2.44E+00	1.94E+00	1.01	1.90E+00	1.51E+00
	0.7272	0.021714	3.466E+07	0.0200	5.30E-01	5.25E-01	1.00	2.784E-01	1.68E+00	1.33E+00	1.01	9.00E-01	7.13E-01
	0.7285	0.010857	3.466E+07	0.0200	2.65E-01	2.63E-01	1.01	7.042E-02	8.42E-01	6.67E-01	1.01	2.25E-01	1.79E-01
	0.7645	0.003948	3.466E+07	0.0200	9.64E-02	1.00E-01	1.01	9.777E-03	3.21E-01	2.54E-01	1.01	3.12E-02	2.47E-02
	0.77261	0.76196	3.466E+07	0.0200	1.86E+01	1.96E+01	1.01	3.681E+02	6.25E+01	4.95E+01	1.01	1.17E+03	9.30E+02
	0.7802	0.012338	3.466E+07	0.0200	3.01E-01	3.21E-01	1.01	9.751E-02	1.02E+00	8.09E-01	1.01	3.11E-01	2.46E-01
	0.7845	0.004244	3.466E+07	0.0200	1.04E-01	1.11E-01	1.01	1.161E-02	3.53E-01	2.80E-01	1.01	3.70E-02	2.93E-02
	0.8098	0.028623	3.466E+07	0.0200	6.99E-01	7.72E-01	1.01	5.448E-01	2.45E+00	1.94E+00	1.01	1.73E+00	1.37E+00
	0.8122	0.056259	3.466E+07	0.0200	1.37E+00	1.52E+00	1.01	2.110E+00	4.84E+00	3.83E+00	1.01	6.71E+00	5.32E+00
	0.8633	0.005823	3.466E+07	0.0200	1.42E-01	1.66E-01	1.01	2.390E-02	5.30E-01	4.19E-01	1.02	7.68E-02	6.08E-02
	0.8768	0.010758	3.466E+07	0.0200	2.63E-01	3.12E-01	1.01	8.280E-02	9.92E-01	7.86E-01	1.02	2.66E-01	2.11E-01
	0.9103	0.009179	3.466E+07	0.0200	2.24E-01	2.76E-01	1.01	6.251E-02	8.75E-01	6.93E-01	1.01	1.98E-01	1.57E-01
	0.9276	0.004145	3.466E+07	0.0200	1.01E-01	1.27E-01	1.01	1.299E-02	4.02E-01	3.18E-01	1.01	4.11E-02	3.25E-02
	0.95455	0.18062	3.466E+07	0.0200	4.41E+00	5.71E+00	1.01	2.541E+01	1.79E+01	1.42E+01	1.01	7.99E+01	6.33E+01
	0.9837	0.005626	3.466E+07	0.0200	1.37E-01	1.84E-01	1.01	2.546E-02	5.73E-01	4.54E-01	1.01	7.95E-02	6.30E-02
	1.0347	0.004738	3.466E+07	0.0200	1.16E-01	1.62E-01	1.01	1.895E-02	5.03E-01	3.99E-01	1.01	5.88E-02	4.66E-02
	1.136	0.02961	3.466E+07	0.0200	7.23E-01	1.11E+00	1.01	8.075E-01	3.39E+00	2.68E+00	1.00	2.45E+00	1.94E+00
	1.1434	0.013522	3.466E+07	0.0200	3.30E-01	5.08E-01	1.01	1.694E-01	1.55E+00	1.23E+00	1.00	5.13E-01	4.06E-01
	1.1474	0.002764	3.466E+07	0.0200	6.75E-02	1.04E-01	1.01	7.106E-03	3.18E-01	2.52E-01	1.00	2.15E-02	1.70E-02
	1.1732	0.010857	3.466E+07	0.0200	2.65E-01	4.19E-01	1.02	1.132E-01	1.27E+00	1.01E+00	1.00	3.37E-01	2.67E-01
	1.2727	0.001777	3.466E+07	0.0200	4.34E-02	7.44E-02	1.02	3.292E-03	2.21E-01	1.75E-01	0.99	9.50E-03	7.52E-03
	1.2907	0.011351	3.466E+07	0.0200	2.77E-01	4.82E-01	1.02	1.363E-01	1.43E+00	1.13E+00	0.99	3.91E-01	3.10E-01
	1.2953	0.01974	3.466E+07	0.0200	4.82E-01	8.42E-01	1.02	4.139E-01	2.49E+00	1.97E+00	0.99	1.19E+00	9.40E-01
	1.2976	0.008883	3.466E+07	0.0200	2.17E-01	3.80E-01	1.02	8.397E-02	1.12E+00	8.88E-01	0.99	2.41E-01	1.91E-01
	1.3178	0.001184	3.466E+07	0.0200	2.89E-02	5.14E-02	1.02	1.516E-03	1.51E-01	1.20E-01	0.99	4.32E-03	3.42E-03
	1.3721	0.024675	3.466E+07	0.0200	6.02E-01	1.12E+00	1.03	6.943E-01	3.24E+00	2.57E+00	0.99	1.93E+00	1.53E+00
	1.3986	0.071064	3.466E+07	0.0200	1.73E+00	3.29E+00	1.03	5.879E+00	9.46E+00	7.49E+00	0.99	1.62E+01	1.29E+01
	1.4426	0.014213	3.466E+07	0.0200	3.47E-01	6.81E-01	1.04	2.457E-01	1.93E+00	1.53E+00	0.99	6.64E-01	5.26E-01
	1.4768	0.001352	3.466E+07	0.0200	3.30E-02	6.65E-02	1.04	2.281E-03	1.87E-01	1.48E-01	0.99	6.11E-03	4.84E-03

Case #3- 2077 Slad Failure
CMS-RE-27A,B,E,F Reactor Response

Calc. No.: NE-02-94-01 rev 1
Prepared By: S. J. Haynes 6/94
page:5.029

v/b 209 9/14/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	1.7575	0.002961	3.466E+07	0.0200	7.23E-02	1.70E-01	1.07	1.315E-02	4.60E-01	3.64E-01	0.98	3.26E-02	2.58E-02
	1.9211	0.011844	3.466E+07	0.0200	2.89E-01	7.37E-01	1.09	2.322E-01	1.95E+00	1.54E+00	0.97	5.47E-01	4.33E-01
	2.0022	0.010857	3.466E+07	0.0200	2.65E-01	7.01E-01	1.10	2.045E-01	1.84E+00	1.45E+00	0.97	4.72E-01	3.74E-01
	2.0868	0.002369	3.466E+07	0.0200	5.78E-02	1.58E-01	1.11	1.011E-02	4.12E-01	3.26E-01	0.97	2.31E-02	1.83E-02
	2.1727	0.001974	3.466E+07	0.0200	4.82E-02	1.35E-01	1.12	7.292E-03	3.52E-01	2.79E-01	0.96	1.63E-02	1.29E-02
	2.2232	0.001184	3.466E+07	0.0200	2.89E-02	8.23E-02	1.13	2.690E-03	2.14E-01	1.70E-01	0.96	5.95E-03	4.71E-03
	2.3905	0.001678	3.466E+07	0.0200	4.10E-02	1.23E-01	1.15	5.794E-03	3.18E-01	2.52E-01	0.95	1.24E-02	9.80E-03
	1.0146	0.031946	3.466E+07	0.0200	7.80E-01	1.07E+00	1.01	8.465E-01	3.34E+00	2.64E+00	1.01	2.63E+00	2.08E+00
I-133	0.2627	0.003565	4.747E+07	0.0200	1.19E-01	9.73E-03	1.03	1.194E-03	9.06E-02	7.17E-02	0.97	1.05E-02	8.29E-03
	0.26717	0.001165	4.747E+07	0.0200	3.90E-02	3.35E-03	1.03	1.344E-04	3.03E-02	2.39E-02	0.97	1.14E-03	9.05E-04
	0.34543	0.001036	4.747E+07	0.0200	3.46E-02	5.83E-03	1.00	2.018E-04	3.69E-02	2.92E-02	0.95	1.21E-03	9.61E-04
	0.36108	0.001122	4.747E+07	0.0200	3.75E-02	6.93E-03	1.00	2.601E-04	4.20E-02	3.32E-02	0.95	1.50E-03	1.18E-03
	0.41805	0.001528	4.747E+07	0.0200	5.11E-02	1.26E-02	1.00	6.459E-04	6.62E-02	5.24E-02	0.95	3.21E-03	2.54E-03
	0.42291	0.00309	4.747E+07	0.0200	1.03E-01	2.61E-02	1.00	2.693E-03	1.35E-01	1.07E-01	0.95	1.33E-02	1.05E-02
	0.51053	0.018127	4.747E+07	0.0200	6.06E-01	2.64E-01	0.99	1.585E-01	1.12E+00	8.83E-01	0.96	6.49E-01	5.14E-01
	0.52987	0.8632	4.747E+07	0.0200	2.89E+01	1.38E+01	0.99	3.939E+02	5.31E+01	4.21E+01	0.97	1.49E+03	1.18E+03
	0.61797	0.005395	4.747E+07	0.0200	1.80E-01	1.11E-01	1.00	1.994E-02	3.60E-01	2.86E-01	0.99	6.43E-02	5.10E-02
	0.68025	0.006448	4.747E+07	0.0200	2.16E-01	1.46E-01	1.00	3.147E-02	4.69E-01	3.71E-01	1.00	1.01E-01	8.01E-02
	0.70658	0.014933	4.747E+07	0.0200	4.99E-01	3.51E-01	1.00	1.753E-01	1.13E+00	8.92E-01	1.01	5.67E-01	4.50E-01
	0.76838	0.004566	4.747E+07	0.0200	1.53E-01	1.17E-01	1.01	1.800E-02	3.73E-01	2.95E-01	1.01	5.75E-02	4.55E-02
	0.82051	0.001537	4.747E+07	0.0200	5.14E-02	4.19E-02	1.01	2.177E-03	1.33E-01	1.06E-01	1.02	7.00E-03	5.54E-03
	0.85628	0.012344	4.747E+07	0.0200	4.13E-01	3.50E-01	1.01	1.459E-01	1.11E+00	8.83E-01	1.02	4.69E-01	3.72E-01
	0.87533	0.044714	4.747E+07	0.0200	1.50E+00	1.29E+00	1.01	1.955E+00	4.12E+00	3.26E+00	1.02	6.28E+00	4.97E+00
	0.90967	0.002124	4.747E+07	0.0200	7.10E-02	6.39E-02	1.01	4.582E-03	2.02E-01	1.60E-01	1.01	1.45E-02	1.15E-02
	1.0523	0.005516	4.747E+07	0.0200	1.84E-01	1.92E-01	1.01	3.572E-02	5.94E-01	4.70E-01	1.01	1.11E-01	8.76E-02
	1.0601	0.001373	4.747E+07	0.0200	4.59E-02	4.80E-02	1.01	2.228E-03	1.49E-01	1.18E-01	1.01	6.90E-03	5.46E-03
	1.2364	0.014933	4.747E+07	0.0200	4.99E-01	6.07E-01	1.02	3.091E-01	1.82E+00	1.44E+00	1.00	9.09E-01	7.19E-01
	1.2982	0.023306	4.747E+07	0.0200	7.79E-01	9.96E-01	1.02	7.919E-01	2.94E+00	2.33E+00	0.99	2.27E+00	1.80E+00
	1.3504	0.001485	4.747E+07	0.0200	4.97E-02	6.62E-02	1.03	3.386E-03	1.93E-01	1.53E-01	0.99	9.48E-03	7.51E-03
	0.53524	0.006072	4.747E+07	0.0200	2.03E-01	9.92E-02	0.99	1.994E-02	3.74E-01	2.97E-01	0.97	7.37E-02	5.84E-02
I-134	0.1354	0.037592	5.183E+07	0.0200	1.37E+00	3.23E-03	1.03	4.568E-03	4.01E-01	3.18E-01	1.02	5.62E-01	4.44E-01
	0.13903	0.006869	5.183E+07	0.0200	2.51E-01	8.09E-04	1.02	2.069E-04	7.56E-02	5.98E-02	1.02	1.93E-02	1.53E-02
	0.15198	0.001059	5.183E+07	0.0200	3.87E-02	3.36E-04	1.00	1.298E-05	1.30E-02	1.03E-02	1.00	5.02E-04	3.98E-04
	0.16248	0.002576	5.183E+07	0.0200	9.40E-02	1.11E-03	1.00	1.042E-04	3.44E-02	2.72E-02	0.98	3.17E-03	2.51E-03


[The body of the document contains several paragraphs of text that are extremely faint and illegible due to the quality of the scan. The text appears to be organized into sections, possibly separated by headings or subheadings, but the specific content cannot be discerned.]

Case #3- 20% Clad Failure
CMS-RE-27A,B,E,F Detector Response

Calc. No.: NE-02-94-57 rev 1
Prepared By: S. J. Haynes 5/94
page:5.030

6/13 2014
9/16/14

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)	
	0.18847	0.006965	5.183E+07	0.0200	2.54E-01	6.22E-03	1.04	1.644E-03	1.13E-01	8.95E-02	0.97	2.79E-02	2.21E-02
	0.217	0.002481	5.183E+07	0.0200	9.06E-02	3.81E-03	1.06	3.659E-04	4.88E-02	3.86E-02	0.97	4.29E-03	3.39E-03
	0.23547	0.019845	5.183E+07	0.0200	7.25E-01	3.88E-02	1.05	2.949E-02	4.36E-01	3.45E-01	0.97	3.06E-01	2.42E-01
	0.2788	0.001307	5.183E+07	0.0200	4.77E-02	4.30E-03	1.02	2.093E-04	3.59E-02	2.84E-02	0.96	1.64E-03	1.30E-03
	0.31981	0.005152	5.183E+07	0.0200	1.88E-01	2.46E-02	1.00	4.623E-03	1.68E-01	1.33E-01	0.96	3.03E-02	2.40E-02
	0.35108	0.004961	5.183E+07	0.0200	1.81E-01	2.89E-02	1.00	5.231E-03	1.80E-01	1.42E-01	0.95	3.09E-02	2.45E-02
	0.40545	0.073466	5.183E+07	0.0200	2.68E+00	5.77E-01	1.00	1.548E+00	3.09E+00	2.45E+00	0.95	7.88E+00	6.24E+00
	0.411	0.006106	5.183E+07	0.0200	2.23E-01	4.91E-02	1.00	1.094E-02	2.60E-01	2.06E-01	0.95	5.51E-02	4.36E-02
	0.43335	0.041885	5.183E+07	0.0200	1.53E+00	3.68E-01	1.00	5.626E-01	1.87E+00	1.48E+00	0.95	2.72E+00	2.15E+00
	0.45892	0.012976	5.183E+07	0.0200	4.74E-01	1.25E-01	0.99	5.871E-02	6.08E-01	4.82E-01	0.96	2.77E-01	2.19E-01
	0.4655	0.003626	5.183E+07	0.0200	1.32E-01	3.58E-02	0.99	4.691E-03	1.72E-01	1.36E-01	0.96	2.18E-02	1.73E-02
	0.48888	0.014121	5.183E+07	0.0200	5.16E-01	1.51E-01	0.99	7.688E-02	6.94E-01	5.49E-01	0.96	3.43E-01	2.72E-01
	0.5144	0.023375	5.183E+07	0.0200	8.53E-01	3.48E-01	0.99	2.936E-01	1.44E+00	1.14E+00	0.97	1.19E+00	9.42E-01
	0.54083	0.078236	5.183E+07	0.0200	2.86E+00	1.31E+00	0.99	3.691E+00	4.83E+00	3.83E+00	0.97	1.34E+01	1.06E+01
	0.56552	0.008778	5.183E+07	0.0200	3.20E-01	1.59E-01	0.99	5.044E-02	5.52E-01	4.38E-01	0.98	1.73E-01	1.38E-01
	0.57075	0.002099	5.183E+07	0.0200	7.66E-02	3.86E-02	0.99	2.927E-03	1.33E-01	1.05E-01	0.98	9.96E-03	7.90E-03
	0.59536	0.11354	5.183E+07	0.0200	4.15E+00	2.22E+00	0.99	9.130E+00	7.37E+00	5.85E+00	0.99	3.03E+01	2.40E+01
	0.62179	0.10591	5.183E+07	0.0200	3.87E+00	2.19E+00	1.00	8.453E+00	7.11E+00	5.64E+00	0.99	2.72E+01	2.16E+01
	0.62796	0.023662	5.183E+07	0.0200	8.64E-01	4.94E-01	1.00	4.263E-01	1.60E+00	1.27E+00	0.99	1.37E+00	1.09E+00
	0.67734	0.084915	5.183E+07	0.0200	3.10E+00	1.91E+00	1.00	5.935E+00	6.15E+00	4.87E+00	1.00	1.91E+01	1.51E+01
	0.70665	0.008301	5.183E+07	0.0200	3.03E-01	1.95E-01	1.00	5.915E-02	6.26E-01	4.96E-01	1.01	1.91E-01	1.52E-01
	0.73074	0.019082	5.183E+07	0.0200	6.97E-01	4.64E-01	1.01	3.262E-01	1.48E+00	1.18E+00	1.01	1.04E+00	8.27E-01
	0.73918	0.007633	5.183E+07	0.0200	2.79E-01	1.88E-01	1.01	5.281E-02	6.00E-01	4.76E-01	1.01	1.69E-01	1.34E-01
	0.76668	0.041026	5.183E+07	0.0200	1.50E+00	1.05E+00	1.01	1.583E+00	3.34E+00	2.65E+00	1.01	5.05E+00	4.00E+00
	0.81638	0.005248	5.183E+07	0.0200	1.92E-01	1.43E-01	1.01	2.758E-02	4.53E-01	3.59E-01	1.02	8.86E-02	7.02E-02
	0.84702	0.9541	5.183E+07	0.0200	3.48E+01	2.68E+01	1.01	9.424E+02	8.53E+01	6.75E+01	1.02	3.03E+03	2.40E+03
	0.85729	0.069649	5.183E+07	0.0200	2.54E+00	1.98E+00	1.01	5.079E+00	6.29E+00	4.99E+00	1.02	1.63E+01	1.29E+01
	0.864	0.001908	5.183E+07	0.0200	6.97E-02	5.46E-02	1.01	3.840E-03	1.74E-01	1.38E-01	1.02	1.23E-02	9.77E-03
	0.88409	0.6526	5.183E+07	0.0200	2.38E+01	1.91E+01	1.01	4.591E+02	6.06E+01	4.80E+01	1.01	1.46E+03	1.16E+03
	0.9226	0.001431	5.183E+07	0.0200	5.22E-02	4.36E-02	1.01	2.303E-03	1.38E-01	1.09E-01	1.01	7.28E-03	5.77E-03
	0.94786	0.040358	5.183E+07	0.0200	1.47E+00	1.27E+00	1.01	1.883E+00	3.99E+00	3.16E+00	1.01	5.93E+00	4.70E+00
	0.9669	0.00353	5.183E+07	0.0200	1.29E-01	1.13E-01	1.01	1.472E-02	3.55E-01	2.81E-01	1.01	4.62E-02	3.65E-02
	0.97467	0.046751	5.183E+07	0.0200	1.71E+00	1.51E+00	1.01	2.603E+00	4.73E+00	3.74E+00	1.01	8.15E+00	6.45E+00
	1.0403	0.019082	5.183E+07	0.0200	6.97E-01	6.56E-01	1.01	4.618E-01	2.04E+00	1.61E+00	1.01	1.43E+00	1.13E+00



Case #3- 2U-235 Fuel Failure
CMS-RE-27A,B,E,F Detector Response

Calc. No.: NE-02-94- rev 1
Prepared By: S. J. Haynes 5/94
page:5.031

v/B
u/c
S
5/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)	
	1.0726	0.15266	5.183E+07	0.0200	5.57E+00	5.40E+00	1.01	3.040E+01	1.67E+01	1.32E+01	1.01	9.40E+01	7.44E+01
	1.1001	0.006869	5.183E+07	0.0200	2.51E-01	2.49E-01	1.01	6.302E-02	7.66E-01	6.07E-01	1.00	1.92E-01	1.52E-01
	1.1032	0.007251	5.183E+07	0.0200	2.65E-01	2.63E-01	1.01	7.041E-02	8.10E-01	6.42E-01	1.00	2.15E-01	1.70E-01
	1.1362	0.097318	5.183E+07	0.0200	3.55E+00	3.64E+00	1.01	1.305E+01	1.11E+01	8.81E+00	1.00	3.96E+01	3.13E+01
	1.1591	0.00353	5.183E+07	0.0200	1.29E-01	1.34E-01	1.01	1.751E-02	4.10E-01	3.25E-01	1.00	5.28E-02	4.18E-02
	1.164	0.001336	5.183E+07	0.0200	4.88E-02	5.11E-02	1.02	2.543E-03	1.56E-01	1.23E-01	1.00	7.59E-03	6.01E-03
	1.19	0.00353	5.183E+07	0.0200	1.29E-01	1.38E-01	1.02	1.815E-02	4.18E-01	3.31E-01	1.00	5.39E-02	4.27E-02
	1.239	0.002099	5.183E+07	0.0200	7.66E-02	8.55E-02	1.02	6.681E-03	2.56E-01	2.03E-01	1.00	1.96E-02	1.55E-02
	1.2695	0.005629	5.183E+07	0.0200	2.06E-01	2.35E-01	1.02	4.927E-02	6.99E-01	5.54E-01	1.00	1.44E-01	1.14E-01
	1.3224	0.00105	5.183E+07	0.0200	3.83E-02	4.58E-02	1.03	1.807E-03	1.34E-01	1.06E-01	0.99	5.10E-03	4.03E-03
	1.336	0.001431	5.183E+07	0.0200	5.22E-02	6.31E-02	1.03	3.393E-03	1.84E-01	1.46E-01	0.99	9.54E-03	7.55E-03
	1.3526	0.004484	5.183E+07	0.0200	1.64E-01	2.00E-01	1.03	3.376E-02	5.83E-01	4.62E-01	0.99	9.45E-02	7.48E-02
	1.4143	0.002194	5.183E+07	0.0200	8.01E-02	1.03E-01	1.03	8.481E-03	2.94E-01	2.33E-01	0.99	2.33E-02	1.85E-02
	1.4282	0.001717	5.183E+07	0.0200	6.27E-02	8.14E-02	1.03	5.252E-03	2.32E-01	1.84E-01	0.99	1.44E-02	1.14E-02
	1.4314	0.001717	5.183E+07	0.0200	6.27E-02	8.16E-02	1.03	5.265E-03	2.32E-01	1.84E-01	0.99	1.44E-02	1.14E-02
	1.4552	0.022898	5.183E+07	0.0200	8.36E-01	1.11E+00	1.04	9.629E-01	3.13E+00	2.48E+00	0.99	2.59E+00	2.05E+00
	1.47	0.007728	5.183E+07	0.0200	2.82E-01	3.78E-01	1.04	1.108E-01	1.06E+00	8.43E-01	0.99	2.97E-01	2.35E-01
	1.5055	0.001145	5.183E+07	0.0200	4.18E-02	5.75E-02	1.04	2.499E-03	1.60E-01	1.27E-01	0.99	6.64E-03	5.26E-03
	1.5415	0.005057	5.183E+07	0.0200	1.85E-01	2.59E-01	1.04	4.972E-02	7.20E-01	5.70E-01	0.98	1.30E-01	1.03E-01
	1.6138	0.043602	5.183E+07	0.0200	1.59E+00	2.32E+00	1.05	3.882E+00	6.40E+00	5.07E+00	0.98	9.99E+00	7.91E+00
	1.6292	0.002576	5.183E+07	0.0200	9.40E-02	1.38E-01	1.05	1.367E-02	3.81E-01	3.01E-01	0.98	3.51E-02	2.78E-02
	1.6443	0.004007	5.183E+07	0.0200	1.46E-01	2.17E-01	1.06	3.364E-02	5.96E-01	4.72E-01	0.98	8.54E-02	6.76E-02
	1.6552	0.00229	5.183E+07	0.0200	8.36E-02	1.25E-01	1.06	1.105E-02	3.42E-01	2.71E-01	0.98	2.80E-02	2.22E-02
	1.7415	0.026715	5.183E+07	0.0200	9.75E-01	1.52E+00	1.07	1.588E+00	4.13E+00	3.27E+00	0.98	3.94E+00	3.12E+00
	1.8068	0.057246	5.183E+07	0.0200	2.09E+00	3.37E+00	1.08	7.603E+00	9.06E+00	7.17E+00	0.98	1.86E+01	1.47E+01
	1.9259	0.001813	5.183E+07	0.0200	6.62E-02	1.13E-01	1.09	8.153E-03	2.99E-01	2.37E-01	0.97	1.92E-02	1.52E-02
	2.0206	0.001717	5.183E+07	0.0200	6.27E-02	1.12E-01	1.10	7.697E-03	2.92E-01	2.31E-01	0.97	1.78E-02	1.41E-02
	2.1599	0.002099	5.183E+07	0.0200	7.66E-02	1.43E-01	1.12	1.227E-02	3.73E-01	2.95E-01	0.96	2.74E-02	2.17E-02
	2.3124	0.002385	5.183E+07	0.0200	8.71E-02	1.71E-01	1.14	1.694E-02	4.43E-01	3.51E-01	0.96	3.70E-02	2.93E-02
	2.4674	0.001527	5.183E+07	0.0200	5.57E-02	1.15E-01	1.16	7.405E-03	2.95E-01	2.34E-01	0.95	1.56E-02	1.24E-02
	1.7872	0.013348	5.183E+07	0.0200	4.87E-01	7.78E-01	1.07	4.055E-01	2.10E+00	1.66E+00	0.98	1.00E+00	7.93E-01
I-135	0.2205	0.017452	4.470E+07	0.0200	5.49E-01	2.81E-02	1.06	1.636E-02	3.51E-01	2.77E-01	0.97	1.87E-01	1.48E-01
	0.22972	0.002317	4.470E+07	0.0200	7.30E-02	4.20E-03	1.05	3.221E-04	4.92E-02	3.89E-02	0.97	3.48E-03	2.76E-03
	0.26426	0.00184	4.470E+07	0.0200	5.79E-02	5.11E-03	1.03	3.051E-04	4.71E-02	3.73E-02	0.97	2.65E-03	2.10E-03

Case #3- 20% Glad Failure
CMS-RE-27A,B,E, F Detector Response

Calc. No.: NE-02-94-5 rev 1
Prepared By: S. J. Haynes 5/6/94
page:5.032

1/5 Q2.8.7.5
5/6/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)	
	0.28845	0.030899	4.470E+07	0.0200	9.73E-01	1.13E-01	1.02	1.125E-01	8.86E-01	7.01E-01	0.96	8.27E-01	6.55E-01
	0.29027	0.003033	4.470E+07	0.0200	9.55E-02	1.14E-02	1.01	1.095E-03	8.76E-02	6.94E-02	0.96	8.03E-03	6.36E-03
	0.36185	0.00186	4.470E+07	0.0200	5.86E-02	1.15E-02	1.00	6.761E-04	6.97E-02	5.52E-02	0.95	3.88E-03	3.07E-03
	0.40303	0.002317	4.470E+07	0.0200	7.30E-02	1.80E-02	1.00	1.315E-03	9.70E-02	7.68E-02	0.95	6.72E-03	5.32E-03
	0.41483	0.003004	4.470E+07	0.0200	9.46E-02	2.45E-02	1.00	2.321E-03	1.29E-01	1.02E-01	0.95	1.16E-02	9.19E-03
	0.41763	0.03519	4.470E+07	0.0200	1.11E+00	2.91E-01	1.00	3.220E-01	1.52E+00	1.21E+00	0.95	1.60E+00	1.27E+00
	0.42993	0.003033	4.470E+07	0.0200	9.55E-02	2.63E-02	1.00	2.511E-03	1.35E-01	1.07E-01	0.95	1.22E-02	9.67E-03
	0.43374	0.005522	4.470E+07	0.0200	1.74E-01	4.86E-02	1.00	8.446E-03	2.47E-01	1.96E-01	0.95	4.08E-02	3.23E-02
	0.45163	0.003147	4.470E+07	0.0200	9.91E-02	2.96E-02	1.00	2.931E-03	1.46E-01	1.15E-01	0.95	1.37E-02	1.09E-02
	0.54656	0.071239	4.470E+07	0.0200	2.24E+00	1.21E+00	0.99	2.696E+00	4.42E+00	3.50E+00	0.97	9.61E+00	7.62E+00
	0.57597	0.001288	4.470E+07	0.0200	4.06E-02	2.40E-02	0.99	9.644E-04	8.18E-02	6.49E-02	0.98	3.25E-03	2.58E-03
	0.64985	0.004549	4.470E+07	0.0200	1.43E-01	9.84E-02	1.00	1.409E-02	3.17E-01	2.51E-01	1.00	4.54E-02	3.60E-02
	0.69013	0.001288	4.470E+07	0.0200	4.06E-02	2.96E-02	1.00	1.199E-03	9.49E-02	7.52E-02	1.00	3.85E-03	3.05E-03
	0.70792	0.00658	4.470E+07	0.0200	2.07E-01	1.55E-01	1.00	3.210E-02	4.97E-01	3.93E-01	1.01	1.04E-01	8.23E-02
	0.78548	0.001516	4.470E+07	0.0200	4.77E-02	3.97E-02	1.01	1.913E-03	1.26E-01	1.00E-01	1.01	6.09E-03	4.82E-03
	0.79771	0.001717	4.470E+07	0.0200	5.41E-02	4.57E-02	1.01	2.495E-03	1.45E-01	1.15E-01	1.01	7.93E-03	6.28E-03
	0.8368	0.066661	4.470E+07	0.0200	2.10E+00	1.85E+00	1.01	3.924E+00	5.89E+00	4.67E+00	1.02	1.26E+01	9.99E+00
	0.96146	0.001459	4.470E+07	0.0200	4.59E-02	4.64E-02	1.01	2.155E-03	1.46E-01	1.15E-01	1.01	6.77E-03	5.36E-03
	0.97196	0.008869	4.470E+07	0.0200	2.79E-01	2.86E-01	1.01	8.056E-02	8.95E-01	7.08E-01	1.01	2.52E-01	2.00E-01
	0.97261	0.012016	4.470E+07	0.0200	3.78E-01	3.87E-01	1.01	1.480E-01	1.21E+00	9.61E-01	1.01	4.64E-01	3.67E-01
	0.99509	0.001545	4.470E+07	0.0200	4.86E-02	5.10E-02	1.01	2.507E-03	1.59E-01	1.26E-01	1.01	7.81E-03	6.18E-03
	1.0388	0.07925	4.470E+07	0.0200	2.50E+00	2.72E+00	1.01	6.864E+00	8.45E+00	6.69E+00	1.01	2.13E+01	1.69E+01
	1.1016	0.016022	4.470E+07	0.0200	5.04E-01	5.81E-01	1.01	2.961E-01	1.79E+00	1.42E+00	1.00	9.02E-01	7.14E-01
	1.124	0.036049	4.470E+07	0.0200	1.14E+00	1.33E+00	1.01	1.528E+00	4.09E+00	3.24E+00	1.00	4.64E+00	3.67E+00
	1.1315	0.22516	4.470E+07	0.0200	7.09E+00	8.38E+00	1.01	5.999E+01	2.57E+01	2.03E+01	1.00	1.82E+02	1.44E+02
	1.1599	0.00103	4.470E+07	0.0200	3.24E-02	3.93E-02	1.02	1.299E-03	1.20E-01	9.47E-02	1.00	3.88E-03	3.07E-03
	1.169	0.008726	4.470E+07	0.0200	2.75E-01	3.35E-01	1.02	9.394E-02	1.02E+00	8.07E-01	1.00	2.80E-01	2.22E-01
	1.2405	0.009012	4.470E+07	0.0200	2.84E-01	3.68E-01	1.02	1.064E-01	1.10E+00	8.72E-01	1.00	3.12E-01	2.47E-01
	1.2604	0.2861	4.470E+07	0.0200	9.01E+00	1.19E+01	1.02	1.090E+02	3.54E+01	2.80E+01	1.00	3.19E+02	2.52E+02
	1.3679	0.006065	4.470E+07	0.0200	1.91E-01	2.74E-01	1.03	5.392E-02	7.95E-01	6.29E-01	0.99	1.50E-01	1.19E-01
	1.4484	0.003147	4.470E+07	0.0200	9.91E-02	1.51E-01	1.04	1.560E-02	4.29E-01	3.40E-01	0.99	4.21E-02	3.33E-02
	1.4576	0.086402	4.470E+07	0.0200	2.72E+00	4.19E+00	1.04	1.185E+01	1.18E+01	9.38E+00	0.99	3.19E+01	2.52E+01
	1.5028	0.010729	4.470E+07	0.0200	3.38E-01	5.38E-01	1.04	1.889E-01	1.50E+00	1.19E+00	0.99	5.02E-01	3.98E-01
	1.5664	0.012875	4.470E+07	0.0200	4.05E-01	6.69E-01	1.05	2.846E-01	1.85E+00	1.47E+00	0.98	7.36E-01	5.83E-01

1. The first part of the document discusses the importance of maintaining accurate records of all transactions and activities. It emphasizes that proper record-keeping is essential for transparency and accountability, particularly in the context of public administration and financial management.

2. The second part of the document outlines the various methods and tools used to collect and analyze data. It highlights the need for standardized procedures and the use of modern technology to ensure the reliability and validity of the information gathered.

3. The third part of the document focuses on the interpretation of the data and the drawing of conclusions. It stresses the importance of critical thinking and the ability to identify patterns and trends within the data set.

4. The fourth part of the document discusses the implications of the findings and the potential for future research. It suggests that the results of the study could be used to inform policy decisions and to improve the efficiency of the system being studied.

5. The fifth part of the document provides a summary of the key findings and conclusions. It reiterates the importance of the research and the need for continued efforts to improve the system.

6. The sixth part of the document includes a list of references and a bibliography. It cites various sources of information used in the study, including books, articles, and reports.

7. The seventh part of the document contains a list of appendices and a list of figures. It provides additional information and data that support the findings of the study.

8. The eighth part of the document includes a list of tables and a list of figures. It provides additional information and data that support the findings of the study.

9. The ninth part of the document contains a list of appendices and a list of figures. It provides additional information and data that support the findings of the study.

10. The tenth part of the document includes a list of tables and a list of figures. It provides additional information and data that support the findings of the study.

Case #3- 20% Rad Failure
CMS-RE-27A,B,E,F Detector Response

Calc. No.: NE-02-94- rev 1
Prepared By: S. J. Haynes 3/94
page:5.033

4/13/03-52-7-5
9/16/04

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	1.678	0.095271	4.470E+07	0.0200	3.00E+00	5.25E+00	1.06	1.669E+01	1.44E+01	1.14E+01	0.98	4.22E+01	3.34E+01
	1.7065	0.040912	4.470E+07	0.0200	1.29E+00	2.29E+00	1.06	3.125E+00	6.24E+00	4.94E+00	0.98	7.87E+00	6.23E+00
	1.7912	0.076961	4.470E+07	0.0200	2.42E+00	4.49E+00	1.07	1.165E+01	1.21E+01	9.58E+00	0.98	2.88E+01	2.28E+01
	1.8307	0.005779	4.470E+07	0.0200	1.82E-01	3.44E-01	1.08	6.762E-02	9.23E-01	7.30E-01	0.98	1.64E-01	1.30E-01
	1.9273	0.002947	4.470E+07	0.0200	9.28E-02	1.84E-01	1.09	1.859E-02	4.87E-01	3.85E-01	0.97	4.38E-02	3.47E-02
	2.0459	0.008697	4.470E+07	0.0200	2.74E-01	5.70E-01	1.11	1.733E-01	1.49E+00	1.18E+00	0.97	3.96E-01	3.14E-01
	2.2555	0.006123	4.470E+07	0.0200	1.93E-01	4.30E-01	1.13	9.374E-02	1.12E+00	8.86E-01	0.96	2.07E-01	1.64E-01
	2.4087	0.009527	4.470E+07	0.0200	3.00E-01	7.02E-01	1.15	2.421E-01	1.82E+00	1.44E+00	0.95	5.17E-01	4.09E-01
	1.0734	0.014948	4.470E+07	0.0200	4.71E-01	5.29E-01	1.01	2.516E-01	1.64E+00	1.29E+00	1.01	7.77E-01	6.16E-01
Kr-85	0.51399	0.00434	8.915E+05	0.0300	4.09E-03	6.44E-02	0.99	2.606E-04	2.67E-01	2.11E-01	0.97	1.06E-03	8.38E-04
Kr-85m	0.30487	0.13989	1.976E+07	0.0300	2.92E+00	6.03E-01	1.01	1.777E+00	4.30E+00	3.40E+00	0.96	1.20E+01	9.53E+00
	0.00169	0.000586	1.976E+07	0.0300	1.22E-02	0.00E+00	0	0.000E+00	9.00E+10	7.10E+10	0	0.00E+00	0.00E+00
	0.013336	0.006116	1.976E+07	0.0300	1.28E-01	0.00E+00	0	0.000E+00	2.48E+00	1.95E+00	0	0.00E+00	0.00E+00
	0.013395	0.01183	1.976E+07	0.0300	2.47E-01	0.00E+00	0	0.000E+00	4.66E+00	3.68E+00	0	0.00E+00	0.00E+00
	0.015	0.003105	1.976E+07	0.0300	6.48E-02	0.00E+00	0	0.000E+00	6.42E-01	5.06E-01	0	0.00E+00	0.00E+00
	0.12985	0.003011	1.976E+07	0.0300	6.29E-02	1.59E-04	1.05	1.051E-05	3.06E-02	2.42E-02	1.02	1.97E-03	1.55E-03
	0.15118	0.75278	1.976E+07	0.0300	1.57E+01	2.33E-01	1.00	3.665E+00	9.18E+00	7.26E+00	1.00	1.44E+02	1.14E+02
	0.58128	0.000211	1.976E+07	0.0300	4.41E-03	3.99E-03	0.99	1.741E-05	1.35E-02	1.07E-02	0.98	5.82E-05	4.62E-05
Kr-87	0.40258	0.495	3.671E+07	0.0300	1.92E+01	3.84E+00	1.00	7.377E+01	2.07E+01	1.64E+01	0.95	3.77E+02	2.99E+02
	0.67387	0.019058	3.671E+07	0.0300	7.39E-01	4.27E-01	1.00	3.159E-01	1.37E+00	1.09E+00	1.00	1.01E+00	8.04E-01
	0.81425	0.001683	3.671E+07	0.0300	6.53E-02	4.56E-02	1.01	3.006E-03	1.45E-01	1.15E-01	1.02	9.66E-03	7.65E-03
	0.83637	0.007524	3.671E+07	0.0300	2.92E-01	2.09E-01	1.01	6.156E-02	6.65E-01	5.27E-01	1.02	1.98E-01	1.57E-01
	0.84543	0.072765	3.671E+07	0.0300	2.82E+00	2.04E+00	1.01	5.814E+00	6.49E+00	5.14E+00	1.02	1.87E+01	1.48E+01
	0.94664	0.001386	3.671E+07	0.0300	5.38E-02	4.34E-02	1.01	2.356E-03	1.37E-01	1.08E-01	1.01	7.42E-03	5.88E-03
	1.1754	0.011237	3.671E+07	0.0300	4.36E-01	4.34E-01	1.02	1.929E-01	1.32E+00	1.04E+00	1.00	5.75E-01	4.55E-01
	1.338	0.006484	3.671E+07	0.0300	2.51E-01	2.86E-01	1.03	7.413E-02	8.37E-01	6.62E-01	0.99	2.08E-01	1.65E-01
	1.3825	0.002871	3.671E+07	0.0300	1.11E-01	1.31E-01	1.03	1.505E-02	3.79E-01	3.00E-01	0.99	4.18E-02	3.31E-02
	1.3899	0.001237	3.671E+07	0.0300	4.80E-02	5.69E-02	1.03	2.812E-03	1.64E-01	1.30E-01	0.99	7.79E-03	6.17E-03
	1.5312	0.003564	3.671E+07	0.0300	1.38E-01	1.81E-01	1.04	2.609E-02	5.05E-01	4.00E-01	0.98	6.84E-02	5.42E-02
	1.578	0.001287	3.671E+07	0.0300	4.99E-02	6.72E-02	1.05	3.525E-03	1.86E-01	1.47E-01	0.98	9.11E-03	7.21E-03
	1.6112	0.00104	3.671E+07	0.0300	4.03E-02	5.53E-02	1.05	2.343E-03	1.53E-01	1.21E-01	0.98	6.03E-03	4.77E-03
	1.7405	0.020493	3.671E+07	0.0300	7.95E-01	1.17E+00	1.07	9.922E-01	3.16E+00	2.51E+00	0.98	2.47E+00	1.95E+00
	1.8426	0.001386	3.671E+07	0.0300	5.38E-02	8.30E-02	1.08	4.818E-03	2.22E-01	1.76E-01	0.97	1.16E-02	9.17E-03
	2.0119	0.028957	3.671E+07	0.0300	1.12E+00	1.88E+00	1.10	2.318E+00	4.92E+00	3.89E+00	0.97	5.36E+00	4.24E+00

Case #3- 20% Glad Failure
CMS-RE-27A,B,E,F Factor Response

Calc. No.: NE-02-94-57 rev 1
Prepared By: S. J. Haynes 5/94
page:5.034

13, 20, 27, 47, 7/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	2.4085	0.002129	3.671E+07	0.0300	8.26E-02	1.57E-01	1.15	1.490E-02	4.06E-01	3.21E-01	0.95	3.18E-02	2.52E-02
	2.5548	0.09306	3.671E+07	0.0300	3.61E+00	7.16E+00	1.17	3.024E+01	1.84E+01	1.46E+01	0.94	6.25E+01	4.95E+01
	2.5581	0.039105	3.671E+07	0.0300	1.52E+00	3.01E+00	1.17	5.345E+00	7.74E+00	6.13E+00	0.94	1.10E+01	8.74E+00
	2.8114	0.003168	3.671E+07	0.0300	1.23E-01	2.62E-01	1.19	3.831E-02	6.66E-01	5.27E-01	0.92	7.53E-02	5.96E-02
	3.3085	0.004504	3.671E+07	0.0300	1.75E-01	4.15E-01	1.20	8.707E-02	1.05E+00	8.31E-01	0.85	1.56E-01	1.23E-01
	1.6201	0.006499	3.671E+07	0.0300	2.52E-01	3.47E-01	1.05	9.194E-02	9.57E-01	7.57E-01	0.98	2.36E-01	1.87E-01
Kr-88	0.12227	0.001972	5.139E+07	0.0300	1.07E-01	5.33E-05	1.08	6.158E-06	1.88E-02	1.49E-02	1.01	2.03E-03	1.61E-03
	0.16598	0.031036	5.139E+07	0.0300	1.69E+00	1.48E-02	1.01	2.513E-02	4.26E-01	3.37E-01	0.98	7.04E-01	5.57E-01
	0.19632	0.25985	5.139E+07	0.0300	1.41E+01	2.87E-01	1.05	4.253E+00	4.46E+00	3.53E+00	0.97	6.10E+01	4.83E+01
	0.24071	0.002526	5.139E+07	0.0300	1.37E-01	5.27E-03	1.05	7.590E-04	5.71E-02	4.52E-02	0.97	7.60E-03	6.01E-03
	0.31169	0.001073	5.139E+07	0.0300	5.83E-02	4.85E-03	1.01	2.852E-04	3.39E-02	2.68E-02	0.96	1.89E-03	1.50E-03
	0.33471	0.001453	5.139E+07	0.0300	7.89E-02	7.64E-03	1.00	6.026E-04	4.99E-02	3.95E-02	0.95	3.74E-03	2.96E-03
	0.36223	0.02249	5.139E+07	0.0300	1.22E+00	1.40E-01	1.00	1.709E-01	8.44E-01	6.68E-01	0.95	9.79E-01	7.75E-01
	0.39054	0.006436	5.139E+07	0.0300	3.49E-01	4.70E-02	1.00	1.642E-02	2.61E-01	2.07E-01	0.95	8.67E-02	6.86E-02
	0.4217	0.00128	5.139E+07	0.0300	6.95E-02	1.07E-02	1.00	7.469E-04	5.59E-02	4.42E-02	0.95	3.69E-03	2.92E-03
	0.4718	0.007266	5.139E+07	0.0300	3.95E-01	7.33E-02	0.99	2.862E-02	3.48E-01	2.75E-01	0.96	1.32E-01	1.04E-01
	0.67734	0.002353	5.139E+07	0.0300	1.28E-01	5.30E-02	1.00	6.775E-03	1.70E-01	1.35E-01	1.00	2.18E-02	1.72E-02
	0.78828	0.005328	5.139E+07	0.0300	2.89E-01	1.40E-01	1.01	4.090E-02	4.45E-01	3.53E-01	1.01	1.30E-01	1.03E-01
	0.79032	0.001246	5.139E+07	0.0300	6.77E-02	3.28E-02	1.01	2.243E-03	1.04E-01	8.27E-02	1.01	7.14E-03	5.65E-03
	0.83483	0.12975	5.139E+07	0.0300	7.05E+00	3.60E+00	1.01	2.559E+01	1.14E+01	9.07E+00	1.02	8.23E+01	6.51E+01
	0.85034	0.00173	5.139E+07	0.0300	9.39E-02	4.88E-02	1.01	4.626E-03	1.55E-01	1.23E-01	1.02	1.49E-02	1.18E-02
	0.86233	0.006712	5.139E+07	0.0300	3.64E-01	1.92E-01	1.01	7.054E-02	6.10E-01	4.83E-01	1.02	2.27E-01	1.80E-01
	0.94492	0.002941	5.139E+07	0.0300	1.60E-01	9.19E-02	1.01	1.483E-02	2.90E-01	2.29E-01	1.01	4.67E-02	3.70E-02
	0.98578	0.013148	5.139E+07	0.0300	7.14E-01	4.30E-01	1.01	3.100E-01	1.34E+00	1.06E+00	1.01	9.68E-01	7.66E-01
	0.99009	0.001419	5.139E+07	0.0300	7.70E-02	4.66E-02	1.01	3.628E-03	1.45E-01	1.15E-01	1.01	1.13E-02	8.96E-03
	1.0396	0.004844	5.139E+07	0.0300	2.63E-01	1.67E-01	1.01	4.424E-02	5.17E-01	4.09E-01	1.01	1.37E-01	1.09E-01
	1.0495	0.001419	5.139E+07	0.0300	7.70E-02	4.92E-02	1.01	3.829E-03	1.52E-01	1.21E-01	1.01	1.19E-02	9.39E-03
	1.1413	0.012837	5.139E+07	0.0300	6.97E-01	4.82E-01	1.01	3.392E-01	1.47E+00	1.17E+00	1.00	1.03E+00	8.13E-01
	1.1795	0.009965	5.139E+07	0.0300	5.41E-01	3.86E-01	1.02	2.131E-01	1.17E+00	9.28E-01	1.00	6.34E-01	5.02E-01
	1.185	0.006885	5.139E+07	0.0300	3.74E-01	2.68E-01	1.02	1.022E-01	8.13E-01	6.44E-01	1.00	3.04E-01	2.41E-01
	1.2098	0.001419	5.139E+07	0.0300	7.70E-02	5.64E-02	1.02	4.433E-03	1.70E-01	1.35E-01	1.00	1.31E-02	1.04E-02
	1.2127	0.001384	5.139E+07	0.0300	7.51E-02	5.52E-02	1.02	4.228E-03	1.66E-01	1.32E-01	1.00	1.25E-02	9.89E-03
	1.2452	0.003633	5.139E+07	0.0300	1.97E-01	1.49E-01	1.02	2.992E-02	4.45E-01	3.52E-01	1.00	8.78E-02	6.95E-02
	1.2507	0.01121	5.139E+07	0.0300	6.09E-01	4.61E-01	1.02	2.863E-01	1.38E+00	1.09E+00	1.00	8.39E-01	6.64E-01

v16
7-2-7
9/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	1.325	0.001592	5.139E+07	0.0300	8.64E-02	6.95E-02	1.03	6.192E-03	2.04E-01	1.62E-01	0.99	1.75E-02	1.38E-02
	1.3523	0.001592	5.139E+07	0.0300	8.64E-02	7.11E-02	1.03	6.329E-03	2.07E-01	1.64E-01	0.99	1.77E-02	1.40E-02
	1.3695	0.014774	5.139E+07	0.0300	8.02E-01	6.69E-01	1.03	5.525E-01	1.94E+00	1.53E+00	0.99	1.54E+00	1.22E+00
	1.4069	0.00218	5.139E+07	0.0300	1.18E-01	1.02E-01	1.03	1.238E-02	2.91E-01	2.31E-01	0.99	3.42E-02	2.70E-02
	1.4648	0.001142	5.139E+07	0.0300	6.20E-02	5.56E-02	1.04	3.587E-03	1.57E-01	1.24E-01	0.99	9.63E-03	7.63E-03
	1.5184	0.021521	5.139E+07	0.0300	1.17E+00	1.09E+00	1.04	1.322E+00	3.03E+00	2.40E+00	0.98	3.47E+00	2.75E+00
	1.5298	0.10934	5.139E+07	0.0300	5.94E+00	5.56E+00	1.04	3.435E+01	1.55E+01	1.23E+01	0.98	9.01E+01	7.13E+01
	1.6038	0.004567	5.139E+07	0.0300	2.48E-01	2.42E-01	1.05	6.301E-02	6.68E-01	5.29E-01	0.98	1.62E-01	1.28E-01
	1.6856	0.006643	5.139E+07	0.0300	3.61E-01	7.37E-01	1.06	2.819E-01	1.00E+00	7.95E-01	0.98	3.55E-01	2.81E-01
	1.8928	0.001384	5.139E+07	0.0300	7.51E-02	1.66E-01	1.09	1.358E-02	2.26E-01	1.79E-01	0.97	1.65E-02	1.30E-02
	1.9087	0.001003	5.139E+07	0.0300	5.45E-02	1.21E-01	1.09	7.172E-03	1.65E-01	1.30E-01	0.97	8.69E-03	6.88E-03
	2.0298	0.045291	5.139E+07	0.0300	2.46E+00	5.68E+00	1.10	1.536E+01	7.73E+00	6.12E+00	0.97	1.84E+01	1.46E+01
	2.0354	0.037368	5.139E+07	0.0300	2.03E+00	4.69E+00	1.10	1.048E+01	6.39E+00	5.06E+00	0.97	1.26E+01	9.96E+00
	2.1865	0.002872	5.139E+07	0.0300	1.56E-01	3.78E-01	1.12	6.596E-02	5.14E-01	4.07E-01	0.96	7.70E-02	6.10E-02
	2.1958	0.13183	5.139E+07	0.0300	7.16E+00	1.74E+01	1.13	1.407E+02	2.37E+01	1.88E+01	0.96	1.63E+02	1.29E+02
	2.2318	0.033908	5.139E+07	0.0300	1.84E+00	4.52E+00	1.13	9.401E+00	6.15E+00	4.87E+00	0.96	1.09E+01	8.61E+00
	2.3521	0.007301	5.139E+07	0.0300	3.96E-01	1.01E+00	1.14	4.547E-01	1.37E+00	1.08E+00	0.96	5.21E-01	4.13E-01
	2.3921	0.346	5.139E+07	0.0300	1.88E+01	4.82E+01	1.15	1.041E+03	6.56E+01	5.20E+01	0.95	1.17E+03	9.27E+02
	2.4089	0.001038	5.139E+07	0.0300	5.64E-02	1.45E-01	1.15	9.418E-03	1.98E-01	1.57E-01	0.95	1.06E-02	8.39E-03
	2.5484	0.006228	5.139E+07	0.0300	3.38E-01	9.03E-01	1.17	3.574E-01	1.23E+00	9.74E-01	0.94	3.91E-01	3.10E-01
	2.771	0.001488	5.139E+07	0.0300	8.08E-02	2.28E-01	1.19	2.189E-02	3.10E-01	2.45E-01	0.93	2.33E-02	1.84E-02
	1.0001	0.018892	5.139E+07	0.0300	1.03E+00	1.43E+00	1.01	1.485E+00	1.95E+00	1.55E+00	1.01	2.02E+00	1.60E+00
Kr-89	0.1962	0.0022	6.082E+07	0.0300	1.41E-01	2.42E-03	1.05	3.597E-04	3.77E-02	2.99E-02	0.97	5.18E-03	4.10E-03
	0.1975	0.0182	6.082E+07	0.0300	1.17E+00	2.08E-02	1.05	2.549E-02	3.15E-01	2.49E-01	0.97	3.57E-01	2.83E-01
	0.20503	0.00124	6.082E+07	0.0300	7.97E-02	1.62E-03	1.05	1.356E-04	2.26E-02	1.79E-02	0.98	1.76E-03	1.40E-03
	0.2209	0.2	6.082E+07	0.0300	1.29E+01	3.24E-01	1.06	4.407E+00	4.03E+00	3.19E+00	0.97	5.02E+01	3.97E+01
	0.26411	0.0066	6.082E+07	0.0300	4.24E-01	1.83E-02	1.03	7.997E-03	1.69E-01	1.34E-01	0.97	6.95E-02	5.50E-02
	0.3382	0.00342	6.082E+07	0.0300	2.20E-01	1.84E-02	1.00	4.041E-03	1.19E-01	9.41E-02	0.95	2.48E-02	1.96E-02
	0.34503	0.0118	6.082E+07	0.0300	7.58E-01	6.62E-02	1.00	5.019E-02	4.20E-01	3.32E-01	0.95	3.02E-01	2.39E-01
	0.35606	0.0414	6.082E+07	0.0300	2.66E+00	2.48E-01	1.00	6.607E-01	1.52E+00	1.21E+00	0.95	3.85E+00	3.05E+00
	0.36488	0.009	6.082E+07	0.0300	5.78E-01	5.69E-02	1.00	3.288E-02	3.40E-01	2.69E-01	0.95	1.87E-01	1.48E-01
	0.3693	0.0138	6.082E+07	0.0300	8.87E-01	8.94E-02	1.00	7.932E-02	5.28E-01	4.18E-01	0.95	4.45E-01	3.52E-01
	0.40225	0.00318	6.082E+07	0.0300	2.04E-01	2.46E-02	1.00	5.037E-03	1.33E-01	1.05E-01	0.95	2.58E-02	2.04E-02
	0.41142	0.0256	6.082E+07	0.0300	1.65E+00	2.06E-01	1.00	3.391E-01	1.09E+00	8.65E-01	0.95	1.71E+00	1.35E+00

Case #3- 2011 Rad Failure
CMS-RE-27A,B,E,F Detector Response

Calc. No.: NE-02-94-Rev 1
Prepared By: S. J. Haynes 5/5/94
page:5.036

4/13
2.2
9/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	0.43808	0.0096	6.082E+07	0.0300	6.17E-01	8.59E-02	1.00	5.296E-02	4.33E-01	3.43E-01	0.95	2.54E-01	2.01E-01
	0.46613	0.008	6.082E+07	0.0300	5.14E-01	7.92E-02	0.99	4.029E-02	3.80E-01	3.01E-01	0.96	1.87E-01	1.48E-01
	0.49076	0.00322	6.082E+07	0.0300	2.07E-01	3.46E-02	0.99	7.079E-03	1.59E-01	1.26E-01	0.96	3.15E-02	2.49E-02
	0.4975	0.0664	6.082E+07	0.0300	4.27E+00	7.28E-01	0.99	3.075E+00	3.30E+00	2.61E+00	0.96	1.35E+01	1.07E+01
	0.4986	0.0114	6.082E+07	0.0300	7.33E-01	1.25E-01	0.99	9.095E-02	5.67E-01	4.49E-01	0.96	3.99E-01	3.16E-01
	0.5573	0.0016	6.082E+07	0.0300	1.03E-01	2.83E-02	0.99	2.876E-03	1.00E-01	7.92E-02	0.98	1.01E-02	7.98E-03
	0.57696	0.0564	6.082E+07	0.0300	3.62E+00	1.05E+00	0.99	3.785E+00	3.59E+00	2.85E+00	0.98	1.27E+01	1.01E+01
	0.5858	0.166	6.082E+07	0.0300	1.07E+01	3.18E+00	0.99	3.355E+01	1.07E+01	8.45E+00	0.98	1.11E+02	8.84E+01
	0.6262	0.006	6.082E+07	0.0300	3.86E-01	1.25E-01	1.00	4.810E-02	4.05E-01	3.21E-01	0.99	1.55E-01	1.23E-01
	0.62975	0.00342	6.082E+07	0.0300	2.20E-01	7.16E-02	1.00	1.573E-02	2.32E-01	1.84E-01	0.99	5.05E-02	4.00E-02
	0.66572	0.00114	6.082E+07	0.0300	7.33E-02	2.53E-02	1.00	1.850E-03	8.12E-02	6.44E-02	1.00	5.95E-03	4.72E-03
	0.6714	0.00106	6.082E+07	0.0300	6.81E-02	2.37E-02	1.00	1.614E-03	7.61E-02	6.03E-02	1.00	5.18E-03	4.11E-03
	0.67411	0.00232	6.082E+07	0.0300	1.49E-01	5.21E-02	1.00	7.760E-03	1.67E-01	1.33E-01	1.00	2.49E-02	1.98E-02
	0.69624	0.0178	6.082E+07	0.0300	1.14E+00	4.12E-01	1.00	4.716E-01	1.32E+00	1.05E+00	1.01	1.53E+00	1.21E+00
	0.70701	0.00498	6.082E+07	0.0300	3.20E-01	1.17E-01	1.00	3.748E-02	3.75E-01	2.97E-01	1.01	1.21E-01	9.61E-02
	0.71005	0.0078	6.082E+07	0.0300	5.01E-01	1.84E-01	1.00	9.232E-02	5.90E-01	4.68E-01	1.01	2.99E-01	2.37E-01
	0.72963	0.00296	6.082E+07	0.0300	1.90E-01	7.18E-02	1.01	1.380E-02	2.30E-01	1.82E-01	1.01	4.42E-02	3.50E-02
	0.73839	0.042	6.082E+07	0.0300	2.70E+00	1.03E+00	1.01	2.812E+00	3.30E+00	2.61E+00	1.01	8.99E+00	7.13E+00
	0.7474	0.00114	6.082E+07	0.0300	7.33E-02	2.83E-02	1.01	2.097E-03	9.06E-02	7.18E-02	1.01	6.70E-03	5.31E-03
	0.7629	0.004	6.082E+07	0.0300	2.57E-01	1.02E-01	1.01	2.636E-02	3.24E-01	2.57E-01	1.01	8.42E-02	6.67E-02
	0.7629	0.0092	6.082E+07	0.0300	5.91E-01	2.34E-01	1.01	1.395E-01	7.46E-01	5.91E-01	1.01	4.45E-01	3.53E-01
	0.77649	0.0112	6.082E+07	0.0300	7.20E-01	2.90E-01	1.01	2.104E-01	9.23E-01	7.31E-01	1.01	6.71E-01	5.31E-01
	0.82675	0.0076	6.082E+07	0.0300	4.88E-01	2.09E-01	1.01	1.030E-01	6.65E-01	5.26E-01	1.02	3.31E-01	2.62E-01
	0.83553	0.011	6.082E+07	0.0300	7.07E-01	3.05E-01	1.01	2.178E-01	9.71E-01	7.69E-01	1.02	7.00E-01	5.55E-01
	0.85737	0.00286	6.082E+07	0.0300	1.84E-01	8.12E-02	1.01	1.507E-02	2.58E-01	2.05E-01	1.02	4.85E-02	3.84E-02
	0.86708	0.0592	6.082E+07	0.0300	3.80E+00	1.70E+00	1.01	6.528E+00	5.41E+00	4.28E+00	1.02	2.10E+01	1.66E+01
	0.87042	0.0016	6.082E+07	0.0300	1.03E-01	4.61E-02	1.01	4.785E-03	1.47E-01	1.16E-01	1.02	1.54E-02	1.22E-02
	0.90427	0.0718	6.082E+07	0.0300	4.61E+00	2.15E+00	1.01	1.000E+01	6.81E+00	5.39E+00	1.01	3.17E+01	2.51E+01
	0.93095	0.0062	6.082E+07	0.0300	3.98E-01	1.91E-01	1.01	7.680E-02	6.03E-01	4.77E-01	1.01	2.43E-01	1.92E-01
	0.94419	0.00164	6.082E+07	0.0300	1.05E-01	5.12E-02	1.01	5.451E-03	1.61E-01	1.28E-01	1.01	1.72E-02	1.36E-02
	0.95318	0.00106	6.082E+07	0.0300	6.81E-02	3.34E-02	1.01	2.301E-03	1.05E-01	8.33E-02	1.01	7.24E-03	5.73E-03
	0.96042	0.00322	6.082E+07	0.0300	2.07E-01	1.02E-01	1.01	2.140E-02	3.22E-01	2.55E-01	1.01	6.72E-02	5.32E-02
	0.97439	0.0098	6.082E+07	0.0300	6.30E-01	3.16E-01	1.01	2.012E-01	9.90E-01	7.84E-01	1.01	6.30E-01	4.99E-01
	0.99737	0.0066	6.082E+07	0.0300	4.24E-01	2.19E-01	1.01	9.363E-02	6.80E-01	5.39E-01	1.01	2.91E-01	2.31E-01



Case #3- 20% Slad Failure
CMS-RE-27A,B,E, F Detector Response

Calc. No.: NE-02-94-07 rev 1
Prepared By: S. J. Haynes 5/94
page:5.037

1/15 228
7/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	1.0108	0.00108	6.082E+07	0.0300	6.94E-02	3.62E-02	1.01	2.538E-03	1.13E-01	8.91E-02	1.01	7.89E-03	6.25E-03
	1.0444	0.00408	6.082E+07	0.0300	2.62E-01	1.41E-01	1.01	3.730E-02	4.37E-01	3.46E-01	1.01	1.16E-01	9.16E-02
	1.0765	0.00236	6.082E+07	0.0300	1.52E-01	8.38E-02	1.01	1.283E-02	2.59E-01	2.05E-01	1.01	3.96E-02	3.14E-02
	1.0881	0.00358	6.082E+07	0.0300	2.30E-01	1.28E-01	1.01	2.983E-02	3.96E-01	3.13E-01	1.00	9.11E-02	7.21E-02
	1.1032	0.009	6.082E+07	0.0300	5.78E-01	3.27E-01	1.01	1.909E-01	1.01E+00	7.96E-01	1.00	5.82E-01	4.61E-01
	1.1078	0.0292	6.082E+07	0.0300	1.88E+00	1.06E+00	1.01	2.018E+00	3.27E+00	2.59E+00	1.00	6.14E+00	4.86E+00
	1.1166	0.0166	6.082E+07	0.0300	1.07E+00	6.10E-01	1.01	6.571E-01	1.87E+00	1.48E+00	1.00	2.00E+00	1.58E+00
	1.1315	0.0016	6.082E+07	0.0300	1.03E-01	5.95E-02	1.01	6.182E-03	1.82E-01	1.44E-01	1.00	1.88E-02	1.48E-02
	1.1625	0.00214	6.082E+07	0.0300	1.38E-01	8.18E-02	1.02	1.147E-02	2.49E-01	1.97E-01	1.00	3.42E-02	2.71E-02
	1.1723	0.0098	6.082E+07	0.0300	6.30E-01	3.77E-01	1.02	2.424E-01	1.15E+00	9.08E-01	1.00	7.23E-01	5.72E-01
	1.1824	0.00166	6.082E+07	0.0300	1.07E-01	6.45E-02	1.02	7.018E-03	1.96E-01	1.55E-01	1.00	2.09E-02	1.65E-02
	1.1865	0.00184	6.082E+07	0.0300	1.18E-01	7.17E-02	1.02	8.652E-03	2.17E-01	1.72E-01	1.00	2.57E-02	2.04E-02
	1.2288	0.00144	6.082E+07	0.0300	9.25E-02	5.82E-02	1.02	5.489E-03	1.75E-01	1.38E-01	1.00	1.62E-02	1.28E-02
	1.2356	0.00594	6.082E+07	0.0300	3.82E-01	2.41E-01	1.02	9.393E-02	7.24E-01	5.73E-01	1.00	2.76E-01	2.19E-01
	1.2737	0.0136	6.082E+07	0.0300	8.74E-01	5.70E-01	1.02	5.081E-01	1.69E+00	1.34E+00	0.99	1.47E+00	1.16E+00
	1.3027	0.001	6.082E+07	0.0300	6.43E-02	4.29E-02	1.02	2.812E-03	1.27E-01	1.00E-01	0.99	8.05E-03	6.37E-03
	1.3243	0.0306	6.082E+07	0.0300	1.97E+00	1.34E+00	1.03	2.706E+00	3.92E+00	3.10E+00	0.99	7.63E+00	6.04E+00
	1.3354	0.00132	6.082E+07	0.0300	8.48E-02	5.81E-02	1.03	5.080E-03	1.70E-01	1.35E-01	0.99	1.43E-02	1.13E-02
	1.3406	0.00194	6.082E+07	0.0300	1.25E-01	8.58E-02	1.03	1.102E-02	2.51E-01	1.98E-01	0.99	3.09E-02	2.45E-02
	1.3675	0.00148	6.082E+07	0.0300	9.51E-02	6.69E-02	1.03	6.550E-03	1.94E-01	1.54E-01	0.99	1.83E-02	1.45E-02
	1.3722	0.00126	6.082E+07	0.0300	8.10E-02	5.71E-02	1.03	4.765E-03	1.65E-01	1.31E-01	0.99	1.33E-02	1.05E-02
	1.4126	0.00264	6.082E+07	0.0300	1.70E-01	1.24E-01	1.03	2.159E-02	3.54E-01	2.80E-01	0.99	5.94E-02	4.71E-02
	1.4216	0.00224	6.082E+07	0.0300	1.44E-01	1.06E-01	1.03	1.565E-02	3.02E-01	2.39E-01	0.99	4.30E-02	3.40E-02
	1.4613	0.00122	6.082E+07	0.0300	7.84E-02	5.93E-02	1.04	4.833E-03	1.67E-01	1.33E-01	0.99	1.30E-02	1.03E-02
	1.4642	0.00178	6.082E+07	0.0300	1.14E-01	8.67E-02	1.04	1.031E-02	2.45E-01	1.94E-01	0.99	2.77E-02	2.19E-02
	1.4685	0.00188	6.082E+07	0.0300	1.21E-01	9.19E-02	1.04	1.154E-02	2.59E-01	2.05E-01	0.99	3.10E-02	2.45E-02
	1.4728	0.0688	6.082E+07	0.0300	4.42E+00	3.37E+00	1.04	1.550E+01	9.49E+00	7.52E+00	0.99	4.16E+01	3.29E+01
	1.501	0.0132	6.082E+07	0.0300	8.48E-01	6.61E-01	1.04	5.830E-01	1.85E+00	1.46E+00	0.99	1.55E+00	1.23E+00
	1.5062	0.00112	6.082E+07	0.0300	7.20E-02	5.62E-02	1.04	4.208E-03	1.57E-01	1.24E-01	0.99	1.12E-02	8.85E-03
	1.53	0.0332	6.082E+07	0.0300	2.13E+00	1.69E+00	1.04	3.748E+00	4.70E+00	3.72E+00	0.98	9.83E+00	7.78E+00
	1.5337	0.0512	6.082E+07	0.0300	3.29E+00	2.61E+00	1.04	8.932E+00	7.26E+00	5.75E+00	0.98	2.34E+01	1.85E+01
	1.5553	0.00152	6.082E+07	0.0300	9.77E-02	7.84E-02	1.05	8.044E-03	2.18E-01	1.72E-01	0.98	2.08E-02	1.65E-02
	1.5738	0.0019	6.082E+07	0.0300	1.22E-01	9.90E-02	1.05	1.270E-02	2.74E-01	2.17E-01	0.98	3.28E-02	2.60E-02
	1.6341	0.0082	6.082E+07	0.0300	5.27E-01	4.42E-01	1.05	2.443E-01	1.21E+00	9.61E-01	0.98	6.27E-01	4.96E-01

Case #3- 20% Rad Failure
CMS-RE-27A,B,E,F Detector Response

Calc. No.: NE-02-94-b7 rev 1
Prepared By: S. J. Haynes 9/94
page:5.038

1/3 2.8. 5
9/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	1.6438	0.00338	6.082E+07	0.0300	2.17E-01	1.83E-01	1.06	4.212E-02	5.02E-01	3.98E-01	0.98	1.07E-01	8.47E-02
	1.6675	0.00128	6.082E+07	0.0300	8.23E-02	7.02E-02	1.06	6.119E-03	1.92E-01	1.52E-01	0.98	1.55E-02	1.23E-02
	1.6769	0.0014	6.082E+07	0.0300	9.00E-02	7.71E-02	1.06	7.355E-03	2.11E-01	1.67E-01	0.98	1.86E-02	1.47E-02
	1.6838	0.00132	6.082E+07	0.0300	8.48E-02	7.30E-02	1.06	6.562E-03	1.99E-01	1.58E-01	0.98	1.66E-02	1.31E-02
	1.692	0.0026	6.082E+07	0.0300	1.67E-01	1.44E-01	1.06	2.556E-02	3.94E-01	3.12E-01	0.98	6.45E-02	5.11E-02
	1.6937	0.0438	6.082E+07	0.0300	2.81E+00	2.43E+00	1.06	7.262E+00	6.64E+00	5.26E+00	0.98	1.83E+01	1.45E+01
	1.7213	0.00224	6.082E+07	0.0300	1.44E-01	1.26E-01	1.06	1.927E-02	3.43E-01	2.72E-01	0.98	4.84E-02	3.83E-02
	1.7776	0.0076	6.082E+07	0.0300	4.88E-01	4.41E-01	1.07	2.304E-01	1.19E+00	9.42E-01	0.98	5.70E-01	4.51E-01
	1.7882	0.00106	6.082E+07	0.0300	6.81E-02	6.18E-02	1.07	4.505E-03	1.67E-01	1.32E-01	0.98	1.11E-02	8.81E-03
	1.8107	0.0014	6.082E+07	0.0300	9.00E-02	8.25E-02	1.08	8.020E-03	2.22E-01	1.76E-01	0.98	1.96E-02	1.55E-02
	1.8375	0.00118	6.082E+07	0.0300	7.58E-02	7.05E-02	1.08	5.773E-03	1.89E-01	1.49E-01	0.98	1.40E-02	1.11E-02
	1.8397	0.0035	6.082E+07	0.0300	2.25E-01	2.09E-01	1.08	5.085E-02	5.61E-01	4.44E-01	0.97	1.22E-01	9.68E-02
	1.8685	0.00196	6.082E+07	0.0300	1.26E-01	1.19E-01	1.08	1.617E-02	3.17E-01	2.51E-01	0.97	3.87E-02	3.07E-02
	1.8798	0.00158	6.082E+07	0.0300	1.02E-01	9.64E-02	1.08	1.057E-02	2.57E-01	2.03E-01	0.97	2.53E-02	2.00E-02
	1.9034	0.0104	6.082E+07	0.0300	6.68E-01	6.41E-01	1.09	4.672E-01	1.70E+00	1.35E+00	0.97	1.10E+00	8.74E-01
	1.9391	0.0064	6.082E+07	0.0300	4.11E-01	4.01E-01	1.09	1.800E-01	1.06E+00	8.40E-01	0.97	4.23E-01	3.35E-01
	1.9666	0.00132	6.082E+07	0.0300	8.48E-02	8.39E-02	1.10	7.827E-03	2.21E-01	1.75E-01	0.97	1.82E-02	1.44E-02
	1.9986	0.00118	6.082E+07	0.0300	7.58E-02	7.61E-02	1.10	6.347E-03	1.99E-01	1.58E-01	0.97	1.47E-02	1.16E-02
	2.0122	0.0156	6.082E+07	0.0300	1.00E+00	1.01E+00	1.10	1.115E+00	2.65E+00	2.10E+00	0.97	2.58E+00	2.04E+00
	2.021	0.00244	6.082E+07	0.0300	1.57E-01	1.59E-01	1.10	2.736E-02	4.15E-01	3.29E-01	0.97	6.32E-02	5.00E-02
	2.0465	0.00262	6.082E+07	0.0300	1.68E-01	1.72E-01	1.11	3.211E-02	4.50E-01	3.56E-01	0.97	7.34E-02	5.81E-02
	2.1006	0.0094	6.082E+07	0.0300	6.04E-01	6.28E-01	1.11	4.209E-01	1.64E+00	1.30E+00	0.97	9.61E-01	7.61E-01
	2.16	0.00528	6.082E+07	0.0300	3.39E-01	3.60E-01	1.12	1.367E-01	9.38E-01	7.43E-01	0.96	3.06E-01	2.42E-01
	2.1958	0.00128	6.082E+07	0.0300	8.23E-02	8.83E-02	1.13	8.204E-03	2.30E-01	1.82E-01	0.96	1.82E-02	1.44E-02
	2.2802	0.00204	6.082E+07	0.0300	1.31E-01	1.44E-01	1.14	2.159E-02	3.75E-01	2.97E-01	0.96	4.72E-02	3.74E-02
	2.3774	0.008	6.082E+07	0.0300	5.14E-01	5.84E-01	1.15	3.454E-01	1.51E+00	1.20E+00	0.95	7.39E-01	5.85E-01
	2.401	0.0072	6.082E+07	0.0300	4.63E-01	5.29E-01	1.15	2.817E-01	1.37E+00	1.08E+00	0.95	6.02E-01	4.76E-01
	2.5979	0.00108	6.082E+07	0.0300	6.94E-02	8.41E-02	1.17	6.832E-03	2.16E-01	1.71E-01	0.94	1.41E-02	1.12E-02
	2.6453	0.0042	6.082E+07	0.0300	2.70E-01	3.32E-01	1.18	1.056E-01	8.50E-01	6.73E-01	0.94	2.16E-01	1.71E-01
	2.7509	0.00124	6.082E+07	0.0300	7.97E-02	1.01E-01	1.19	9.567E-03	2.57E-01	2.04E-01	0.93	1.91E-02	1.51E-02
	2.7821	0.0076	6.082E+07	0.0300	4.88E-01	6.24E-01	1.19	3.625E-01	1.59E+00	1.26E+00	0.92	7.14E-01	5.65E-01
	2.7938	0.0068	6.082E+07	0.0300	4.37E-01	5.60E-01	1.19	2.910E-01	1.42E+00	1.13E+00	0.92	5.73E-01	4.53E-01
	2.8196	0.00132	6.082E+07	0.0300	8.48E-02	1.09E-01	1.19	1.105E-02	2.78E-01	2.20E-01	0.92	2.17E-02	1.72E-02
	2.8533	0.0024	6.082E+07	0.0300	1.54E-01	2.01E-01	1.19	3.685E-02	5.09E-01	4.03E-01	0.92	7.23E-02	5.72E-02



u/b
2-5-94
5/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	2.8662	0.0174	6.082E+07	0.0300	1.12E+00	1.46E+00	1.19	1.943E+00	3.70E+00	2.93E+00	0.92	3.81E+00	3.02E+00
	2.8787	0.00324	6.082E+07	0.0300	2.08E-01	2.73E-01	1.19	6.762E-02	6.92E-01	5.48E-01	0.91	1.31E-01	1.04E-01
	3.0179	0.00254	6.082E+07	0.0300	1.63E-01	2.22E-01	1.20	4.344E-02	5.59E-01	4.42E-01	0.90	8.21E-02	6.50E-02
	3.0292	0.0027	6.082E+07	0.0300	1.74E-01	2.36E-01	1.20	4.918E-02	5.95E-01	4.71E-01	0.90	9.30E-02	7.36E-02
	3.1073	0.00194	6.082E+07	0.0300	1.25E-01	1.72E-01	1.20	2.577E-02	4.35E-01	3.44E-01	0.89	4.82E-02	3.82E-02
	3.1403	0.0104	6.082E+07	0.0300	6.68E-01	9.29E-01	1.20	7.454E-01	2.35E+00	1.86E+00	0.88	1.38E+00	1.09E+00
	3.1721	0.001	6.082E+07	0.0300	6.43E-02	8.99E-02	1.20	6.933E-03	2.27E-01	1.80E-01	0.88	1.28E-02	1.02E-02
	3.2198	0.00428	6.082E+07	0.0300	2.75E-01	3.88E-01	1.20	1.282E-01	9.81E-01	7.76E-01	0.87	2.35E-01	1.86E-01
	3.3617	0.0104	6.082E+07	0.0300	6.68E-01	9.68E-01	1.20	7.765E-01	2.45E+00	1.94E+00	0.84	1.37E+00	1.09E+00
	3.3711	0.0062	6.082E+07	0.0300	3.98E-01	5.78E-01	1.20	2.765E-01	1.46E+00	1.16E+00	0.84	4.89E-01	3.87E-01
	3.3999	0.00136	6.082E+07	0.0300	8.74E-02	1.28E-01	1.20	1.337E-02	3.23E-01	2.55E-01	0.83	2.34E-02	1.85E-02
	3.5329	0.0134	6.082E+07	0.0300	8.61E-01	1.29E+00	1.18	1.307E+00	3.25E+00	2.58E+00	0.80	2.24E+00	1.77E+00
	3.5839	0.00258	6.082E+07	0.0300	1.66E-01	2.50E-01	1.18	4.888E-02	6.32E-01	5.01E-01	0.79	8.28E-02	6.56E-02
	3.7178	0.0084	6.082E+07	0.0300	5.40E-01	8.32E-01	1.16	5.213E-01	2.11E+00	1.67E+00	0.76	8.65E-01	6.84E-01
	3.7325	0.00138	6.082E+07	0.0300	8.87E-02	1.37E-01	1.16	1.410E-02	3.47E-01	2.75E-01	0.75	2.31E-02	1.83E-02
	3.7814	0.00132	6.082E+07	0.0300	8.48E-02	1.32E-01	1.15	1.290E-02	3.35E-01	2.65E-01	0.74	2.10E-02	1.66E-02
	3.8274	0.00138	6.082E+07	0.0300	8.87E-02	1.39E-01	1.14	1.408E-02	3.52E-01	2.79E-01	0.72	2.25E-02	1.78E-02
	3.8427	0.0011	6.082E+07	0.0300	7.07E-02	1.11E-01	1.14	8.970E-03	2.82E-01	2.23E-01	0.72	1.43E-02	1.13E-02
	3.9018	0.00134	6.082E+07	0.0300	8.61E-02	1.37E-01	1.12	1.320E-02	3.46E-01	2.74E-01	0.70	2.09E-02	1.65E-02
	3.923	0.00414	6.082E+07	0.0300	2.66E-01	4.24E-01	1.12	1.265E-01	1.07E+00	8.50E-01	0.69	1.97E-01	1.56E-01
	3.9655	0.00208	6.082E+07	0.0300	1.34E-01	2.15E-01	1.11	3.186E-02	5.43E-01	4.30E-01	0.68	4.94E-02	3.91E-02
	3.9775	0.0027	6.082E+07	0.0300	1.74E-01	2.79E-01	1.10	5.330E-02	7.06E-01	5.59E-01	0.67	8.21E-02	6.50E-02
	3.996	0.00142	6.082E+07	0.0300	9.13E-02	1.47E-01	1.10	1.479E-02	3.73E-01	2.95E-01	0.67	2.28E-02	1.80E-02
	4.048	0.00116	6.082E+07	0.0300	7.45E-02	1.21E-01	1.09	9.846E-03	3.07E-01	2.43E-01	0.65	1.49E-02	1.18E-02
	4.3411	0.00104	6.082E+07	0.0300	6.68E-02	1.13E-01	0.98	7.395E-03	2.87E-01	2.27E-01	0.52	9.98E-03	7.90E-03
	4.4892	0.00134	6.082E+07	0.0300	8.61E-02	1.48E-01	0.91	1.161E-02	3.78E-01	2.99E-01	0.45	1.46E-02	1.16E-02
	2.1811	0.07118	6.082E+07	0.0300	4.57E+00	4.88E+00	1.12	2.502E+01	1.27E+01	1.01E+01	0.96	5.59E+01	4.42E+01
Xe-131m	0.16393	0.0196	9.762E+05	0.0300	2.02E-02	8.79E-03	1.00	1.777E-04	2.65E-01	2.10E-01	0.98	5.25E-03	4.15E-03
Xe-133	0.079621	0.002165	1.902E+08	0.0300	4.35E-01	1.86E-08	0.70	5.678E-09	1.48E-02	1.17E-02	0.93	5.98E-03	4.73E-03
	0.080997	0.36483	1.902E+08	0.0300	7.33E+01	5.66E-06	0.73	3.027E-04	2.51E+00	1.99E+00	0.82	1.51E+02	1.19E+02
	0.1777	0.000712	1.902E+08	0.0300	1.43E-01	4.72E-04	1.02	6.886E-05	1.07E-02	8.46E-03	0.98	1.50E-03	1.19E-03
Xe-133m	0.23322	0.103	6.044E+06	0.0300	6.58E-01	1.96E-01	1.05	1.350E-01	2.23E+00	1.77E+00	0.97	1.42E+00	1.13E+00
Xe-135	0.1582	0.002886	4.723E+07	0.0300	1.44E-01	1.10E-03	1.00	1.580E-04	3.73E-02	2.95E-02	0.99	5.31E-03	4.20E-03
	0.24979	0.899	4.723E+07	0.0300	4.49E+01	2.10E+00	1.04	9.793E+01	2.14E+01	1.69E+01	0.97	9.30E+02	7.36E+02



Case #3- 2u Clad Failure
CMS-RE-27A,B,E, Detector Response

Calc. No.: NE-02-94- rev 1
Prepared By: S. J. Haynes 5/94
page:5.040

4/13 J.S. 11
5/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	0.35839	0.002203	4.723E+07	0.0300	1.10E-01	1.34E-02	1.00	1.473E-03	8.17E-02	6.47E-02	0.95	8.53E-03	6.75E-03
	0.40799	0.003578	4.723E+07	0.0300	1.79E-01	2.84E-02	1.00	5.072E-03	1.51E-01	1.20E-01	0.95	2.57E-02	2.03E-02
	0.60819	0.028948	4.723E+07	0.0300	1.44E+00	5.83E-01	0.99	8.333E-01	1.91E+00	1.51E+00	0.99	2.73E+00	2.17E+00
	0.68433	0.002093	4.723E+07	0.0300	1.04E-01	4.77E-02	1.00	4.979E-03	1.53E-01	1.21E-01	1.00	1.60E-02	1.27E-02
Xe-135m	0.52656	0.80997	3.905E+07	0.0300	3.34E+01	1.28E+01	0.99	4.222E+02	4.98E+01	3.95E+01	0.97	1.61E+03	1.28E+03
Xe-137	0.298	0.001167	1.656E+08	0.0300	2.04E-01	4.76E-03	1.01	9.807E-04	3.49E-02	2.76E-02	0.96	6.83E-03	5.41E-03
	0.39335	0.001381	1.656E+08	0.0300	2.42E-01	1.02E-02	1.00	2.473E-03	5.64E-02	4.47E-02	0.95	1.30E-02	1.03E-02
	0.45549	0.307	1.656E+08	0.0300	5.37E+01	2.93E+00	0.99	1.556E+02	1.43E+01	1.13E+01	0.95	7.30E+02	5.78E+02
	0.84895	0.00614	1.656E+08	0.0300	1.07E+00	1.73E-01	1.01	1.875E-01	5.50E-01	4.36E-01	1.02	6.03E-01	4.77E-01
	0.98225	0.002057	1.656E+08	0.0300	3.60E-01	6.70E-02	1.01	2.436E-02	2.09E-01	1.66E-01	1.01	7.61E-02	6.03E-02
	1.1193	0.001053	1.656E+08	0.0300	1.84E-01	3.88E-02	1.01	7.214E-03	1.19E-01	9.42E-02	1.00	2.19E-02	1.74E-02
	1.2732	0.002241	1.656E+08	0.0300	3.92E-01	9.39E-02	1.02	3.754E-02	2.79E-01	2.21E-01	0.99	1.08E-01	8.57E-02
	1.5768	0.001013	1.656E+08	0.0300	1.77E-01	5.29E-02	1.05	9.842E-03	1.46E-01	1.16E-01	0.98	2.54E-02	2.01E-02
	1.6125	0.001228	1.656E+08	0.0300	2.15E-01	6.54E-02	1.05	1.475E-02	1.80E-01	1.43E-01	0.98	3.80E-02	3.00E-02
	1.7834	0.004083	1.656E+08	0.0300	7.14E-01	2.37E-01	1.07	1.815E-01	6.41E-01	5.07E-01	0.98	4.49E-01	3.55E-01
	2.8498	0.001811	1.656E+08	0.0300	3.17E-01	1.51E-01	1.19	5.706E-02	3.84E-01	3.04E-01	0.92	1.12E-01	8.86E-02
	1.4906	0.01315	1.656E+08	0.0300	2.30E+00	6.53E-01	1.04	1.563E+00	1.83E+00	1.45E+00	0.99	4.17E+00	3.30E+00
Xe-138	0.15375	0.059535	1.506E+08	0.0300	9.47E+00	1.99E-02	1.00	1.884E-01	7.42E-01	5.87E-01	0.99	6.95E+00	5.50E+00
	0.24256	0.034965	1.506E+08	0.0300	5.56E+00	7.47E-02	1.05	4.362E-01	7.99E-01	6.32E-01	0.97	4.31E+00	3.41E+00
	0.25831	0.315	1.506E+08	0.0300	5.01E+01	8.15E-01	1.03	4.210E+01	7.83E+00	6.19E+00	0.97	3.80E+02	3.01E+02
	0.28251	0.004284	1.506E+08	0.0300	6.82E-01	1.47E-02	1.02	1.022E-02	1.20E-01	9.46E-02	0.96	7.83E-02	6.19E-02
	0.33528	0.001071	1.506E+08	0.0300	1.70E-01	5.65E-03	1.00	9.629E-04	3.68E-02	2.92E-02	0.95	5.96E-03	4.72E-03
	0.37144	0.005009	1.506E+08	0.0300	7.97E-01	3.29E-02	1.00	2.620E-02	1.93E-01	1.53E-01	0.95	1.46E-01	1.16E-01
	0.39643	0.063	1.506E+08	0.0300	1.00E+01	4.75E-01	1.00	4.757E+00	2.59E+00	2.05E+00	0.95	2.47E+01	1.96E+01
	0.40136	0.021735	1.506E+08	0.0300	3.46E+00	1.68E-01	1.00	5.804E-01	9.06E-01	7.17E-01	0.95	2.98E+00	2.36E+00
	0.43449	0.20318	1.506E+08	0.0300	3.23E+01	1.79E+00	1.00	5.795E+01	9.11E+00	7.21E+00	0.95	2.80E+02	2.21E+02
	0.50022	0.003622	1.506E+08	0.0300	5.76E-01	4.97E-02	0.99	2.833E-02	2.24E-01	1.77E-01	0.96	1.24E-01	9.80E-02
	0.53007	0.00252	1.506E+08	0.0300	4.01E-01	4.03E-02	0.99	1.600E-02	1.55E-01	1.23E-01	0.97	6.03E-02	4.78E-02
	0.53776	0.001166	1.506E+08	0.0300	1.86E-01	1.92E-02	0.99	3.532E-03	7.20E-02	5.70E-02	0.97	1.29E-02	1.03E-02
	0.55595	0.001166	1.506E+08	0.0300	1.86E-01	2.05E-02	0.99	3.765E-03	7.28E-02	5.77E-02	0.98	1.32E-02	1.05E-02
	0.56853	0.003055	1.506E+08	0.0300	4.86E-01	5.58E-02	0.99	2.686E-02	1.93E-01	1.53E-01	0.98	9.18E-02	7.28E-02
	0.58884	0.001228	1.506E+08	0.0300	1.95E-01	2.37E-02	0.99	4.582E-03	7.92E-02	6.28E-02	0.98	1.52E-02	1.20E-02
	0.65408	0.001449	1.506E+08	0.0300	2.31E-01	3.15E-02	1.00	7.272E-03	1.02E-01	8.05E-02	1.00	2.34E-02	1.86E-02
	0.86582	0.002961	1.506E+08	0.0300	4.71E-01	8.49E-02	1.01	4.038E-02	2.70E-01	2.14E-01	1.02	1.30E-01	1.03E-01

u/s 27A-B-E-F
7/6/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	0.86935	0.006206	1.506E+08	0.0300	9.88E-01	1.79E-01	1.01	1.781E-01	5.68E-01	4.50E-01	1.02	5.72E-01	4.53E-01
	0.89687	0.001323	1.506E+08	0.0300	2.11E-01	3.92E-02	1.01	8.342E-03	1.25E-01	9.86E-02	1.01	2.65E-02	2.10E-02
	0.91251	0.003276	1.506E+08	0.0300	5.21E-01	9.88E-02	1.01	5.202E-02	3.13E-01	2.48E-01	1.01	1.65E-01	1.30E-01
	0.91713	0.009198	1.506E+08	0.0300	1.46E+00	2.79E-01	1.01	4.123E-01	8.83E-01	6.99E-01	1.01	1.31E+00	1.03E+00
	0.93636	0.001355	1.506E+08	0.0300	2.16E-01	4.20E-02	1.01	9.136E-03	1.32E-01	1.05E-01	1.01	2.88E-02	2.28E-02
	0.94125	0.002299	1.506E+08	0.0300	3.66E-01	7.16E-02	1.01	2.644E-02	2.26E-01	1.79E-01	1.01	8.34E-02	6.60E-02
	1.0939	0.004095	1.506E+08	0.0300	6.52E-01	1.48E-01	1.01	9.710E-02	4.55E-01	3.60E-01	1.00	2.96E-01	2.35E-01
	1.0988	0.002142	1.506E+08	0.0300	3.41E-01	7.75E-02	1.01	2.669E-02	2.39E-01	1.89E-01	1.00	8.14E-02	6.44E-02
	1.1022	0.001071	1.506E+08	0.0300	1.70E-01	3.89E-02	1.01	6.689E-03	1.20E-01	9.47E-02	1.00	2.04E-02	1.61E-02
	1.1143	0.014742	1.506E+08	0.0300	2.35E+00	5.40E-01	1.01	1.281E+00	1.66E+00	1.31E+00	1.00	3.90E+00	3.08E+00
	1.1416	0.005134	1.506E+08	0.0300	8.17E-01	1.93E-01	1.01	1.590E-01	5.89E-01	4.67E-01	1.00	4.81E-01	3.81E-01
	1.1454	0.001323	1.506E+08	0.0300	2.11E-01	4.98E-02	1.01	1.059E-02	1.52E-01	1.21E-01	1.00	3.21E-02	2.54E-02
	1.5718	0.002646	1.506E+08	0.0300	4.21E-01	1.38E-01	1.05	6.091E-02	3.82E-01	3.02E-01	0.98	1.57E-01	1.25E-01
	1.6146	0.002363	1.506E+08	0.0300	3.76E-01	1.26E-01	1.05	4.973E-02	3.47E-01	2.75E-01	0.98	1.28E-01	1.01E-01
	1.7683	0.16727	1.506E+08	0.0300	2.66E+01	9.66E+00	1.07	2.750E+02	2.61E+01	2.07E+01	0.98	6.81E+02	5.39E+02
	1.8125	0.001796	1.506E+08	0.0300	2.86E-01	1.06E-01	1.08	3.270E-02	2.85E-01	2.25E-01	0.98	7.98E-02	6.31E-02
	1.8509	0.014238	1.506E+08	0.0300	2.27E+00	8.56E-01	1.08	2.094E+00	2.29E+00	1.81E+00	0.97	5.03E+00	3.98E+00
	1.9254	0.005639	1.506E+08	0.0300	8.97E-01	3.51E-01	1.09	3.437E-01	9.30E-01	7.36E-01	0.97	8.10E-01	6.41E-01
	2.0048	0.05355	1.506E+08	0.0300	8.52E+00	3.46E+00	1.10	3.244E+01	9.07E+00	7.18E+00	0.97	7.50E+01	5.93E+01
	2.0158	0.12254	1.506E+08	0.0300	1.95E+01	7.95E+00	1.10	1.705E+02	2.08E+01	1.65E+01	0.97	3.94E+02	3.12E+02
	2.0792	0.014427	1.506E+08	0.0300	2.30E+00	9.57E-01	1.11	2.437E+00	2.50E+00	1.98E+00	0.97	5.57E+00	4.41E+00
	2.2523	0.022869	1.506E+08	0.0300	3.64E+00	1.61E+00	1.13	6.603E+00	4.18E+00	3.30E+00	0.96	1.46E+01	1.15E+01
	2.3219	0.006206	1.506E+08	0.0300	9.88E-01	4.45E-01	1.14	5.014E-01	1.16E+00	9.15E-01	0.96	1.10E+00	8.67E-01
	2.4753	0.003119	1.506E+08	0.0300	4.96E-01	2.34E-01	1.16	1.350E-01	6.05E-01	4.79E-01	0.95	2.85E-01	2.26E-01
	2.4976	0.001733	1.506E+08	0.0300	2.76E-01	1.31E-01	1.16	4.196E-02	3.38E-01	2.68E-01	0.95	8.85E-02	7.01E-02
	1.1186	0.026586	1.506E+08	0.0300	4.23E+00	9.78E-01	1.01	4.181E+00	3.00E+00	2.38E+00	1.00	1.27E+01	1.27E+01
								SUM =	6.003E+03			1.85E+04	1.46E+04

27A = 51.385 Rad/hr
27B = 58.408 Rad/hr

27E = 1.85E+04 Rad/hr
27F = 1.47E+04 Rad/hr

Con. Vol= 5.68E+09 cm**3
27A Cone Factor 0.00856
27B Cone Factor 0.00973
Release Frac. 0.2

Case #4- 0.1% Clad Failure
CMS-RE-27A,B,E,F Detector Response

Calc. No.: NE-02-94-03 rev 1
Prepared By: S. J. Haynes 5/94
page: 5.042

4/15
S. J. Haynes
5/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
I-131	0.080183	0.026182	2.422E+07	0.0200	2.23E-03	3.20E-07	0.71	5.077E-10	1.794E-01	1.418E-01	0.88	3.53E-04	2.79E-04
	0.17721	0.002648	2.422E+07	0.0200	2.26E-04	1.73E-03	1.02	3.988E-07	3.963E-02	3.135E-02	0.98	8.77E-06	6.94E-06
	0.2843	0.060521	2.422E+07	0.0200	5.16E-03	2.12E-01	1.02	1.116E-03	1.703E+00	1.348E+00	0.96	8.44E-03	6.68E-03
	0.32578	0.002507	2.422E+07	0.0200	2.14E-04	1.24E-02	1.00	2.661E-06	8.341E-02	6.603E-02	0.96	1.71E-05	1.36E-05
	0.36448	0.81164	2.422E+07	0.0200	6.92E-02	5.12E+00	1.00	3.542E-01	3.065E+01	2.426E+01	0.95	2.02E+00	1.60E+00
	0.50299	0.003605	2.422E+07	0.0200	3.08E-04	5.03E-02	0.99	1.531E-05	2.224E-01	1.761E-01	0.96	6.56E-05	5.20E-05
	0.63697	0.072605	2.422E+07	0.0200	6.19E-03	1.54E+00	1.00	9.522E-03	4.973E+00	3.942E+00	0.99	3.05E-02	2.42E-02
	0.6427	0.002195	2.422E+07	0.0200	1.87E-04	4.69E-02	1.00	8.785E-06	1.515E-01	1.201E-01	1.00	2.84E-05	2.25E-05
	0.72289	0.018025	2.422E+07	0.0200	1.54E-03	4.33E-01	1.00	6.663E-04	1.388E+00	1.100E+00	1.01	2.15E-03	1.71E-03
	0.32939	0.002304	2.422E+07	0.0200	1.97E-04	1.17E-02	1.00	2.301E-06	7.767E-02	6.148E-02	0.95	1.45E-05	1.15E-05
I-132	0.1472	0.002369	3.466E+07	0.0200	2.89E-04	5.60E-04	1.01	1.637E-07	2.796E-02	2.211E-02	1.01	8.16E-06	6.46E-06
	0.1833	0.001382	3.466E+07	0.0200	1.69E-04	1.07E-03	1.03	1.860E-07	2.163E-02	1.712E-02	0.97	3.54E-06	2.80E-06
	0.2548	0.001875	3.466E+07	0.0200	2.29E-04	4.65E-03	1.04	1.108E-06	4.574E-02	3.620E-02	0.97	1.02E-05	8.04E-06
	0.2627	0.01441	3.466E+07	0.0200	1.76E-03	3.93E-02	1.03	7.121E-05	3.660E-01	2.896E-01	0.97	6.24E-04	4.94E-04
	0.2848	0.007205	3.466E+07	0.0200	8.80E-04	2.54E-02	1.02	2.276E-05	2.032E-01	1.608E-01	0.96	1.72E-04	1.36E-04
	0.3165	0.001382	3.466E+07	0.0200	1.69E-04	6.45E-03	1.00	1.088E-06	4.443E-02	3.516E-02	0.96	7.19E-06	5.69E-06
	0.3635	0.004935	3.466E+07	0.0200	6.02E-04	3.09E-02	1.00	1.864E-05	1.859E-01	1.471E-01	0.95	1.06E-04	8.42E-05
	0.3878	0.002961	3.466E+07	0.0200	3.61E-04	2.13E-02	1.00	7.696E-06	1.193E-01	9.443E-02	0.95	4.10E-05	3.24E-05
	0.4168	0.004738	3.466E+07	0.0200	5.78E-04	3.90E-02	1.00	2.256E-05	2.046E-01	1.620E-01	0.95	1.12E-04	8.90E-05
	0.4319	0.004836	3.466E+07	0.0200	5.90E-04	4.22E-02	1.00	2.494E-05	2.156E-01	1.707E-01	0.95	1.21E-04	9.57E-05
	0.446	0.006021	3.466E+07	0.0200	7.35E-04	5.55E-02	1.00	4.076E-05	2.759E-01	2.184E-01	0.95	1.93E-04	1.52E-04
	0.4739	0.001777	3.466E+07	0.0200	2.17E-04	1.80E-02	0.99	3.876E-06	8.537E-02	6.759E-02	0.96	1.78E-05	1.41E-05
	0.4785	0.001481	3.466E+07	0.0200	1.81E-04	1.53E-02	0.99	2.733E-06	7.164E-02	5.672E-02	0.96	1.24E-05	9.84E-06
	0.4882	0.004145	3.466E+07	0.0200	5.06E-04	4.41E-02	0.99	2.210E-05	2.034E-01	1.611E-01	0.96	9.88E-05	7.82E-05
	0.5059	0.050337	3.466E+07	0.0200	6.14E-03	7.14E-01	0.99	4.345E-03	3.101E+00	2.456E+00	0.96	1.83E-02	1.45E-02
	0.52265	0.16088	3.466E+07	0.0200	1.96E-02	2.49E+00	0.99	4.841E-02	9.888E+00	7.835E+00	0.97	1.88E-01	1.49E-01
	0.5355	0.005231	3.466E+07	0.0200	6.39E-04	8.55E-02	0.99	5.407E-05	3.226E-01	2.556E-01	0.97	2.00E-04	1.58E-04
	0.54	0.001086	3.466E+07	0.0200	1.33E-04	1.81E-02	0.99	2.371E-06	6.709E-02	5.318E-02	0.97	8.63E-06	6.84E-06
	0.5471	0.012535	3.466E+07	0.0200	1.53E-03	2.14E-01	0.99	3.241E-04	7.774E-01	6.162E-01	0.97	1.15E-03	9.15E-04
	0.6	0.001382	3.466E+07	0.0200	1.69E-04	2.74E-02	0.99	4.572E-06	9.024E-02	7.155E-02	0.99	1.51E-05	1.19E-05
	0.6208	0.003948	3.466E+07	0.0200	4.82E-04	8.13E-02	1.00	3.919E-05	2.646E-01	2.098E-01	0.99	1.26E-04	1.00E-04
	0.6212	0.015792	3.466E+07	0.0200	1.93E-03	3.26E-01	1.00	6.276E-04	1.059E+00	8.399E-01	0.99	2.02E-03	1.60E-03
	0.63022	0.13719	3.466E+07	0.0200	1.67E-02	2.87E+00	1.00	4.812E-02	9.314E+00	7.384E+00	0.99	1.54E-01	1.22E-01

Case #4- 0.1% Clad Failure
CMS-RE-27A,B,E,F Detector Response

Calc. No.: NE-02-94-07 rev 1
Prepared By: S. J. Haynes 5/94
page: 5.043

Handwritten: 7/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)	
	0.6506	0.026649	3.466E+07	0.0200	3.25E-03	5.77E-01	1.00	1.876E-03	1.859E+00	1.474E+00	1.00	6.05E-03	4.79E-03
	0.659	0.003948	3.466E+07	0.0200	4.82E-04	8.66E-02	1.00	4.173E-05	2.786E-01	2.209E-01	1.00	1.34E-04	1.06E-04
	0.66769	0.987	3.466E+07	0.0200	1.20E-01	2.19E+01	1.00	2.643E+00	7.051E+01	5.589E+01	1.00	8.50E+00	6.73E+00
	0.6698	0.04935	3.466E+07	0.0200	6.02E-03	1.10E+00	1.00	6.627E-03	3.535E+00	2.802E+00	1.00	2.13E-02	1.69E-02
	0.6716	0.052311	3.466E+07	0.0200	6.39E-03	1.17E+00	1.00	7.466E-03	3.757E+00	2.978E+00	1.00	2.40E-02	1.90E-02
	0.727	0.031584	3.466E+07	0.0200	3.86E-03	7.64E-01	1.00	2.944E-03	2.444E+00	1.937E+00	1.01	9.52E-03	7.54E-03
	0.7272	0.021714	3.466E+07	0.0200	2.65E-03	5.25E-01	1.00	1.392E-03	1.681E+00	1.332E+00	1.01	4.50E-03	3.57E-03
	0.7285	0.010857	3.466E+07	0.0200	1.33E-03	2.63E-01	1.01	3.521E-04	8.421E-01	6.673E-01	1.01	1.13E-03	8.93E-04
	0.7645	0.003948	3.466E+07	0.0200	4.82E-04	1.00E-01	1.01	4.888E-05	3.206E-01	2.540E-01	1.01	1.56E-04	1.24E-04
	0.77261	0.76196	3.466E+07	0.0200	9.30E-02	1.96E+01	1.01	1.841E+00	6.249E+01	4.951E+01	1.01	5.87E+00	4.65E+00
	0.7802	0.012338	3.466E+07	0.0200	1.51E-03	3.21E-01	1.01	4.875E-04	1.021E+00	8.091E-01	1.01	1.55E-03	1.23E-03
	0.7845	0.004244	3.466E+07	0.0200	5.18E-04	1.11E-01	1.01	5.803E-05	3.532E-01	2.798E-01	1.01	1.85E-04	1.46E-04
	0.8098	0.028623	3.466E+07	0.0200	3.49E-03	7.72E-01	1.01	2.724E-03	2.454E+00	1.944E+00	1.01	8.66E-03	6.86E-03
	0.8122	0.056259	3.466E+07	0.0200	6.87E-03	1.52E+00	1.01	1.055E-02	4.838E+00	3.832E+00	1.01	3.36E-02	2.66E-02
	0.8633	0.005823	3.466E+07	0.0200	7.11E-04	1.66E-01	1.01	1.195E-04	5.296E-01	4.194E-01	1.02	3.84E-04	3.04E-04
	0.8768	0.010758	3.466E+07	0.0200	1.31E-03	3.12E-01	1.01	4.140E-04	9.925E-01	7.860E-01	1.02	1.33E-03	1.05E-03
	0.9103	0.009179	3.466E+07	0.0200	1.12E-03	2.76E-01	1.01	3.125E-04	8.752E-01	6.930E-01	1.01	9.90E-04	7.84E-04
	0.9276	0.004145	3.466E+07	0.0200	5.06E-04	1.27E-01	1.01	6.496E-05	4.018E-01	3.182E-01	1.01	2.05E-04	1.63E-04
	0.95455	0.18062	3.466E+07	0.0200	2.20E-02	5.71E+00	1.01	1.271E-01	1.795E+01	1.421E+01	1.01	4.00E-01	3.16E-01
	0.9837	0.005626	3.466E+07	0.0200	6.87E-04	1.84E-01	1.01	1.273E-04	5.733E-01	4.540E-01	1.01	3.98E-04	3.15E-04
	1.0347	0.004738	3.466E+07	0.0200	5.78E-04	1.62E-01	1.01	9.476E-05	5.034E-01	3.985E-01	1.01	2.94E-04	2.33E-04
	1.136	0.02961	3.466E+07	0.0200	3.61E-03	1.11E+00	1.01	4.038E-03	3.385E+00	2.680E+00	1.00	1.22E-02	9.69E-03
	1.1434	0.013522	3.466E+07	0.0200	1.65E-03	5.08E-01	1.01	8.472E-04	1.554E+00	1.230E+00	1.00	2.56E-03	2.03E-03
	1.1474	0.002764	3.466E+07	0.0200	3.37E-04	1.04E-01	1.01	3.553E-05	3.185E-01	2.521E-01	1.00	1.07E-04	8.51E-05
	1.1732	0.010857	3.466E+07	0.0200	1.33E-03	4.19E-01	1.02	5.659E-04	1.272E+00	1.007E+00	1.00	1.69E-03	1.34E-03
	1.2727	0.001777	3.466E+07	0.0200	2.17E-04	7.44E-02	1.02	1.646E-05	2.212E-01	1.751E-01	0.99	4.75E-05	3.76E-05
	1.2907	0.011351	3.466E+07	0.0200	1.39E-03	4.82E-01	1.02	6.815E-04	1.427E+00	1.130E+00	0.99	1.96E-03	1.55E-03
	1.2953	0.01974	3.466E+07	0.0200	2.41E-03	8.42E-01	1.02	2.069E-03	2.489E+00	1.970E+00	0.99	5.94E-03	4.70E-03
	1.2976	0.008883	3.466E+07	0.0200	1.08E-03	3.80E-01	1.02	4.199E-04	1.121E+00	8.878E-01	0.99	1.20E-03	9.53E-04
	1.3178	0.001184	3.466E+07	0.0200	1.45E-04	5.14E-02	1.02	7.579E-06	1.511E-01	1.196E-01	0.99	2.16E-05	1.71E-05
	1.3721	0.024675	3.466E+07	0.0200	3.01E-03	1.12E+00	1.03	3.472E-03	3.241E+00	2.566E+00	0.99	9.67E-03	7.65E-03
	1.3986	0.071064	3.466E+07	0.0200	8.67E-03	3.29E+00	1.03	2.939E-02	9.460E+00	7.489E+00	0.99	8.12E-02	6.43E-02
	1.4426	0.014213	3.466E+07	0.0200	1.73E-03	6.81E-01	1.04	1.228E-03	1.933E+00	1.531E+00	0.99	3.32E-03	2.63E-03
	1.4768	0.001352	3.466E+07	0.0200	1.65E-04	6.65E-02	1.04	1.141E-05	1.869E-01	1.480E-01	0.99	3.05E-05	2.42E-05

Case #4- 0. Clad Failure
CMS-RE-27A,B,E, Detector Response

Calc. No.: NE-02-94 Rev 1
Prepared By: S. J. Haynes 5/15/94
page: 5.044

V/B 922 4
5/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	1.7575	0.002961	3.466E+07	0.0200	3.61E-04	1.70E-01	1.07	6.574E-05	4.601E-01	3.642E-01	0.98	1.63E-04	1.29E-04
	1.9211	0.011844	3.466E+07	0.0200	1.45E-03	7.37E-01	1.09	1.161E-03	1.952E+00	1.545E+00	0.97	2.74E-03	2.17E-03
	2.0022	0.010857	3.466E+07	0.0200	1.33E-03	7.01E-01	1.10	1.022E-03	1.838E+00	1.455E+00	0.97	2.36E-03	1.87E-03
	2.0868	0.002369	3.466E+07	0.0200	2.89E-04	1.58E-01	1.11	5.057E-05	4.118E-01	3.260E-01	0.97	1.16E-04	9.14E-05
	2.1727	0.001974	3.466E+07	0.0200	2.41E-04	1.35E-01	1.12	3.646E-05	3.522E-01	2.788E-01	0.96	8.15E-05	6.45E-05
	2.2232	0.001184	3.466E+07	0.0200	1.45E-04	8.23E-02	1.13	1.345E-05	2.143E-01	1.697E-01	0.96	2.97E-05	2.35E-05
	2.3905	0.001678	3.466E+07	0.0200	2.05E-04	1.23E-01	1.15	2.897E-05	3.183E-01	2.519E-01	0.95	6.19E-05	4.90E-05
	1.0146	0.031946	3.466E+07	0.0200	3.90E-03	1.07E+00	1.01	4.232E-03	3.340E+00	2.644E+00	1.01	1.32E-02	1.04E-02
I-133	0.2627	0.003565	4.747E+07	0.0200	5.96E-04	9.73E-03	1.03	5.971E-06	9.055E-02	7.167E-02	0.97	5.24E-05	4.14E-05
	0.26717	0.001165	4.747E+07	0.0200	1.95E-04	3.35E-03	1.03	6.721E-07	3.025E-02	2.394E-02	0.97	5.72E-06	4.52E-06
	0.34543	0.001036	4.747E+07	0.0200	1.73E-04	5.83E-03	1.00	1.009E-06	3.689E-02	2.920E-02	0.95	6.07E-06	4.80E-06
	0.36108	0.001122	4.747E+07	0.0200	1.88E-04	6.93E-03	1.00	1.301E-06	4.195E-02	3.321E-02	0.95	7.48E-06	5.92E-06
	0.41805	0.001528	4.747E+07	0.0200	2.55E-04	1.26E-02	1.00	3.230E-06	6.618E-02	5.240E-02	0.95	1.61E-05	1.27E-05
	0.42291	0.00309	4.747E+07	0.0200	5.17E-04	2.61E-02	1.00	1.347E-05	1.352E-01	1.071E-01	0.95	6.64E-05	5.25E-05
	0.51053	0.018127	4.747E+07	0.0200	3.03E-03	2.64E-01	0.99	7.923E-04	1.115E+00	8.834E-01	0.96	3.24E-03	2.57E-03
	0.52987	0.8632	4.747E+07	0.0200	1.44E-01	1.38E+01	0.99	1.970E+00	5.310E+01	4.208E+01	0.97	7.43E+00	5.89E+00
	0.61797	0.005395	4.747E+07	0.0200	9.02E-04	1.11E-01	1.00	9.971E-05	3.603E-01	2.857E-01	0.99	3.22E-04	2.55E-04
	0.68025	0.006448	4.747E+07	0.0200	1.08E-03	1.46E-01	1.00	1.574E-04	4.686E-01	3.714E-01	1.00	5.05E-04	4.00E-04
	0.70658	0.014933	4.747E+07	0.0200	2.50E-03	3.51E-01	1.00	8.764E-04	1.125E+00	8.915E-01	1.01	2.84E-03	2.25E-03
	0.76838	0.004566	4.747E+07	0.0200	7.63E-04	1.17E-01	1.01	9.002E-05	3.726E-01	2.952E-01	1.01	2.87E-04	2.28E-04
	0.82051	0.001537	4.747E+07	0.0200	2.57E-04	4.19E-02	1.01	1.089E-05	1.334E-01	1.057E-01	1.02	3.50E-05	2.77E-05
	0.85628	0.012344	4.747E+07	0.0200	2.06E-03	3.50E-01	1.01	7.297E-04	1.114E+00	8.825E-01	1.02	2.35E-03	1.86E-03
	0.87533	0.044714	4.747E+07	0.0200	7.48E-03	1.29E+00	1.01	9.777E-03	4.118E+00	3.261E+00	1.02	3.14E-02	2.49E-02
	0.90967	0.002124	4.747E+07	0.0200	3.55E-04	6.39E-02	1.01	2.291E-05	2.024E-01	1.603E-01	1.01	7.26E-05	5.75E-05
	1.0523	0.005516	4.747E+07	0.0200	9.22E-04	1.92E-01	1.01	1.786E-04	5.940E-01	4.703E-01	1.01	5.53E-04	4.38E-04
	1.0601	0.001373	4.747E+07	0.0200	2.30E-04	4.80E-02	1.01	1.114E-05	1.487E-01	1.178E-01	1.01	3.45E-05	2.73E-05
	1.2364	0.014933	4.747E+07	0.0200	2.50E-03	6.07E-01	1.02	1.546E-03	1.820E+00	1.441E+00	1.00	4.54E-03	3.60E-03
	1.2982	0.023306	4.747E+07	0.0200	3.90E-03	9.96E-01	1.02	3.960E-03	2.943E+00	2.330E+00	0.99	1.14E-02	8.99E-03
	1.3504	0.001485	4.747E+07	0.0200	2.48E-04	6.62E-02	1.03	1.693E-05	1.929E-01	1.527E-01	0.99	4.74E-05	3.75E-05
I-134	0.53524	0.006072	4.747E+07	0.0200	1.02E-03	9.92E-02	0.99	9.968E-05	3.744E-01	2.967E-01	0.97	3.69E-04	2.92E-04
	0.1354	0.037592	5.183E+07	0.0200	6.86E-03	3.23E-03	1.03	2.284E-05	4.014E-01	3.175E-01	1.02	2.81E-03	2.22E-03
	0.13903	0.006869	5.183E+07	0.0200	1.25E-03	8.09E-04	1.02	1.034E-06	7.565E-02	5.984E-02	1.02	9.67E-05	7.65E-05
	0.15198	0.001059	5.183E+07	0.0200	1.93E-04	3.36E-04	1.00	6.491E-08	1.300E-02	1.028E-02	1.00	2.51E-06	1.99E-06
	0.16248	0.002576	5.183E+07	0.0200	4.70E-04	1.11E-03	1.00	5.212E-07	3.442E-02	2.723E-02	0.98	1.59E-05	1.25E-05

1/3/98
7/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)	
	0.18847	0.006965	5.183E+07	0.0200	1.27E-03	6.22E-03	1.04	8.222E-06	1.132E-01	8.954E-02	0.97	1.40E-04	1.10E-04
	0.217	0.002481	5.183E+07	0.0200	4.53E-04	3.81E-03	1.06	1.830E-06	4.877E-02	3.859E-02	0.97	2.14E-05	1.70E-05
	0.23547	0.019845	5.183E+07	0.0200	3.62E-03	3.88E-02	1.05	1.474E-04	4.358E-01	3.449E-01	0.97	1.53E-03	1.21E-03
	0.2788	0.001307	5.183E+07	0.0200	2.39E-04	4.30E-03	1.02	1.047E-06	3.588E-02	2.840E-02	0.96	8.22E-06	6.50E-06
	0.31981	0.005152	5.183E+07	0.0200	9.40E-04	2.46E-02	1.00	2.312E-05	1.677E-01	1.327E-01	0.96	1.51E-04	1.20E-04
	0.35108	0.004961	5.183E+07	0.0200	9.06E-04	2.89E-02	1.00	2.615E-05	1.799E-01	1.424E-01	0.95	1.55E-04	1.22E-04
	0.40545	0.073466	5.183E+07	0.0200	1.34E-02	5.77E-01	1.00	7.740E-03	3.092E+00	2.448E+00	0.95	3.94E-02	3.12E-02
	0.411	0.006106	5.183E+07	0.0200	1.11E-03	4.91E-02	1.00	5.471E-05	2.603E-01	2.061E-01	0.95	2.76E-04	2.18E-04
	0.43335	0.041885	5.183E+07	0.0200	7.65E-03	3.68E-01	1.00	2.813E-03	1.873E+00	1.483E+00	0.95	1.36E-02	1.08E-02
	0.45892	0.012976	5.183E+07	0.0200	2.37E-03	1.25E-01	0.99	2.936E-04	6.084E-01	4.817E-01	0.96	1.38E-03	1.10E-03
	0.4655	0.003626	5.183E+07	0.0200	6.62E-04	3.58E-02	0.99	2.345E-05	1.719E-01	1.361E-01	0.96	1.09E-04	8.65E-05
	0.48888	0.014121	5.183E+07	0.0200	2.58E-03	1.51E-01	0.99	3.844E-04	6.936E-01	5.492E-01	0.96	1.72E-03	1.36E-03
	0.5144	0.023375	5.183E+07	0.0200	4.27E-03	3.48E-01	0.99	1.468E-03	1.437E+00	1.138E+00	0.97	5.95E-03	4.71E-03
	0.54083	0.078236	5.183E+07	0.0200	1.43E-02	1.31E+00	0.99	1.846E-02	4.835E+00	3.832E+00	0.97	6.70E-02	5.31E-02
	0.56552	0.008778	5.183E+07	0.0200	1.60E-03	1.59E-01	0.99	2.522E-04	5.524E-01	4.379E-01	0.98	8.67E-04	6.88E-04
	0.57075	0.002099	5.183E+07	0.0200	3.83E-04	3.86E-02	0.99	1.464E-05	1.327E-01	1.052E-01	0.98	4.98E-05	3.95E-05
	0.59536	0.11354	5.183E+07	0.0200	2.07E-02	2.22E+00	0.99	4.565E-02	7.374E+00	5.847E+00	0.99	1.51E-01	1.20E-01
	0.62179	0.10591	5.183E+07	0.0200	1.93E-02	2.19E+00	1.00	4.226E-02	7.111E+00	5.638E+00	0.99	1.36E-01	1.08E-01
	0.62796	0.023662	5.183E+07	0.0200	4.32E-03	4.94E-01	1.00	2.132E-03	1.601E+00	1.269E+00	0.99	6.85E-03	5.43E-03
	0.67734	0.084915	5.183E+07	0.0200	1.55E-02	1.91E+00	1.00	2.967E-02	6.147E+00	4.872E+00	1.00	9.53E-02	7.55E-02
	0.70665	0.008301	5.183E+07	0.0200	1.52E-03	1.95E-01	1.00	2.958E-04	6.256E-01	4.957E-01	1.01	9.57E-04	7.59E-04
	0.73074	0.019082	5.183E+07	0.0200	3.48E-03	4.64E-01	1.01	1.631E-03	1.484E+00	1.176E+00	1.01	5.22E-03	4.14E-03
	0.73918	0.007633	5.183E+07	0.0200	1.39E-03	1.88E-01	1.01	2.641E-04	6.003E-01	4.756E-01	1.01	8.45E-04	6.69E-04
	0.76668	0.041026	5.183E+07	0.0200	7.49E-03	1.05E+00	1.01	7.917E-03	3.341E+00	2.647E+00	1.01	2.53E-02	2.00E-02
	0.81638	0.005248	5.183E+07	0.0200	9.58E-04	1.43E-01	1.01	1.379E-04	4.534E-01	3.591E-01	1.02	4.43E-04	3.51E-04
	0.84702	0.9541	5.183E+07	0.0200	1.74E-01	2.68E+01	1.01	4.712E+00	8.528E+01	6.754E+01	1.02	1.51E+01	1.20E+01
	0.85729	0.069649	5.183E+07	0.0200	1.27E-02	1.98E+00	1.01	2.540E-02	6.295E+00	4.985E+00	1.02	8.16E-02	6.47E-02
	0.864	0.001908	5.183E+07	0.0200	3.48E-04	5.46E-02	1.01	1.920E-05	1.737E-01	1.375E-01	1.02	6.17E-05	4.89E-05
	0.88409	0.6526	5.183E+07	0.0200	1.19E-01	1.91E+01	1.01	2.296E+00	6.064E+01	4.802E+01	1.01	7.30E+00	5.78E+00
	0.9226	0.001431	5.183E+07	0.0200	2.61E-04	4.36E-02	1.01	1.151E-05	1.381E-01	1.093E-01	1.01	3.64E-05	2.88E-05
	0.94786	0.040358	5.183E+07	0.0200	7.37E-03	1.27E+00	1.01	9.417E-03	3.986E+00	3.156E+00	1.01	2.97E-02	2.35E-02
	0.9669	0.00353	5.183E+07	0.0200	6.44E-04	1.13E-01	1.01	7.358E-05	3.546E-01	2.808E-01	1.01	2.31E-04	1.83E-04
	0.97467	0.046751	5.183E+07	0.0200	8.53E-03	1.51E+00	1.01	1.302E-02	4.727E+00	3.743E+00	1.01	4.07E-02	3.23E-02
	1.0403	0.019082	5.183E+07	0.0200	3.48E-03	6.56E-01	1.01	2.309E-03	2.036E+00	1.612E+00	1.01	7.16E-03	5.67E-03

Case #4- 0.1% Clad Failure
CMS-RE-27A,B,E,F Detector Response

Calc. No.: NE-02-94- rev 1
Prepared By: S. J. Haynes 5/5/94
page: 5.046

*u/b 9282-5
9/16/94*

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	1.0726	0.15266	5.183E+07	0.0200	2.79E-02	5.40E+00	1.01	1.520E-01	1.669E+01	1.322E+01	1.01	4.70E-01	3.72E-01
	1.1001	0.006869	5.183E+07	0.0200	1.25E-03	2.49E-01	1.01	3.151E-04	7.661E-01	6.065E-01	1.00	9.61E-04	7.61E-04
	1.1032	0.007251	5.183E+07	0.0200	1.32E-03	2.63E-01	1.01	3.521E-04	8.105E-01	6.417E-01	1.00	1.07E-03	8.49E-04
	1.1362	0.097318	5.183E+07	0.0200	1.78E-02	3.64E+00	1.01	6.526E-02	1.113E+01	8.815E+00	1.00	1.98E-01	1.57E-01
	1.1591	0.00353	5.183E+07	0.0200	6.44E-04	1.34E-01	1.01	8.753E-05	4.099E-01	3.245E-01	1.00	2.64E-04	2.09E-04
	1.164	0.001336	5.183E+07	0.0200	2.44E-04	5.11E-02	1.02	1.271E-05	1.556E-01	1.232E-01	1.00	3.80E-05	3.00E-05
	1.19	0.00353	5.183E+07	0.0200	6.44E-04	1.38E-01	1.02	9.073E-05	4.181E-01	3.310E-01	1.00	2.69E-04	2.13E-04
	1.239	0.002099	5.183E+07	0.0200	3.83E-04	8.55E-02	1.02	3.340E-05	2.561E-01	2.028E-01	1.00	9.81E-05	7.77E-05
	1.2695	0.005629	5.183E+07	0.0200	1.03E-03	2.35E-01	1.02	2.464E-04	6.993E-01	5.536E-01	1.00	7.19E-04	5.69E-04
	1.3224	0.00105	5.183E+07	0.0200	1.92E-04	4.58E-02	1.03	9.033E-06	1.343E-01	1.063E-01	0.99	2.55E-05	2.02E-05
	1.336	0.001431	5.183E+07	0.0200	2.61E-04	6.31E-02	1.03	1.697E-05	1.844E-01	1.460E-01	0.99	4.77E-05	3.78E-05
	1.3526	0.004484	5.183E+07	0.0200	8.19E-04	2.00E-01	1.03	1.688E-04	5.830E-01	4.615E-01	0.99	4.72E-04	3.74E-04
	1.4143	0.002194	5.183E+07	0.0200	4.00E-04	1.03E-01	1.03	4.241E-05	2.943E-01	2.330E-01	0.99	1.17E-04	9.24E-05
	1.4282	0.001717	5.183E+07	0.0200	3.13E-04	8.14E-02	1.03	2.626E-05	2.320E-01	1.837E-01	0.99	7.20E-05	5.70E-05
	1.4314	0.001717	5.183E+07	0.0200	3.13E-04	8.16E-02	1.03	2.633E-05	2.324E-01	1.839E-01	0.99	7.21E-05	5.71E-05
	1.4552	0.022898	5.183E+07	0.0200	4.18E-03	1.11E+00	1.04	4.814E-03	3.134E+00	2.481E+00	0.99	1.30E-02	1.03E-02
	1.47	0.007728	5.183E+07	0.0200	1.41E-03	3.78E-01	1.04	5.542E-04	1.065E+00	8.427E-01	0.99	1.49E-03	1.18E-03
	1.5055	0.001145	5.183E+07	0.0200	2.09E-04	5.75E-02	1.04	1.249E-05	1.605E-01	1.270E-01	0.99	3.32E-05	2.63E-05
	1.5415	0.005057	5.183E+07	0.0200	9.23E-04	2.59E-01	1.04	2.486E-04	7.200E-01	5.700E-01	0.98	6.51E-04	5.16E-04
	1.6138	0.043602	5.183E+07	0.0200	7.96E-03	2.32E+00	1.05	1.941E-02	6.402E+00	5.068E+00	0.98	4.99E-02	3.95E-02
	1.6292	0.002576	5.183E+07	0.0200	4.70E-04	1.38E-01	1.05	6.833E-05	3.807E-01	3.014E-01	0.98	1.75E-04	1.39E-04
	1.6443	0.004007	5.183E+07	0.0200	7.31E-04	2.17E-01	1.06	1.682E-04	5.957E-01	4.716E-01	0.98	4.27E-04	3.38E-04
	1.6552	0.00229	5.183E+07	0.0200	4.18E-04	1.25E-01	1.06	5.526E-05	3.420E-01	2.708E-01	0.98	1.40E-04	1.11E-04
	1.7415	0.026715	5.183E+07	0.0200	4.88E-03	1.52E+00	1.07	7.938E-03	4.126E+00	3.267E+00	0.98	1.97E-02	1.56E-02
	1.8068	0.057246	5.183E+07	0.0200	1.04E-02	3.37E+00	1.08	3.802E-02	9.060E+00	7.172E+00	0.98	9.28E-02	7.35E-02
	1.9259	0.001813	5.183E+07	0.0200	3.31E-04	1.13E-01	1.09	4.077E-05	2.992E-01	2.369E-01	0.97	9.60E-05	7.60E-05
	2.0206	0.001717	5.183E+07	0.0200	3.13E-04	1.12E-01	1.10	3.848E-05	2.924E-01	2.315E-01	0.97	8.89E-05	7.04E-05
	2.1599	0.002099	5.183E+07	0.0200	3.83E-04	1.43E-01	1.12	6.137E-05	3.729E-01	2.953E-01	0.96	1.37E-04	1.09E-04
	2.3124	0.002385	5.183E+07	0.0200	4.35E-04	1.71E-01	1.14	8.469E-05	4.428E-01	3.505E-01	0.96	1.85E-04	1.46E-04
	2.4674	0.001527	5.183E+07	0.0200	2.79E-04	1.15E-01	1.16	3.703E-05	2.954E-01	2.339E-01	0.95	7.82E-05	6.19E-05
	1.7872	0.013348	5.183E+07	0.0200	2.44E-03	7.78E-01	1.07	2.028E-03	2.097E+00	1.660E+00	0.98	5.01E-03	3.96E-03
I-135	0.2205	0.017452	4.470E+07	0.0200	2.75E-03	2.81E-02	1.06	8.179E-05	3.506E-01	2.775E-01	0.97	9.34E-04	7.39E-04
	0.22972	0.002317	4.470E+07	0.0200	3.65E-04	4.20E-03	1.05	1.610E-06	4.921E-02	3.894E-02	0.97	1.74E-05	1.38E-05
	0.26426	0.00184	4.470E+07	0.0200	2.90E-04	5.11E-03	1.03	1.526E-06	4.711E-02	3.728E-02	0.97	1.32E-05	1.05E-05



Case #4- 0.1% Clad Failure
CMS-RE-27A,B,E,F Detector Response

Calc. No.: NE-02-94-57 rev 1
Prepared By: S. J. Haynes 6/94
page: 5.047

Handwritten: 4/3/94
2/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	0.28845	0.030899	4.470E+07	0.0200	4.86E-03	1.13E-01	1.02	5.624E-04	8.857E-01	7.010E-01	0.96	4.14E-03	3.27E-03
	0.29027	0.003033	4.470E+07	0.0200	4.77E-04	1.14E-02	1.01	5.474E-06	8.763E-02	6.936E-02	0.96	4.02E-05	3.18E-05
	0.36185	0.00186	4.470E+07	0.0200	2.93E-04	1.15E-02	1.00	3.381E-06	6.969E-02	5.517E-02	0.95	1.94E-05	1.53E-05
	0.40303	0.002317	4.470E+07	0.0200	3.65E-04	1.80E-02	1.00	6.573E-06	9.697E-02	7.676E-02	0.95	3.36E-05	2.66E-05
	0.41483	0.003004	4.470E+07	0.0200	4.73E-04	2.45E-02	1.00	1.160E-05	1.292E-01	1.023E-01	0.95	5.80E-05	4.60E-05
	0.41763	0.03519	4.470E+07	0.0200	5.54E-03	2.91E-01	1.00	1.610E-03	1.523E+00	1.205E+00	0.95	8.01E-03	6.34E-03
	0.42993	0.003033	4.470E+07	0.0200	4.77E-04	2.63E-02	1.00	1.256E-05	1.347E-01	1.066E-01	0.95	6.11E-05	4.84E-05
	0.43374	0.005522	4.470E+07	0.0200	8.69E-04	4.86E-02	1.00	4.223E-05	2.471E-01	1.956E-01	0.95	2.04E-04	1.62E-04
	0.45163	0.003147	4.470E+07	0.0200	4.95E-04	2.96E-02	1.00	1.466E-05	1.457E-01	1.153E-01	0.95	6.86E-05	5.43E-05
	0.54656	0.071239	4.470E+07	0.0200	1.12E-02	1.21E+00	0.99	1.348E-02	4.418E+00	3.502E+00	0.97	4.81E-02	3.81E-02
	0.57597	0.001288	4.470E+07	0.0200	2.03E-04	2.40E-02	0.99	4.822E-06	8.185E-02	6.489E-02	0.98	1.63E-05	1.29E-05
	0.64985	0.004549	4.470E+07	0.0200	7.16E-04	9.84E-02	1.00	7.044E-05	3.171E-01	2.514E-01	1.00	2.27E-04	1.80E-04
	0.69013	0.001288	4.470E+07	0.0200	2.03E-04	2.96E-02	1.00	5.996E-06	9.486E-02	7.518E-02	1.00	1.92E-05	1.52E-05
	0.70792	0.00658	4.470E+07	0.0200	1.04E-03	1.55E-01	1.00	1.605E-04	4.965E-01	3.935E-01	1.01	5.19E-04	4.12E-04
	0.78548	0.001516	4.470E+07	0.0200	2.39E-04	3.97E-02	1.01	9.563E-06	1.263E-01	1.001E-01	1.01	3.05E-05	2.41E-05
	0.79771	0.001717	4.470E+07	0.0200	2.70E-04	4.57E-02	1.01	1.247E-05	1.452E-01	1.150E-01	1.01	3.96E-05	3.14E-05
	0.8368	0.066661	4.470E+07	0.0200	1.05E-02	1.85E+00	1.01	1.962E-02	5.893E+00	4.667E+00	1.02	6.31E-02	5.00E-02
	0.96146	0.001459	4.470E+07	0.0200	2.30E-04	4.64E-02	1.01	1.077E-05	1.458E-01	1.155E-01	1.01	3.38E-05	2.68E-05
	0.97196	0.008869	4.470E+07	0.0200	1.40E-03	2.86E-01	1.01	4.028E-04	8.948E-01	7.085E-01	1.01	1.26E-03	9.99E-04
	0.97261	0.012016	4.470E+07	0.0200	1.89E-03	3.87E-01	1.01	7.400E-04	1.213E+00	9.606E-01	1.01	2.32E-03	1.84E-03
	0.99509	0.001545	4.470E+07	0.0200	2.43E-04	5.10E-02	1.01	1.254E-05	1.589E-01	1.259E-01	1.01	3.90E-05	3.09E-05
	1.0388	0.07925	4.470E+07	0.0200	1.25E-02	2.72E+00	1.01	3.432E-02	8.448E+00	6.689E+00	1.01	1.06E-01	8.43E-02
	1.1016	0.016022	4.470E+07	0.0200	2.52E-03	5.81E-01	1.01	1.480E-03	1.789E+00	1.416E+00	1.00	4.51E-03	3.57E-03
	1.124	0.036049	4.470E+07	0.0200	5.68E-03	1.33E+00	1.01	7.640E-03	4.089E+00	3.237E+00	1.00	2.32E-02	1.84E-02
	1.1315	0.22516	4.470E+07	0.0200	3.54E-02	8.38E+00	1.01	3.000E-01	2.567E+01	2.032E+01	1.00	9.10E-01	7.20E-01
	1.1599	0.00103	4.470E+07	0.0200	1.62E-04	3.93E-02	1.02	6.495E-06	1.197E-01	9.474E-02	1.00	1.94E-05	1.54E-05
	1.169	0.008726	4.470E+07	0.0200	1.37E-03	3.35E-01	1.02	4.697E-04	1.020E+00	8.074E-01	1.00	1.40E-03	1.11E-03
	1.2405	0.009012	4.470E+07	0.0200	1.42E-03	3.68E-01	1.02	5.318E-04	1.101E+00	8.715E-01	1.00	1.56E-03	1.24E-03
	1.2604	0.2861	4.470E+07	0.0200	4.50E-02	1.19E+01	1.02	5.449E-01	3.536E+01	2.799E+01	1.00	1.59E+00	1.26E+00
	1.3679	0.006065	4.470E+07	0.0200	9.55E-04	2.74E-01	1.03	2.696E-04	7.949E-01	6.293E-01	0.99	7.51E-04	5.95E-04
	1.4484	0.003147	4.470E+07	0.0200	4.95E-04	1.51E-01	1.04	7.801E-05	4.293E-01	3.398E-01	0.99	2.11E-04	1.67E-04
	1.4576	0.086402	4.470E+07	0.0200	1.36E-02	4.19E+00	1.04	5.924E-02	1.184E+01	9.375E+00	0.99	1.59E-01	1.26E-01
	1.5028	0.010729	4.470E+07	0.0200	1.69E-03	5.38E-01	1.04	9.445E-04	1.502E+00	1.189E+00	0.99	2.51E-03	1.99E-03
	1.5664	0.012875	4.470E+07	0.0200	2.03E-03	6.69E-01	1.05	1.423E-03	1.853E+00	1.467E+00	0.98	3.68E-03	2.91E-03

Case #4- 0.1% Clad Failure
CMS-RE-27A,B,E, Detector Response

Calc. No.: NE-02-94-1 rev 1
Prepared By: S. J. Haynes 5/94
page: 5.048

v/B
9/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	1.678	0.095271	4.470E+07	0.0200	1.50E-02	5.25E+00	1.06	8.346E-02	1.436E+01	1.136E+01	0.98	2.11E-01	1.67E-01
	1.7065	0.040912	4.470E+07	0.0200	6.44E-03	2.29E+00	1.06	1.562E-02	6.235E+00	4.936E+00	0.98	3.94E-02	3.12E-02
	1.7912	0.076961	4.470E+07	0.0200	1.21E-02	4.49E+00	1.07	5.824E-02	1.211E+01	9.585E+00	0.98	1.44E-01	1.14E-01
	1.8307	0.005779	4.470E+07	0.0200	9.10E-04	3.44E-01	1.08	3.381E-04	9.225E-01	7.303E-01	0.98	8.22E-04	6.51E-04
	1.9273	0.002947	4.470E+07	0.0200	4.64E-04	1.84E-01	1.09	9.296E-05	4.866E-01	3.852E-01	0.97	2.19E-04	1.73E-04
	2.0459	0.008697	4.470E+07	0.0200	1.37E-03	5.70E-01	1.11	8.666E-04	1.492E+00	1.181E+00	0.97	1.98E-03	1.57E-03
	2.2555	0.006123	4.470E+07	0.0200	9.64E-04	4.30E-01	1.13	4.687E-04	1.119E+00	8.856E-01	0.96	1.04E-03	8.20E-04
	2.4087	0.009527	4.470E+07	0.0200	1.50E-03	7.02E-01	1.15	1.211E-03	1.815E+00	1.437E+00	0.95	2.59E-03	2.05E-03
	1.0734	0.014948	4.470E+07	0.0200	2.35E-03	5.29E-01	1.01	1.258E-03	1.636E+00	1.295E+00	1.01	3.89E-03	3.08E-03
Kr-85	0.51399	0.00434	8.915E+05	0.0300	2.04E-05	6.44E-02	0.99	1.303E-06	2.668E-01	2.113E-01	0.97	5.29E-06	4.19E-06
Kr-85m	0.30487	0.13989	1.976E+07	0.0300	1.46E-02	6.03E-01	1.01	8.887E-03	4.296E+00	3.400E+00	0.96	6.02E-02	4.77E-02
	0.00169	0.000586	1.976E+07	0.0300	6.12E-05	0.00E+00	0	0.000E+00	9.001E+10	7.101E+10	0	0.00E+00	0.00E+00
	0.013336	0.006116	1.976E+07	0.0300	6.38E-04	0.00E+00	0	0.000E+00	2.476E+00	1.954E+00	0	0.00E+00	0.00E+00
	0.013395	0.01183	1.976E+07	0.0300	1.23E-03	0.00E+00	0	0.000E+00	4.664E+00	3.681E+00	0	0.00E+00	0.00E+00
	0.015	0.003105	1.976E+07	0.0300	3.24E-04	0.00E+00	0	0.000E+00	6.416E-01	5.064E-01	0	0.00E+00	0.00E+00
	0.12985	0.003011	1.976E+07	0.0300	3.14E-04	1.59E-04	1.05	5.255E-08	3.065E-02	2.424E-02	1.02	9.83E-06	7.77E-06
	0.15118	0.75278	1.976E+07	0.0300	7.86E-02	2.33E-01	1.00	1.833E-02	9.181E+00	7.263E+00	1.00	7.21E-01	5.71E-01
	0.58128	0.000211	1.976E+07	0.0300	2.20E-05	3.99E-03	0.99	8.704E-08	1.348E-02	1.069E-02	0.98	2.91E-07	2.31E-07
Kr-87	0.40258	0.495	3.671E+07	0.0300	9.60E-02	3.84E+00	1.00	3.688E-01	2.069E+01	1.638E+01	0.95	1.89E+00	1.49E+00
	0.67387	0.019058	3.671E+07	0.0300	3.70E-03	4.27E-01	1.00	1.580E-03	1.373E+00	1.088E+00	1.00	5.07E-03	4.02E-03
	0.81425	0.001683	3.671E+07	0.0300	3.26E-04	4.56E-02	1.01	1.503E-05	1.450E-01	1.149E-01	1.02	4.83E-05	3.82E-05
	0.83637	0.007524	3.671E+07	0.0300	1.46E-03	2.09E-01	1.01	3.078E-04	6.648E-01	5.266E-01	1.02	9.89E-04	7.84E-04
	0.84543	0.072765	3.671E+07	0.0300	1.41E-02	2.04E+00	1.01	2.907E-02	6.493E+00	5.143E+00	1.02	9.35E-02	7.40E-02
	0.94664	0.001386	3.671E+07	0.0300	2.69E-04	4.34E-02	1.01	1.178E-05	1.367E-01	1.082E-01	1.01	3.71E-05	2.94E-05
	1.1754	0.011237	3.671E+07	0.0300	2.18E-03	4.34E-01	1.02	9.646E-04	1.319E+00	1.044E+00	1.00	2.87E-03	2.27E-03
	1.338	0.006484	3.671E+07	0.0300	1.26E-03	2.86E-01	1.03	3.707E-04	8.366E-01	6.623E-01	0.99	1.04E-03	8.25E-04
	1.3825	0.002871	3.671E+07	0.0300	5.57E-04	1.31E-01	1.03	7.527E-05	3.791E-01	3.001E-01	0.99	2.09E-04	1.65E-04
	1.3899	0.001237	3.671E+07	0.0300	2.40E-04	5.69E-02	1.03	1.406E-05	1.640E-01	1.298E-01	0.99	3.89E-05	3.08E-05
	1.5312	0.003564	3.671E+07	0.0300	6.91E-04	1.81E-01	1.04	1.305E-04	5.051E-01	3.999E-01	0.98	3.42E-04	2.71E-04
	1.578	0.001287	3.671E+07	0.0300	2.50E-04	6.72E-02	1.05	1.762E-05	1.862E-01	1.474E-01	0.98	4.55E-05	3.60E-05
	1.6112	0.00104	3.671E+07	0.0300	2.02E-04	5.53E-02	1.05	1.172E-05	1.525E-01	1.208E-01	0.98	3.01E-05	2.39E-05
	1.7405	0.020493	3.671E+07	0.0300	3.97E-03	1.17E+00	1.07	4.961E-03	3.165E+00	2.506E+00	0.98	1.23E-02	9.76E-03
	1.8426	0.001386	3.671E+07	0.0300	2.69E-04	8.30E-02	1.08	2.409E-05	2.222E-01	1.759E-01	0.97	5.79E-05	4.59E-05
	2.0119	0.028957	3.671E+07	0.0300	5.62E-03	1.88E+00	1.10	1.159E-02	4.916E+00	3.892E+00	0.97	2.68E-02	2.12E-02

Case #4- 0.1% Clad Failure
CMS-RE-27A,B,E,F Detector Response

Calc. No.: NE-02-94 Rev 1
Prepared By: S. J. Haynes 11/5/94
page: 5.049

*U/B 9.28
2/16/94*

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	2.4085	0.002129	3.671E+07	0.0300	4.13E-04	1.57E-01	1.15	7.449E-05	4.056E-01	3.211E-01	0.95	1.59E-04	1.26E-04
	2.5548	0.09306	3.671E+07	0.0300	1.80E-02	7.16E+00	1.17	1.512E-01	1.841E+01	1.458E+01	0.94	3.12E-01	2.47E-01
	2.5581	0.039105	3.671E+07	0.0300	7.58E-03	3.01E+00	1.17	2.672E-02	7.743E+00	6.129E+00	0.94	5.52E-02	4.37E-02
	2.8114	0.003168	3.671E+07	0.0300	6.14E-04	2.62E-01	1.19	1.916E-04	6.662E-01	5.274E-01	0.92	3.77E-04	2.98E-04
	3.3085	0.004504	3.671E+07	0.0300	8.73E-04	4.15E-01	1.20	4.354E-04	1.050E+00	8.310E-01	0.85	7.79E-04	6.17E-04
	1.6201	0.006499	3.671E+07	0.0300	1.26E-03	3.47E-01	1.05	4.597E-04	9.567E-01	7.574E-01	0.98	1.18E-03	9.36E-04
Kr-88	0.12227	0.001972	5.139E+07	0.0300	5.35E-04	5.33E-05	1.08	3.079E-08	1.879E-02	1.486E-02	1.01	1.02E-05	8.04E-06
	0.16598	0.031036	5.139E+07	0.0300	8.43E-03	1.48E-02	1.01	1.256E-04	4.263E-01	3.373E-01	0.98	3.52E-03	2.78E-03
	0.19632	0.25985	5.139E+07	0.0300	7.05E-02	2.87E-01	1.05	2.126E-02	4.460E+00	3.529E+00	0.97	3.05E-01	2.42E-01
	0.24071	0.002526	5.139E+07	0.0300	6.86E-04	5.27E-03	1.05	3.795E-06	5.712E-02	4.521E-02	0.97	3.80E-05	3.01E-05
	0.31169	0.001073	5.139E+07	0.0300	2.91E-04	4.85E-03	1.01	1.426E-06	3.386E-02	2.680E-02	0.96	9.47E-06	7.50E-06
	0.33471	0.001453	5.139E+07	0.0300	3.94E-04	7.64E-03	1.00	3.013E-06	4.989E-02	3.949E-02	0.95	1.87E-05	1.48E-05
	0.36223	0.02249	5.139E+07	0.0300	6.11E-03	1.40E-01	1.00	8.545E-04	8.439E-01	6.680E-01	0.95	4.89E-03	3.87E-03
	0.39054	0.006436	5.139E+07	0.0300	1.75E-03	4.70E-02	1.00	8.208E-05	2.612E-01	2.067E-01	0.95	4.33E-04	3.43E-04
	0.4217	0.00128	5.139E+07	0.0300	3.48E-04	1.07E-02	1.00	3.735E-06	5.589E-02	4.424E-02	0.95	1.84E-05	1.46E-05
	0.4718	0.007266	5.139E+07	0.0300	1.97E-03	7.33E-02	0.99	1.431E-04	3.479E-01	2.755E-01	0.96	6.59E-04	5.22E-04
	0.67734	0.002353	5.139E+07	0.0300	6.39E-04	5.30E-02	1.00	3.388E-05	1.703E-01	1.350E-01	1.00	1.09E-04	8.62E-05
	0.78828	0.005328	5.139E+07	0.0300	1.45E-03	1.40E-01	1.01	2.045E-04	4.455E-01	3.529E-01	1.01	6.51E-04	5.16E-04
	0.79032	0.001246	5.139E+07	0.0300	3.38E-04	3.28E-02	1.01	1.122E-05	1.045E-01	8.275E-02	1.01	3.57E-05	2.83E-05
	0.83483	0.12975	5.139E+07	0.0300	3.52E-02	3.60E+00	1.01	1.279E-01	1.145E+01	9.066E+00	1.02	4.11E-01	3.26E-01
	0.85034	0.00173	5.139E+07	0.0300	4.70E-04	4.88E-02	1.01	2.313E-05	1.552E-01	1.229E-01	1.02	7.44E-05	5.89E-05
	0.86233	0.006712	5.139E+07	0.0300	1.82E-03	1.92E-01	1.01	3.527E-04	6.098E-01	4.830E-01	1.02	1.13E-03	8.98E-04
	0.94492	0.002941	5.139E+07	0.0300	7.98E-04	9.19E-02	1.01	7.414E-05	2.897E-01	2.294E-01	1.01	2.34E-04	1.85E-04
	0.98578	0.013148	5.139E+07	0.0300	3.57E-03	4.30E-01	1.01	1.550E-03	1.342E+00	1.063E+00	1.01	4.84E-03	3.83E-03
	0.99009	0.001419	5.139E+07	0.0300	3.85E-04	4.66E-02	1.01	1.814E-05	1.454E-01	1.151E-01	1.01	5.66E-05	4.48E-05
	1.0396	0.004844	5.139E+07	0.0300	1.32E-03	1.67E-01	1.01	2.212E-04	5.165E-01	4.090E-01	1.01	6.86E-04	5.43E-04
	1.0495	0.001419	5.139E+07	0.0300	3.85E-04	4.92E-02	1.01	1.914E-05	1.525E-01	1.207E-01	1.01	5.93E-05	4.70E-05
	1.1413	0.012837	5.139E+07	0.0300	3.49E-03	4.82E-01	1.01	1.696E-03	1.474E+00	1.167E+00	1.00	5.14E-03	4.07E-03
	1.1795	0.009965	5.139E+07	0.0300	2.71E-03	3.86E-01	1.02	1.065E-03	1.172E+00	9.279E-01	1.00	3.17E-03	2.51E-03
	1.185	0.006885	5.139E+07	0.0300	1.87E-03	2.68E-01	1.02	5.111E-04	8.129E-01	6.436E-01	1.00	1.52E-03	1.20E-03
	1.2098	0.001419	5.139E+07	0.0300	3.85E-04	5.64E-02	1.02	2.216E-05	1.701E-01	1.347E-01	1.00	6.55E-05	5.19E-05
	1.2127	0.001384	5.139E+07	0.0300	3.76E-04	5.52E-02	1.02	2.114E-05	1.663E-01	1.316E-01	1.00	6.25E-05	4.95E-05
	1.2452	0.003633	5.139E+07	0.0300	9.86E-04	1.49E-01	1.02	1.496E-04	4.450E-01	3.523E-01	1.00	4.39E-04	3.47E-04
	1.2507	0.01121	5.139E+07	0.0300	3.04E-03	4.61E-01	1.02	1.431E-03	1.378E+00	1.091E+00	1.00	4.19E-03	3.32E-03

1/5 92.8
3/14/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	1.325	0.001592	5.139E+07	0.0300	4.32E-04	6.95E-02	1.03	3.096E-05	2.040E-01	1.615E-01	0.99	8.73E-05	6.91E-05
	1.3523	0.001592	5.139E+07	0.0300	4.32E-04	7.11E-02	1.03	3.164E-05	2.070E-01	1.639E-01	0.99	8.86E-05	7.01E-05
	1.3695	0.014774	5.139E+07	0.0300	4.01E-03	6.69E-01	1.03	2.763E-03	1.938E+00	1.535E+00	0.99	7.70E-03	6.09E-03
	1.4069	0.00218	5.139E+07	0.0300	5.92E-04	1.02E-01	1.03	6.192E-05	2.914E-01	2.307E-01	0.99	1.71E-04	1.35E-04
	1.4648	0.001142	5.139E+07	0.0300	3.10E-04	5.56E-02	1.04	1.793E-05	1.570E-01	1.243E-01	0.99	4.82E-05	3.81E-05
	1.5184	0.021521	5.139E+07	0.0300	5.84E-03	1.09E+00	1.04	6.611E-03	3.033E+00	2.401E+00	0.98	1.74E-02	1.37E-02
	1.5298	0.10934	5.139E+07	0.0300	2.97E-02	5.56E+00	1.04	1.717E-01	1.549E+01	1.226E+01	0.98	4.51E-01	3.57E-01
	1.6038	0.004567	5.139E+07	0.0300	1.24E-03	2.42E-01	1.05	3.151E-04	6.678E-01	5.287E-01	0.98	8.11E-04	6.42E-04
	1.6856	0.006643	5.139E+07	0.0300	1.80E-03	7.37E-01	1.06	1.410E-03	1.004E+00	7.950E-01	0.98	1.77E-03	1.41E-03
	1.8928	0.001384	5.139E+07	0.0300	3.76E-04	1.66E-01	1.09	6.792E-05	2.259E-01	1.788E-01	0.97	8.23E-05	6.52E-05
	1.9087	0.001003	5.139E+07	0.0300	2.72E-04	1.21E-01	1.09	3.586E-05	1.645E-01	1.303E-01	0.97	4.35E-05	3.44E-05
	2.0298	0.045291	5.139E+07	0.0300	1.23E-02	5.68E+00	1.10	7.680E-02	7.733E+00	6.122E+00	0.97	9.22E-02	7.30E-02
	2.0354	0.037368	5.139E+07	0.0300	1.01E-02	4.69E+00	1.10	5.238E-02	6.392E+00	5.060E+00	0.97	6.29E-02	4.98E-02
	2.1865	0.002872	5.139E+07	0.0300	7.80E-04	3.78E-01	1.12	3.298E-04	5.144E-01	4.072E-01	0.96	3.85E-04	3.05E-04
	2.1958	0.13183	5.139E+07	0.0300	3.58E-02	1.74E+01	1.13	7.033E-01	2.368E+01	1.875E+01	0.96	8.14E-01	6.44E-01
	2.2318	0.033908	5.139E+07	0.0300	9.21E-03	4.52E+00	1.13	4.701E-02	6.154E+00	4.872E+00	0.96	5.44E-02	4.31E-02
	2.3521	0.007301	5.139E+07	0.0300	1.98E-03	1.01E+00	1.14	2.274E-03	1.370E+00	1.085E+00	0.96	2.61E-03	2.06E-03
	2.3921	0.346	5.139E+07	0.0300	9.39E-02	4.82E+01	1.15	5.207E+00	6.565E+01	5.197E+01	0.95	5.86E+00	4.64E+00
	2.4089	0.001038	5.139E+07	0.0300	2.82E-04	1.45E-01	1.15	4.709E-05	1.979E-01	1.567E-01	0.95	5.30E-05	4.19E-05
	2.5484	0.006228	5.139E+07	0.0300	1.69E-03	9.03E-01	1.17	1.787E-03	1.230E+00	9.739E-01	0.94	1.96E-03	1.55E-03
	2.771	0.001488	5.139E+07	0.0300	4.04E-04	2.28E-01	1.19	1.095E-04	3.101E-01	2.455E-01	0.93	1.17E-04	9.22E-05
	1.0001	0.018892	5.139E+07	0.0300	5.13E-03	1.43E+00	1.01	7.425E-03	1.952E+00	1.545E+00	1.01	1.01E-02	8.01E-03
Kr-89	0.1962	0.0022	6.082E+07	0.0300	7.07E-04	2.42E-03	1.05	1.799E-06	3.774E-02	2.986E-02	0.97	2.59E-05	2.05E-05
	0.1975	0.0182	6.082E+07	0.0300	5.85E-03	2.08E-02	1.05	1.274E-04	3.149E-01	2.492E-01	0.97	1.79E-03	1.41E-03
	0.20503	0.00124	6.082E+07	0.0300	3.98E-04	1.62E-03	1.05	6.782E-07	2.258E-02	1.787E-02	0.98	8.82E-06	6.98E-06
	0.2209	0.2	6.082E+07	0.0300	6.43E-02	3.24E-01	1.06	2.204E-02	4.028E+00	3.187E+00	0.97	2.51E-01	1.99E-01
	0.26411	0.0066	6.082E+07	0.0300	2.12E-03	1.83E-02	1.03	3.999E-05	1.688E-01	1.336E-01	0.97	3.47E-04	2.75E-04
	0.3382	0.00342	6.082E+07	0.0300	1.10E-03	1.84E-02	1.00	2.020E-05	1.189E-01	9.409E-02	0.95	1.24E-04	9.82E-05
	0.34503	0.0118	6.082E+07	0.0300	3.79E-03	6.62E-02	1.00	2.510E-04	4.195E-01	3.321E-01	0.95	1.51E-03	1.20E-03
	0.35606	0.0414	6.082E+07	0.0300	1.33E-02	2.48E-01	1.00	3.303E-03	1.524E+00	1.207E+00	0.95	1.93E-02	1.52E-02
	0.36488	0.009	6.082E+07	0.0300	2.89E-03	5.69E-02	1.00	1.644E-04	3.402E-01	2.693E-01	0.95	9.35E-04	7.40E-04
	0.3693	0.0138	6.082E+07	0.0300	4.43E-03	8.94E-02	1.00	3.966E-04	5.285E-01	4.184E-01	0.95	2.23E-03	1.76E-03
	0.40225	0.00318	6.082E+07	0.0300	1.02E-03	2.46E-02	1.00	2.518E-05	1.328E-01	1.052E-01	0.95	1.29E-04	1.02E-04
	0.41142	0.0256	6.082E+07	0.0300	8.23E-03	2.06E-01	1.00	1.696E-03	1.092E+00	8.648E-01	0.95	8.54E-03	6.76E-03

V/B 90.8-5
9/6/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	0.43808	0.0096	6.082E+07	0.0300	3.08E-03	8.59E-02	1.00	2.648E-04	4.333E-01	3.430E-01	0.95	1.27E-03	1.01E-03
	0.46613	0.008	6.082E+07	0.0300	2.57E-03	7.92E-02	0.99	2.015E-04	3.797E-01	3.007E-01	0.96	9.37E-04	7.42E-04
	0.49076	0.00322	6.082E+07	0.0300	1.03E-03	3.46E-02	0.99	3.539E-05	1.586E-01	1.256E-01	0.96	1.57E-04	1.25E-04
	0.4975	0.0664	6.082E+07	0.0300	2.13E-02	7.28E-01	0.99	1.537E-02	3.300E+00	2.613E+00	0.96	6.76E-02	5.35E-02
	0.4986	0.0114	6.082E+07	0.0300	3.66E-03	1.25E-01	0.99	4.547E-04	5.675E-01	4.493E-01	0.96	2.00E-03	1.58E-03
	0.5573	0.0016	6.082E+07	0.0300	5.14E-04	2.83E-02	0.99	1.438E-05	9.996E-02	7.925E-02	0.98	5.04E-05	3.99E-05
	0.57696	0.0564	6.082E+07	0.0300	1.81E-02	1.05E+00	0.99	1.892E-02	3.588E+00	2.845E+00	0.98	6.37E-02	5.05E-02
	0.5858	0.166	6.082E+07	0.0300	5.33E-02	3.18E+00	0.99	1.678E-01	1.066E+01	8.454E+00	0.98	5.57E-01	4.42E-01
	0.6262	0.006	6.082E+07	0.0300	1.93E-03	1.25E-01	1.00	2.405E-04	4.051E-01	3.211E-01	0.99	7.73E-04	6.13E-04
	0.62975	0.00342	6.082E+07	0.0300	1.10E-03	7.16E-02	1.00	7.863E-05	2.320E-01	1.839E-01	0.99	2.52E-04	2.00E-04
	0.66572	0.00114	6.082E+07	0.0300	3.66E-04	2.53E-02	1.00	9.252E-06	8.122E-02	6.438E-02	1.00	2.97E-05	2.36E-05
	0.6714	0.00106	6.082E+07	0.0300	3.41E-04	2.37E-02	1.00	8.069E-06	7.612E-02	6.034E-02	1.00	2.59E-05	2.05E-05
	0.67411	0.00232	6.082E+07	0.0300	7.45E-04	5.21E-02	1.00	3.880E-05	1.672E-01	1.325E-01	1.00	1.25E-04	9.88E-05
	0.69624	0.0178	6.082E+07	0.0300	5.72E-03	4.12E-01	1.00	2.358E-03	1.322E+00	1.048E+00	1.01	7.64E-03	6.05E-03
	0.70701	0.00498	6.082E+07	0.0300	1.60E-03	1.17E-01	1.00	1.874E-04	3.753E-01	2.975E-01	1.01	6.07E-04	4.81E-04
	0.71005	0.0078	6.082E+07	0.0300	2.51E-03	1.84E-01	1.00	4.616E-04	5.902E-01	4.677E-01	1.01	1.49E-03	1.18E-03
	0.72963	0.00296	6.082E+07	0.0300	9.51E-04	7.18E-02	1.01	6.899E-05	2.299E-01	1.822E-01	1.01	2.21E-04	1.75E-04
	0.73839	0.042	6.082E+07	0.0300	1.35E-02	1.03E+00	1.01	1.406E-02	3.300E+00	2.615E+00	1.01	4.50E-02	3.56E-02
	0.7474	0.00114	6.082E+07	0.0300	3.66E-04	2.83E-02	1.01	1.048E-05	9.061E-02	7.179E-02	1.01	3.35E-05	2.66E-05
	0.7629	0.004	6.082E+07	0.0300	1.29E-03	1.02E-01	1.01	1.318E-04	3.242E-01	2.568E-01	1.01	4.21E-04	3.33E-04
	0.7629	0.0092	6.082E+07	0.0300	2.96E-03	2.34E-01	1.01	6.973E-04	7.457E-01	5.908E-01	1.01	2.23E-03	1.76E-03
	0.77649	0.0112	6.082E+07	0.0300	3.60E-03	2.90E-01	1.01	1.052E-03	9.229E-01	7.312E-01	1.01	3.35E-03	2.66E-03
	0.82675	0.0076	6.082E+07	0.0300	2.44E-03	2.09E-01	1.01	5.151E-04	6.647E-01	5.265E-01	1.02	1.66E-03	1.31E-03
	0.83553	0.011	6.082E+07	0.0300	3.53E-03	3.05E-01	1.01	1.089E-03	9.712E-01	7.692E-01	1.02	3.50E-03	2.77E-03
	0.85737	0.00286	6.082E+07	0.0300	9.19E-04	8.12E-02	1.01	7.537E-05	2.585E-01	2.047E-01	1.02	2.42E-04	1.92E-04
	0.86708	0.0592	6.082E+07	0.0300	1.90E-02	1.70E+00	1.01	3.264E-02	5.405E+00	4.281E+00	1.02	1.05E-01	8.31E-02
	0.87042	0.0016	6.082E+07	0.0300	5.14E-04	4.61E-02	1.01	2.393E-05	1.466E-01	1.161E-01	1.02	7.69E-05	6.09E-05
	0.90427	0.0718	6.082E+07	0.0300	2.31E-02	2.15E+00	1.01	5.001E-02	6.806E+00	5.390E+00	1.01	1.59E-01	1.26E-01
	0.93095	0.0062	6.082E+07	0.0300	1.99E-03	1.91E-01	1.01	3.840E-04	6.029E-01	4.774E-01	1.01	1.21E-03	9.60E-04
	0.94419	0.00164	6.082E+07	0.0300	5.27E-04	5.12E-02	1.01	2.726E-05	1.614E-01	1.278E-01	1.01	8.59E-05	6.80E-05
	0.95318	0.00106	6.082E+07	0.0300	3.41E-04	3.34E-02	1.01	1.150E-05	1.052E-01	8.330E-02	1.01	3.62E-05	2.87E-05
	0.96042	0.00322	6.082E+07	0.0300	1.03E-03	1.02E-01	1.01	1.070E-04	3.216E-01	2.546E-01	1.01	3.36E-04	2.66E-04
	0.97439	0.0098	6.082E+07	0.0300	3.15E-03	3.16E-01	1.01	1.006E-03	9.903E-01	7.842E-01	1.01	3.15E-03	2.49E-03
	0.99737	0.0066	6.082E+07	0.0300	2.12E-03	2.19E-01	1.01	4.681E-04	6.803E-01	5.387E-01	1.01	1.46E-03	1.15E-03

v/b J.S. 2/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont.	27A&B	27A&B	27E	27F	27E&F	27E	27F	
					Conc. (uCi/cc)	QAD Det. Response (Rad/hr)	Eff.	Response (Rad/hr)	QAD Det. Response (Rad/hr)	QAD Det. Response (Rad/hr)	Eff.	Response (Rad/hr)	Response (Rad/hr)
	1.0108	0.00108	6.082E+07	0.0300	3.47E-04	3.62E-02	1.01	1.269E-05	1.126E-01	8.911E-02	1.01	3.94E-05	3.12E-05
	1.0444	0.00408	6.082E+07	0.0300	1.31E-03	1.41E-01	1.01	1.865E-04	4.367E-01	3.457E-01	1.01	5.78E-04	4.58E-04
	1.0765	0.00236	6.082E+07	0.0300	7.58E-04	8.38E-02	1.01	6.416E-05	2.588E-01	2.049E-01	1.01	1.98E-04	1.57E-04
	1.0881	0.00358	6.082E+07	0.0300	1.15E-03	1.28E-01	1.01	1.491E-04	3.959E-01	3.134E-01	1.00	4.55E-04	3.61E-04
	1.1032	0.009	6.082E+07	0.0300	2.89E-03	3.27E-01	1.01	9.545E-04	1.006E+00	7.963E-01	1.00	2.91E-03	2.30E-03
	1.1078	0.0292	6.082E+07	0.0300	9.38E-03	1.06E+00	1.01	1.009E-02	3.275E+00	2.593E+00	1.00	3.07E-02	2.43E-02
	1.1166	0.0166	6.082E+07	0.0300	5.33E-03	6.10E-01	1.01	3.286E-03	1.873E+00	1.483E+00	1.00	9.99E-03	7.91E-03
	1.1315	0.0016	6.082E+07	0.0300	5.14E-04	5.95E-02	1.01	3.091E-05	1.824E-01	1.444E-01	1.00	9.38E-05	7.42E-05
	1.1625	0.00214	6.082E+07	0.0300	6.88E-04	8.18E-02	1.02	5.734E-05	2.491E-01	1.972E-01	1.00	1.71E-04	1.36E-04
	1.1723	0.0098	6.082E+07	0.0300	3.15E-03	3.77E-01	1.02	1.212E-03	1.147E+00	9.083E-01	1.00	3.61E-03	2.86E-03
	1.1824	0.00166	6.082E+07	0.0300	5.33E-04	6.45E-02	1.02	3.509E-05	1.957E-01	1.549E-01	1.00	1.04E-04	8.26E-05
	1.1865	0.00184	6.082E+07	0.0300	5.91E-04	7.17E-02	1.02	4.326E-05	2.175E-01	1.722E-01	1.00	1.29E-04	1.02E-04
	1.2288	0.00144	6.082E+07	0.0300	4.63E-04	5.82E-02	1.02	2.745E-05	1.747E-01	1.383E-01	1.00	8.08E-05	6.40E-05
	1.2356	0.00594	6.082E+07	0.0300	1.91E-03	2.41E-01	1.02	4.696E-04	7.235E-01	5.728E-01	1.00	1.38E-03	1.09E-03
	1.2737	0.0136	6.082E+07	0.0300	4.37E-03	5.70E-01	1.02	2.540E-03	1.694E+00	1.341E+00	0.99	7.33E-03	5.80E-03
	1.3027	0.001	6.082E+07	0.0300	3.21E-04	4.29E-02	1.02	1.406E-05	1.266E-01	1.002E-01	0.99	4.03E-05	3.19E-05
	1.3243	0.0306	6.082E+07	0.0300	9.83E-03	1.34E+00	1.03	1.353E-02	3.919E+00	3.103E+00	0.99	3.82E-02	3.02E-02
	1.3354	0.00132	6.082E+07	0.0300	4.24E-04	5.81E-02	1.03	2.540E-05	1.701E-01	1.347E-01	0.99	7.14E-05	5.65E-05
	1.3406	0.00194	6.082E+07	0.0300	6.23E-04	8.58E-02	1.03	5.508E-05	2.506E-01	1.984E-01	0.99	1.55E-04	1.22E-04
	1.3675	0.00148	6.082E+07	0.0300	4.76E-04	6.69E-02	1.03	3.275E-05	1.939E-01	1.535E-01	0.99	9.13E-05	7.23E-05
	1.3722	0.00126	6.082E+07	0.0300	4.05E-04	5.71E-02	1.03	2.382E-05	1.655E-01	1.310E-01	0.99	6.63E-05	5.25E-05
	1.4126	0.00264	6.082E+07	0.0300	8.48E-04	1.24E-01	1.03	1.079E-04	3.539E-01	2.801E-01	0.99	2.97E-04	2.35E-04
	1.4216	0.00224	6.082E+07	0.0300	7.20E-04	1.06E-01	1.03	7.827E-05	3.017E-01	2.388E-01	0.99	2.15E-04	1.70E-04
	1.4613	0.00122	6.082E+07	0.0300	3.92E-04	5.93E-02	1.04	2.417E-05	1.675E-01	1.326E-01	0.99	6.50E-05	5.14E-05
	1.4642	0.00178	6.082E+07	0.0300	5.72E-04	8.67E-02	1.04	5.155E-05	2.446E-01	1.937E-01	0.99	1.39E-04	1.10E-04
	1.4685	0.00188	6.082E+07	0.0300	6.04E-04	9.19E-02	1.04	5.770E-05	2.589E-01	2.050E-01	0.99	1.55E-04	1.23E-04
	1.4728	0.0688	6.082E+07	0.0300	2.21E-02	3.37E+00	1.04	7.752E-02	9.494E+00	7.516E+00	0.99	2.08E-01	1.64E-01
	1.501	0.0132	6.082E+07	0.0300	4.24E-03	6.61E-01	1.04	2.915E-03	1.846E+00	1.461E+00	0.99	7.75E-03	6.14E-03
	1.5062	0.00112	6.082E+07	0.0300	3.60E-04	5.62E-02	1.04	2.104E-05	1.569E-01	1.242E-01	0.99	5.59E-05	4.43E-05
	1.53	0.0332	6.082E+07	0.0300	1.07E-02	1.69E+00	1.04	1.874E-02	4.703E+00	3.723E+00	0.98	4.92E-02	3.89E-02
	1.5337	0.0512	6.082E+07	0.0300	1.65E-02	2.61E+00	1.04	4.466E-02	7.264E+00	5.750E+00	0.98	1.17E-01	9.27E-02
	1.5553	0.00152	6.082E+07	0.0300	4.88E-04	7.84E-02	1.05	4.022E-05	2.177E-01	1.723E-01	0.98	1.04E-04	8.25E-05
	1.5738	0.0019	6.082E+07	0.0300	6.10E-04	9.90E-02	1.05	6.348E-05	2.743E-01	2.171E-01	0.98	1.64E-04	1.30E-04
	1.6341	0.0082	6.082E+07	0.0300	2.63E-03	4.42E-01	1.05	1.221E-03	1.214E+00	9.610E-01	0.98	3.13E-03	2.48E-03

1/3 222
9/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	1.6438	0.00338	6.082E+07	0.0300	1.09E-03	1.83E-01	1.06	2.106E-04	5.024E-01	3.977E-01	0.98	5.35E-04	4.23E-04
	1.6675	0.00128	6.082E+07	0.0300	4.11E-04	7.02E-02	1.06	3.059E-05	1.922E-01	1.521E-01	0.98	7.74E-05	6.13E-05
	1.6769	0.0014	6.082E+07	0.0300	4.50E-04	7.71E-02	1.06	3.677E-05	2.109E-01	1.670E-01	0.98	9.30E-05	7.36E-05
	1.6838	0.00132	6.082E+07	0.0300	4.24E-04	7.30E-02	1.06	3.281E-05	1.994E-01	1.579E-01	0.98	8.29E-05	6.56E-05
	1.692	0.0026	6.082E+07	0.0300	8.35E-04	1.44E-01	1.06	1.278E-04	3.940E-01	3.119E-01	0.98	3.23E-04	2.55E-04
	1.6937	0.0438	6.082E+07	0.0300	1.41E-02	2.43E+00	1.06	3.631E-02	6.643E+00	5.259E+00	0.98	9.16E-02	7.25E-02
	1.7213	0.00224	6.082E+07	0.0300	7.20E-04	1.26E-01	1.06	9.633E-05	3.434E-01	2.719E-01	0.98	2.42E-04	1.92E-04
	1.7776	0.0076	6.082E+07	0.0300	2.44E-03	4.41E-01	1.07	1.152E-03	1.191E+00	9.425E-01	0.98	2.85E-03	2.26E-03
	1.7882	0.00106	6.082E+07	0.0300	3.41E-04	6.18E-02	1.07	2.253E-05	1.667E-01	1.319E-01	0.98	5.56E-05	4.40E-05
	1.8107	0.0014	6.082E+07	0.0300	4.50E-04	8.25E-02	1.08	4.010E-05	2.219E-01	1.757E-01	0.98	9.78E-05	7.74E-05
	1.8375	0.00118	6.082E+07	0.0300	3.79E-04	7.05E-02	1.08	2.887E-05	1.888E-01	1.495E-01	0.98	7.02E-05	5.55E-05
	1.8397	0.0035	6.082E+07	0.0300	1.12E-03	2.09E-01	1.08	2.542E-04	5.606E-01	4.438E-01	0.97	6.11E-04	4.84E-04
	1.8685	0.00196	6.082E+07	0.0300	6.30E-04	1.19E-01	1.08	8.084E-05	3.171E-01	2.510E-01	0.97	1.94E-04	1.53E-04
	1.8798	0.00158	6.082E+07	0.0300	5.08E-04	9.64E-02	1.08	5.283E-05	2.567E-01	2.032E-01	0.97	1.26E-04	1.00E-04
	1.9034	0.0104	6.082E+07	0.0300	3.34E-03	6.41E-01	1.09	2.336E-03	1.703E+00	1.348E+00	0.97	5.52E-03	4.37E-03
	1.9391	0.0064	6.082E+07	0.0300	2.06E-03	4.01E-01	1.09	8.998E-04	1.061E+00	8.398E-01	0.97	2.12E-03	1.68E-03
	1.9666	0.00132	6.082E+07	0.0300	4.24E-04	8.39E-02	1.10	3.913E-05	2.208E-01	1.748E-01	0.97	9.09E-05	7.19E-05
	1.9986	0.00118	6.082E+07	0.0300	3.79E-04	7.61E-02	1.10	3.174E-05	1.995E-01	1.579E-01	0.97	7.34E-05	5.81E-05
	2.0122	0.0156	6.082E+07	0.0300	5.01E-03	1.01E+00	1.10	5.574E-03	2.648E+00	2.097E+00	0.97	1.29E-02	1.02E-02
	2.021	0.00244	6.082E+07	0.0300	7.84E-04	1.59E-01	1.10	1.368E-04	4.154E-01	3.289E-01	0.97	3.16E-04	2.50E-04
	2.0465	0.00262	6.082E+07	0.0300	8.42E-04	1.72E-01	1.11	1.606E-04	4.497E-01	3.560E-01	0.97	3.67E-04	2.91E-04
	2.1006	0.0094	6.082E+07	0.0300	3.02E-03	6.28E-01	1.11	2.105E-03	1.640E+00	1.299E+00	0.97	4.81E-03	3.80E-03
	2.16	0.00528	6.082E+07	0.0300	1.70E-03	3.60E-01	1.12	6.836E-04	9.384E-01	7.428E-01	0.96	1.53E-03	1.21E-03
	2.1958	0.00128	6.082E+07	0.0300	4.11E-04	8.83E-02	1.13	4.102E-05	2.299E-01	1.820E-01	0.96	9.08E-05	7.19E-05
	2.2802	0.00204	6.082E+07	0.0300	6.55E-04	1.44E-01	1.14	1.080E-04	3.753E-01	2.971E-01	0.96	2.36E-04	1.87E-04
	2.3774	0.008	6.082E+07	0.0300	2.57E-03	5.84E-01	1.15	1.727E-03	1.512E+00	1.197E+00	0.95	3.69E-03	2.92E-03
	2.401	0.0072	6.082E+07	0.0300	2.31E-03	5.29E-01	1.15	1.408E-03	1.369E+00	1.084E+00	0.95	3.01E-03	2.38E-03
	2.5979	0.00108	6.082E+07	0.0300	3.47E-04	8.41E-02	1.17	3.416E-05	2.159E-01	1.709E-01	0.94	7.04E-05	5.58E-05
	2.6453	0.0042	6.082E+07	0.0300	1.35E-03	3.32E-01	1.18	5.282E-04	8.496E-01	6.726E-01	0.94	1.08E-03	8.53E-04
	2.7509	0.00124	6.082E+07	0.0300	3.98E-04	1.01E-01	1.19	4.783E-05	2.573E-01	2.036E-01	0.93	9.53E-05	7.54E-05
	2.7821	0.0076	6.082E+07	0.0300	2.44E-03	6.24E-01	1.19	1.813E-03	1.588E+00	1.257E+00	0.92	3.57E-03	2.82E-03
	2.7938	0.0068	6.082E+07	0.0300	2.18E-03	5.60E-01	1.19	1.455E-03	1.424E+00	1.128E+00	0.92	2.86E-03	2.27E-03
	2.8196	0.00132	6.082E+07	0.0300	4.24E-04	1.09E-01	1.19	5.524E-05	2.782E-01	2.202E-01	0.92	1.09E-04	8.59E-05
	2.8533	0.0024	6.082E+07	0.0300	7.71E-04	2.01E-01	1.19	1.842E-04	5.095E-01	4.033E-01	0.92	3.61E-04	2.86E-04

Case #4- 0. Clad Failure
CMS-RE-27A,B,E, Detector Response

Calc. No.: NE-02-94 Rev 1
Prepared By: S. J. Haynes 15/94
page: 5.054

1/13 27.2
9/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)	
	2.8662	0.0174	6.082E+07	0.0300	5.59E-03	1.46E+00	1.19	9.717E-03	3.704E+00	2.932E+00	0.92	1.91E-02	1.51E-02
	2.8787	0.00324	6.082E+07	0.0300	1.04E-03	2.73E-01	1.19	3.381E-04	6.917E-01	5.476E-01	0.91	6.55E-04	5.19E-04
	3.0179	0.00254	6.082E+07	0.0300	8.16E-04	2.22E-01	1.20	2.172E-04	5.588E-01	4.423E-01	0.90	4.10E-04	3.25E-04
	3.0292	0.0027	6.082E+07	0.0300	8.68E-04	2.36E-01	1.20	2.459E-04	5.954E-01	4.713E-01	0.90	4.65E-04	3.68E-04
	3.1073	0.00194	6.082E+07	0.0300	6.23E-04	1.72E-01	1.20	1.289E-04	4.346E-01	3.440E-01	0.89	2.41E-04	1.91E-04
	3.1403	0.0104	6.082E+07	0.0300	3.34E-03	9.29E-01	1.20	3.727E-03	2.346E+00	1.857E+00	0.88	6.90E-03	5.46E-03
	3.1721	0.001	6.082E+07	0.0300	3.21E-04	8.99E-02	1.20	3.467E-05	2.270E-01	1.797E-01	0.88	6.42E-05	5.08E-05
	3.2198	0.00428	6.082E+07	0.0300	1.38E-03	3.88E-01	1.20	6.408E-04	9.808E-01	7.763E-01	0.87	1.17E-03	9.29E-04
	3.3617	0.0104	6.082E+07	0.0300	3.34E-03	9.68E-01	1.20	3.883E-03	2.448E+00	1.938E+00	0.84	6.87E-03	5.44E-03
	3.3711	0.0062	6.082E+07	0.0300	1.99E-03	5.78E-01	1.20	1.382E-03	1.462E+00	1.158E+00	0.84	2.45E-03	1.94E-03
	3.3999	0.00136	6.082E+07	0.0300	4.37E-04	1.28E-01	1.20	6.687E-05	3.225E-01	2.553E-01	0.83	1.17E-04	9.26E-05
	3.5329	0.0134	6.082E+07	0.0300	4.31E-03	1.29E+00	1.18	6.534E-03	3.254E+00	2.576E+00	0.80	1.12E-02	8.87E-03
	3.5839	0.00258	6.082E+07	0.0300	8.29E-04	2.50E-01	1.18	2.444E-04	6.324E-01	5.006E-01	0.79	4.14E-04	3.28E-04
	3.7178	0.0084	6.082E+07	0.0300	2.70E-03	8.32E-01	1.16	2.606E-03	2.107E+00	1.668E+00	0.76	4.32E-03	3.42E-03
	3.7325	0.00138	6.082E+07	0.0300	4.43E-04	1.37E-01	1.16	7.049E-05	3.469E-01	2.746E-01	0.75	1.15E-04	9.13E-05
	3.7814	0.00132	6.082E+07	0.0300	4.24E-04	1.32E-01	1.15	6.448E-05	3.347E-01	2.649E-01	0.74	1.05E-04	8.31E-05
	3.8274	0.00138	6.082E+07	0.0300	4.43E-04	1.39E-01	1.14	7.038E-05	3.524E-01	2.790E-01	0.72	1.13E-04	8.91E-05
	3.8427	0.0011	6.082E+07	0.0300	3.53E-04	1.11E-01	1.14	4.485E-05	2.817E-01	2.230E-01	0.72	7.17E-05	5.67E-05
	3.9018	0.00134	6.082E+07	0.0300	4.31E-04	1.37E-01	1.12	6.601E-05	3.464E-01	2.742E-01	0.70	1.04E-04	8.26E-05
	3.923	0.00414	6.082E+07	0.0300	1.33E-03	4.24E-01	1.12	6.324E-04	1.074E+00	8.501E-01	0.69	9.86E-04	7.80E-04
	3.9655	0.00208	6.082E+07	0.0300	6.68E-04	2.15E-01	1.11	1.593E-04	5.432E-01	4.300E-01	0.68	2.47E-04	1.95E-04
	3.9775	0.0027	6.082E+07	0.0300	8.68E-04	2.79E-01	1.10	2.665E-04	7.065E-01	5.592E-01	0.67	4.11E-04	3.25E-04
	3.996	0.00142	6.082E+07	0.0300	4.56E-04	1.47E-01	1.10	7.393E-05	3.726E-01	2.949E-01	0.67	1.14E-04	9.01E-05
	4.048	0.00116	6.082E+07	0.0300	3.73E-04	1.21E-01	1.09	4.923E-05	3.068E-01	2.429E-01	0.65	7.43E-05	5.88E-05
	4.3411	0.00104	6.082E+07	0.0300	3.34E-04	1.13E-01	0.98	3.698E-05	2.873E-01	2.274E-01	0.52	4.99E-05	3.95E-05
	4.4892	0.00134	6.082E+07	0.0300	4.31E-04	1.48E-01	0.91	5.807E-05	3.780E-01	2.992E-01	0.45	7.32E-05	5.80E-05
	2.1811	0.07118	6.082E+07	0.0300	2.29E-02	4.88E+00	1.12	1.251E-01	1.273E+01	1.008E+01	0.96	2.79E-01	2.21E-01
Xe-131m	0.16393	0.0196	9.762E+05	0.0300	1.01E-04	8.79E-03	1.00	8.886E-07	2.649E-01	2.096E-01	0.98	2.62E-05	2.08E-05
Xe-133	0.079621	0.002165	1.902E+08	0.0300	2.18E-03	1.86E-08	0.70	2.839E-11	1.479E-02	1.169E-02	0.93	2.99E-05	2.37E-05
	0.080997	0.36483	1.902E+08	0.0300	3.67E-01	5.66E-06	0.73	1.514E-06	2.511E+00	1.986E+00	0.82	7.55E-01	5.97E-01
	0.1777	0.000712	1.902E+08	0.0300	7.15E-04	4.72E-04	1.02	3.443E-07	1.070E-02	8.462E-03	0.98	7.50E-06	5.93E-06
Xe-133m	0.23322	0.103	6.044E+06	0.0300	3.29E-03	1.96E-01	1.05	6.751E-04	2.233E+00	1.767E+00	0.97	7.12E-03	5.64E-03
Xe-135 -	0.1582	0.002886	4.723E+07	0.0300	7.20E-04	1.10E-03	1.00	7.901E-07	3.727E-02	2.948E-02	0.99	2.66E-05	2.10E-05
	0.24979	0.899	4.723E+07	0.0300	2.24E-01	2.10E+00	1.04	4.897E-01	2.136E+01	1.691E+01	0.97	4.65E+00	3.68E+00

Case #4- O. . . Clad Failure
CMS-RE-27A,B,E, . . . Detector Response

Calc. No.: NE-02-94- . . . rev 1
Prepared By: S. J. Haynes . . . 5/94
page: 5.055

*U/B 9252-5
7/16/94*

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	0.35839	0.002203	4.723E+07	0.0300	5.50E-04	1.34E-02	1.00	7.364E-06	8.168E-02	6.466E-02	0.95	4.27E-05	3.38E-05
	0.40799	0.003578	4.723E+07	0.0300	8.93E-04	2.84E-02	1.00	2.536E-05	1.515E-01	1.199E-01	0.95	1.28E-04	1.02E-04
	0.60819	0.028948	4.723E+07	0.0300	7.22E-03	5.83E-01	0.99	4.166E-03	1.910E+00	1.514E+00	0.99	1.37E-02	1.08E-02
	0.68433	0.002093	4.723E+07	0.0300	5.22E-04	4.77E-02	1.00	2.489E-05	1.530E-01	1.213E-01	1.00	7.99E-05	6.33E-05
Xe-135m	0.52656	0.80997	3.905E+07	0.0300	1.67E-01	1.28E+01	0.99	2.111E+00	4.982E+01	3.948E+01	0.97	8.07E+00	6.40E+00
Xe-137	0.298	0.001167	1.656E+08	0.0300	1.02E-03	4.76E-03	1.01	4.903E-06	3.485E-02	2.759E-02	0.96	3.42E-05	2.70E-05
	0.39335	0.001381	1.656E+08	0.0300	1.21E-03	1.02E-02	1.00	1.237E-05	5.645E-02	4.469E-02	0.95	6.48E-05	5.13E-05
	0.45549	0.307	1.656E+08	0.0300	2.69E-01	2.93E+00	0.99	7.780E-01	1.431E+01	1.133E+01	0.95	3.65E+00	2.89E+00
	0.84895	0.00614	1.656E+08	0.0300	5.37E-03	1.73E-01	1.01	9.373E-04	5.500E-01	4.356E-01	1.02	3.01E-03	2.39E-03
	0.98225	0.002057	1.656E+08	0.0300	1.80E-03	6.70E-02	1.01	1.218E-04	2.094E-01	1.658E-01	1.01	3.81E-04	3.01E-04
	1.1193	0.001053	1.656E+08	0.0300	9.21E-04	3.88E-02	1.01	3.607E-05	1.190E-01	9.422E-02	1.00	1.10E-04	8.68E-05
	1.2732	0.002241	1.656E+08	0.0300	1.96E-03	9.39E-02	1.02	1.877E-04	2.790E-01	2.209E-01	0.99	5.42E-04	4.29E-04
	1.5768	0.001013	1.656E+08	0.0300	8.86E-04	5.29E-02	1.05	4.921E-05	1.464E-01	1.159E-01	0.98	1.27E-04	1.01E-04
	1.6125	0.001228	1.656E+08	0.0300	1.07E-03	6.54E-02	1.05	7.376E-05	1.803E-01	1.427E-01	0.98	1.90E-04	1.50E-04
	1.7834	0.004083	1.656E+08	0.0300	3.57E-03	2.37E-01	1.07	9.076E-04	6.406E-01	5.072E-01	0.98	2.24E-03	1.78E-03
	2.8498	0.001811	1.656E+08	0.0300	1.58E-03	1.51E-01	1.19	2.853E-04	3.841E-01	3.041E-01	0.92	5.60E-04	4.43E-04
	1.4906	0.01315	1.656E+08	0.0300	1.15E-02	6.53E-01	1.04	7.815E-03	1.830E+00	1.449E+00	0.99	2.08E-02	1.65E-02
Xe-138	0.15375	0.059535	1.506E+08	0.0300	4.74E-02	1.99E-02	1.00	9.419E-04	7.416E-01	5.866E-01	0.99	3.48E-02	2.75E-02
	0.24256	0.034965	1.506E+08	0.0300	2.78E-02	7.47E-02	1.05	2.181E-03	7.989E-01	6.322E-01	0.97	2.16E-02	1.71E-02
	0.25831	0.315	1.506E+08	0.0300	2.51E-01	8.15E-01	1.03	2.105E-01	7.825E+00	6.193E+00	0.97	1.90E+00	1.51E+00
	0.28251	0.004284	1.506E+08	0.0300	3.41E-03	1.47E-02	1.02	5.110E-05	1.196E-01	9.464E-02	0.96	3.91E-04	3.10E-04
	0.33528	0.001071	1.506E+08	0.0300	8.52E-04	5.65E-03	1.00	4.814E-06	3.684E-02	2.916E-02	0.95	2.98E-05	2.36E-05
	0.37144	0.005009	1.506E+08	0.0300	3.99E-03	3.29E-02	1.00	1.310E-04	1.930E-01	1.528E-01	0.95	7.31E-04	5.78E-04
	0.39643	0.063	1.506E+08	0.0300	5.01E-02	4.75E-01	1.00	2.379E-02	2.594E+00	2.054E+00	0.95	1.24E-01	9.78E-02
	0.40136	0.021735	1.506E+08	0.0300	1.73E-02	1.68E-01	1.00	2.902E-03	9.058E-01	7.171E-01	0.95	1.49E-02	1.18E-02
	0.43449	0.20318	1.506E+08	0.0300	1.62E-01	1.79E+00	1.00	2.897E-01	9.105E+00	7.208E+00	0.95	1.40E+00	1.11E+00
	0.50022	0.003622	1.506E+08	0.0300	2.88E-03	4.97E-02	0.99	1.417E-04	2.238E-01	1.772E-01	0.96	6.19E-04	4.90E-04
	0.53007	0.00252	1.506E+08	0.0300	2.00E-03	4.03E-02	0.99	7.999E-05	1.551E-01	1.229E-01	0.97	3.02E-04	2.39E-04
	0.53776	0.001166	1.506E+08	0.0300	9.28E-04	1.92E-02	0.99	1.766E-05	7.195E-02	5.703E-02	0.97	6.47E-05	5.13E-05
	0.55595	0.001166	1.506E+08	0.0300	9.28E-04	2.05E-02	0.99	1.883E-05	7.276E-02	5.768E-02	0.98	6.61E-05	5.24E-05
	0.56853	0.003055	1.506E+08	0.0300	2.43E-03	5.58E-02	0.99	1.343E-04	1.927E-01	1.528E-01	0.98	4.59E-04	3.64E-04
	0.58884	0.001228	1.506E+08	0.0300	9.77E-04	2.37E-02	0.99	2.291E-05	7.916E-02	6.276E-02	0.98	7.58E-05	6.01E-05
	0.65408	0.001449	1.506E+08	0.0300	1.15E-03	3.15E-02	1.00	3.636E-05	1.016E-01	8.053E-02	1.00	1.17E-04	9.28E-05
	0.86582	0.002961	1.506E+08	0.0300	2.36E-03	8.49E-02	1.01	2.019E-04	2.700E-01	2.138E-01	1.02	6.49E-04	5.14E-04

Case #4- 0. Clad Failure
CMS-RE-27A,B,E, Detector Response

Calc. No.: NE-02-94 rev 1
Prepared By: S. J. Haynes 5/94
page: 5.056

VJB 9/23/94 47

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont.	27A&B	27A&B		27E	27F	27E&F		
					Conc.	QAD Det.	Eff.	27A&B	QAD Det.	QAD Det.	Eff.	27E	27F
					(uCi/cc)	Response (Rad/hr)		Response (Rad/hr)	Response (Rad/hr)	Response (Rad/hr)		Response (Rad/hr)	Response (Rad/hr)
	0.86935	0.006206	1.506E+08	0.0300	4.94E-03	1.79E-01	1.01	8.905E-04	5.680E-01	4.499E-01	1.02	2.86E-03	2.27E-03
	0.89687	0.001323	1.506E+08	0.0300	1.05E-03	3.92E-02	1.01	4.171E-05	1.245E-01	9.862E-02	1.01	1.32E-04	1.05E-04
	0.91251	0.003276	1.506E+08	0.0300	2.61E-03	9.88E-02	1.01	2.601E-04	3.130E-01	2.479E-01	1.01	8.24E-04	6.52E-04
	0.91713	0.009198	1.506E+08	0.0300	7.32E-03	2.79E-01	1.01	2.062E-03	8.831E-01	6.993E-01	1.01	6.53E-03	5.17E-03
	0.93636	0.001355	1.506E+08	0.0300	1.08E-03	4.20E-02	1.01	4.568E-05	1.324E-01	1.048E-01	1.01	1.44E-04	1.14E-04
	0.94125	0.002299	1.506E+08	0.0300	1.83E-03	7.16E-02	1.01	1.322E-04	2.257E-01	1.787E-01	1.01	4.17E-04	3.30E-04
	1.0939	0.004095	1.506E+08	0.0300	3.26E-03	1.48E-01	1.01	4.855E-04	4.547E-01	3.600E-01	1.00	1.48E-03	1.17E-03
	1.0988	0.002142	1.506E+08	0.0300	1.70E-03	7.75E-02	1.01	1.334E-04	2.387E-01	1.890E-01	1.00	4.07E-04	3.22E-04
	1.1022	0.001071	1.506E+08	0.0300	8.52E-04	3.89E-02	1.01	3.344E-05	1.196E-01	9.470E-02	1.00	1.02E-04	8.07E-05
	1.1143	0.014742	1.506E+08	0.0300	1.17E-02	5.40E-01	1.01	6.403E-03	1.661E+00	1.315E+00	1.00	1.95E-02	1.54E-02
	1.1416	0.005134	1.506E+08	0.0300	4.08E-03	1.93E-01	1.01	7.949E-04	5.893E-01	4.665E-01	1.00	2.41E-03	1.91E-03
	1.1454	0.001323	1.506E+08	0.0300	1.05E-03	4.98E-02	1.01	5.297E-05	1.523E-01	1.206E-01	1.00	1.60E-04	1.27E-04
	1.5718	0.002646	1.506E+08	0.0300	2.11E-03	1.38E-01	1.05	3.045E-04	3.817E-01	3.021E-01	0.98	7.87E-04	6.23E-04
	1.6146	0.002363	1.506E+08	0.0300	1.88E-03	1.26E-01	1.05	2.486E-04	3.471E-01	2.748E-01	0.98	6.40E-04	5.06E-04
	1.7683	0.16727	1.506E+08	0.0300	1.33E-01	9.66E+00	1.07	1.375E+00	2.610E+01	2.066E+01	0.98	3.40E+00	2.69E+00
	1.8125	0.001796	1.506E+08	0.0300	1.43E-03	1.06E-01	1.08	1.635E-04	2.848E-01	2.255E-01	0.98	3.99E-04	3.16E-04
	1.8509	0.014238	1.506E+08	0.0300	1.13E-02	8.56E-01	1.08	1.047E-02	2.289E+00	1.812E+00	0.97	2.51E-02	1.99E-02
	1.9254	0.005639	1.506E+08	0.0300	4.49E-03	3.51E-01	1.09	1.718E-03	9.303E-01	7.365E-01	0.97	4.05E-03	3.21E-03
	2.0048	0.05355	1.506E+08	0.0300	4.26E-02	3.46E+00	1.10	1.622E-01	9.070E+00	7.180E+00	0.97	3.75E-01	2.97E-01
	2.0158	0.12254	1.506E+08	0.0300	9.75E-02	7.95E+00	1.10	8.526E-01	2.083E+01	1.649E+01	0.97	1.97E+00	1.56E+00
	2.0792	0.014427	1.506E+08	0.0300	1.15E-02	9.57E-01	1.11	1.219E-02	2.501E+00	1.980E+00	0.97	2.78E-02	2.20E-02
	2.2523	0.022869	1.506E+08	0.0300	1.82E-02	1.61E+00	1.13	3.301E-02	4.175E+00	3.305E+00	0.96	7.29E-02	5.77E-02
	2.3219	0.006206	1.506E+08	0.0300	4.94E-03	4.45E-01	1.14	2.507E-03	1.155E+00	9.145E-01	0.96	5.48E-03	4.33E-03
	2.4753	0.003119	1.506E+08	0.0300	2.48E-03	2.34E-01	1.16	6.750E-04	6.048E-01	4.788E-01	0.95	1.43E-03	1.13E-03
	2.4976	0.001733	1.506E+08	0.0300	1.38E-03	1.31E-01	1.16	2.098E-04	3.380E-01	2.676E-01	0.95	4.43E-04	3.50E-04
	1.1186	0.026586	1.506E+08	0.0300	2.12E-02	9.78E-01	1.01	2.090E-02	3.004E+00	2.378E+00	1.00	6.35E-02	6.35E-02
SUM =								3.001E+01				9.25E+01	7.32E+01

27A = 0.257 Rad/hr
27B = 0.292 Rad/hr

27E = 92.535 Rad/hr
27F = 73.299 Rad/hr

Con. Vol = 5.68E+09 cm**3
27A Cone Factor 0.00856
27B Cone Factor 0.00973
Release Frac. 0.001

v/B P. 27-4
7/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
I-131	0.080183	0.026182	2.422E+07	0.0200	4.47E-02	3.20E-07	0.71	1.015E-08	1.794E-01	1.418E-01	0.88	7.05E-03	5.58E-03
	0.17721	0.002648	2.422E+07	0.0200	4.52E-03	1.73E-03	1.02	7.975E-06	3.963E-02	3.135E-02	0.98	1.75E-04	1.39E-04
	0.2843	0.060521	2.422E+07	0.0200	1.03E-01	2.12E-01	1.02	2.231E-02	1.703E+00	1.348E+00	0.96	1.69E-01	1.34E-01
	0.32578	0.002507	2.422E+07	0.0200	4.28E-03	1.24E-02	1.00	5.321E-05	8.341E-02	6.603E-02	0.96	3.42E-04	2.71E-04
	0.36448	0.81164	2.422E+07	0.0200	1.38E+00	5.12E+00	1.00	7.085E+00	3.065E+01	2.426E+01	0.95	4.03E+01	3.19E+01
	0.50299	0.003605	2.422E+07	0.0200	6.15E-03	5.03E-02	0.99	3.061E-04	2.224E-01	1.761E-01	0.96	1.31E-03	1.04E-03
	0.63697	0.072605	2.422E+07	0.0200	1.24E-01	1.54E+00	1.00	1.904E-01	4.973E+00	3.942E+00	0.99	6.10E-01	4.83E-01
	0.6427	0.002195	2.422E+07	0.0200	3.74E-03	4.69E-02	1.00	1.757E-04	1.515E-01	1.201E-01	1.00	5.67E-04	4.50E-04
	0.72289	0.018025	2.422E+07	0.0200	3.08E-02	4.33E-01	1.00	1.333E-02	1.388E+00	1.100E+00	1.01	4.31E-02	3.41E-02
	0.32939	0.002304	2.422E+07	0.0200	3.93E-03	1.17E-02	1.00	4.602E-05	7.767E-02	6.148E-02	0.95	2.90E-04	2.30E-04
I-132	0.1472	0.002369	3.466E+07	0.0200	5.78E-03	5.60E-04	1.01	3.273E-06	2.796E-02	2.211E-02	1.01	1.63E-04	1.29E-04
	0.1833	0.001382	3.466E+07	0.0200	3.37E-03	1.07E-03	1.03	3.719E-06	2.163E-02	1.712E-02	0.97	7.08E-05	5.60E-05
	0.2548	0.001875	3.466E+07	0.0200	4.58E-03	4.65E-03	1.04	2.215E-05	4.574E-02	3.620E-02	0.97	2.03E-04	1.61E-04
	0.2627	0.01441	3.466E+07	0.0200	3.52E-02	3.93E-02	1.03	1.424E-03	3.660E-01	2.896E-01	0.97	1.25E-02	9.88E-03
	0.2848	0.007205	3.466E+07	0.0200	1.76E-02	2.54E-02	1.02	4.551E-04	2.032E-01	1.608E-01	0.96	3.43E-03	2.72E-03
	0.3165	0.001382	3.466E+07	0.0200	3.37E-03	6.45E-03	1.00	2.176E-05	4.443E-02	3.516E-02	0.96	1.44E-04	1.14E-04
	0.3635	0.004935	3.466E+07	0.0200	1.20E-02	3.09E-02	1.00	3.727E-04	1.859E-01	1.471E-01	0.95	2.13E-03	1.68E-03
	0.3878	0.002961	3.466E+07	0.0200	7.23E-03	2.13E-02	1.00	1.539E-04	1.193E-01	9.443E-02	0.95	8.19E-04	6.49E-04
	0.4168	0.004738	3.466E+07	0.0200	1.16E-02	3.90E-02	1.00	4.512E-04	2.046E-01	1.620E-01	0.95	2.25E-03	1.78E-03
	0.4319	0.004836	3.466E+07	0.0200	1.18E-02	4.22E-02	1.00	4.988E-04	2.156E-01	1.707E-01	0.95	2.42E-03	1.91E-03
	0.446	0.006021	3.466E+07	0.0200	1.47E-02	5.55E-02	1.00	8.151E-04	2.759E-01	2.184E-01	0.95	3.85E-03	3.05E-03
	0.4739	0.001777	3.466E+07	0.0200	4.34E-03	1.80E-02	0.99	7.752E-05	8.537E-02	6.759E-02	0.96	3.56E-04	2.81E-04
	0.4785	0.001481	3.466E+07	0.0200	3.62E-03	1.53E-02	0.99	5.467E-05	7.164E-02	5.672E-02	0.96	2.49E-04	1.97E-04
	0.4882	0.004145	3.466E+07	0.0200	1.01E-02	4.41E-02	0.99	4.421E-04	2.034E-01	1.611E-01	0.96	1.98E-03	1.56E-03
	0.5059	0.050337	3.466E+07	0.0200	1.23E-01	7.14E-01	0.99	8.690E-02	3.101E+00	2.456E+00	0.96	3.66E-01	2.90E-01
	0.52265	0.16088	3.466E+07	0.0200	3.93E-01	2.49E+00	0.99	9.682E-01	9.888E+00	7.835E+00	0.97	3.77E+00	2.98E+00
	0.5355	0.005231	3.466E+07	0.0200	1.28E-02	8.55E-02	0.99	1.081E-03	3.226E-01	2.556E-01	0.97	4.00E-03	3.17E-03
	0.54	0.001086	3.466E+07	0.0200	2.65E-03	1.81E-02	0.99	4.742E-05	6.709E-02	5.318E-02	0.97	1.73E-04	1.37E-04
	0.5471	0.012535	3.466E+07	0.0200	3.06E-02	2.14E-01	0.99	6.481E-03	7.774E-01	6.162E-01	0.97	2.31E-02	1.83E-02
	0.6	0.001382	3.466E+07	0.0200	3.37E-03	2.74E-02	0.99	9.143E-05	9.024E-02	7.155E-02	0.99	3.01E-04	2.39E-04
	0.6208	0.003948	3.466E+07	0.0200	9.64E-03	8.13E-02	1.00	7.838E-04	2.646E-01	2.098E-01	0.99	2.53E-03	2.00E-03
	0.6212	0.015792	3.466E+07	0.0200	3.86E-02	3.26E-01	1.00	1.255E-02	1.059E+00	8.399E-01	0.99	4.04E-02	3.21E-02
	0.63022	0.13719	3.466E+07	0.0200	3.35E-01	2.87E+00	1.00	9.623E-01	9.314E+00	7.384E+00	0.99	3.09E+00	2.45E+00

*u/B 92.2
9/16/94*

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	0.6506	0.026649	3.466E+07	0.0200	6.51E-02	5.77E-01	1.00	3.753E-02	1.859E+00	1.474E+00	1.00	1.21E-01	9.59E-02
	0.659	0.003948	3.466E+07	0.0200	9.64E-03	8.66E-02	1.00	8.345E-04	2.786E-01	2.209E-01	1.00	2.69E-03	2.13E-03
	0.66769	0.987	3.466E+07	0.0200	2.41E+00	2.19E+01	1.00	5.286E+01	7.051E+01	5.589E+01	1.00	1.70E+02	1.35E+02
	0.6698	0.04935	3.466E+07	0.0200	1.20E-01	1.10E+00	1.00	1.325E-01	3.535E+00	2.802E+00	1.00	4.26E-01	3.38E-01
	0.6716	0.052311	3.466E+07	0.0200	1.28E-01	1.17E+00	1.00	1.493E-01	3.757E+00	2.978E+00	1.00	4.80E-01	3.80E-01
	0.727	0.031584	3.466E+07	0.0200	7.71E-02	7.64E-01	1.00	5.887E-02	2.444E+00	1.937E+00	1.01	1.90E-01	1.51E-01
	0.7272	0.021714	3.466E+07	0.0200	5.30E-02	5.25E-01	1.00	2.784E-02	1.681E+00	1.332E+00	1.01	9.00E-02	7.13E-02
	0.7285	0.010857	3.466E+07	0.0200	2.65E-02	2.63E-01	1.01	7.042E-03	8.421E-01	6.673E-01	1.01	2.25E-02	1.79E-02
	0.7645	0.003948	3.466E+07	0.0200	9.64E-03	1.00E-01	1.01	9.777E-04	3.206E-01	2.540E-01	1.01	3.12E-03	2.47E-03
	0.77261	0.76196	3.466E+07	0.0200	1.86E+00	1.96E+01	1.01	3.681E+01	6.249E+01	4.951E+01	1.01	1.17E+02	9.30E+01
	0.7802	0.012338	3.466E+07	0.0200	3.01E-02	3.21E-01	1.01	9.751E-03	1.021E+00	8.091E-01	1.01	3.11E-02	2.46E-02
	0.7845	0.004244	3.466E+07	0.0200	1.04E-02	1.11E-01	1.01	1.161E-03	3.532E-01	2.798E-01	1.01	3.70E-03	2.93E-03
	0.8098	0.028623	3.466E+07	0.0200	6.99E-02	7.72E-01	1.01	5.448E-02	2.454E+00	1.944E+00	1.01	1.73E-01	1.37E-01
	0.8122	0.056259	3.466E+07	0.0200	1.37E-01	1.52E+00	1.01	2.110E-01	4.838E+00	3.832E+00	1.01	6.71E-01	5.32E-01
	0.8633	0.005823	3.466E+07	0.0200	1.42E-02	1.66E-01	1.01	2.390E-03	5.296E-01	4.194E-01	1.02	7.68E-03	6.08E-03
	0.8768	0.010758	3.466E+07	0.0200	2.63E-02	3.12E-01	1.01	8.280E-03	9.925E-01	7.860E-01	1.02	2.66E-02	2.11E-02
	0.9103	0.009179	3.466E+07	0.0200	2.24E-02	2.76E-01	1.01	6.251E-03	8.752E-01	6.930E-01	1.01	1.98E-02	1.57E-02
	0.9276	0.004145	3.466E+07	0.0200	1.01E-02	1.27E-01	1.01	1.299E-03	4.018E-01	3.182E-01	1.01	4.11E-03	3.25E-03
	0.95455	0.18062	3.466E+07	0.0200	4.41E-01	5.71E+00	1.01	2.541E+00	1.795E+01	1.421E+01	1.01	7.99E+00	6.33E+00
	0.9837	0.005626	3.466E+07	0.0200	1.37E-02	1.84E-01	1.01	2.546E-03	5.733E-01	4.540E-01	1.01	7.95E-03	6.30E-03
	1.0347	0.004738	3.466E+07	0.0200	1.16E-02	1.62E-01	1.01	1.895E-03	5.034E-01	3.985E-01	1.01	5.88E-03	4.66E-03
	1.136	0.02961	3.466E+07	0.0200	7.23E-02	1.11E+00	1.01	8.075E-02	3.385E+00	2.680E+00	1.00	2.45E-01	1.94E-01
	1.1434	0.013522	3.466E+07	0.0200	3.30E-02	5.08E-01	1.01	1.694E-02	1.554E+00	1.230E+00	1.00	5.13E-02	4.06E-02
	1.1474	0.002764	3.466E+07	0.0200	6.75E-03	1.04E-01	1.01	7.106E-04	3.185E-01	2.521E-01	1.00	2.15E-03	1.70E-03
	1.1732	0.010857	3.466E+07	0.0200	2.65E-02	4.19E-01	1.02	1.132E-02	1.272E+00	1.007E+00	1.00	3.37E-02	2.67E-02
	1.2727	0.001777	3.466E+07	0.0200	4.34E-03	7.44E-02	1.02	3.292E-04	2.212E-01	1.751E-01	0.99	9.50E-04	7.52E-04
	1.2907	0.011351	3.466E+07	0.0200	2.77E-02	4.82E-01	1.02	1.363E-02	1.427E+00	1.130E+00	0.99	3.91E-02	3.10E-02
	1.2953	0.01974	3.466E+07	0.0200	4.82E-02	8.42E-01	1.02	4.139E-02	2.489E+00	1.970E+00	0.99	1.19E-01	9.40E-02
	1.2976	0.008883	3.466E+07	0.0200	2.17E-02	3.80E-01	1.02	8.397E-03	1.121E+00	8.878E-01	0.99	2.41E-02	1.91E-02
	1.3178	0.001184	3.466E+07	0.0200	2.89E-03	5.14E-02	1.02	1.516E-04	1.511E-01	1.196E-01	0.99	4.32E-04	3.42E-04
	1.3721	0.024675	3.466E+07	0.0200	6.02E-02	1.12E+00	1.03	6.943E-02	3.241E+00	2.566E+00	0.99	1.93E-01	1.53E-01
	1.3986	0.071064	3.466E+07	0.0200	1.73E-01	3.29E+00	1.03	5.879E-01	9.460E+00	7.489E+00	0.99	1.62E+00	1.29E+00
	1.4426	0.014213	3.466E+07	0.0200	3.47E-02	6.81E-01	1.04	2.457E-02	1.933E+00	1.531E+00	0.99	6.64E-02	5.26E-02
	1.4768	0.001352	3.466E+07	0.0200	3.30E-03	6.65E-02	1.04	2.281E-04	1.869E-01	1.480E-01	0.99	6.11E-04	4.84E-04

v/B
9/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	1.7575	0.002961	3.466E+07	0.0200	7.23E-03	1.70E-01	1.07	1.315E-03	4.601E-01	3.642E-01	0.98	3.26E-03	2.58E-03
	1.9211	0.011844	3.466E+07	0.0200	2.89E-02	7.37E-01	1.09	2.322E-02	1.952E+00	1.545E+00	0.97	5.47E-02	4.33E-02
	2.0022	0.010857	3.466E+07	0.0200	2.65E-02	7.01E-01	1.10	2.045E-02	1.838E+00	1.455E+00	0.97	4.72E-02	3.74E-02
	2.0868	0.002369	3.466E+07	0.0200	5.78E-03	1.58E-01	1.11	1.011E-03	4.118E-01	3.260E-01	0.97	2.31E-03	1.83E-03
	2.1727	0.001974	3.466E+07	0.0200	4.82E-03	1.35E-01	1.12	7.292E-04	3.522E-01	2.788E-01	0.96	1.63E-03	1.29E-03
	2.2232	0.001184	3.466E+07	0.0200	2.89E-03	8.23E-02	1.13	2.690E-04	2.143E-01	1.697E-01	0.96	5.95E-04	4.71E-04
	2.3905	0.001678	3.466E+07	0.0200	4.10E-03	1.23E-01	1.15	5.794E-04	3.183E-01	2.519E-01	0.95	1.24E-03	9.80E-04
	1.0146	0.031946	3.466E+07	0.0200	7.80E-02	1.07E+00	1.01	8.465E-02	3.340E+00	2.644E+00	1.01	2.63E-01	2.08E-01
I-133	0.2627	0.003565	4.747E+07	0.0200	1.19E-02	9.73E-03	1.03	1.194E-04	9.055E-02	7.167E-02	0.97	1.05E-03	8.29E-04
	0.26717	0.001165	4.747E+07	0.0200	3.90E-03	3.35E-03	1.03	1.344E-05	3.025E-02	2.394E-02	0.97	1.14E-04	9.05E-05
	0.34543	0.001036	4.747E+07	0.0200	3.46E-03	5.83E-03	1.00	2.018E-05	3.689E-02	2.920E-02	0.95	1.21E-04	9.61E-05
	0.36108	0.001122	4.747E+07	0.0200	3.75E-03	6.93E-03	1.00	2.601E-05	4.195E-02	3.321E-02	0.95	1.50E-04	1.18E-04
	0.41805	0.001528	4.747E+07	0.0200	5.11E-03	1.26E-02	1.00	6.459E-05	6.618E-02	5.240E-02	0.95	3.21E-04	2.54E-04
	0.42291	0.00309	4.747E+07	0.0200	1.03E-02	2.61E-02	1.00	2.693E-04	1.352E-01	1.071E-01	0.95	1.33E-03	1.05E-03
	0.51053	0.018127	4.747E+07	0.0200	6.06E-02	2.64E-01	0.99	1.585E-02	1.115E+00	8.834E-01	0.96	6.49E-02	5.14E-02
	0.52987	0.8632	4.747E+07	0.0200	2.89E+00	1.38E+01	0.99	3.939E+01	5.310E+01	4.208E+01	0.97	1.49E+02	1.18E+02
	0.61797	0.005395	4.747E+07	0.0200	1.80E-02	1.11E-01	1.00	1.994E-03	3.603E-01	2.857E-01	0.99	6.43E-03	5.10E-03
	0.68025	0.006448	4.747E+07	0.0200	2.16E-02	1.46E-01	1.00	3.147E-03	4.686E-01	3.714E-01	1.00	1.01E-02	8.01E-03
	0.70658	0.014933	4.747E+07	0.0200	4.99E-02	3.51E-01	1.00	1.753E-02	1.125E+00	8.915E-01	1.01	5.67E-02	4.50E-02
	0.76838	0.004566	4.747E+07	0.0200	1.53E-02	1.17E-01	1.01	1.800E-03	3.726E-01	2.952E-01	1.01	5.75E-03	4.55E-03
	0.82051	0.001537	4.747E+07	0.0200	5.14E-03	4.19E-02	1.01	2.177E-04	1.334E-01	1.057E-01	1.02	7.00E-04	5.54E-04
	0.85628	0.012344	4.747E+07	0.0200	4.13E-02	3.50E-01	1.01	1.459E-02	1.114E+00	8.825E-01	1.02	4.69E-02	3.72E-02
	0.87533	0.044714	4.747E+07	0.0200	1.50E-01	1.29E+00	1.01	1.955E-01	4.118E+00	3.261E+00	1.02	6.28E-01	4.97E-01
	0.90967	0.002124	4.747E+07	0.0200	7.10E-03	6.39E-02	1.01	4.582E-04	2.024E-01	1.603E-01	1.01	1.45E-03	1.15E-03
	1.0523	0.005516	4.747E+07	0.0200	1.84E-02	1.92E-01	1.01	3.572E-03	5.940E-01	4.703E-01	1.01	1.11E-02	8.76E-03
	1.0601	0.001373	4.747E+07	0.0200	4.59E-03	4.80E-02	1.01	2.228E-04	1.487E-01	1.178E-01	1.01	6.90E-04	5.46E-04
	1.2364	0.014933	4.747E+07	0.0200	4.99E-02	6.07E-01	1.02	3.091E-02	1.820E+00	1.441E+00	1.00	9.09E-02	7.19E-02
	1.2982	0.023306	4.747E+07	0.0200	7.79E-02	9.96E-01	1.02	7.919E-02	2.943E+00	2.330E+00	0.99	2.27E-01	1.80E-01
	1.3504	0.001485	4.747E+07	0.0200	4.97E-03	6.62E-02	1.03	3.386E-04	1.929E-01	1.527E-01	0.99	9.48E-04	7.51E-04
I-134	0.53524	0.006072	4.747E+07	0.0200	2.03E-02	9.92E-02	0.99	1.994E-03	3.744E-01	2.967E-01	0.97	7.37E-03	5.84E-03
	0.1354	0.037592	5.183E+07	0.0200	1.37E-01	3.23E-03	1.03	4.568E-04	4.014E-01	3.175E-01	1.02	5.62E-02	4.44E-02
	0.13903	0.006869	5.183E+07	0.0200	2.51E-02	8.09E-04	1.02	2.069E-05	7.565E-02	5.984E-02	1.02	1.93E-03	1.53E-03
	0.15198	0.001059	5.183E+07	0.0200	3.87E-03	3.36E-04	1.00	1.298E-06	1.300E-02	1.028E-02	1.00	5.02E-05	3.98E-05
	0.16248	0.002576	5.183E+07	0.0200	9.40E-03	1.11E-03	1.00	1.042E-05	3.442E-02	2.723E-02	0.98	3.17E-04	2.51E-04



U/B P.2
7/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	0.18847	0.006965	5.183E+07	0.0200	2.54E-02	6.22E-03	1.04	1.644E-04	1.132E-01	8.954E-02	0.97	2.79E-03	2.21E-03
	0.217	0.002481	5.183E+07	0.0200	9.06E-03	3.81E-03	1.06	3.659E-05	4.877E-02	3.859E-02	0.97	4.29E-04	3.39E-04
	0.23547	0.019845	5.183E+07	0.0200	7.25E-02	3.88E-02	1.05	2.949E-03	4.358E-01	3.449E-01	0.97	3.06E-02	2.42E-02
	0.2788	0.001307	5.183E+07	0.0200	4.77E-03	4.30E-03	1.02	2.093E-05	3.588E-02	2.840E-02	0.96	1.64E-04	1.30E-04
	0.31981	0.005152	5.183E+07	0.0200	1.88E-02	2.46E-02	1.00	4.623E-04	1.677E-01	1.327E-01	0.96	3.03E-03	2.40E-03
	0.35108	0.004961	5.183E+07	0.0200	1.81E-02	2.89E-02	1.00	5.231E-04	1.799E-01	1.424E-01	0.95	3.09E-03	2.45E-03
	0.40545	0.073466	5.183E+07	0.0200	2.68E-01	5.77E-01	1.00	1.548E-01	3.092E+00	2.448E+00	0.95	7.88E-01	6.24E-01
	0.411	0.006106	5.183E+07	0.0200	2.23E-02	4.91E-02	1.00	1.094E-03	2.603E-01	2.061E-01	0.95	5.51E-03	4.36E-03
	0.43335	0.041885	5.183E+07	0.0200	1.53E-01	3.68E-01	1.00	5.626E-02	1.873E+00	1.483E+00	0.95	2.72E-01	2.15E-01
	0.45892	0.012976	5.183E+07	0.0200	4.74E-02	1.25E-01	0.99	5.871E-03	6.084E-01	4.817E-01	0.96	2.77E-02	2.19E-02
	0.4655	0.003626	5.183E+07	0.0200	1.32E-02	3.58E-02	0.99	4.691E-04	1.719E-01	1.361E-01	0.96	2.18E-03	1.73E-03
	0.48888	0.014121	5.183E+07	0.0200	5.16E-02	1.51E-01	0.99	7.688E-03	6.936E-01	5.492E-01	0.96	3.43E-02	2.72E-02
	0.5144	0.023375	5.183E+07	0.0200	8.53E-02	3.48E-01	0.99	2.936E-02	1.437E+00	1.138E+00	0.97	1.19E-01	9.42E-02
	0.54083	0.078236	5.183E+07	0.0200	2.86E-01	1.31E+00	0.99	3.691E-01	4.835E+00	3.832E+00	0.97	1.34E+00	1.06E+00
	0.56552	0.008778	5.183E+07	0.0200	3.20E-02	1.59E-01	0.99	5.044E-03	5.524E-01	4.379E-01	0.98	1.73E-02	1.38E-02
	0.57075	0.002099	5.183E+07	0.0200	7.66E-03	3.86E-02	0.99	2.927E-04	1.327E-01	1.052E-01	0.98	9.96E-04	7.90E-04
	0.59536	0.11354	5.183E+07	0.0200	4.15E-01	2.22E+00	0.99	9.130E-01	7.374E+00	5.847E+00	0.99	3.03E+00	2.40E+00
	0.62179	0.10591	5.183E+07	0.0200	3.87E-01	2.19E+00	1.00	8.453E-01	7.111E+00	5.638E+00	0.99	2.72E+00	2.16E+00
	0.62796	0.023662	5.183E+07	0.0200	8.64E-02	4.94E-01	1.00	4.263E-02	1.601E+00	1.269E+00	0.99	1.37E-01	1.09E-01
	0.67734	0.084915	5.183E+07	0.0200	3.10E-01	1.91E+00	1.00	5.935E-01	6.147E+00	4.872E+00	1.00	1.91E+00	1.51E+00
	0.70665	0.008301	5.183E+07	0.0200	3.03E-02	1.95E-01	1.00	5.915E-03	6.256E-01	4.957E-01	1.01	1.91E-02	1.52E-02
	0.73074	0.019082	5.183E+07	0.0200	6.97E-02	4.64E-01	1.01	3.262E-02	1.484E+00	1.176E+00	1.01	1.04E-01	8.27E-02
	0.73918	0.007633	5.183E+07	0.0200	2.79E-02	1.88E-01	1.01	5.281E-03	6.003E-01	4.756E-01	1.01	1.69E-02	1.34E-02
	0.76668	0.041026	5.183E+07	0.0200	1.50E-01	1.05E+00	1.01	1.583E-01	3.341E+00	2.647E+00	1.01	5.05E-01	4.00E-01
	0.81638	0.005248	5.183E+07	0.0200	1.92E-02	1.43E-01	1.01	2.758E-03	4.534E-01	3.591E-01	1.02	8.86E-03	7.02E-03
	0.84702	0.9541	5.183E+07	0.0200	3.48E+00	2.68E+01	1.01	9.424E+01	8.528E+01	6.754E+01	1.02	3.03E+02	2.40E+02
	0.85729	0.069649	5.183E+07	0.0200	2.54E-01	1.98E+00	1.01	5.079E-01	6.295E+00	4.985E+00	1.02	1.63E+00	1.29E+00
	0.864	0.001908	5.183E+07	0.0200	6.97E-03	5.46E-02	1.01	3.840E-04	1.737E-01	1.375E-01	1.02	1.23E-03	9.77E-04
	0.88409	0.6526	5.183E+07	0.0200	2.38E+00	1.91E+01	1.01	4.591E+01	6.064E+01	4.802E+01	1.01	1.46E+02	1.16E+02
	0.9226	0.001431	5.183E+07	0.0200	5.22E-03	4.36E-02	1.01	2.303E-04	1.381E-01	1.093E-01	1.01	7.28E-04	5.77E-04
	0.94786	0.040358	5.183E+07	0.0200	1.47E-01	1.27E+00	1.01	1.883E-01	3.986E+00	3.156E+00	1.01	5.93E-01	4.70E-01
	0.9669	0.00353	5.183E+07	0.0200	1.29E-02	1.13E-01	1.01	1.472E-03	3.546E-01	2.808E-01	1.01	4.62E-03	3.65E-03
	0.97467	0.046751	5.183E+07	0.0200	1.71E-01	1.51E+00	1.01	2.603E-01	4.727E+00	3.743E+00	1.01	8.15E-01	6.45E-01
	1.0403	0.019082	5.183E+07	0.0200	6.97E-02	6.56E-01	1.01	4.618E-02	2.036E+00	1.612E+00	1.01	1.43E-01	1.13E-01



Case #5- 27A,B,E,P Rad Failure
CMS-RE-27A,B,E,P Detector Response

Calc. No.: NE-02-94 rev 1
Prepared By: S. J. Haynes 15/94
page: 5.061

VP 222-1
2/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	1.0726	0.15266	5.183E+07	0.0200	5.57E-01	5.40E+00	1.01	3.040E+00	1.669E+01	1.322E+01	1.01	9.40E+00	7.44E+00
	1.1001	0.006869	5.183E+07	0.0200	2.51E-02	2.49E-01	1.01	6.302E-03	7.661E-01	6.065E-01	1.00	1.92E-02	1.52E-02
	1.1032	0.007251	5.183E+07	0.0200	2.65E-02	2.63E-01	1.01	7.041E-03	8.105E-01	6.417E-01	1.00	2.15E-02	1.70E-02
	1.1362	0.097318	5.183E+07	0.0200	3.55E-01	3.64E+00	1.01	1.305E+00	1.113E+01	8.815E+00	1.00	3.96E+00	3.13E+00
	1.1591	0.00353	5.183E+07	0.0200	1.29E-02	1.34E-01	1.01	1.751E-03	4.099E-01	3.245E-01	1.00	5.28E-03	4.18E-03
	1.164	0.001336	5.183E+07	0.0200	4.88E-03	5.11E-02	1.02	2.543E-04	1.556E-01	1.232E-01	1.00	7.59E-04	6.01E-04
	1.19	0.00353	5.183E+07	0.0200	1.29E-02	1.38E-01	1.02	1.815E-03	4.181E-01	3.310E-01	1.00	5.39E-03	4.27E-03
	1.239	0.002099	5.183E+07	0.0200	7.66E-03	8.55E-02	1.02	6.681E-04	2.561E-01	2.028E-01	1.00	1.96E-03	1.55E-03
	1.2695	0.005629	5.183E+07	0.0200	2.06E-02	2.35E-01	1.02	4.927E-03	6.993E-01	5.536E-01	1.00	1.44E-02	1.14E-02
	1.3224	0.00105	5.183E+07	0.0200	3.83E-03	4.58E-02	1.03	1.807E-04	1.343E-01	1.063E-01	0.99	5.10E-04	4.03E-04
	1.336	0.001431	5.183E+07	0.0200	5.22E-03	6.31E-02	1.03	3.393E-04	1.844E-01	1.460E-01	0.99	9.54E-04	7.55E-04
	1.3526	0.004484	5.183E+07	0.0200	1.64E-02	2.00E-01	1.03	3.376E-03	5.830E-01	4.615E-01	0.99	9.45E-03	7.48E-03
	1.4143	0.002194	5.183E+07	0.0200	8.01E-03	1.03E-01	1.03	8.481E-04	2.943E-01	2.330E-01	0.99	2.33E-03	1.85E-03
	1.4282	0.001717	5.183E+07	0.0200	6.27E-03	8.14E-02	1.03	5.252E-04	2.320E-01	1.837E-01	0.99	1.44E-03	1.14E-03
	1.4314	0.001717	5.183E+07	0.0200	6.27E-03	8.16E-02	1.03	5.265E-04	2.324E-01	1.839E-01	0.99	1.44E-03	1.14E-03
	1.4552	0.022898	5.183E+07	0.0200	8.36E-02	1.11E+00	1.04	9.629E-02	3.134E+00	2.481E+00	0.99	2.59E-01	2.05E-01
	1.47	0.007728	5.183E+07	0.0200	2.82E-02	3.78E-01	1.04	1.108E-02	1.065E+00	8.427E-01	0.99	2.97E-02	2.35E-02
	1.5055	0.001145	5.183E+07	0.0200	4.18E-03	5.75E-02	1.04	2.499E-04	1.605E-01	1.270E-01	0.99	6.64E-04	5.26E-04
	1.5415	0.005057	5.183E+07	0.0200	1.85E-02	2.59E-01	1.04	4.972E-03	7.200E-01	5.700E-01	0.98	1.30E-02	1.03E-02
	1.6138	0.043602	5.183E+07	0.0200	1.59E-01	2.32E+00	1.05	3.882E-01	6.402E+00	5.068E+00	0.98	9.99E-01	7.91E-01
	1.6292	0.002576	5.183E+07	0.0200	9.40E-03	1.38E-01	1.05	1.367E-03	3.807E-01	3.014E-01	0.98	3.51E-03	2.78E-03
	1.6443	0.004007	5.183E+07	0.0200	1.46E-02	2.17E-01	1.06	3.364E-03	5.957E-01	4.716E-01	0.98	8.54E-03	6.76E-03
	1.6552	0.00229	5.183E+07	0.0200	8.36E-03	1.25E-01	1.06	1.105E-03	3.420E-01	2.708E-01	0.98	2.80E-03	2.22E-03
	1.7415	0.026715	5.183E+07	0.0200	9.75E-02	1.52E+00	1.07	1.588E-01	4.126E+00	3.267E+00	0.98	3.94E-01	3.12E-01
	1.8068	0.057246	5.183E+07	0.0200	2.09E-01	3.37E+00	1.08	7.603E-01	9.060E+00	7.172E+00	0.98	1.86E+00	1.47E+00
	1.9259	0.001813	5.183E+07	0.0200	6.62E-03	1.13E-01	1.09	8.153E-04	2.992E-01	2.369E-01	0.97	1.92E-03	1.52E-03
	2.0206	0.001717	5.183E+07	0.0200	6.27E-03	1.12E-01	1.10	7.697E-04	2.924E-01	2.315E-01	0.97	1.78E-03	1.41E-03
	2.1599	0.002099	5.183E+07	0.0200	7.66E-03	1.43E-01	1.12	1.227E-03	3.729E-01	2.953E-01	0.96	2.74E-03	2.17E-03
	2.3124	0.002385	5.183E+07	0.0200	8.71E-03	1.71E-01	1.14	1.694E-03	4.428E-01	3.505E-01	0.96	3.70E-03	2.93E-03
	2.4674	0.001527	5.183E+07	0.0200	5.57E-03	1.15E-01	1.16	7.405E-04	2.954E-01	2.339E-01	0.95	1.56E-03	1.24E-03
	1.7872	0.013348	5.183E+07	0.0200	4.87E-02	7.78E-01	1.07	4.055E-02	2.097E+00	1.660E+00	0.98	1.00E-01	7.93E-02
I-135	0.2205	0.017452	4.470E+07	0.0200	5.49E-02	2.81E-02	1.06	1.636E-03	3.506E-01	2.775E-01	0.97	1.87E-02	1.48E-02
	0.22972	0.002317	4.470E+07	0.0200	7.30E-03	4.20E-03	1.05	3.221E-05	4.921E-02	3.894E-02	0.97	3.48E-04	2.76E-04
	0.26426	0.00184	4.470E+07	0.0200	5.79E-03	5.11E-03	1.03	3.051E-05	4.711E-02	3.728E-02	0.97	2.65E-04	2.10E-04



Case #5- 2nd Glad Failure
CMS-RE-27A,B,E, Detector Response

Calc. No.: NE-02-94-7 rev 1
Prepared By: S. J. Haynes 5/94
page: 5.062

*u/B 228.4
9/16/94*

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont.	27A&B	27A&B	27A&B Response (Rad/hr)	27E	27F	27E&F	27E Response (Rad/hr)	27F Response (Rad/hr)
					Conc.	QAD Det.	Eff.		QAD Det.	QAD Det.	Eff.		
					(uCi/cc)	Response (Rad/hr)			Response (Rad/hr)	Response (Rad/hr)			
	0.28845	0.030899	4.470E+07	0.0200	9.73E-02	1.13E-01	1.02	1.125E-02	8.857E-01	7.010E-01	0.96	8.27E-02	6.55E-02
	0.29027	0.003033	4.470E+07	0.0200	9.55E-03	1.14E-02	1.01	1.095E-04	8.763E-02	6.936E-02	0.96	8.03E-04	6.36E-04
	0.36185	0.00186	4.470E+07	0.0200	5.86E-03	1.15E-02	1.00	6.761E-05	6.969E-02	5.517E-02	0.95	3.88E-04	3.07E-04
	0.40303	0.002317	4.470E+07	0.0200	7.30E-03	1.80E-02	1.00	1.315E-04	9.697E-02	7.676E-02	0.95	6.72E-04	5.32E-04
	0.41483	0.003004	4.470E+07	0.0200	9.46E-03	2.45E-02	1.00	2.321E-04	1.292E-01	1.023E-01	0.95	1.16E-03	9.19E-04
	0.41763	0.03519	4.470E+07	0.0200	1.11E-01	2.91E-01	1.00	3.220E-02	1.523E+00	1.205E+00	0.95	1.60E-01	1.27E-01
	0.42993	0.003033	4.470E+07	0.0200	9.55E-03	2.63E-02	1.00	2.511E-04	1.347E-01	1.066E-01	0.95	1.22E-03	9.67E-04
	0.43374	0.005522	4.470E+07	0.0200	1.74E-02	4.86E-02	1.00	8.446E-04	2.471E-01	1.956E-01	0.95	4.08E-03	3.23E-03
	0.45163	0.003147	4.470E+07	0.0200	9.91E-03	2.96E-02	1.00	2.931E-04	1.457E-01	1.153E-01	0.95	1.37E-03	1.09E-03
	0.54656	0.071239	4.470E+07	0.0200	2.24E-01	1.21E+00	0.99	2.696E-01	4.418E+00	3.502E+00	0.97	9.61E-01	7.62E-01
	0.57597	0.001288	4.470E+07	0.0200	4.06E-03	2.40E-02	0.99	9.644E-05	8.185E-02	6.489E-02	0.98	3.25E-04	2.58E-04
	0.64985	0.004549	4.470E+07	0.0200	1.43E-02	9.84E-02	1.00	1.409E-03	3.171E-01	2.514E-01	1.00	4.54E-03	3.60E-03
	0.69013	0.001288	4.470E+07	0.0200	4.06E-03	2.96E-02	1.00	1.199E-04	9.486E-02	7.518E-02	1.00	3.85E-04	3.05E-04
	0.70792	0.00658	4.470E+07	0.0200	2.07E-02	1.55E-01	1.00	3.210E-03	4.965E-01	3.935E-01	1.01	1.04E-02	8.23E-03
	0.78548	0.001516	4.470E+07	0.0200	4.77E-03	3.97E-02	1.01	1.913E-04	1.263E-01	1.001E-01	1.01	6.09E-04	4.82E-04
	0.79771	0.001717	4.470E+07	0.0200	5.41E-03	4.57E-02	1.01	2.495E-04	1.452E-01	1.150E-01	1.01	7.93E-04	6.28E-04
	0.8368	0.066661	4.470E+07	0.0200	2.10E-01	1.85E+00	1.01	3.924E-01	5.893E+00	4.667E+00	1.02	1.26E+00	9.99E-01
	0.96146	0.001459	4.470E+07	0.0200	4.59E-03	4.64E-02	1.01	2.155E-04	1.458E-01	1.155E-01	1.01	6.77E-04	5.36E-04
	0.97196	0.008869	4.470E+07	0.0200	2.79E-02	2.86E-01	1.01	8.056E-03	8.948E-01	7.085E-01	1.01	2.52E-02	2.00E-02
	0.97261	0.012016	4.470E+07	0.0200	3.78E-02	3.87E-01	1.01	1.480E-02	1.213E+00	9.606E-01	1.01	4.64E-02	3.67E-02
	0.99509	0.001545	4.470E+07	0.0200	4.86E-03	5.10E-02	1.01	2.507E-04	1.589E-01	1.259E-01	1.01	7.81E-04	6.18E-04
	1.0388	0.07925	4.470E+07	0.0200	2.50E-01	2.72E+00	1.01	6.864E-01	8.448E+00	6.689E+00	1.01	2.13E+00	1.69E+00
	1.1016	0.016022	4.470E+07	0.0200	5.04E-02	5.81E-01	1.01	2.961E-02	1.789E+00	1.416E+00	1.00	9.02E-02	7.14E-02
	1.124	0.036049	4.470E+07	0.0200	1.14E-01	1.33E+00	1.01	1.528E-01	4.089E+00	3.237E+00	1.00	4.64E-01	3.67E-01
	1.1315	0.22516	4.470E+07	0.0200	7.09E-01	8.38E+00	1.01	5.999E+00	2.567E+01	2.032E+01	1.00	1.82E+01	1.44E+01
	1.1599	0.00103	4.470E+07	0.0200	3.24E-03	3.93E-02	1.02	1.299E-04	1.197E-01	9.474E-02	1.00	3.88E-04	3.07E-04
	1.169	0.008726	4.470E+07	0.0200	2.75E-02	3.35E-01	1.02	9.394E-03	1.020E+00	8.074E-01	1.00	2.80E-02	2.22E-02
	1.2405	0.009012	4.470E+07	0.0200	2.84E-02	3.68E-01	1.02	1.064E-02	1.101E+00	8.715E-01	1.00	3.12E-02	2.47E-02
	1.2604	0.2861	4.470E+07	0.0200	9.01E-01	1.19E+01	1.02	1.090E+01	3.536E+01	2.799E+01	1.00	3.19E+01	2.52E+01
	1.3679	0.006065	4.470E+07	0.0200	1.91E-02	2.74E-01	1.03	5.392E-03	7.949E-01	6.293E-01	0.99	1.50E-02	1.19E-02
	1.4484	0.003147	4.470E+07	0.0200	9.91E-03	1.51E-01	1.04	1.560E-03	4.293E-01	3.398E-01	0.99	4.21E-03	3.33E-03
	1.4576	0.086402	4.470E+07	0.0200	2.72E-01	4.19E+00	1.04	1.185E+00	1.184E+01	9.375E+00	0.99	3.19E+00	2.52E+00
	1.5028	0.010729	4.470E+07	0.0200	3.38E-02	5.38E-01	1.04	1.889E-02	1.502E+00	1.189E+00	0.99	5.02E-02	3.98E-02
	1.5664	0.012875	4.470E+07	0.0200	4.05E-02	6.69E-01	1.05	2.846E-02	1.853E+00	1.467E+00	0.98	7.36E-02	5.83E-02



*4/10 2025
7/16/14*

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	1.678	0.095271	4.470E+07	0.0200	3.00E-01	5.25E+00	1.06	1.669E+00	1.436E+01	1.136E+01	0.98	4.22E+00	3.34E+00
	1.7065	0.040912	4.470E+07	0.0200	1.29E-01	2.29E+00	1.06	3.125E-01	6.235E+00	4.936E+00	0.98	7.87E-01	6.23E-01
	1.7912	0.076961	4.470E+07	0.0200	2.42E-01	4.49E+00	1.07	1.165E+00	1.211E+01	9.585E+00	0.98	2.88E+00	2.28E+00
	1.8307	0.005779	4.470E+07	0.0200	1.82E-02	3.44E-01	1.08	6.762E-03	9.225E-01	7.303E-01	0.98	1.64E-02	1.30E-02
	1.9273	0.002947	4.470E+07	0.0200	9.28E-03	1.84E-01	1.09	1.859E-03	4.866E-01	3.852E-01	0.97	4.38E-03	3.47E-03
	2.0459	0.008697	4.470E+07	0.0200	2.74E-02	5.70E-01	1.11	1.733E-02	1.492E+00	1.181E+00	0.97	3.96E-02	3.14E-02
	2.2555	0.006123	4.470E+07	0.0200	1.93E-02	4.30E-01	1.13	9.374E-03	1.119E+00	8.856E-01	0.96	2.07E-02	1.64E-02
	2.4087	0.009527	4.470E+07	0.0200	3.00E-02	7.02E-01	1.15	2.421E-02	1.815E+00	1.437E+00	0.95	5.17E-02	4.09E-02
	1.0734	0.014948	4.470E+07	0.0200	4.71E-02	5.29E-01	1.01	2.516E-02	1.636E+00	1.295E+00	1.01	7.77E-02	6.16E-02
Kr-85	0.51399	0.00434	8.915E+05	0.0300	4.09E-04	6.44E-02	0.99	2.606E-05	2.668E-01	2.113E-01	0.97	1.06E-04	8.38E-05
Kr-85m	0.30487	0.13989	1.976E+07	0.0300	2.92E-01	6.03E-01	1.01	1.777E-01	4.296E+00	3.400E+00	0.96	1.20E+00	9.53E-01
	0.00169	0.000586	1.976E+07	0.0300	1.22E-03	0.00E+00	0	0.000E+00	9.001E+10	7.101E+10	0	0.00E+00	0.00E+00
	0.013336	0.006116	1.976E+07	0.0300	1.28E-02	0.00E+00	0	0.000E+00	2.476E+00	1.954E+00	0	0.00E+00	0.00E+00
	0.013395	0.01183	1.976E+07	0.0300	2.47E-02	0.00E+00	0	0.000E+00	4.664E+00	3.681E+00	0	0.00E+00	0.00E+00
	0.015	0.003105	1.976E+07	0.0300	6.48E-03	0.00E+00	0	0.000E+00	6.416E-01	5.064E-01	0	0.00E+00	0.00E+00
	0.12985	0.003011	1.976E+07	0.0300	6.29E-03	1.59E-04	1.05	1.051E-06	3.065E-02	2.424E-02	1.02	1.97E-04	1.55E-04
	0.15118	0.75278	1.976E+07	0.0300	1.57E+00	2.33E-01	1.00	3.665E-01	9.181E+00	7.263E+00	1.00	1.44E+01	1.14E+01
	0.58128	0.000211	1.976E+07	0.0300	4.41E-04	3.99E-03	0.99	1.741E-06	1.348E-02	1.069E-02	0.98	5.82E-06	4.62E-06
Kr-87	0.40258	0.495	3.671E+07	0.0300	1.92E+00	3.84E+00	1.00	7.377E+00	2.069E+01	1.638E+01	0.95	3.77E+01	2.99E+01
	0.67387	0.019058	3.671E+07	0.0300	7.39E-02	4.27E-01	1.00	3.159E-02	1.373E+00	1.088E+00	1.00	1.01E-01	8.04E-02
	0.81425	0.001683	3.671E+07	0.0300	6.53E-03	4.56E-02	1.01	3.006E-04	1.450E-01	1.149E-01	1.02	9.66E-04	7.65E-04
	0.83637	0.007524	3.671E+07	0.0300	2.92E-02	2.09E-01	1.01	6.156E-03	6.648E-01	5.266E-01	1.02	1.98E-02	1.57E-02
	0.84543	0.072765	3.671E+07	0.0300	2.82E-01	2.04E+00	1.01	5.814E-01	6.493E+00	5.143E+00	1.02	1.87E+00	1.48E+00
	0.94664	0.001386	3.671E+07	0.0300	5.38E-03	4.34E-02	1.01	2.356E-04	1.367E-01	1.082E-01	1.01	7.42E-04	5.88E-04
	1.1754	0.011237	3.671E+07	0.0300	4.36E-02	4.34E-01	1.02	1.929E-02	1.319E+00	1.044E+00	1.00	5.75E-02	4.55E-02
	1.338	0.006484	3.671E+07	0.0300	2.51E-02	2.86E-01	1.03	7.413E-03	8.366E-01	6.623E-01	0.99	2.08E-02	1.65E-02
	1.3825	0.002871	3.671E+07	0.0300	1.11E-02	1.31E-01	1.03	1.505E-03	3.791E-01	3.001E-01	0.99	4.18E-03	3.31E-03
	1.3899	0.001237	3.671E+07	0.0300	4.80E-03	5.69E-02	1.03	2.812E-04	1.640E-01	1.298E-01	0.99	7.79E-04	6.17E-04
	1.5312	0.003564	3.671E+07	0.0300	1.38E-02	1.81E-01	1.04	2.609E-03	5.051E-01	3.999E-01	0.98	6.84E-03	5.42E-03
	1.578	0.001287	3.671E+07	0.0300	4.99E-03	6.72E-02	1.05	3.525E-04	1.862E-01	1.474E-01	0.98	9.11E-04	7.21E-04
	1.6112	0.00104	3.671E+07	0.0300	4.03E-03	5.53E-02	1.05	2.343E-04	1.525E-01	1.208E-01	0.98	6.03E-04	4.77E-04
	1.7405	0.020493	3.671E+07	0.0300	7.95E-02	1.17E+00	1.07	9.922E-02	3.165E+00	2.506E+00	0.98	2.47E-01	1.95E-01
	1.8426	0.001386	3.671E+07	0.0300	5.38E-03	8.30E-02	1.08	4.818E-04	2.222E-01	1.759E-01	0.97	1.16E-03	9.17E-04
	2.0119	0.028957	3.671E+07	0.0300	1.12E-01	1.88E+00	1.10	2.318E-01	4.916E+00	3.892E+00	0.97	5.36E-01	4.24E-01



u/B 278
9/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont.	27A&B	27A&B	27A&B Response (Rad/hr)	27E	27F	27E&F	27E Response (Rad/hr)	27F Response (Rad/hr)
					Conc.	QAD Det.	Eff.		QAD Det.	Eff.			
					(uCi/cc)	Response (Rad/hr)			Response (Rad/hr)	Response (Rad/hr)			
	2.4085	0.002129	3.671E+07	0.0300	8.26E-03	1.57E-01	1.15	1.490E-03	4.056E-01	3.211E-01	0.95	3.18E-03	2.52E-03
	2.5548	0.09306	3.671E+07	0.0300	3.61E-01	7.16E+00	1.17	3.024E+00	1.841E+01	1.458E+01	0.94	6.25E+00	4.95E+00
	2.5581	0.039105	3.671E+07	0.0300	1.52E-01	3.01E+00	1.17	5.345E-01	7.743E+00	6.129E+00	0.94	1.10E+00	8.74E-01
	2.8114	0.003168	3.671E+07	0.0300	1.23E-02	2.62E-01	1.19	3.831E-03	6.662E-01	5.274E-01	0.92	7.53E-03	5.96E-03
	3.3085	0.004504	3.671E+07	0.0300	1.75E-02	4.15E-01	1.20	8.707E-03	1.050E+00	8.310E-01	0.85	1.56E-02	1.23E-02
	1.6201	0.006499	3.671E+07	0.0300	2.52E-02	3.47E-01	1.05	9.194E-03	9.567E-01	7.574E-01	0.98	2.36E-02	1.87E-02
Kr-88	0.12227	0.001972	5.139E+07	0.0300	1.07E-02	5.33E-05	1.08	6.158E-07	1.879E-02	1.486E-02	1.01	2.03E-04	1.61E-04
	0.16598	0.031036	5.139E+07	0.0300	1.69E-01	1.48E-02	1.01	2.513E-03	4.263E-01	3.373E-01	0.98	7.04E-02	5.57E-02
	0.19632	0.25985	5.139E+07	0.0300	1.41E+00	2.87E-01	1.05	4.253E-01	4.460E+00	3.529E+00	0.97	6.10E+00	4.83E+00
	0.24071	0.002526	5.139E+07	0.0300	1.37E-02	5.27E-03	1.05	7.590E-05	5.712E-02	4.521E-02	0.97	7.60E-04	6.01E-04
	0.31169	0.001073	5.139E+07	0.0300	5.83E-03	4.85E-03	1.01	2.852E-05	3.386E-02	2.680E-02	0.96	1.89E-04	1.50E-04
	0.33471	0.001453	5.139E+07	0.0300	7.89E-03	7.64E-03	1.00	6.026E-05	4.989E-02	3.949E-02	0.95	3.74E-04	2.96E-04
	0.36223	0.02249	5.139E+07	0.0300	1.22E-01	1.40E-01	1.00	1.709E-02	8.439E-01	6.680E-01	0.95	9.79E-02	7.75E-02
	0.39054	0.006436	5.139E+07	0.0300	3.49E-02	4.70E-02	1.00	1.642E-03	2.612E-01	2.067E-01	0.95	8.67E-03	6.86E-03
	0.4217	0.00128	5.139E+07	0.0300	6.95E-03	1.07E-02	1.00	7.469E-05	5.589E-02	4.424E-02	0.95	3.69E-04	2.92E-04
	0.4718	0.007266	5.139E+07	0.0300	3.95E-02	7.33E-02	0.99	2.862E-03	3.479E-01	2.755E-01	0.96	1.32E-02	1.04E-02
	0.67734	0.002353	5.139E+07	0.0300	1.28E-02	5.30E-02	1.00	6.775E-04	1.703E-01	1.350E-01	1.00	2.18E-03	1.72E-03
	0.78828	0.005328	5.139E+07	0.0300	2.89E-02	1.40E-01	1.01	4.090E-03	4.455E-01	3.529E-01	1.01	1.30E-02	1.03E-02
	0.79032	0.001246	5.139E+07	0.0300	6.77E-03	3.28E-02	1.01	2.243E-04	1.045E-01	8.275E-02	1.01	7.14E-04	5.65E-04
	0.83483	0.12975	5.139E+07	0.0300	7.05E-01	3.60E+00	1.01	2.559E+00	1.145E+01	9.066E+00	1.02	8.23E+00	6.51E+00
	0.85034	0.00173	5.139E+07	0.0300	9.39E-03	4.88E-02	1.01	4.626E-04	1.552E-01	1.229E-01	1.02	1.49E-03	1.18E-03
	0.86233	0.006712	5.139E+07	0.0300	3.64E-02	1.92E-01	1.01	7.054E-03	6.098E-01	4.830E-01	1.02	2.27E-02	1.80E-02
	0.94492	0.002941	5.139E+07	0.0300	1.60E-02	9.19E-02	1.01	1.483E-03	2.897E-01	2.294E-01	1.01	4.67E-03	3.70E-03
	0.98578	0.013148	5.139E+07	0.0300	7.14E-02	4.30E-01	1.01	3.100E-02	1.342E+00	1.063E+00	1.01	9.68E-02	7.66E-02
	0.99009	0.001419	5.139E+07	0.0300	7.70E-03	4.66E-02	1.01	3.628E-04	1.454E-01	1.151E-01	1.01	1.13E-03	8.96E-04
	1.0396	0.004844	5.139E+07	0.0300	2.63E-02	1.67E-01	1.01	4.424E-03	5.165E-01	4.090E-01	1.01	1.37E-02	1.09E-02
	1.0495	0.001419	5.139E+07	0.0300	7.70E-03	4.92E-02	1.01	3.829E-04	1.525E-01	1.207E-01	1.01	1.19E-03	9.39E-04
	1.1413	0.012837	5.139E+07	0.0300	6.97E-02	4.82E-01	1.01	3.392E-02	1.474E+00	1.167E+00	1.00	1.03E-01	8.13E-02
	1.1795	0.009965	5.139E+07	0.0300	5.41E-02	3.86E-01	1.02	2.131E-02	1.172E+00	9.279E-01	1.00	6.34E-02	5.02E-02
	1.185	0.006885	5.139E+07	0.0300	3.74E-02	2.68E-01	1.02	1.022E-02	8.129E-01	6.436E-01	1.00	3.04E-02	2.41E-02
	1.2098	0.001419	5.139E+07	0.0300	7.70E-03	5.64E-02	1.02	4.433E-04	1.701E-01	1.347E-01	1.00	1.31E-03	1.04E-03
	1.2127	0.001384	5.139E+07	0.0300	7.51E-03	5.52E-02	1.02	4.228E-04	1.663E-01	1.316E-01	1.00	1.25E-03	9.89E-04
	1.2452	0.003633	5.139E+07	0.0300	1.97E-02	1.49E-01	1.02	2.992E-03	4.450E-01	3.523E-01	1.00	8.78E-03	6.95E-03
	1.2507	0.01121	5.139E+07	0.0300	6.09E-02	4.61E-01	1.02	2.863E-02	1.378E+00	1.091E+00	1.00	8.39E-02	6.64E-02

Case #5- 2% Rad Failure
CMS-RE-27A,B,E, F Detector Response

Calc. No.: NE-02-94-27 rev 1
Prepared By: S. J. Haynes 5/6/94
page: 5.065

4/13 928
9/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	1.325	0.001592	5.139E+07	0.0300	8.64E-03	6.95E-02	1.03	6.192E-04	2.040E-01	1.615E-01	0.99	1.75E-03	1.38E-03
	1.3523	0.001592	5.139E+07	0.0300	8.64E-03	7.11E-02	1.03	6.329E-04	2.070E-01	1.639E-01	0.99	1.77E-03	1.40E-03
	1.3695	0.014774	5.139E+07	0.0300	8.02E-02	6.69E-01	1.03	5.525E-02	1.938E+00	1.535E+00	0.99	1.54E-01	1.22E-01
	1.4069	0.00218	5.139E+07	0.0300	1.18E-02	1.02E-01	1.03	1.238E-03	2.914E-01	2.307E-01	0.99	3.42E-03	2.70E-03
	1.4648	0.001142	5.139E+07	0.0300	6.20E-03	5.56E-02	1.04	3.587E-04	1.570E-01	1.243E-01	0.99	9.63E-04	7.63E-04
	1.5184	0.021521	5.139E+07	0.0300	1.17E-01	1.09E+00	1.04	1.322E-01	3.033E+00	2.401E+00	0.98	3.47E-01	2.75E-01
	1.5298	0.10934	5.139E+07	0.0300	5.94E-01	5.56E+00	1.04	3.435E+00	1.549E+01	1.226E+01	0.98	9.01E+00	7.13E+00
	1.6038	0.004567	5.139E+07	0.0300	2.48E-02	2.42E-01	1.05	6.301E-03	6.678E-01	5.287E-01	0.98	1.62E-02	1.28E-02
	1.6856	0.006643	5.139E+07	0.0300	3.61E-02	7.37E-01	1.06	2.819E-02	1.004E+00	7.950E-01	0.98	3.55E-02	2.81E-02
	1.8928	0.001384	5.139E+07	0.0300	7.51E-03	1.66E-01	1.09	1.358E-03	2.259E-01	1.788E-01	0.97	1.65E-03	1.30E-03
	1.9087	0.001003	5.139E+07	0.0300	5.45E-03	1.21E-01	1.09	7.172E-04	1.645E-01	1.303E-01	0.97	8.69E-04	6.88E-04
	2.0298	0.045291	5.139E+07	0.0300	2.46E-01	5.68E+00	1.10	1.536E+00	7.733E+00	6.122E+00	0.97	1.84E+00	1.46E+00
	2.0354	0.037368	5.139E+07	0.0300	2.03E-01	4.69E+00	1.10	1.048E+00	6.392E+00	5.060E+00	0.97	1.26E+00	9.96E-01
	2.1865	0.002872	5.139E+07	0.0300	1.56E-02	3.78E-01	1.12	6.596E-03	5.144E-01	4.072E-01	0.96	7.70E-03	6.10E-03
	2.1958	0.13183	5.139E+07	0.0300	7.16E-01	1.74E+01	1.13	1.407E+01	2.368E+01	1.875E+01	0.96	1.63E+01	1.29E+01
	2.2318	0.033908	5.139E+07	0.0300	1.84E-01	4.52E+00	1.13	9.401E-01	6.154E+00	4.872E+00	0.96	1.09E+00	8.61E-01
	2.3521	0.007301	5.139E+07	0.0300	3.96E-02	1.01E+00	1.14	4.547E-02	1.370E+00	1.085E+00	0.96	5.21E-02	4.13E-02
	2.3921	0.346	5.139E+07	0.0300	1.88E+00	4.82E+01	1.15	1.041E+02	6.565E+01	5.197E+01	0.95	1.17E+02	9.27E+01
	2.4089	0.001038	5.139E+07	0.0300	5.64E-03	1.45E-01	1.15	9.418E-04	1.979E-01	1.567E-01	0.95	1.06E-03	8.39E-04
	2.5484	0.006228	5.139E+07	0.0300	3.38E-02	9.03E-01	1.17	3.574E-02	1.230E+00	9.739E-01	0.94	3.91E-02	3.10E-02
	2.771	0.001488	5.139E+07	0.0300	8.08E-03	2.28E-01	1.19	2.189E-03	3.101E-01	2.455E-01	0.93	2.33E-03	1.84E-03
	1.0001	0.018892	5.139E+07	0.0300	1.03E-01	1.43E+00	1.01	1.485E-01	1.952E+00	1.545E+00	1.01	2.02E-01	1.60E-01
Kr-89	0.1962	0.0022	6.082E+07	0.0300	1.41E-02	2.42E-03	1.05	3.597E-05	3.774E-02	2.986E-02	0.97	5.18E-04	4.10E-04
	0.1975	0.0182	6.082E+07	0.0300	1.17E-01	2.08E-02	1.05	2.549E-03	3.149E-01	2.492E-01	0.97	3.57E-02	2.83E-02
	0.20503	0.00124	6.082E+07	0.0300	7.97E-03	1.62E-03	1.05	1.356E-05	2.258E-02	1.787E-02	0.98	1.76E-04	1.40E-04
	0.2209	0.2	6.082E+07	0.0300	1.29E+00	3.24E-01	1.06	4.407E-01	4.028E+00	3.187E+00	0.97	5.02E+00	3.97E+00
	0.26411	0.0066	6.082E+07	0.0300	4.24E-02	1.83E-02	1.03	7.997E-04	1.688E-01	1.336E-01	0.97	6.95E-03	5.50E-03
	0.3382	0.00342	6.082E+07	0.0300	2.20E-02	1.84E-02	1.00	4.041E-04	1.189E-01	9.409E-02	0.95	2.48E-03	1.96E-03
	0.34503	0.0118	6.082E+07	0.0300	7.58E-02	6.62E-02	1.00	5.019E-03	4.195E-01	3.321E-01	0.95	3.02E-02	2.39E-02
	0.35606	0.0414	6.082E+07	0.0300	2.66E-01	2.48E-01	1.00	6.607E-02	1.524E+00	1.207E+00	0.95	3.85E-01	3.05E-01
	0.36488	0.009	6.082E+07	0.0300	5.78E-02	5.69E-02	1.00	3.288E-03	3.402E-01	2.693E-01	0.95	1.87E-02	1.48E-02
	0.3693	0.0138	6.082E+07	0.0300	8.87E-02	8.94E-02	1.00	7.932E-03	5.285E-01	4.184E-01	0.95	4.45E-02	3.52E-02
	0.40225	0.00318	6.082E+07	0.0300	2.04E-02	2.46E-02	1.00	5.037E-04	1.328E-01	1.052E-01	0.95	2.58E-03	2.04E-03
	0.41142	0.0256	6.082E+07	0.0300	1.65E-01	2.06E-01	1.00	3.391E-02	1.092E+00	8.648E-01	0.95	1.71E-01	1.35E-01

1. The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that proper record-keeping is essential for the integrity of the financial system and for the ability to detect and prevent fraud.

2. The second part of the document outlines the specific procedures for recording transactions. It details the steps involved in the accounting cycle, from identifying the transaction to posting it to the appropriate ledger account.

3. The third part of the document discusses the role of internal controls in ensuring the accuracy of financial records. It describes various control measures, such as segregation of duties and independent verification, that are designed to minimize the risk of errors and fraud.

4. The fourth part of the document addresses the importance of regular audits in the financial reporting process. It explains how audits provide an independent assessment of the reliability of the financial statements and help to identify areas for improvement.

5. The fifth part of the document discusses the impact of technology on financial reporting. It highlights the benefits of using accounting software and other digital tools to streamline the reporting process and improve the accuracy of the data.

6. The sixth part of the document discusses the importance of transparency and disclosure in financial reporting. It emphasizes that providing clear and concise information to stakeholders is essential for building trust and ensuring the long-term success of the organization.

7. The seventh part of the document discusses the role of the accounting profession in maintaining the integrity of the financial system. It highlights the importance of adhering to professional standards and ethics, and of continuing education to stay current in the field.

8. The eighth part of the document discusses the impact of global economic trends on financial reporting. It highlights the challenges posed by international trade and investment, and the need for harmonized accounting standards across different countries.

9. The ninth part of the document discusses the importance of risk management in financial reporting. It emphasizes that identifying and managing financial risks is essential for ensuring the stability and resilience of the organization.

10. The tenth part of the document discusses the future of financial reporting. It highlights the potential of emerging technologies, such as artificial intelligence and blockchain, to revolutionize the way financial data is collected, processed, and reported.

Case #5- 2% Rad Failure
CMS-RE-27A,B,E,F Detector Response

Calc. No.: NE-02-94- Rev 1
Prepared By: S. J. Haynes 7/5/94
page: 5.066

4/18/94
9/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	0.43808	0.0096	6.082E+07	0.0300	6.17E-02	8.59E-02	1.00	5.296E-03	4.333E-01	3.430E-01	0.95	2.54E-02	2.01E-02
	0.46613	0.008	6.082E+07	0.0300	5.14E-02	7.92E-02	0.99	4.029E-03	3.797E-01	3.007E-01	0.96	1.87E-02	1.48E-02
	0.49076	0.00322	6.082E+07	0.0300	2.07E-02	3.46E-02	0.99	7.079E-04	1.586E-01	1.256E-01	0.96	3.15E-03	2.49E-03
	0.4975	0.0664	6.082E+07	0.0300	4.27E-01	7.28E-01	0.99	3.075E-01	3.300E+00	2.613E+00	0.96	1.35E+00	1.07E+00
	0.4986	0.0114	6.082E+07	0.0300	7.33E-02	1.25E-01	0.99	9.095E-03	5.675E-01	4.493E-01	0.96	3.99E-02	3.16E-02
	0.5573	0.0016	6.082E+07	0.0300	1.03E-02	2.83E-02	0.99	2.876E-04	9.996E-02	7.925E-02	0.98	1.01E-03	7.98E-04
	0.57696	0.0564	6.082E+07	0.0300	3.62E-01	1.05E+00	0.99	3.785E-01	3.588E+00	2.845E+00	0.98	1.27E+00	1.01E+00
	0.5858	0.166	6.082E+07	0.0300	1.07E+00	3.18E+00	0.99	3.355E+00	1.066E+01	8.454E+00	0.98	1.11E+01	8.84E+00
	0.6262	0.006	6.082E+07	0.0300	3.86E-02	1.25E-01	1.00	4.810E-03	4.051E-01	3.211E-01	0.99	1.55E-02	1.23E-02
	0.62975	0.00342	6.082E+07	0.0300	2.20E-02	7.16E-02	1.00	1.573E-03	2.320E-01	1.839E-01	0.99	5.05E-03	4.00E-03
	0.66572	0.00114	6.082E+07	0.0300	7.33E-03	2.53E-02	1.00	1.850E-04	8.122E-02	6.438E-02	1.00	5.95E-04	4.72E-04
	0.6714	0.00106	6.082E+07	0.0300	6.81E-03	2.37E-02	1.00	1.614E-04	7.612E-02	6.034E-02	1.00	5.18E-04	4.11E-04
	0.67411	0.00232	6.082E+07	0.0300	1.49E-02	5.21E-02	1.00	7.760E-04	1.672E-01	1.325E-01	1.00	2.49E-03	1.98E-03
	0.69624	0.0178	6.082E+07	0.0300	1.14E-01	4.12E-01	1.00	4.716E-02	1.322E+00	1.048E+00	1.01	1.53E-01	1.21E-01
	0.70701	0.00498	6.082E+07	0.0300	3.20E-02	1.17E-01	1.00	3.748E-03	3.753E-01	2.975E-01	1.01	1.21E-02	9.61E-03
	0.71005	0.0078	6.082E+07	0.0300	5.01E-02	1.84E-01	1.00	9.232E-03	5.902E-01	4.677E-01	1.01	2.99E-02	2.37E-02
	0.72963	0.00296	6.082E+07	0.0300	1.90E-02	7.18E-02	1.01	1.380E-03	2.299E-01	1.822E-01	1.01	4.42E-03	3.50E-03
	0.73839	0.042	6.082E+07	0.0300	2.70E-01	1.03E+00	1.01	2.812E-01	3.300E+00	2.615E+00	1.01	8.99E-01	7.13E-01
	0.7474	0.00114	6.082E+07	0.0300	7.33E-03	2.83E-02	1.01	2.097E-04	9.061E-02	7.179E-02	1.01	6.70E-04	5.31E-04
	0.7629	0.004	6.082E+07	0.0300	2.57E-02	1.02E-01	1.01	2.636E-03	3.242E-01	2.568E-01	1.01	8.42E-03	6.67E-03
	0.7629	0.0092	6.082E+07	0.0300	5.91E-02	2.34E-01	1.01	1.395E-02	7.457E-01	5.908E-01	1.01	4.45E-02	3.53E-02
	0.77649	0.0112	6.082E+07	0.0300	7.20E-02	2.90E-01	1.01	2.104E-02	9.229E-01	7.312E-01	1.01	6.71E-02	5.31E-02
	0.82675	0.0076	6.082E+07	0.0300	4.88E-02	2.09E-01	1.01	1.030E-02	6.647E-01	5.265E-01	1.02	3.31E-02	2.62E-02
	0.83553	0.011	6.082E+07	0.0300	7.07E-02	3.05E-01	1.01	2.178E-02	9.712E-01	7.692E-01	1.02	7.00E-02	5.55E-02
	0.85737	0.00286	6.082E+07	0.0300	1.84E-02	8.12E-02	1.01	1.507E-03	2.585E-01	2.047E-01	1.02	4.85E-03	3.84E-03
	0.86708	0.0592	6.082E+07	0.0300	3.80E-01	1.70E+00	1.01	6.528E-01	5.405E+00	4.281E+00	1.02	2.10E+00	1.66E+00
	0.87042	0.0016	6.082E+07	0.0300	1.03E-02	4.61E-02	1.01	4.785E-04	1.466E-01	1.161E-01	1.02	1.54E-03	1.22E-03
	0.90427	0.0718	6.082E+07	0.0300	4.61E-01	2.15E+00	1.01	1.000E+00	6.806E+00	5.390E+00	1.01	3.17E+00	2.51E+00
	0.93095	0.0062	6.082E+07	0.0300	3.98E-02	1.91E-01	1.01	7.680E-03	6.029E-01	4.774E-01	1.01	2.43E-02	1.92E-02
	0.94419	0.00164	6.082E+07	0.0300	1.05E-02	5.12E-02	1.01	5.451E-04	1.614E-01	1.278E-01	1.01	1.72E-03	1.36E-03
	0.95318	0.00106	6.082E+07	0.0300	6.81E-03	3.34E-02	1.01	2.301E-04	1.052E-01	8.330E-02	1.01	7.24E-04	5.73E-04
	0.96042	0.00322	6.082E+07	0.0300	2.07E-02	1.02E-01	1.01	2.140E-03	3.216E-01	2.546E-01	1.01	6.72E-03	5.32E-03
	0.97439	0.0098	6.082E+07	0.0300	6.30E-02	3.16E-01	1.01	2.012E-02	9.903E-01	7.842E-01	1.01	6.30E-02	4.99E-02
	0.99737	0.0066	6.082E+07	0.0300	4.24E-02	2.19E-01	1.01	9.363E-03	6.803E-01	5.387E-01	1.01	2.91E-02	2.31E-02

VP
9/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	1.0108	0.00108	6.082E+07	0.0300	6.94E-03	3.62E-02	1.01	2.538E-04	1.126E-01	8.911E-02	1.01	7.89E-04	6.25E-04
	1.0444	0.00408	6.082E+07	0.0300	2.62E-02	1.41E-01	1.01	3.730E-03	4.367E-01	3.457E-01	1.01	1.16E-02	9.16E-03
	1.0765	0.00236	6.082E+07	0.0300	1.52E-02	8.38E-02	1.01	1.283E-03	2.588E-01	2.049E-01	1.01	3.96E-03	3.14E-03
	1.0881	0.00358	6.082E+07	0.0300	2.30E-02	1.28E-01	1.01	2.983E-03	3.959E-01	3.134E-01	1.00	9.11E-03	7.21E-03
	1.1032	0.009	6.082E+07	0.0300	5.78E-02	3.27E-01	1.01	1.909E-02	1.006E+00	7.963E-01	1.00	5.82E-02	4.61E-02
	1.1078	0.0292	6.082E+07	0.0300	1.88E-01	1.06E+00	1.01	2.018E-01	3.275E+00	2.593E+00	1.00	6.14E-01	4.86E-01
	1.1166	0.0166	6.082E+07	0.0300	1.07E-01	6.10E-01	1.01	6.571E-02	1.873E+00	1.483E+00	1.00	2.00E-01	1.58E-01
	1.1315	0.0016	6.082E+07	0.0300	1.03E-02	5.95E-02	1.01	6.182E-04	1.824E-01	1.444E-01	1.00	1.88E-03	1.48E-03
	1.1625	0.00214	6.082E+07	0.0300	1.38E-02	8.18E-02	1.02	1.147E-03	2.491E-01	1.972E-01	1.00	3.42E-03	2.71E-03
	1.1723	0.0098	6.082E+07	0.0300	6.30E-02	3.77E-01	1.02	2.424E-02	1.147E+00	9.083E-01	1.00	7.23E-02	5.72E-02
	1.1824	0.00166	6.082E+07	0.0300	1.07E-02	6.45E-02	1.02	7.018E-04	1.957E-01	1.549E-01	1.00	2.09E-03	1.65E-03
	1.1865	0.00184	6.082E+07	0.0300	1.18E-02	7.17E-02	1.02	8.652E-04	2.175E-01	1.722E-01	1.00	2.57E-03	2.04E-03
	1.2288	0.00144	6.082E+07	0.0300	9.25E-03	5.82E-02	1.02	5.489E-04	1.747E-01	1.383E-01	1.00	1.62E-03	1.28E-03
	1.2356	0.00594	6.082E+07	0.0300	3.82E-02	2.41E-01	1.02	9.393E-03	7.235E-01	5.728E-01	1.00	2.76E-02	2.19E-02
	1.2737	0.0136	6.082E+07	0.0300	8.74E-02	5.70E-01	1.02	5.081E-02	1.694E+00	1.341E+00	0.99	1.47E-01	1.16E-01
	1.3027	0.001	6.082E+07	0.0300	6.43E-03	4.29E-02	1.02	2.812E-04	1.266E-01	1.002E-01	0.99	8.05E-04	6.37E-04
	1.3243	0.0306	6.082E+07	0.0300	1.97E-01	1.34E+00	1.03	2.706E-01	3.919E+00	3.103E+00	0.99	7.63E-01	6.04E-01
	1.3354	0.00132	6.082E+07	0.0300	8.48E-03	5.81E-02	1.03	5.080E-04	1.701E-01	1.347E-01	0.99	1.43E-03	1.13E-03
	1.3406	0.00194	6.082E+07	0.0300	1.25E-02	8.58E-02	1.03	1.102E-03	2.506E-01	1.984E-01	0.99	3.09E-03	2.45E-03
	1.3675	0.00148	6.082E+07	0.0300	9.51E-03	6.69E-02	1.03	6.550E-04	1.939E-01	1.535E-01	0.99	1.83E-03	1.45E-03
	1.3722	0.00126	6.082E+07	0.0300	8.10E-03	5.71E-02	1.03	4.765E-04	1.655E-01	1.310E-01	0.99	1.33E-03	1.05E-03
	1.4126	0.00264	6.082E+07	0.0300	1.70E-02	1.24E-01	1.03	2.159E-03	3.539E-01	2.801E-01	0.99	5.94E-03	4.71E-03
	1.4216	0.00224	6.082E+07	0.0300	1.44E-02	1.06E-01	1.03	1.565E-03	3.017E-01	2.388E-01	0.99	4.30E-03	3.40E-03
	1.4613	0.00122	6.082E+07	0.0300	7.84E-03	5.93E-02	1.04	4.833E-04	1.675E-01	1.326E-01	0.99	1.30E-03	1.03E-03
	1.4642	0.00178	6.082E+07	0.0300	1.14E-02	8.67E-02	1.04	1.031E-03	2.446E-01	1.937E-01	0.99	2.77E-03	2.19E-03
	1.4685	0.00188	6.082E+07	0.0300	1.21E-02	9.19E-02	1.04	1.154E-03	2.589E-01	2.050E-01	0.99	3.10E-03	2.45E-03
	1.4728	0.0688	6.082E+07	0.0300	4.42E-01	3.37E+00	1.04	1.550E+00	9.494E+00	7.516E+00	0.99	4.16E+00	3.29E+00
	1.501	0.0132	6.082E+07	0.0300	8.48E-02	6.61E-01	1.04	5.830E-02	1.846E+00	1.461E+00	0.99	1.55E-01	1.23E-01
	1.5062	0.00112	6.082E+07	0.0300	7.20E-03	5.62E-02	1.04	4.208E-04	1.569E-01	1.242E-01	0.99	1.12E-03	8.85E-04
	1.53	0.0332	6.082E+07	0.0300	2.13E-01	1.69E+00	1.04	3.748E-01	4.703E+00	3.723E+00	0.98	9.83E-01	7.78E-01
	1.5337	0.0512	6.082E+07	0.0300	3.29E-01	2.61E+00	1.04	8.932E-01	7.264E+00	5.750E+00	0.98	2.34E+00	1.85E+00
	1.5553	0.00152	6.082E+07	0.0300	9.77E-03	7.84E-02	1.05	8.044E-04	2.177E-01	1.723E-01	0.98	2.08E-03	1.65E-03
	1.5738	0.0019	6.082E+07	0.0300	1.22E-02	9.90E-02	1.05	1.270E-03	2.743E-01	2.171E-01	0.98	3.28E-03	2.60E-03
	1.6341	0.0082	6.082E+07	0.0300	5.27E-02	4.42E-01	1.05	2.443E-02	1.214E+00	9.610E-01	0.98	6.27E-02	4.96E-02



*v/b 729
3/16/94*

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	1.6438	0.00338	6.082E+07	0.0300	2.17E-02	1.83E-01	1.06	4.212E-03	5.024E-01	3.977E-01	0.98	1.07E-02	8.47E-03
	1.6675	0.00128	6.082E+07	0.0300	8.23E-03	7.02E-02	1.06	6.119E-04	1.922E-01	1.521E-01	0.98	1.55E-03	1.23E-03
	1.6769	0.0014	6.082E+07	0.0300	9.00E-03	7.71E-02	1.06	7.355E-04	2.109E-01	1.670E-01	0.98	1.86E-03	1.47E-03
	1.6838	0.00132	6.082E+07	0.0300	8.48E-03	7.30E-02	1.06	6.562E-04	1.994E-01	1.579E-01	0.98	1.66E-03	1.31E-03
	1.692	0.0026	6.082E+07	0.0300	1.67E-02	1.44E-01	1.06	2.556E-03	3.940E-01	3.119E-01	0.98	6.45E-03	5.11E-03
	1.6937	0.0438	6.082E+07	0.0300	2.81E-01	2.43E+00	1.06	7.262E-01	6.643E+00	5.259E+00	0.98	1.83E+00	1.45E+00
	1.7213	0.00224	6.082E+07	0.0300	1.44E-02	1.26E-01	1.06	1.927E-03	3.434E-01	2.719E-01	0.98	4.84E-03	3.83E-03
	1.7776	0.0076	6.082E+07	0.0300	4.88E-02	4.41E-01	1.07	2.304E-02	1.191E+00	9.425E-01	0.98	5.70E-02	4.51E-02
	1.7882	0.00106	6.082E+07	0.0300	6.81E-03	6.18E-02	1.07	4.505E-04	1.667E-01	1.319E-01	0.98	1.11E-03	8.81E-04
	1.8107	0.0014	6.082E+07	0.0300	9.00E-03	8.25E-02	1.08	8.020E-04	2.219E-01	1.757E-01	0.98	1.96E-03	1.55E-03
	1.8375	0.00118	6.082E+07	0.0300	7.58E-03	7.05E-02	1.08	5.773E-04	1.888E-01	1.495E-01	0.98	1.40E-03	1.11E-03
	1.8397	0.0035	6.082E+07	0.0300	2.25E-02	2.09E-01	1.08	5.085E-03	5.606E-01	4.438E-01	0.97	1.22E-02	9.68E-03
	1.8685	0.00196	6.082E+07	0.0300	1.26E-02	1.19E-01	1.08	1.617E-03	3.171E-01	2.510E-01	0.97	3.87E-03	3.07E-03
	1.8798	0.00158	6.082E+07	0.0300	1.02E-02	9.64E-02	1.08	1.057E-03	2.567E-01	2.032E-01	0.97	2.53E-03	2.00E-03
	1.9034	0.0104	6.082E+07	0.0300	6.68E-02	6.41E-01	1.09	4.672E-02	1.703E+00	1.348E+00	0.97	1.10E-01	8.74E-02
	1.9391	0.0064	6.082E+07	0.0300	4.11E-02	4.01E-01	1.09	1.800E-02	1.061E+00	8.398E-01	0.97	4.23E-02	3.35E-02
	1.9666	0.00132	6.082E+07	0.0300	8.48E-03	8.39E-02	1.10	7.827E-04	2.208E-01	1.748E-01	0.97	1.82E-03	1.44E-03
	1.9986	0.00118	6.082E+07	0.0300	7.58E-03	7.61E-02	1.10	6.347E-04	1.995E-01	1.579E-01	0.97	1.47E-03	1.16E-03
	2.0122	0.0156	6.082E+07	0.0300	1.00E-01	1.01E+00	1.10	1.115E-01	2.648E+00	2.097E+00	0.97	2.58E-01	2.04E-01
	2.021	0.00244	6.082E+07	0.0300	1.57E-02	1.59E-01	1.10	2.736E-03	4.154E-01	3.289E-01	0.97	6.32E-03	5.00E-03
	2.0465	0.00262	6.082E+07	0.0300	1.68E-02	1.72E-01	1.11	3.211E-03	4.497E-01	3.560E-01	0.97	7.34E-03	5.81E-03
	2.1006	0.0094	6.082E+07	0.0300	6.04E-02	6.28E-01	1.11	4.209E-02	1.640E+00	1.299E+00	0.97	9.61E-02	7.61E-02
	2.16	0.00528	6.082E+07	0.0300	3.39E-02	3.60E-01	1.12	1.367E-02	9.384E-01	7.428E-01	0.96	3.06E-02	2.42E-02
	2.1958	0.00128	6.082E+07	0.0300	8.23E-03	8.83E-02	1.13	8.204E-04	2.299E-01	1.820E-01	0.96	1.82E-03	1.44E-03
	2.2802	0.00204	6.082E+07	0.0300	1.31E-02	1.44E-01	1.14	2.159E-03	3.753E-01	2.971E-01	0.96	4.72E-03	3.74E-03
	2.3774	0.008	6.082E+07	0.0300	5.14E-02	5.84E-01	1.15	3.454E-02	1.512E+00	1.197E+00	0.95	7.39E-02	5.85E-02
	2.401	0.0072	6.082E+07	0.0300	4.63E-02	5.29E-01	1.15	2.817E-02	1.369E+00	1.084E+00	0.95	6.02E-02	4.76E-02
	2.5979	0.00108	6.082E+07	0.0300	6.94E-03	8.41E-02	1.17	6.832E-04	2.159E-01	1.709E-01	0.94	1.41E-03	1.12E-03
	2.6453	0.0042	6.082E+07	0.0300	2.70E-02	3.32E-01	1.18	1.056E-02	8.496E-01	6.726E-01	0.94	2.16E-02	1.71E-02
	2.7509	0.00124	6.082E+07	0.0300	7.97E-03	1.01E-01	1.19	9.567E-04	2.573E-01	2.036E-01	0.93	1.91E-03	1.51E-03
	2.7821	0.0076	6.082E+07	0.0300	4.88E-02	6.24E-01	1.19	3.625E-02	1.588E+00	1.257E+00	0.92	7.14E-02	5.65E-02
	2.7938	0.0068	6.082E+07	0.0300	4.37E-02	5.60E-01	1.19	2.910E-02	1.424E+00	1.128E+00	0.92	5.73E-02	4.53E-02
	2.8196	0.00132	6.082E+07	0.0300	8.48E-03	1.09E-01	1.19	1.105E-03	2.782E-01	2.202E-01	0.92	2.17E-03	1.72E-03
	2.8533	0.0024	6.082E+07	0.0300	1.54E-02	2.01E-01	1.19	3.685E-03	5.095E-01	4.033E-01	0.92	7.23E-03	5.72E-03

1/3 222
9/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	2.8662	0.0174	6.082E+07	0.0300	1.12E-01	1.46E+00	1.19	1.943E-01	3.704E+00	2.932E+00	0.92	3.81E-01	3.02E-01
	2.8787	0.00324	6.082E+07	0.0300	2.08E-02	2.73E-01	1.19	6.762E-03	6.917E-01	5.476E-01	0.91	1.31E-02	1.04E-02
	3.0179	0.00254	6.082E+07	0.0300	1.63E-02	2.22E-01	1.20	4.344E-03	5.588E-01	4.423E-01	0.90	8.21E-03	6.50E-03
	3.0292	0.0027	6.082E+07	0.0300	1.74E-02	2.36E-01	1.20	4.918E-03	5.954E-01	4.713E-01	0.90	9.30E-03	7.36E-03
	3.1073	0.00194	6.082E+07	0.0300	1.25E-02	1.72E-01	1.20	2.577E-03	4.346E-01	3.440E-01	0.89	4.82E-03	3.82E-03
	3.1403	0.0104	6.082E+07	0.0300	6.68E-02	9.29E-01	1.20	7.454E-02	2.346E+00	1.857E+00	0.88	1.38E-01	1.09E-01
	3.1721	0.001	6.082E+07	0.0300	6.43E-03	8.99E-02	1.20	6.933E-04	2.270E-01	1.797E-01	0.88	1.28E-03	1.02E-03
	3.2198	0.00428	6.082E+07	0.0300	2.75E-02	3.88E-01	1.20	1.282E-02	9.808E-01	7.763E-01	0.87	2.35E-02	1.86E-02
	3.3617	0.0104	6.082E+07	0.0300	6.68E-02	9.68E-01	1.20	7.765E-02	2.448E+00	1.938E+00	0.84	1.37E-01	1.09E-01
	3.3711	0.0062	6.082E+07	0.0300	3.98E-02	5.78E-01	1.20	2.765E-02	1.462E+00	1.158E+00	0.84	4.89E-02	3.87E-02
	3.3999	0.00136	6.082E+07	0.0300	8.74E-03	1.28E-01	1.20	1.337E-03	3.225E-01	2.553E-01	0.83	2.34E-03	1.85E-03
	3.5329	0.0134	6.082E+07	0.0300	8.61E-02	1.29E+00	1.18	1.307E-01	3.254E+00	2.576E+00	0.80	2.24E-01	1.77E-01
	3.5839	0.00258	6.082E+07	0.0300	1.66E-02	2.50E-01	1.18	4.888E-03	6.324E-01	5.006E-01	0.79	8.28E-03	6.56E-03
	3.7178	0.0084	6.082E+07	0.0300	5.40E-02	8.32E-01	1.16	5.213E-02	2.107E+00	1.668E+00	0.76	8.65E-02	6.84E-02
	3.7325	0.00138	6.082E+07	0.0300	8.87E-03	1.37E-01	1.16	1.410E-03	3.469E-01	2.746E-01	0.75	2.31E-03	1.83E-03
	3.7814	0.00132	6.082E+07	0.0300	8.48E-03	1.32E-01	1.15	1.290E-03	3.347E-01	2.649E-01	0.74	2.10E-03	1.66E-03
	3.8274	0.00138	6.082E+07	0.0300	8.87E-03	1.39E-01	1.14	1.408E-03	3.524E-01	2.790E-01	0.72	2.25E-03	1.78E-03
	3.8427	0.0011	6.082E+07	0.0300	7.07E-03	1.11E-01	1.14	8.970E-04	2.817E-01	2.230E-01	0.72	1.43E-03	1.13E-03
	3.9018	0.00134	6.082E+07	0.0300	8.61E-03	1.37E-01	1.12	1.320E-03	3.464E-01	2.742E-01	0.70	2.09E-03	1.65E-03
	3.923	0.00414	6.082E+07	0.0300	2.66E-02	4.24E-01	1.12	1.265E-02	1.074E+00	8.501E-01	0.69	1.97E-02	1.56E-02
	3.9655	0.00208	6.082E+07	0.0300	1.34E-02	2.15E-01	1.11	3.186E-03	5.432E-01	4.300E-01	0.68	4.94E-03	3.91E-03
	3.9775	0.0027	6.082E+07	0.0300	1.74E-02	2.79E-01	1.10	5.330E-03	7.065E-01	5.592E-01	0.67	8.21E-03	6.50E-03
	3.996	0.00142	6.082E+07	0.0300	9.13E-03	1.47E-01	1.10	1.479E-03	3.726E-01	2.949E-01	0.67	2.28E-03	1.80E-03
	4.048	0.00116	6.082E+07	0.0300	7.45E-03	1.21E-01	1.09	9.846E-04	3.068E-01	2.429E-01	0.65	1.49E-03	1.18E-03
	4.3411	0.00104	6.082E+07	0.0300	6.68E-03	1.13E-01	0.98	7.395E-04	2.873E-01	2.274E-01	0.52	9.98E-04	7.90E-04
	4.4892	0.00134	6.082E+07	0.0300	8.61E-03	1.48E-01	0.91	1.161E-03	3.780E-01	2.992E-01	0.45	1.46E-03	1.16E-03
	2.1811	0.07118	6.082E+07	0.0300	4.57E-01	4.88E+00	1.12	2.502E+00	1.273E+01	1.008E+01	0.96	5.59E+00	4.42E+00
Xe-131m	0.16393	0.0196	9.762E+05	0.0300	2.02E-03	8.79E-03	1.00	1.777E-05	2.649E-01	2.096E-01	0.98	5.25E-04	4.15E-04
Xe-133	0.079621	0.002165	1.902E+08	0.0300	4.35E-02	1.86E-08	0.70	5.678E-10	1.479E-02	1.169E-02	0.93	5.98E-04	4.73E-04
	0.080997	0.36483	1.902E+08	0.0300	7.33E+00	5.66E-06	0.73	3.027E-05	2.511E+00	1.986E+00	0.82	1.51E+01	1.19E+01
	0.1777	0.000712	1.902E+08	0.0300	1.43E-02	4.72E-04	1.02	6.886E-06	1.070E-02	8.462E-03	0.98	1.50E-04	1.19E-04
Xe-133m	0.23322	0.103	6.044E+06	0.0300	6.58E-02	1.96E-01	1.05	1.350E-02	2.233E+00	1.767E+00	0.97	1.42E-01	1.13E-01
Xe-135	0.1582	0.002886	4.723E+07	0.0300	1.44E-02	1.10E-03	1.00	1.580E-05	3.727E-02	2.948E-02	0.99	5.31E-04	4.20E-04
	0.24979	0.899	4.723E+07	0.0300	4.49E+00	2.10E+00	1.04	9.793E+00	2.136E+01	1.691E+01	0.97	9.30E+01	7.36E+01

V/B *[Signature]*
9/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	0.35839	0.002203	4.723E+07	0.0300	1.10E-02	1.34E-02	1.00	1.473E-04	8.168E-02	6.466E-02	0.95	8.53E-04	6.75E-04
	0.40799	0.003578	4.723E+07	0.0300	1.79E-02	2.84E-02	1.00	5.072E-04	1.515E-01	1.199E-01	0.95	2.57E-03	2.03E-03
	0.60819	0.028948	4.723E+07	0.0300	1.44E-01	5.83E-01	0.99	8.333E-02	1.910E+00	1.514E+00	0.99	2.73E-01	2.17E-01
	0.68433	0.002093	4.723E+07	0.0300	1.04E-02	4.77E-02	1.00	4.979E-04	1.530E-01	1.213E-01	1.00	1.60E-03	1.27E-03
Xe-135m	0.52656	0.80997	3.905E+07	0.0300	3.34E+00	1.28E+01	0.99	4.222E+01	4.982E+01	3.948E+01	0.97	1.61E+02	1.28E+02
Xe-137	0.298	0.001167	1.656E+08	0.0300	2.04E-02	4.76E-03	1.01	9.807E-05	3.485E-02	2.759E-02	0.96	6.83E-04	5.41E-04
	0.39335	0.001381	1.656E+08	0.0300	2.42E-02	1.02E-02	1.00	2.473E-04	5.645E-02	4.469E-02	0.95	1.30E-03	1.03E-03
	0.45549	0.307	1.656E+08	0.0300	5.37E+00	2.93E+00	0.99	1.556E+01	1.431E+01	1.133E+01	0.95	7.30E+01	5.78E+01
	0.84895	0.00614	1.656E+08	0.0300	1.07E-01	1.73E-01	1.01	1.875E-02	5.500E-01	4.356E-01	1.02	6.03E-02	4.77E-02
	0.98225	0.002057	1.656E+08	0.0300	3.60E-02	6.70E-02	1.01	2.436E-03	2.094E-01	1.658E-01	1.01	7.61E-03	6.03E-03
	1.1193	0.001053	1.656E+08	0.0300	1.84E-02	3.88E-02	1.01	7.214E-04	1.190E-01	9.422E-02	1.00	2.19E-03	1.74E-03
	1.2732	0.002241	1.656E+08	0.0300	3.92E-02	9.39E-02	1.02	3.754E-03	2.790E-01	2.209E-01	0.99	1.08E-02	8.57E-03
	1.5768	0.001013	1.656E+08	0.0300	1.77E-02	5.29E-02	1.05	9.842E-04	1.464E-01	1.159E-01	0.98	2.54E-03	2.01E-03
	1.6125	0.001228	1.656E+08	0.0300	2.15E-02	6.54E-02	1.05	1.475E-03	1.803E-01	1.427E-01	0.98	3.80E-03	3.00E-03
	1.7834	0.004083	1.656E+08	0.0300	7.14E-02	2.37E-01	1.07	1.815E-02	6.406E-01	5.072E-01	0.98	4.49E-02	3.55E-02
	2.8498	0.001811	1.656E+08	0.0300	3.17E-02	1.51E-01	1.19	5.706E-03	3.841E-01	3.041E-01	0.92	1.12E-02	8.86E-03
	1.4906	0.01315	1.656E+08	0.0300	2.30E-01	6.53E-01	1.04	1.563E-01	1.830E+00	1.449E+00	0.99	4.17E-01	3.30E-01
Xe-138	0.15375	0.059535	1.506E+08	0.0300	9.47E-01	1.99E-02	1.00	1.884E-02	7.416E-01	5.866E-01	0.99	6.95E-01	5.50E-01
	0.24256	0.034965	1.506E+08	0.0300	5.56E-01	7.47E-02	1.05	4.362E-02	7.989E-01	6.322E-01	0.97	4.31E-01	3.41E-01
	0.25831	0.315	1.506E+08	0.0300	5.01E+00	8.15E-01	1.03	4.210E+00	7.825E+00	6.193E+00	0.97	3.80E+01	3.01E+01
	0.28251	0.004284	1.506E+08	0.0300	6.82E-02	1.47E-02	1.02	1.022E-03	1.196E-01	9.464E-02	0.96	7.83E-03	6.19E-03
	0.33528	0.001071	1.506E+08	0.0300	1.70E-02	5.65E-03	1.00	9.629E-05	3.684E-02	2.916E-02	0.95	5.96E-04	4.72E-04
	0.37144	0.005009	1.506E+08	0.0300	7.97E-02	3.29E-02	1.00	2.620E-03	1.930E-01	1.528E-01	0.95	1.46E-02	1.16E-02
	0.39643	0.063	1.506E+08	0.0300	1.00E+00	4.75E-01	1.00	4.757E-01	2.594E+00	2.054E+00	0.95	2.47E+00	1.96E+00
	0.40136	0.021735	1.506E+08	0.0300	3.46E-01	1.68E-01	1.00	5.804E-02	9.058E-01	7.171E-01	0.95	2.98E-01	2.36E-01
	0.43449	0.20318	1.506E+08	0.0300	3.23E+00	1.79E+00	1.00	5.795E+00	9.105E+00	7.208E+00	0.95	2.80E+01	2.21E+01
	0.50022	0.003622	1.506E+08	0.0300	5.76E-02	4.97E-02	0.99	2.833E-03	2.238E-01	1.772E-01	0.96	1.24E-02	9.80E-03
	0.53007	0.00252	1.506E+08	0.0300	4.01E-02	4.03E-02	0.99	1.600E-03	1.551E-01	1.229E-01	0.97	6.03E-03	4.78E-03
	0.53776	0.001166	1.506E+08	0.0300	1.86E-02	1.92E-02	0.99	3.532E-04	7.195E-02	5.703E-02	0.97	1.29E-03	1.03E-03
	0.55595	0.001166	1.506E+08	0.0300	1.86E-02	2.05E-02	0.99	3.765E-04	7.276E-02	5.768E-02	0.98	1.32E-03	1.05E-03
	0.56853	0.003055	1.506E+08	0.0300	4.86E-02	5.58E-02	0.99	2.686E-03	1.927E-01	1.528E-01	0.98	9.18E-03	7.28E-03
	0.58884	0.001228	1.506E+08	0.0300	1.95E-02	2.37E-02	0.99	4.582E-04	7.916E-02	6.276E-02	0.98	1.52E-03	1.20E-03
	0.65408	0.001449	1.506E+08	0.0300	2.31E-02	3.15E-02	1.00	7.272E-04	1.016E-01	8.053E-02	1.00	2.34E-03	1.86E-03
	0.86582	0.002961	1.506E+08	0.0300	4.71E-02	8.49E-02	1.01	4.038E-03	2.700E-01	2.138E-01	1.02	1.30E-02	1.03E-02



VJB
5/14/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	0.86935	0.006206	1.506E+08	0.0300	9.88E-02	1.79E-01	1.01	1.781E-02	5.680E-01	4.499E-01	1.02	5.72E-02	4.53E-02
	0.89687	0.001323	1.506E+08	0.0300	2.11E-02	3.92E-02	1.01	8.342E-04	1.245E-01	9.862E-02	1.01	2.65E-03	2.10E-03
	0.91251	0.003276	1.506E+08	0.0300	5.21E-02	9.88E-02	1.01	5.202E-03	3.130E-01	2.479E-01	1.01	1.65E-02	1.30E-02
	0.91713	0.009198	1.506E+08	0.0300	1.46E-01	2.79E-01	1.01	4.123E-02	8.831E-01	6.993E-01	1.01	1.31E-01	1.03E-01
	0.93636	0.001355	1.506E+08	0.0300	2.16E-02	4.20E-02	1.01	9.136E-04	1.324E-01	1.048E-01	1.01	2.88E-03	2.28E-03
	0.94125	0.002299	1.506E+08	0.0300	3.66E-02	7.16E-02	1.01	2.644E-03	2.257E-01	1.787E-01	1.01	8.34E-03	6.60E-03
	1.0939	0.004095	1.506E+08	0.0300	6.52E-02	1.48E-01	1.01	9.710E-03	4.547E-01	3.600E-01	1.00	2.96E-02	2.35E-02
	1.0988	0.002142	1.506E+08	0.0300	3.41E-02	7.75E-02	1.01	2.669E-03	2.387E-01	1.890E-01	1.00	8.14E-03	6.44E-03
	1.1022	0.001071	1.506E+08	0.0300	1.70E-02	3.89E-02	1.01	6.689E-04	1.196E-01	9.470E-02	1.00	2.04E-03	1.61E-03
	1.1143	0.014742	1.506E+08	0.0300	2.35E-01	5.40E-01	1.01	1.281E-01	1.661E+00	1.315E+00	1.00	3.90E-01	3.08E-01
	1.1416	0.005134	1.506E+08	0.0300	8.17E-02	1.93E-01	1.01	1.590E-02	5.893E-01	4.665E-01	1.00	4.81E-02	3.81E-02
	1.1454	0.001323	1.506E+08	0.0300	2.11E-02	4.98E-02	1.01	1.059E-03	1.523E-01	1.206E-01	1.00	3.21E-03	2.54E-03
	1.5718	0.002646	1.506E+08	0.0300	4.21E-02	1.38E-01	1.05	6.091E-03	3.817E-01	3.021E-01	0.98	1.57E-02	1.25E-02
	1.6146	0.002363	1.506E+08	0.0300	3.76E-02	1.26E-01	1.05	4.973E-03	3.471E-01	2.748E-01	0.98	1.28E-02	1.01E-02
	1.7683	0.16727	1.506E+08	0.0300	2.66E+00	9.66E+00	1.07	2.750E+01	2.610E+01	2.066E+01	0.98	6.81E+01	5.39E+01
	1.8125	0.001796	1.506E+08	0.0300	2.86E-02	1.06E-01	1.08	3.270E-03	2.848E-01	2.255E-01	0.98	7.98E-03	6.31E-03
	1.8509	0.014238	1.506E+08	0.0300	2.27E-01	8.56E-01	1.08	2.094E-01	2.289E+00	1.812E+00	0.97	5.03E-01	3.98E-01
	1.9254	0.005639	1.506E+08	0.0300	8.97E-02	3.51E-01	1.09	3.437E-02	9.303E-01	7.365E-01	0.97	8.10E-02	6.41E-02
	2.0048	0.05355	1.506E+08	0.0300	8.52E-01	3.46E+00	1.10	3.244E+00	9.070E+00	7.180E+00	0.97	7.50E+00	5.93E+00
	2.0158	0.12254	1.506E+08	0.0300	1.95E+00	7.95E+00	1.10	1.705E+01	2.083E+01	1.649E+01	0.97	3.94E+01	3.12E+01
	2.0792	0.014427	1.506E+08	0.0300	2.30E-01	9.57E-01	1.11	2.437E-01	2.501E+00	1.980E+00	0.97	5.57E-01	4.41E-01
	2.2523	0.022869	1.506E+08	0.0300	3.64E-01	1.61E+00	1.13	6.603E-01	4.175E+00	3.305E+00	0.96	1.46E+00	1.15E+00
	2.3219	0.006206	1.506E+08	0.0300	9.88E-02	4.45E-01	1.14	5.014E-02	1.155E+00	9.145E-01	0.96	1.10E-01	8.67E-02
	2.4753	0.003119	1.506E+08	0.0300	4.96E-02	2.34E-01	1.16	1.350E-02	6.048E-01	4.788E-01	0.95	2.85E-02	2.26E-02
	2.4976	0.001733	1.506E+08	0.0300	2.76E-02	1.31E-01	1.16	4.196E-03	3.380E-01	2.676E-01	0.95	8.85E-03	7.01E-03
	1.1186	0.026586	1.506E+08	0.0300	4.23E-01	9.78E-01	1.01	4.181E-01	3.004E+00	2.378E+00	1.00	1.27E+00	1.27E+00
						SUM =		6.003E+02				1.85E+03	1.46E+03

27A = 5.138 Rad/hr
27B = 5.841 Rad/hr

27E = 1.85E+03 Rad/hr
27F = 1.47E+03 Rad/hr

Con. Vol = 5.68E+09 cm**3
27A Cone Factor 0.00856
27B Cone Factor 0.00973
Release Frac. 0.02



4/13 7222
5/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
I-131	0.080183	0.026182	2.422E+07	0.0200	1.12E-01	3.20E-07	0.71	2.539E-08	1.794E-01	1.418E-01	0.88	1.76E-02	1.39E-02
	0.17721	0.002648	2.422E+07	0.0200	1.13E-02	1.73E-03	1.02	1.994E-05	3.963E-02	3.135E-02	0.98	4.39E-04	3.47E-04
	0.2843	0.060521	2.422E+07	0.0200	2.58E-01	2.12E-01	1.02	5.579E-02	1.703E+00	1.348E+00	0.96	4.22E-01	3.34E-01
	0.32578	0.002507	2.422E+07	0.0200	1.07E-02	1.24E-02	1.00	1.330E-04	8.341E-02	6.603E-02	0.96	8.56E-04	6.78E-04
	0.36448	0.81164	2.422E+07	0.0200	3.46E+00	5.12E+00	1.00	1.771E+01	3.065E+01	2.426E+01	0.95	1.01E+02	7.98E+01
	0.50299	0.003605	2.422E+07	0.0200	1.54E-02	5.03E-02	0.99	7.653E-04	2.224E-01	1.761E-01	0.96	3.28E-03	2.60E-03
	0.63697	0.072605	2.422E+07	0.0200	3.10E-01	1.54E+00	1.00	4.761E-01	4.973E+00	3.942E+00	0.99	1.52E+00	1.21E+00
	0.6427	0.002195	2.422E+07	0.0200	9.36E-03	4.69E-02	1.00	4.393E-04	1.515E-01	1.201E-01	1.00	1.42E-03	1.12E-03
	0.72289	0.018025	2.422E+07	0.0200	7.69E-02	4.33E-01	1.00	3.331E-02	1.388E+00	1.100E+00	1.01	1.08E-01	8.54E-02
	0.32939	0.002304	2.422E+07	0.0200	9.83E-03	1.17E-02	1.00	1.151E-04	7.767E-02	6.148E-02	0.95	7.25E-04	5.74E-04
I-132	0.1472	0.002369	3.466E+07	0.0200	1.45E-02	5.60E-04	1.01	8.183E-06	2.796E-02	2.211E-02	1.01	4.08E-04	3.23E-04
	0.1833	0.001382	3.466E+07	0.0200	8.44E-03	1.07E-03	1.03	9.298E-06	2.163E-02	1.712E-02	0.97	1.77E-04	1.40E-04
	0.2548	0.001875	3.466E+07	0.0200	1.14E-02	4.65E-03	1.04	5.538E-05	4.574E-02	3.620E-02	0.97	5.08E-04	4.02E-04
	0.2627	0.01441	3.466E+07	0.0200	8.80E-02	3.93E-02	1.03	3.561E-03	3.660E-01	2.896E-01	0.97	3.12E-02	2.47E-02
	0.2848	0.007205	3.466E+07	0.0200	4.40E-02	2.54E-02	1.02	1.138E-03	2.032E-01	1.608E-01	0.96	8.58E-03	6.79E-03
	0.3165	0.001382	3.466E+07	0.0200	8.44E-03	6.45E-03	1.00	5.439E-05	4.443E-02	3.516E-02	0.96	3.60E-04	2.85E-04
	0.3635	0.004935	3.466E+07	0.0200	3.01E-02	3.09E-02	1.00	9.318E-04	1.859E-01	1.471E-01	0.95	5.32E-03	4.21E-03
	0.3878	0.002961	3.466E+07	0.0200	1.81E-02	2.13E-02	1.00	3.848E-04	1.193E-01	9.443E-02	0.95	2.05E-03	1.62E-03
	0.4168	0.004738	3.466E+07	0.0200	2.89E-02	3.90E-02	1.00	1.128E-03	2.046E-01	1.620E-01	0.95	5.62E-03	4.45E-03
	0.4319	0.004836	3.466E+07	0.0200	2.95E-02	4.22E-02	1.00	1.247E-03	2.156E-01	1.707E-01	0.95	6.05E-03	4.79E-03
	0.446	0.006021	3.466E+07	0.0200	3.67E-02	5.55E-02	1.00	2.038E-03	2.759E-01	2.184E-01	0.95	9.63E-03	7.62E-03
	0.4739	0.001777	3.466E+07	0.0200	1.08E-02	1.80E-02	0.99	1.938E-04	8.537E-02	6.759E-02	0.96	8.89E-04	7.04E-04
	0.4785	0.001481	3.466E+07	0.0200	9.04E-03	1.53E-02	0.99	1.367E-04	7.164E-02	5.672E-02	0.96	6.22E-04	4.92E-04
	0.4882	0.004145	3.466E+07	0.0200	2.53E-02	4.41E-02	0.99	1.105E-03	2.034E-01	1.611E-01	0.96	4.94E-03	3.91E-03
	0.5059	0.050337	3.466E+07	0.0200	3.07E-01	7.14E-01	0.99	2.173E-01	3.101E+00	2.456E+00	0.96	9.15E-01	7.24E-01
	0.52265	0.16088	3.466E+07	0.0200	9.82E-01	2.49E+00	0.99	2.421E+00	9.888E+00	7.835E+00	0.97	9.42E+00	7.46E+00
	0.5355	0.005231	3.466E+07	0.0200	3.19E-02	8.55E-02	0.99	2.704E-03	3.226E-01	2.556E-01	0.97	9.99E-03	7.92E-03
	0.54	0.001086	3.466E+07	0.0200	6.63E-03	1.81E-02	0.99	1.186E-04	6.709E-02	5.318E-02	0.97	4.31E-04	3.42E-04
	0.5471	0.012535	3.466E+07	0.0200	7.65E-02	2.14E-01	0.99	1.620E-02	7.774E-01	6.162E-01	0.97	5.77E-02	4.57E-02
	0.6	0.001382	3.466E+07	0.0200	8.44E-03	2.74E-02	0.99	2.286E-04	9.024E-02	7.155E-02	0.99	7.54E-04	5.97E-04
	0.6208	0.003948	3.466E+07	0.0200	2.41E-02	8.13E-02	1.00	1.959E-03	2.646E-01	2.098E-01	0.99	6.31E-03	5.01E-03
	0.6212	0.015792	3.466E+07	0.0200	9.64E-02	3.26E-01	1.00	3.138E-02	1.059E+00	8.399E-01	0.99	1.01E-01	8.01E-02
	0.63022	0.13719	3.466E+07	0.0200	8.37E-01	2.87E+00	1.00	2.406E+00	9.314E+00	7.384E+00	0.99	7.72E+00	6.12E+00

1. The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that proper record-keeping is essential for the integrity of the financial system and for the ability to detect and prevent fraud.

2. The second part of the document outlines the specific requirements for record-keeping. It states that all transactions must be recorded in a timely and accurate manner, and that the records must be maintained for a minimum of five years.

3. The third part of the document discusses the role of the auditor in verifying the accuracy of the records. It states that the auditor must perform a thorough review of the records and must report any discrepancies to the appropriate authorities.

4. The fourth part of the document discusses the consequences of failing to maintain accurate records. It states that individuals or organizations that fail to comply with the requirements may be subject to fines, penalties, or even criminal prosecution.

5. The fifth part of the document discusses the importance of training and education for individuals involved in record-keeping. It states that individuals must be properly trained and educated in order to ensure the accuracy and integrity of the records.

6. The sixth part of the document discusses the importance of internal controls in preventing fraud. It states that organizations must implement strong internal controls to ensure that all transactions are properly recorded and that there is no opportunity for fraud.

7. The seventh part of the document discusses the importance of transparency and accountability in the financial system. It states that all transactions must be transparent and that individuals and organizations must be held accountable for their actions.

8. The eighth part of the document discusses the importance of regular audits and reviews. It states that organizations must undergo regular audits and reviews to ensure that their records are accurate and that their internal controls are effective.

9. The ninth part of the document discusses the importance of maintaining the confidentiality of the records. It states that the records must be kept secure and that access must be restricted to authorized personnel only.

10. The tenth part of the document discusses the importance of staying up-to-date with changes in the financial system. It states that individuals and organizations must stay informed of any changes in regulations or procedures and must ensure that their records and internal controls are updated accordingly.

v/B 92.9
9/6/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	0.6506	0.026649	3.466E+07	0.0200	1.63E-01	5.77E-01	1.00	9.381E-02	1.859E+00	1.474E+00	1.00	3.02E-01	2.40E-01
	0.659	0.003948	3.466E+07	0.0200	2.41E-02	8.66E-02	1.00	2.086E-03	2.786E-01	2.209E-01	1.00	6.71E-03	5.32E-03
	0.66769	0.987	3.466E+07	0.0200	6.02E+00	2.19E+01	1.00	1.321E+02	7.051E+01	5.589E+01	1.00	4.25E+02	3.37E+02
	0.6698	0.04935	3.466E+07	0.0200	3.01E-01	1.10E+00	1.00	3.314E-01	3.535E+00	2.802E+00	1.00	1.06E+00	8.44E-01
	0.6716	0.052311	3.466E+07	0.0200	3.19E-01	1.17E+00	1.00	3.733E-01	3.757E+00	2.978E+00	1.00	1.20E+00	9.51E-01
	0.727	0.031584	3.466E+07	0.0200	1.93E-01	7.64E-01	1.00	1.472E-01	2.444E+00	1.937E+00	1.01	4.76E-01	3.77E-01
	0.7272	0.021714	3.466E+07	0.0200	1.33E-01	5.25E-01	1.00	6.960E-02	1.681E+00	1.332E+00	1.01	2.25E-01	1.78E-01
	0.7285	0.010857	3.466E+07	0.0200	6.63E-02	2.63E-01	1.01	1.761E-02	8.421E-01	6.673E-01	1.01	5.64E-02	4.47E-02
	0.7645	0.003948	3.466E+07	0.0200	2.41E-02	1.00E-01	1.01	2.444E-03	3.206E-01	2.540E-01	1.01	7.80E-03	6.18E-03
	0.77261	0.76196	3.466E+07	0.0200	4.65E+00	1.96E+01	1.01	9.203E+01	6.249E+01	4.951E+01	1.01	2.94E+02	2.33E+02
	0.7802	0.012338	3.466E+07	0.0200	7.53E-02	3.21E-01	1.01	2.438E-02	1.021E+00	8.091E-01	1.01	7.77E-02	6.15E-02
	0.7845	0.004244	3.466E+07	0.0200	2.59E-02	1.11E-01	1.01	2.902E-03	3.532E-01	2.798E-01	1.01	9.24E-03	7.32E-03
	0.8098	0.028623	3.466E+07	0.0200	1.75E-01	7.72E-01	1.01	1.362E-01	2.454E+00	1.944E+00	1.01	4.33E-01	3.43E-01
	0.8122	0.056259	3.466E+07	0.0200	3.43E-01	1.52E+00	1.01	5.276E-01	4.838E+00	3.832E+00	1.01	1.68E+00	1.33E+00
	0.8633	0.005823	3.466E+07	0.0200	3.55E-02	1.66E-01	1.01	5.974E-03	5.296E-01	4.194E-01	1.02	1.92E-02	1.52E-02
	0.8768	0.010758	3.466E+07	0.0200	6.57E-02	3.12E-01	1.01	2.070E-02	9.925E-01	7.860E-01	1.02	6.65E-02	5.26E-02
	0.9103	0.009179	3.466E+07	0.0200	5.60E-02	2.76E-01	1.01	1.563E-02	8.752E-01	6.930E-01	1.01	4.95E-02	3.92E-02
	0.9276	0.004145	3.466E+07	0.0200	2.53E-02	1.27E-01	1.01	3.248E-03	4.018E-01	3.182E-01	1.01	1.03E-02	8.13E-03
	0.95455	0.18062	3.466E+07	0.0200	1.10E+00	5.71E+00	1.01	6.353E+00	1.795E+01	1.421E+01	1.01	2.00E+01	1.58E+01
	0.9837	0.005626	3.466E+07	0.0200	3.43E-02	1.84E-01	1.01	6.365E-03	5.733E-01	4.540E-01	1.01	1.99E-02	1.57E-02
	1.0347	0.004738	3.466E+07	0.0200	2.89E-02	1.62E-01	1.01	4.738E-03	5.034E-01	3.985E-01	1.01	1.47E-02	1.16E-02
	1.136	0.02961	3.466E+07	0.0200	1.81E-01	1.11E+00	1.01	2.019E-01	3.385E+00	2.680E+00	1.00	6.12E-01	4.84E-01
	1.1434	0.013522	3.466E+07	0.0200	8.25E-02	5.08E-01	1.01	4.236E-02	1.554E+00	1.230E+00	1.00	1.28E-01	1.02E-01
	1.1474	0.002764	3.466E+07	0.0200	1.69E-02	1.04E-01	1.01	1.776E-03	3.185E-01	2.521E-01	1.00	5.37E-03	4.25E-03
	1.1732	0.010857	3.466E+07	0.0200	6.63E-02	4.19E-01	1.02	2.829E-02	1.272E+00	1.007E+00	1.00	8.43E-02	6.68E-02
	1.2727	0.001777	3.466E+07	0.0200	1.08E-02	7.44E-02	1.02	8.231E-04	2.212E-01	1.751E-01	0.99	2.37E-03	1.88E-03
	1.2907	0.011351	3.466E+07	0.0200	6.93E-02	4.82E-01	1.02	3.407E-02	1.427E+00	1.130E+00	0.99	9.79E-02	7.75E-02
	1.2953	0.01974	3.466E+07	0.0200	1.20E-01	8.42E-01	1.02	1.035E-01	2.489E+00	1.970E+00	0.99	2.97E-01	2.35E-01
	1.2976	0.008883	3.466E+07	0.0200	5.42E-02	3.80E-01	1.02	2.099E-02	1.121E+00	8.878E-01	0.99	6.02E-02	4.77E-02
	1.3178	0.001184	3.466E+07	0.0200	7.23E-03	5.14E-02	1.02	3.790E-04	1.511E-01	1.196E-01	0.99	1.08E-03	8.56E-04
	1.3721	0.024675	3.466E+07	0.0200	1.51E-01	1.12E+00	1.03	1.736E-01	3.241E+00	2.566E+00	0.99	4.83E-01	3.83E-01
	1.3986	0.071064	3.466E+07	0.0200	4.34E-01	3.29E+00	1.03	1.470E+00	9.460E+00	7.489E+00	0.99	4.06E+00	3.22E+00
	1.4426	0.014213	3.466E+07	0.0200	8.67E-02	6.81E-01	1.04	6.141E-02	1.933E+00	1.531E+00	0.99	1.66E-01	1.31E-01
	1.4768	0.001352	3.466E+07	0.0200	8.25E-03	6.65E-02	1.04	5.704E-04	1.869E-01	1.480E-01	0.99	1.53E-03	1.21E-03



*u/s 902-9
9/16/94*

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	1.7575	0.002961	3.466E+07	0.0200	1.81E-02	1.70E-01	1.07	3.287E-03	4.601E-01	3.642E-01	0.98	8.15E-03	6.45E-03
	1.9211	0.011844	3.466E+07	0.0200	7.23E-02	7.37E-01	1.09	5.805E-02	1.952E+00	1.545E+00	0.97	1.37E-01	1.08E-01
	2.0022	0.010857	3.466E+07	0.0200	6.63E-02	7.01E-01	1.10	5.112E-02	1.838E+00	1.455E+00	0.97	1.18E-01	9.35E-02
	2.0868	0.002369	3.466E+07	0.0200	1.45E-02	1.58E-01	1.11	2.528E-03	4.118E-01	3.260E-01	0.97	5.78E-03	4.57E-03
	2.1727	0.001974	3.466E+07	0.0200	1.20E-02	1.35E-01	1.12	1.823E-03	3.522E-01	2.788E-01	0.96	4.07E-03	3.22E-03
	2.2232	0.001184	3.466E+07	0.0200	7.23E-03	8.23E-02	1.13	6.724E-04	2.143E-01	1.697E-01	0.96	1.49E-03	1.18E-03
	2.3905	0.001678	3.466E+07	0.0200	1.02E-02	1.23E-01	1.15	1.449E-03	3.183E-01	2.519E-01	0.95	3.10E-03	2.45E-03
	1.0146	0.031946	3.466E+07	0.0200	1.95E-01	1.07E+00	1.01	2.116E-01	3.340E+00	2.644E+00	1.01	6.58E-01	5.21E-01
I-133	0.2627	0.003565	4.747E+07	0.0200	2.98E-02	9.73E-03	1.03	2.985E-04	9.055E-02	7.167E-02	0.97	2.62E-03	2.07E-03
	0.26717	0.001165	4.747E+07	0.0200	9.74E-03	3.35E-03	1.03	3.361E-05	3.025E-02	2.394E-02	0.97	2.86E-04	2.26E-04
	0.34543	0.001036	4.747E+07	0.0200	8.66E-03	5.83E-03	1.00	5.046E-05	3.689E-02	2.920E-02	0.95	3.03E-04	2.40E-04
	0.36108	0.001122	4.747E+07	0.0200	9.38E-03	6.93E-03	1.00	6.504E-05	4.195E-02	3.321E-02	0.95	3.74E-04	2.96E-04
	0.41805	0.001528	4.747E+07	0.0200	1.28E-02	1.26E-02	1.00	1.615E-04	6.618E-02	5.240E-02	0.95	8.03E-04	6.36E-04
	0.42291	0.00309	4.747E+07	0.0200	2.58E-02	2.61E-02	1.00	6.733E-04	1.352E-01	1.071E-01	0.95	3.32E-03	2.63E-03
	0.51053	0.018127	4.747E+07	0.0200	1.52E-01	2.64E-01	0.99	3.961E-02	1.115E+00	8.834E-01	0.96	1.62E-01	1.29E-01
	0.52987	0.8632	4.747E+07	0.0200	7.22E+00	1.38E+01	0.99	9.848E+01	5.310E+01	4.208E+01	0.97	3.72E+02	2.95E+02
	0.61797	0.005395	4.747E+07	0.0200	4.51E-02	1.11E-01	1.00	4.986E-03	3.603E-01	2.857E-01	0.99	1.61E-02	1.28E-02
	0.68025	0.006448	4.747E+07	0.0200	5.39E-02	1.46E-01	1.00	7.868E-03	4.686E-01	3.714E-01	1.00	2.53E-02	2.00E-02
	0.70658	0.014933	4.747E+07	0.0200	1.25E-01	3.51E-01	1.00	4.382E-02	1.125E+00	8.915E-01	1.01	1.42E-01	1.12E-01
	0.76838	0.004566	4.747E+07	0.0200	3.82E-02	1.17E-01	1.01	4.501E-03	3.726E-01	2.952E-01	1.01	1.44E-02	1.14E-02
	0.82051	0.001537	4.747E+07	0.0200	1.28E-02	4.19E-02	1.01	5.443E-04	1.334E-01	1.057E-01	1.02	1.75E-03	1.39E-03
	0.85628	0.012344	4.747E+07	0.0200	1.03E-01	3.50E-01	1.01	3.649E-02	1.114E+00	8.825E-01	1.02	1.17E-01	9.29E-02
	0.87533	0.044714	4.747E+07	0.0200	3.74E-01	1.29E+00	1.01	4.888E-01	4.118E+00	3.261E+00	1.02	1.57E+00	1.24E+00
	0.90967	0.002124	4.747E+07	0.0200	1.78E-02	6.39E-02	1.01	1.145E-03	2.024E-01	1.603E-01	1.01	3.63E-03	2.87E-03
	1.0523	0.005516	4.747E+07	0.0200	4.61E-02	1.92E-01	1.01	8.930E-03	5.940E-01	4.703E-01	1.01	2.77E-02	2.19E-02
	1.0601	0.001373	4.747E+07	0.0200	1.15E-02	4.80E-02	1.01	5.570E-04	1.487E-01	1.178E-01	1.01	1.72E-03	1.36E-03
	1.2364	0.014933	4.747E+07	0.0200	1.25E-01	6.07E-01	1.02	7.728E-02	1.820E+00	1.441E+00	1.00	2.27E-01	1.80E-01
	1.2982	0.023306	4.747E+07	0.0200	1.95E-01	9.96E-01	1.02	1.980E-01	2.943E+00	2.330E+00	0.99	5.68E-01	4.49E-01
	1.3504	0.001485	4.747E+07	0.0200	1.24E-02	6.62E-02	1.03	8.465E-04	1.929E-01	1.527E-01	0.99	2.37E-03	1.88E-03
	0.53524	0.006072	4.747E+07	0.0200	5.08E-02	9.92E-02	0.99	4.984E-03	3.744E-01	2.967E-01	0.97	1.84E-02	1.46E-02
I-134	0.1354	0.037592	5.183E+07	0.0200	3.43E-01	3.23E-03	1.03	1.142E-03	4.014E-01	3.175E-01	1.02	1.40E-01	1.11E-01
	0.13903	0.006869	5.183E+07	0.0200	6.27E-02	8.09E-04	1.02	5.172E-05	7.565E-02	5.984E-02	1.02	4.84E-03	3.83E-03
	0.15198	0.001059	5.183E+07	0.0200	9.67E-03	3.36E-04	1.00	3.245E-06	1.300E-02	1.028E-02	1.00	1.26E-04	9.94E-05
	0.16248	0.002576	5.183E+07	0.0200	2.35E-02	1.11E-03	1.00	2.606E-05	3.442E-02	2.723E-02	0.98	7.93E-04	6.27E-04



Y/B 9/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	0.18847	0.006965	5.183E+07	0.0200	6.36E-02	6.22E-03	1.04	4.111E-04	1.132E-01	8.954E-02	0.97	6.98E-03	5.52E-03
	0.217	0.002481	5.183E+07	0.0200	2.26E-02	3.81E-03	1.06	9.148E-05	4.877E-02	3.859E-02	0.97	1.07E-03	8.48E-04
	0.23547	0.019845	5.183E+07	0.0200	1.81E-01	3.88E-02	1.05	7.372E-03	4.358E-01	3.449E-01	0.97	7.66E-02	6.06E-02
	0.2788	0.001307	5.183E+07	0.0200	1.19E-02	4.30E-03	1.02	5.233E-05	3.588E-02	2.840E-02	0.96	4.11E-04	3.25E-04
	0.31981	0.005152	5.183E+07	0.0200	4.70E-02	2.46E-02	1.00	1.156E-03	1.677E-01	1.327E-01	0.96	7.57E-03	5.99E-03
	0.35108	0.004961	5.183E+07	0.0200	4.53E-02	2.89E-02	1.00	1.308E-03	1.799E-01	1.424E-01	0.95	7.74E-03	6.12E-03
	0.40545	0.073466	5.183E+07	0.0200	6.71E-01	5.77E-01	1.00	3.870E-01	3.092E+00	2.448E+00	0.95	1.97E+00	1.56E+00
	0.411	0.006106	5.183E+07	0.0200	5.57E-02	4.91E-02	1.00	2.736E-03	2.603E-01	2.061E-01	0.95	1.38E-02	1.09E-02
	0.43335	0.041885	5.183E+07	0.0200	3.82E-01	3.68E-01	1.00	1.406E-01	1.873E+00	1.483E+00	0.95	6.80E-01	5.38E-01
	0.45892	0.012976	5.183E+07	0.0200	1.18E-01	1.25E-01	0.99	1.468E-02	6.084E-01	4.817E-01	0.96	6.92E-02	5.48E-02
	0.4655	0.003626	5.183E+07	0.0200	3.31E-02	3.58E-02	0.99	1.173E-03	1.719E-01	1.361E-01	0.96	5.46E-03	4.32E-03
	0.48888	0.014121	5.183E+07	0.0200	1.29E-01	1.51E-01	0.99	1.922E-02	6.936E-01	5.492E-01	0.96	8.58E-02	6.79E-02
	0.5144	0.023375	5.183E+07	0.0200	2.13E-01	3.48E-01	0.99	7.340E-02	1.437E+00	1.138E+00	0.97	2.97E-01	2.36E-01
	0.54083	0.078236	5.183E+07	0.0200	7.14E-01	1.31E+00	0.99	9.228E-01	4.835E+00	3.832E+00	0.97	3.35E+00	2.65E+00
	0.56552	0.008778	5.183E+07	0.0200	8.01E-02	1.59E-01	0.99	1.261E-02	5.524E-01	4.379E-01	0.98	4.34E-02	3.44E-02
	0.57075	0.002099	5.183E+07	0.0200	1.92E-02	3.86E-02	0.99	7.318E-04	1.327E-01	1.052E-01	0.98	2.49E-03	1.98E-03
	0.59536	0.11354	5.183E+07	0.0200	1.04E+00	2.22E+00	0.99	2.282E+00	7.374E+00	5.847E+00	0.99	7.57E+00	6.00E+00
	0.62179	0.10591	5.183E+07	0.0200	9.67E-01	2.19E+00	1.00	2.113E+00	7.111E+00	5.638E+00	0.99	6.81E+00	5.40E+00
	0.62796	0.023662	5.183E+07	0.0200	2.16E-01	4.94E-01	1.00	1.066E-01	1.601E+00	1.269E+00	0.99	3.42E-01	2.71E-01
	0.67734	0.084915	5.183E+07	0.0200	7.75E-01	1.91E+00	1.00	1.484E+00	6.147E+00	4.872E+00	1.00	4.76E+00	3.78E+00
	0.70665	0.008301	5.183E+07	0.0200	7.58E-02	1.95E-01	1.00	1.479E-02	6.256E-01	4.957E-01	1.01	4.79E-02	3.79E-02
	0.73074	0.019082	5.183E+07	0.0200	1.74E-01	4.64E-01	1.01	8.156E-02	1.484E+00	1.176E+00	1.01	2.61E-01	2.07E-01
	0.73918	0.007633	5.183E+07	0.0200	6.97E-02	1.88E-01	1.01	1.320E-02	6.003E-01	4.756E-01	1.01	4.22E-02	3.35E-02
	0.76668	0.041026	5.183E+07	0.0200	3.74E-01	1.05E+00	1.01	3.959E-01	3.341E+00	2.647E+00	1.01	1.26E+00	1.00E+00
	0.81638	0.005248	5.183E+07	0.0200	4.79E-02	1.43E-01	1.01	6.896E-03	4.534E-01	3.591E-01	1.02	2.22E-02	1.75E-02
	0.84702	0.9541	5.183E+07	0.0200	8.71E+00	2.68E+01	1.01	2.356E+02	8.528E+01	6.754E+01	1.02	7.57E+02	6.00E+02
	0.85729	0.069649	5.183E+07	0.0200	6.36E-01	1.98E+00	1.01	1.270E+00	6.295E+00	4.985E+00	1.02	4.08E+00	3.23E+00
	0.864	0.001908	5.183E+07	0.0200	1.74E-02	5.46E-02	1.01	9.599E-04	1.737E-01	1.375E-01	1.02	3.08E-03	2.44E-03
	0.88409	0.6526	5.183E+07	0.0200	5.96E+00	1.91E+01	1.01	1.148E+02	6.064E+01	4.802E+01	1.01	3.65E+02	2.89E+02
	0.9226	0.001431	5.183E+07	0.0200	1.31E-02	4.36E-02	1.01	5.757E-04	1.381E-01	1.093E-01	1.01	1.82E-03	1.44E-03
	0.94786	0.040358	5.183E+07	0.0200	3.68E-01	1.27E+00	1.01	4.708E-01	3.986E+00	3.156E+00	1.01	1.48E+00	1.17E+00
	0.9669	0.00353	5.183E+07	0.0200	3.22E-02	1.13E-01	1.01	3.679E-03	3.546E-01	2.808E-01	1.01	1.15E-02	9.14E-03
	0.97467	0.046751	5.183E+07	0.0200	4.27E-01	1.51E+00	1.01	6.508E-01	4.727E+00	3.743E+00	1.01	2.04E+00	1.61E+00
	1.0403	0.019082	5.183E+07	0.0200	1.74E-01	6.56E-01	1.01	1.155E-01	2.036E+00	1.612E+00	1.01	3.58E-01	2.84E-01

1. The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that proper record-keeping is essential for the integrity of the financial system and for the ability to detect and prevent fraud.

2. The second part of the document outlines the specific requirements for record-keeping. It states that all transactions must be recorded in a timely and accurate manner, and that the records must be maintained for a minimum of five years.

3. The third part of the document discusses the role of the auditor in verifying the accuracy of the records. It states that the auditor must perform a thorough review of the records and must report any discrepancies to the appropriate authorities.

4. The fourth part of the document discusses the consequences of failing to maintain accurate records. It states that individuals or organizations that fail to comply with the record-keeping requirements may be subject to fines and penalties.

5. The fifth part of the document discusses the importance of training and education in the field of record-keeping. It states that individuals involved in record-keeping must receive appropriate training and education to ensure that they are able to perform their duties accurately and efficiently.

6. The sixth part of the document discusses the importance of internal controls in the record-keeping process. It states that organizations must implement effective internal controls to ensure that the records are accurate and complete.

7. The seventh part of the document discusses the importance of regular audits in the record-keeping process. It states that organizations must conduct regular audits to ensure that the records are accurate and complete.

8. The eighth part of the document discusses the importance of transparency in the record-keeping process. It states that organizations must be transparent about their record-keeping practices and must provide access to the records to the appropriate authorities.

9. The ninth part of the document discusses the importance of data security in the record-keeping process. It states that organizations must implement effective data security measures to protect the records from unauthorized access and disclosure.

10. The tenth part of the document discusses the importance of ongoing monitoring and evaluation of the record-keeping process. It states that organizations must regularly monitor and evaluate their record-keeping practices to ensure that they are effective and efficient.

V/S *[Signature]*
3/4/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont.	27A&B	27A&B		27E	27F	27E&F		
					Conc. (uCi/cc)	QAD Det. Response (Rad/hr)	Eff.	27A&B Response (Rad/hr)	QAD Det. Response (Rad/hr)	QAD Det. Response (Rad/hr)	Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	1.0726	0.15266	5.183E+07	0.0200	1.39E+00	5.40E+00	1.01	7.601E+00	1.669E+01	1.322E+01	1.01	2.35E+01	1.86E+01
	1.1001	0.006869	5.183E+07	0.0200	6.27E-02	2.49E-01	1.01	1.575E-02	7.661E-01	6.065E-01	1.00	4.80E-02	3.80E-02
	1.1032	0.007251	5.183E+07	0.0200	6.62E-02	2.63E-01	1.01	1.760E-02	8.105E-01	6.417E-01	1.00	5.36E-02	4.25E-02
	1.1362	0.097318	5.183E+07	0.0200	8.88E-01	3.64E+00	1.01	3.263E+00	1.113E+01	8.815E+00	1.00	9.89E+00	7.83E+00
	1.1591	0.00353	5.183E+07	0.0200	3.22E-02	1.34E-01	1.01	4.376E-03	4.099E-01	3.245E-01	1.00	1.32E-02	1.05E-02
	1.164	0.001336	5.183E+07	0.0200	1.22E-02	5.11E-02	1.02	6.357E-04	1.556E-01	1.232E-01	1.00	1.90E-03	1.50E-03
	1.19	0.00353	5.183E+07	0.0200	3.22E-02	1.38E-01	1.02	4.536E-03	4.181E-01	3.310E-01	1.00	1.35E-02	1.07E-02
	1.239	0.002099	5.183E+07	0.0200	1.92E-02	8.55E-02	1.02	1.670E-03	2.561E-01	2.028E-01	1.00	4.91E-03	3.88E-03
	1.2695	0.005629	5.183E+07	0.0200	5.14E-02	2.35E-01	1.02	1.232E-02	6.993E-01	5.536E-01	1.00	3.59E-02	2.84E-02
	1.3224	0.00105	5.183E+07	0.0200	9.58E-03	4.58E-02	1.03	4.516E-04	1.343E-01	1.063E-01	0.99	1.27E-03	1.01E-03
	1.336	0.001431	5.183E+07	0.0200	1.31E-02	6.31E-02	1.03	8.483E-04	1.844E-01	1.460E-01	0.99	2.38E-03	1.89E-03
	1.3526	0.004484	5.183E+07	0.0200	4.09E-02	2.00E-01	1.03	8.439E-03	5.830E-01	4.615E-01	0.99	2.36E-02	1.87E-02
	1.4143	0.002194	5.183E+07	0.0200	2.00E-02	1.03E-01	1.03	2.120E-03	2.943E-01	2.330E-01	0.99	5.83E-03	4.62E-03
	1.4282	0.001717	5.183E+07	0.0200	1.57E-02	8.14E-02	1.03	1.313E-03	2.320E-01	1.837E-01	0.99	3.60E-03	2.85E-03
	1.4314	0.001717	5.183E+07	0.0200	1.57E-02	8.16E-02	1.03	1.316E-03	2.324E-01	1.839E-01	0.99	3.60E-03	2.85E-03
	1.4552	0.022898	5.183E+07	0.0200	2.09E-01	1.11E+00	1.04	2.407E-01	3.134E+00	2.481E+00	0.99	6.48E-01	5.13E-01
	1.47	0.007728	5.183E+07	0.0200	7.05E-02	3.78E-01	1.04	2.771E-02	1.065E+00	8.427E-01	0.99	7.43E-02	5.88E-02
	1.5055	0.001145	5.183E+07	0.0200	1.05E-02	5.75E-02	1.04	6.247E-04	1.605E-01	1.270E-01	0.99	1.66E-03	1.31E-03
	1.5415	0.005057	5.183E+07	0.0200	4.62E-02	2.59E-01	1.04	1.243E-02	7.200E-01	5.700E-01	0.98	3.26E-02	2.58E-02
	1.6138	0.043602	5.183E+07	0.0200	3.98E-01	2.32E+00	1.05	9.706E-01	6.402E+00	5.068E+00	0.98	2.50E+00	1.98E+00
	1.6292	0.002576	5.183E+07	0.0200	2.35E-02	1.38E-01	1.05	3.416E-03	3.807E-01	3.014E-01	0.98	8.77E-03	6.94E-03
	1.6443	0.004007	5.183E+07	0.0200	3.66E-02	2.17E-01	1.06	8.410E-03	5.957E-01	4.716E-01	0.98	2.14E-02	1.69E-02
	1.6552	0.00229	5.183E+07	0.0200	2.09E-02	1.25E-01	1.06	2.763E-03	3.420E-01	2.708E-01	0.98	7.01E-03	5.55E-03
	1.7415	0.026715	5.183E+07	0.0200	2.44E-01	1.52E+00	1.07	3.969E-01	4.126E+00	3.267E+00	0.98	9.86E-01	7.81E-01
	1.8068	0.057246	5.183E+07	0.0200	5.22E-01	3.37E+00	1.08	1.901E+00	9.060E+00	7.172E+00	0.98	4.64E+00	3.67E+00
	1.9259	0.001813	5.183E+07	0.0200	1.65E-02	1.13E-01	1.09	2.038E-03	2.992E-01	2.369E-01	0.97	4.80E-03	3.80E-03
	2.0206	0.001717	5.183E+07	0.0200	1.57E-02	1.12E-01	1.10	1.924E-03	2.924E-01	2.315E-01	0.97	4.44E-03	3.52E-03
	2.1599	0.002099	5.183E+07	0.0200	1.92E-02	1.43E-01	1.12	3.068E-03	3.729E-01	2.953E-01	0.96	6.86E-03	5.43E-03
	2.3124	0.002385	5.183E+07	0.0200	2.18E-02	1.71E-01	1.14	4.235E-03	4.428E-01	3.505E-01	0.96	9.25E-03	7.32E-03
	2.4674	0.001527	5.183E+07	0.0200	1.39E-02	1.15E-01	1.16	1.851E-03	2.954E-01	2.339E-01	0.95	3.91E-03	3.10E-03
	1.7872	0.013348	5.183E+07	0.0200	1.22E-01	7.78E-01	1.07	1.014E-01	2.097E+00	1.660E+00	0.98	2.50E-01	1.98E-01
I-135	0.2205	0.017452	4.470E+07	0.0200	1.37E-01	2.81E-02	1.06	4.089E-03	3.506E-01	2.775E-01	0.97	4.67E-02	3.70E-02
	0.22972	0.002317	4.470E+07	0.0200	1.82E-02	4.20E-03	1.05	8.052E-05	4.921E-02	3.894E-02	0.97	8.71E-04	6.89E-04
	0.26426	0.00184	4.470E+07	0.0200	1.45E-02	5.11E-03	1.03	7.629E-05	4.711E-02	3.728E-02	0.97	6.62E-04	5.24E-04

VB
9/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont.	27A&B	27A&B	27E	27F	27E&F	27E Response (Rad/hr)	27F Response (Rad/hr)	
					Conc.	QAD Det.	Eff.	QAD Det.	QAD Det.	Eff.			
					Response (Rad/hr)	Response (Rad/hr)	Response (Rad/hr)	Response (Rad/hr)	Response (Rad/hr)				
	0.28845	0.030899	4.470E+07	0.0200	2.43E-01	1.13E-01	1.02	2.812E-02	8.857E-01	7.010E-01	0.96	2.07E-01	1.64E-01
	0.29027	0.003033	4.470E+07	0.0200	2.39E-02	1.14E-02	1.01	2.737E-04	8.763E-02	6.936E-02	0.96	2.01E-03	1.59E-03
	0.36185	0.00186	4.470E+07	0.0200	1.46E-02	1.15E-02	1.00	1.690E-04	6.969E-02	5.517E-02	0.95	9.69E-04	7.67E-04
	0.40303	0.002317	4.470E+07	0.0200	1.82E-02	1.80E-02	1.00	3.287E-04	9.697E-02	7.676E-02	0.95	1.68E-03	1.33E-03
	0.41483	0.003004	4.470E+07	0.0200	2.36E-02	2.45E-02	1.00	5.801E-04	1.292E-01	1.023E-01	0.95	2.90E-03	2.30E-03
	0.41763	0.03519	4.470E+07	0.0200	2.77E-01	2.91E-01	1.00	8.050E-02	1.523E+00	1.205E+00	0.95	4.01E-01	3.17E-01
	0.42993	0.003033	4.470E+07	0.0200	2.39E-02	2.63E-02	1.00	6.278E-04	1.347E-01	1.066E-01	0.95	3.05E-03	2.42E-03
	0.43374	0.005522	4.470E+07	0.0200	4.35E-02	4.86E-02	1.00	2.111E-03	2.471E-01	1.956E-01	0.95	1.02E-02	8.08E-03
	0.45163	0.003147	4.470E+07	0.0200	2.48E-02	2.96E-02	1.00	7.328E-04	1.457E-01	1.153E-01	0.95	3.43E-03	2.71E-03
	0.54656	0.071239	4.470E+07	0.0200	5.61E-01	1.21E+00	0.99	6.739E-01	4.418E+00	3.502E+00	0.97	2.40E+00	1.90E+00
	0.57597	0.001288	4.470E+07	0.0200	1.01E-02	2.40E-02	0.99	2.411E-04	8.185E-02	6.489E-02	0.98	8.13E-04	6.45E-04
	0.64985	0.004549	4.470E+07	0.0200	3.58E-02	9.84E-02	1.00	3.522E-03	3.171E-01	2.514E-01	1.00	1.14E-02	9.00E-03
	0.69013	0.001288	4.470E+07	0.0200	1.01E-02	2.96E-02	1.00	2.998E-04	9.486E-02	7.518E-02	1.00	9.62E-04	7.62E-04
	0.70792	0.00658	4.470E+07	0.0200	5.18E-02	1.55E-01	1.00	8.025E-03	4.965E-01	3.935E-01	1.01	2.60E-02	2.06E-02
	0.78548	0.001516	4.470E+07	0.0200	1.19E-02	3.97E-02	1.01	4.782E-04	1.263E-01	1.001E-01	1.01	1.52E-03	1.21E-03
	0.79771	0.001717	4.470E+07	0.0200	1.35E-02	4.57E-02	1.01	6.236E-04	1.452E-01	1.150E-01	1.01	1.98E-03	1.57E-03
	0.8368	0.066661	4.470E+07	0.0200	5.25E-01	1.85E+00	1.01	9.810E-01	5.893E+00	4.667E+00	1.02	3.15E+00	2.50E+00
	0.96146	0.001459	4.470E+07	0.0200	1.15E-02	4.64E-02	1.01	5.387E-04	1.458E-01	1.155E-01	1.01	1.69E-03	1.34E-03
	0.97196	0.008869	4.470E+07	0.0200	6.98E-02	2.86E-01	1.01	2.014E-02	8.948E-01	7.085E-01	1.01	6.31E-02	5.00E-02
	0.97261	0.012016	4.470E+07	0.0200	9.46E-02	3.87E-01	1.01	3.700E-02	1.213E+00	9.606E-01	1.01	1.16E-01	9.18E-02
	0.99509	0.001545	4.470E+07	0.0200	1.22E-02	5.10E-02	1.01	6.268E-04	1.589E-01	1.259E-01	1.01	1.95E-03	1.55E-03
	1.0388	0.07925	4.470E+07	0.0200	6.24E-01	2.72E+00	1.01	1.716E+00	8.448E+00	6.689E+00	1.01	5.32E+00	4.21E+00
	1.1016	0.016022	4.470E+07	0.0200	1.26E-01	5.81E-01	1.01	7.402E-02	1.789E+00	1.416E+00	1.00	2.26E-01	1.79E-01
	1.124	0.036049	4.470E+07	0.0200	2.84E-01	1.33E+00	1.01	3.820E-01	4.089E+00	3.237E+00	1.00	1.16E+00	9.19E-01
	1.1315	0.22516	4.470E+07	0.0200	1.77E+00	8.38E+00	1.01	1.500E+01	2.567E+01	2.032E+01	1.00	4.55E+01	3.60E+01
	1.1599	0.00103	4.470E+07	0.0200	8.11E-03	3.93E-02	1.02	3.247E-04	1.197E-01	9.474E-02	1.00	9.70E-04	7.68E-04
	1.169	0.008726	4.470E+07	0.0200	6.87E-02	3.35E-01	1.02	2.349E-02	1.020E+00	8.074E-01	1.00	7.00E-02	5.55E-02
	1.2405	0.009012	4.470E+07	0.0200	7.09E-02	3.68E-01	1.02	2.659E-02	1.101E+00	8.715E-01	1.00	7.81E-02	6.18E-02
	1.2604	0.2861	4.470E+07	0.0200	2.25E+00	1.19E+01	1.02	2.724E+01	3.536E+01	2.799E+01	1.00	7.96E+01	6.30E+01
	1.3679	0.006065	4.470E+07	0.0200	4.77E-02	2.74E-01	1.03	1.348E-02	7.949E-01	6.293E-01	0.99	3.76E-02	2.97E-02
	1.4484	0.003147	4.470E+07	0.0200	2.48E-02	1.51E-01	1.04	3.900E-03	4.293E-01	3.398E-01	0.99	1.05E-02	8.33E-03
	1.4576	0.086402	4.470E+07	0.0200	6.80E-01	4.19E+00	1.04	2.962E+00	1.184E+01	9.375E+00	0.99	7.97E+00	6.31E+00
	1.5028	0.010729	4.470E+07	0.0200	8.45E-02	5.38E-01	1.04	4.723E-02	1.502E+00	1.189E+00	0.99	1.26E-01	9.94E-02
	1.5664	0.012875	4.470E+07	0.0200	1.01E-01	6.69E-01	1.05	7.115E-02	1.853E+00	1.467E+00	0.98	1.84E-01	1.46E-01



u/B 9022
7/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	1.678	0.095271	4.470E+07	0.0200	7.50E-01	5.25E+00	1.06	4.173E+00	1.436E+01	1.136E+01	0.98	1.05E+01	8.35E+00
	1.7065	0.040912	4.470E+07	0.0200	3.22E-01	2.29E+00	1.06	7.812E-01	6.235E+00	4.936E+00	0.98	1.97E+00	1.56E+00
	1.7912	0.076961	4.470E+07	0.0200	6.06E-01	4.49E+00	1.07	2.912E+00	1.211E+01	9.585E+00	0.98	7.19E+00	5.69E+00
	1.8307	0.005779	4.470E+07	0.0200	4.55E-02	3.44E-01	1.08	1.690E-02	9.225E-01	7.303E-01	0.98	4.11E-02	3.26E-02
	1.9273	0.002947	4.470E+07	0.0200	2.32E-02	1.84E-01	1.09	4.648E-03	4.866E-01	3.852E-01	0.97	1.09E-02	8.67E-03
	2.0459	0.008697	4.470E+07	0.0200	6.85E-02	5.70E-01	1.11	4.333E-02	1.492E+00	1.181E+00	0.97	9.91E-02	7.85E-02
	2.2555	0.006123	4.470E+07	0.0200	4.82E-02	4.30E-01	1.13	2.343E-02	1.119E+00	8.856E-01	0.96	5.18E-02	4.10E-02
	2.4087	0.009527	4.470E+07	0.0200	7.50E-02	7.02E-01	1.15	6.054E-02	1.815E+00	1.437E+00	0.95	1.29E-01	1.02E-01
	1.0734	0.014948	4.470E+07	0.0200	1.18E-01	5.29E-01	1.01	6.290E-02	1.636E+00	1.295E+00	1.01	1.94E-01	1.54E-01
Kr-85	0.51399	0.00434	8.915E+05	0.0300	1.02E-03	6.44E-02	0.99	6.514E-05	2.668E-01	2.113E-01	0.97	2.64E-04	2.09E-04
Kr-85m	0.30487	0.13989	1.976E+07	0.0300	7.30E-01	6.03E-01	1.01	4.444E-01	4.296E+00	3.400E+00	0.96	3.01E+00	2.38E+00
	0.00169	0.000586	1.976E+07	0.0300	3.06E-03	0.00E+00	0	0.000E+00	9.001E+10	7.101E+10	0	0.00E+00	0.00E+00
	0.013336	0.006116	1.976E+07	0.0300	3.19E-02	0.00E+00	0	0.000E+00	2.476E+00	1.954E+00	0	0.00E+00	0.00E+00
	0.013395	0.01183	1.976E+07	0.0300	6.17E-02	0.00E+00	0	0.000E+00	4.664E+00	3.681E+00	0	0.00E+00	0.00E+00
	0.015	0.003105	1.976E+07	0.0300	1.62E-02	0.00E+00	0	0.000E+00	6.416E-01	5.064E-01	0	0.00E+00	0.00E+00
	0.12985	0.003011	1.976E+07	0.0300	1.57E-02	1.59E-04	1.05	2.627E-06	3.065E-02	2.424E-02	1.02	4.91E-04	3.89E-04
	0.15118	0.75278	1.976E+07	0.0300	3.93E+00	2.33E-01	1.00	9.163E-01	9.181E+00	7.263E+00	1.00	3.61E+01	2.85E+01
	0.58128	0.000211	1.976E+07	0.0300	1.10E-03	3.99E-03	0.99	4.352E-06	1.348E-02	1.069E-02	0.98	1.46E-05	1.15E-05
Kr-87	0.40258	0.495	3.671E+07	0.0300	4.80E+00	3.84E+00	1.00	1.844E+01	2.069E+01	1.638E+01	0.95	9.44E+01	7.47E+01
	0.67387	0.019058	3.671E+07	0.0300	1.85E-01	4.27E-01	1.00	7.898E-02	1.373E+00	1.088E+00	1.00	2.54E-01	2.01E-01
	0.81425	0.001683	3.671E+07	0.0300	1.63E-02	4.56E-02	1.01	7.516E-04	1.450E-01	1.149E-01	1.02	2.41E-03	1.91E-03
	0.83637	0.007524	3.671E+07	0.0300	7.30E-02	2.09E-01	1.01	1.539E-02	6.648E-01	5.266E-01	1.02	4.95E-02	3.92E-02
	0.84543	0.072765	3.671E+07	0.0300	7.06E-01	2.04E+00	1.01	1.454E+00	6.493E+00	5.143E+00	1.02	4.67E+00	3.70E+00
	0.94664	0.001386	3.671E+07	0.0300	1.34E-02	4.34E-02	1.01	5.891E-04	1.367E-01	1.082E-01	1.01	1.86E-03	1.47E-03
	1.1754	0.011237	3.671E+07	0.0300	1.09E-01	4.34E-01	1.02	4.823E-02	1.319E+00	1.044E+00	1.00	1.44E-01	1.14E-01
	1.338	0.006484	3.671E+07	0.0300	6.29E-02	2.86E-01	1.03	1.853E-02	8.366E-01	6.623E-01	0.99	5.21E-02	4.12E-02
	1.3825	0.002871	3.671E+07	0.0300	2.78E-02	1.31E-01	1.03	3.764E-03	3.791E-01	3.001E-01	0.99	1.04E-02	8.27E-03
	1.3899	0.001237	3.671E+07	0.0300	1.20E-02	5.69E-02	1.03	7.029E-04	1.640E-01	1.298E-01	0.99	1.95E-03	1.54E-03
	1.5312	0.003564	3.671E+07	0.0300	3.46E-02	1.81E-01	1.04	6.523E-03	5.051E-01	3.999E-01	0.98	1.71E-02	1.35E-02
	1.578	0.001287	3.671E+07	0.0300	1.25E-02	6.72E-02	1.05	8.812E-04	1.862E-01	1.474E-01	0.98	2.28E-03	1.80E-03
	1.6112	0.00104	3.671E+07	0.0300	1.01E-02	5.53E-02	1.05	5.858E-04	1.525E-01	1.208E-01	0.98	1.51E-03	1.19E-03
	1.7405	0.020493	3.671E+07	0.0300	1.99E-01	1.17E+00	1.07	2.480E-01	3.165E+00	2.506E+00	0.98	6.16E-01	4.88E-01
	1.8426	0.001386	3.671E+07	0.0300	1.34E-02	8.30E-02	1.08	1.205E-03	2.222E-01	1.759E-01	0.97	2.90E-03	2.29E-03
	2.0119	0.028957	3.671E+07	0.0300	2.81E-01	1.88E+00	1.10	5.796E-01	4.916E+00	3.892E+00	0.97	1.34E+00	1.06E+00



u/b R. J. Haynes
9/11/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	2.4085	0.002129	3.671E+07	0.0300	2.06E-02	1.57E-01	1.15	3.724E-03	4.056E-01	3.211E-01	0.95	7.96E-03	6.30E-03
	2.5548	0.09306	3.671E+07	0.0300	9.02E-01	7.16E+00	1.17	7.561E+00	1.841E+01	1.458E+01	0.94	1.56E+01	1.24E+01
	2.5581	0.039105	3.671E+07	0.0300	3.79E-01	3.01E+00	1.17	1.336E+00	7.743E+00	6.129E+00	0.94	2.76E+00	2.18E+00
	2.8114	0.003168	3.671E+07	0.0300	3.07E-02	2.62E-01	1.19	9.578E-03	6.662E-01	5.274E-01	0.92	1.88E-02	1.49E-02
	3.3085	0.004504	3.671E+07	0.0300	4.37E-02	4.15E-01	1.20	2.177E-02	1.050E+00	8.310E-01	0.85	3.90E-02	3.08E-02
	1.6201	0.006499	3.671E+07	0.0300	6.30E-02	3.47E-01	1.05	2.299E-02	9.567E-01	7.574E-01	0.98	5.91E-02	4.68E-02
Kr-88	0.12227	0.001972	5.139E+07	0.0300	2.68E-02	5.33E-05	1.08	1.540E-06	1.879E-02	1.486E-02	1.01	5.08E-04	4.02E-04
	0.16598	0.031036	5.139E+07	0.0300	4.21E-01	1.48E-02	1.01	6.282E-03	4.263E-01	3.373E-01	0.98	1.76E-01	1.39E-01
	0.19632	0.25985	5.139E+07	0.0300	3.53E+00	2.87E-01	1.05	1.063E+00	4.460E+00	3.529E+00	0.97	1.53E+01	1.21E+01
	0.24071	0.002526	5.139E+07	0.0300	3.43E-02	5.27E-03	1.05	1.897E-04	5.712E-02	4.521E-02	0.97	1.90E-03	1.50E-03
	0.31169	0.001073	5.139E+07	0.0300	1.46E-02	4.85E-03	1.01	7.129E-05	3.386E-02	2.680E-02	0.96	4.73E-04	3.75E-04
	0.33471	0.001453	5.139E+07	0.0300	1.97E-02	7.64E-03	1.00	1.507E-04	4.989E-02	3.949E-02	0.95	9.35E-04	7.40E-04
	0.36223	0.02249	5.139E+07	0.0300	3.05E-01	1.40E-01	1.00	4.273E-02	8.439E-01	6.680E-01	0.95	2.45E-01	1.94E-01
	0.39054	0.006436	5.139E+07	0.0300	8.74E-02	4.70E-02	1.00	4.104E-03	2.612E-01	2.067E-01	0.95	2.17E-02	1.72E-02
	0.4217	0.00128	5.139E+07	0.0300	1.74E-02	1.07E-02	1.00	1.867E-04	5.589E-02	4.424E-02	0.95	9.22E-04	7.30E-04
	0.4718	0.007266	5.139E+07	0.0300	9.86E-02	7.33E-02	0.99	7.155E-03	3.479E-01	2.755E-01	0.96	3.29E-02	2.61E-02
	0.67734	0.002353	5.139E+07	0.0300	3.19E-02	5.30E-02	1.00	1.694E-03	1.703E-01	1.350E-01	1.00	5.44E-03	4.31E-03
	0.78828	0.005328	5.139E+07	0.0300	7.23E-02	1.40E-01	1.01	1.022E-02	4.455E-01	3.529E-01	1.01	3.25E-02	2.58E-02
	0.79032	0.001246	5.139E+07	0.0300	1.69E-02	3.28E-02	1.01	5.608E-04	1.045E-01	8.275E-02	1.01	1.78E-03	1.41E-03
	0.83483	0.12975	5.139E+07	0.0300	1.76E+00	3.60E+00	1.01	6.396E+00	1.145E+01	9.066E+00	1.02	2.06E+01	1.63E+01
	0.85034	0.00173	5.139E+07	0.0300	2.35E-02	4.88E-02	1.01	1.156E-03	1.552E-01	1.229E-01	1.02	3.72E-03	2.94E-03
	0.86233	0.006712	5.139E+07	0.0300	9.11E-02	1.92E-01	1.01	1.764E-02	6.098E-01	4.830E-01	1.02	5.67E-02	4.49E-02
	0.94492	0.002941	5.139E+07	0.0300	3.99E-02	9.19E-02	1.01	3.707E-03	2.897E-01	2.294E-01	1.01	1.17E-02	9.25E-03
	0.98578	0.013148	5.139E+07	0.0300	1.78E-01	4.30E-01	1.01	7.751E-02	1.342E+00	1.063E+00	1.01	2.42E-01	1.92E-01
	0.99009	0.001419	5.139E+07	0.0300	1.93E-02	4.66E-02	1.01	9.069E-04	1.454E-01	1.151E-01	1.01	2.83E-03	2.24E-03
	1.0396	0.004844	5.139E+07	0.0300	6.58E-02	1.67E-01	1.01	1.106E-02	5.165E-01	4.090E-01	1.01	3.43E-02	2.72E-02
	1.0495	0.001419	5.139E+07	0.0300	1.93E-02	4.92E-02	1.01	9.572E-04	1.525E-01	1.207E-01	1.01	2.97E-03	2.35E-03
	1.1413	0.012837	5.139E+07	0.0300	1.74E-01	4.82E-01	1.01	8.480E-02	1.474E+00	1.167E+00	1.00	2.57E-01	2.03E-01
	1.1795	0.009965	5.139E+07	0.0300	1.35E-01	3.86E-01	1.02	5.327E-02	1.172E+00	9.279E-01	1.00	1.59E-01	1.26E-01
	1.185	0.006885	5.139E+07	0.0300	9.35E-02	2.68E-01	1.02	2.556E-02	8.129E-01	6.436E-01	1.00	7.60E-02	6.01E-02
	1.2098	0.001419	5.139E+07	0.0300	1.93E-02	5.64E-02	1.02	1.108E-03	1.701E-01	1.347E-01	1.00	3.28E-03	2.59E-03
	1.2127	0.001384	5.139E+07	0.0300	1.88E-02	5.52E-02	1.02	1.057E-03	1.663E-01	1.316E-01	1.00	3.12E-03	2.47E-03
	1.2452	0.003633	5.139E+07	0.0300	4.93E-02	1.49E-01	1.02	7.481E-03	4.450E-01	3.523E-01	1.00	2.19E-02	1.74E-02
	1.2507	0.01121	5.139E+07	0.0300	1.52E-01	4.61E-01	1.02	7.157E-02	1.378E+00	1.091E+00	1.00	2.10E-01	1.66E-01



Case #6- Rad Failure
CMS-RE-27A,B, Detector Response

Calc. No.: NE-02-94-1
Prepared By: S. J. Hayne
page: 5.080

4/13 922
5/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	1.325	0.001592	5.139E+07	0.0300	2.16E-02	6.95E-02	1.03	1.548E-03	2.040E-01	1.615E-01	0.99	4.36E-03	3.46E-03
	1.3523	0.001592	5.139E+07	0.0300	2.16E-02	7.11E-02	1.03	1.582E-03	2.070E-01	1.639E-01	0.99	4.43E-03	3.51E-03
	1.3695	0.014774	5.139E+07	0.0300	2.01E-01	6.69E-01	1.03	1.381E-01	1.938E+00	1.535E+00	0.99	3.85E-01	3.05E-01
	1.4069	0.00218	5.139E+07	0.0300	2.96E-02	1.02E-01	1.03	3.096E-03	2.914E-01	2.307E-01	0.99	8.54E-03	6.76E-03
	1.4648	0.001142	5.139E+07	0.0300	1.55E-02	5.56E-02	1.04	8.966E-04	1.570E-01	1.243E-01	0.99	2.41E-03	1.91E-03
	1.5184	0.021521	5.139E+07	0.0300	2.92E-01	1.09E+00	1.04	3.305E-01	3.033E+00	2.401E+00	0.98	8.68E-01	6.87E-01
	1.5298	0.10934	5.139E+07	0.0300	1.48E+00	5.56E+00	1.04	8.587E+00	1.549E+01	1.226E+01	0.98	2.25E+01	1.78E+01
	1.6038	0.004567	5.139E+07	0.0300	6.20E-02	2.42E-01	1.05	1.575E-02	6.678E-01	5.287E-01	0.98	4.06E-02	3.21E-02
	1.6856	0.006643	5.139E+07	0.0300	9.02E-02	7.37E-01	1.06	7.048E-02	1.004E+00	7.950E-01	0.98	8.87E-02	7.03E-02
	1.8928	0.001384	5.139E+07	0.0300	1.88E-02	1.66E-01	1.09	3.396E-03	2.259E-01	1.788E-01	0.97	4.12E-03	3.26E-03
	1.9087	0.001003	5.139E+07	0.0300	1.36E-02	1.21E-01	1.09	1.793E-03	1.645E-01	1.303E-01	0.97	2.17E-03	1.72E-03
	2.0298	0.045291	5.139E+07	0.0300	6.15E-01	5.68E+00	1.10	3.840E+00	7.733E+00	6.122E+00	0.97	4.61E+00	3.65E+00
	2.0354	0.037368	5.139E+07	0.0300	5.07E-01	4.69E+00	1.10	2.619E+00	6.392E+00	5.060E+00	0.97	3.14E+00	2.49E+00
	2.1865	0.002872	5.139E+07	0.0300	3.90E-02	3.78E-01	1.12	1.649E-02	5.144E-01	4.072E-01	0.96	1.93E-02	1.52E-02
	2.1958	0.13183	5.139E+07	0.0300	1.79E+00	1.74E+01	1.13	3.517E+01	2.368E+01	1.875E+01	0.96	4.07E+01	3.22E+01
	2.2318	0.033908	5.139E+07	0.0300	4.60E-01	4.52E+00	1.13	2.350E+00	6.154E+00	4.872E+00	0.96	2.72E+00	2.15E+00
	2.3521	0.007301	5.139E+07	0.0300	9.91E-02	1.01E+00	1.14	1.137E-01	1.370E+00	1.085E+00	0.96	1.30E-01	1.03E-01
	2.3921	0.346	5.139E+07	0.0300	4.70E+00	4.82E+01	1.15	2.603E+02	6.565E+01	5.197E+01	0.95	2.93E+02	2.32E+02
	2.4089	0.001038	5.139E+07	0.0300	1.41E-02	1.45E-01	1.15	2.354E-03	1.979E-01	1.567E-01	0.95	2.65E-03	2.10E-03
	2.5484	0.006228	5.139E+07	0.0300	8.45E-02	9.03E-01	1.17	8.935E-02	1.230E+00	9.739E-01	0.94	9.78E-02	7.74E-02
	2.771	0.001488	5.139E+07	0.0300	2.02E-02	2.28E-01	1.19	5.473E-03	3.101E-01	2.455E-01	0.93	5.83E-03	4.61E-03
	1.0001	0.018892	5.139E+07	0.0300	2.56E-01	1.43E+00	1.01	3.712E-01	1.952E+00	1.545E+00	1.01	5.06E-01	4.00E-01
Kr-89	0.1962	0.0022	6.082E+07	0.0300	3.53E-02	2.42E-03	1.05	8.993E-05	3.774E-02	2.986E-02	0.97	1.29E-03	1.02E-03
	0.1975	0.0182	6.082E+07	0.0300	2.92E-01	2.08E-02	1.05	6.372E-03	3.149E-01	2.492E-01	0.97	8.93E-02	7.07E-02
	0.20503	0.00124	6.082E+07	0.0300	1.99E-02	1.62E-03	1.05	3.391E-05	2.258E-02	1.787E-02	0.98	4.41E-04	3.49E-04
	0.2209	0.2	6.082E+07	0.0300	3.21E+00	3.24E-01	1.06	1.102E+00	4.028E+00	3.187E+00	0.97	1.26E+01	9.93E+00
	0.26411	0.0066	6.082E+07	0.0300	1.06E-01	1.83E-02	1.03	1.999E-03	1.688E-01	1.336E-01	0.97	1.74E-02	1.37E-02
	0.3382	0.00342	6.082E+07	0.0300	5.49E-02	1.84E-02	1.00	1.010E-03	1.189E-01	9.409E-02	0.95	6.20E-03	4.91E-03
	0.34503	0.0118	6.082E+07	0.0300	1.90E-01	6.62E-02	1.00	1.255E-02	4.195E-01	3.321E-01	0.95	7.56E-02	5.98E-02
	0.35606	0.0414	6.082E+07	0.0300	6.65E-01	2.48E-01	1.00	1.652E-01	1.524E+00	1.207E+00	0.95	9.63E-01	7.62E-01
	0.36488	0.009	6.082E+07	0.0300	1.45E-01	5.69E-02	1.00	8.221E-03	3.402E-01	2.693E-01	0.95	4.67E-02	3.70E-02
	0.3693	0.0138	6.082E+07	0.0300	2.22E-01	8.94E-02	1.00	1.983E-02	5.285E-01	4.184E-01	0.95	1.11E-01	8.81E-02
	0.40225	0.00318	6.082E+07	0.0300	5.11E-02	2.46E-02	1.00	1.259E-03	1.328E-01	1.052E-01	0.95	6.45E-03	5.10E-03
	0.41142	0.0256	6.082E+07	0.0300	4.11E-01	2.06E-01	1.00	8.478E-02	1.092E+00	8.648E-01	0.95	4.27E-01	3.38E-01



u/b
9/22/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	0.43808	0.0096	6.082E+07	0.0300	1.54E-01	8.59E-02	1.00	1.324E-02	4.333E-01	0.95	6.35E-02	5.03E-02
	0.46613	0.008	6.082E+07	0.0300	1.29E-01	7.92E-02	0.99	1.007E-02	3.797E-01	0.96	4.69E-02	3.71E-02
	0.49076	0.00322	6.082E+07	0.0300	5.17E-02	3.46E-02	0.99	1.770E-03	1.586E-01	0.96	7.87E-03	6.23E-03
	0.4975	0.0664	6.082E+07	0.0300	1.07E+00	7.28E-01	0.99	7.687E-01	3.300E+00	0.96	3.38E+00	2.68E+00
	0.4986	0.0114	6.082E+07	0.0300	1.83E-01	1.25E-01	0.99	2.274E-02	5.675E-01	0.96	9.98E-02	7.90E-02
	0.5573	0.0016	6.082E+07	0.0300	2.57E-02	2.83E-02	0.99	7.189E-04	9.996E-02	0.98	2.52E-03	2.00E-03
	0.57696	0.0564	6.082E+07	0.0300	9.06E-01	1.05E+00	0.99	9.462E-01	3.588E+00	0.98	3.19E+00	2.53E+00
	0.5858	0.166	6.082E+07	0.0300	2.67E+00	3.18E+00	0.99	8.388E+00	1.066E+01	0.98	2.79E+01	2.21E+01
	0.6262	0.006	6.082E+07	0.0300	9.64E-02	1.25E-01	1.00	1.203E-02	4.051E-01	0.99	3.87E-02	3.06E-02
	0.62975	0.00342	6.082E+07	0.0300	5.49E-02	7.16E-02	1.00	3.932E-03	2.320E-01	0.99	1.26E-02	1.00E-02
	0.66572	0.00114	6.082E+07	0.0300	1.83E-02	2.53E-02	1.00	4.626E-04	8.122E-02	1.00	1.49E-03	1.18E-03
	0.6714	0.00106	6.082E+07	0.0300	1.70E-02	2.37E-02	1.00	4.034E-04	7.612E-02	1.00	1.30E-03	1.03E-03
	0.67411	0.00232	6.082E+07	0.0300	3.73E-02	5.21E-02	1.00	1.940E-03	1.672E-01	1.00	6.23E-03	4.94E-03
	0.69624	0.0178	6.082E+07	0.0300	2.86E-01	4.12E-01	1.00	1.179E-01	1.322E+00	1.01	3.82E-01	3.03E-01
	0.70701	0.00498	6.082E+07	0.0300	8.00E-02	1.17E-01	1.00	9.370E-03	3.753E-01	1.01	3.03E-02	2.40E-02
	0.71005	0.0078	6.082E+07	0.0300	1.25E-01	1.84E-01	1.00	2.308E-02	5.902E-01	1.01	7.47E-02	5.92E-02
	0.72963	0.00296	6.082E+07	0.0300	4.76E-02	7.18E-02	1.01	3.449E-03	2.299E-01	1.01	1.10E-02	8.75E-03
	0.73839	0.042	6.082E+07	0.0300	6.75E-01	1.03E+00	1.01	7.029E-01	3.300E+00	1.01	2.25E+00	1.78E+00
	0.7474	0.00114	6.082E+07	0.0300	1.83E-02	2.83E-02	1.01	5.242E-04	9.061E-02	1.01	1.68E-03	1.33E-03
	0.7629	0.004	6.082E+07	0.0300	6.43E-02	1.02E-01	1.01	6.590E-03	3.242E-01	1.01	2.10E-02	1.67E-02
	0.7629	0.0092	6.082E+07	0.0300	1.48E-01	2.34E-01	1.01	3.486E-02	7.457E-01	1.01	1.11E-01	8.82E-02
	0.77649	0.0112	6.082E+07	0.0300	1.80E-01	2.90E-01	1.01	5.261E-02	9.229E-01	1.01	1.68E-01	1.33E-01
	0.82675	0.0076	6.082E+07	0.0300	1.22E-01	2.09E-01	1.01	2.575E-02	6.647E-01	1.02	8.28E-02	6.56E-02
	0.83553	0.011	6.082E+07	0.0300	1.77E-01	3.05E-01	1.01	5.446E-02	9.712E-01	1.02	1.75E-01	1.39E-01
	0.85737	0.00286	6.082E+07	0.0300	4.59E-02	8.12E-02	1.01	3.769E-03	2.585E-01	1.02	1.21E-02	9.59E-03
	0.86708	0.0592	6.082E+07	0.0300	9.51E-01	1.70E+00	1.01	1.632E+00	5.405E+00	1.02	5.24E+00	4.15E+00
	0.87042	0.0016	6.082E+07	0.0300	2.57E-02	4.61E-02	1.01	1.196E-03	1.466E-01	1.02	3.84E-03	3.04E-03
	0.90427	0.0718	6.082E+07	0.0300	1.15E+00	2.15E+00	1.01	2.500E+00	6.806E+00	1.01	7.93E+00	6.28E+00
	0.93095	0.0062	6.082E+07	0.0300	9.96E-02	1.91E-01	1.01	1.920E-02	6.029E-01	1.01	6.06E-02	4.80E-02
	0.94419	0.00164	6.082E+07	0.0300	2.63E-02	5.12E-02	1.01	1.363E-03	1.614E-01	1.01	4.29E-03	3.40E-03
	0.95318	0.00106	6.082E+07	0.0300	1.70E-02	3.34E-02	1.01	5.752E-04	1.052E-01	1.01	1.81E-03	1.43E-03
	0.96042	0.00322	6.082E+07	0.0300	5.17E-02	1.02E-01	1.01	5.349E-03	3.216E-01	1.01	1.68E-02	1.33E-02
	0.97439	0.0098	6.082E+07	0.0300	1.57E-01	3.16E-01	1.01	5.030E-02	9.903E-01	1.01	1.57E-01	1.25E-01
	0.99737	0.0066	6.082E+07	0.0300	1.06E-01	2.19E-01	1.01	2.341E-02	6.803E-01	1.01	7.29E-02	5.77E-02



Case #6- [redacted] ad Failure
CMS-RE-27A,B,E [redacted] Detector Response

Calc. No.: NE-02-94 [redacted] v 1
Prepared By: S. J. Haynes [redacted] /94
page: 5.082

u/s
9/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	1.0108	0.00108	6.082E+07	0.0300	1.74E-02	3.62E-02	1.01	6.345E-04	1.126E-01	8.911E-02	1.01	1.97E-03	1.56E-03
	1.0444	0.00408	6.082E+07	0.0300	6.55E-02	1.41E-01	1.01	9.324E-03	4.367E-01	3.457E-01	1.01	2.89E-02	2.29E-02
	1.0765	0.00236	6.082E+07	0.0300	3.79E-02	8.38E-02	1.01	3.208E-03	2.588E-01	2.049E-01	1.01	9.91E-03	7.85E-03
	1.0881	0.00358	6.082E+07	0.0300	5.75E-02	1.28E-01	1.01	7.456E-03	3.959E-01	3.134E-01	1.00	2.28E-02	1.80E-02
	1.1032	0.009	6.082E+07	0.0300	1.45E-01	3.27E-01	1.01	4.772E-02	1.006E+00	7.963E-01	1.00	1.45E-01	1.15E-01
	1.1078	0.0292	6.082E+07	0.0300	4.69E-01	1.06E+00	1.01	5.045E-01	3.275E+00	2.593E+00	1.00	1.54E+00	1.22E+00
	1.1166	0.0166	6.082E+07	0.0300	2.67E-01	6.10E-01	1.01	1.643E-01	1.873E+00	1.483E+00	1.00	5.00E-01	3.95E-01
	1.1315	0.0016	6.082E+07	0.0300	2.57E-02	5.95E-02	1.01	1.546E-03	1.824E-01	1.444E-01	1.00	4.69E-03	3.71E-03
	1.1625	0.00214	6.082E+07	0.0300	3.44E-02	8.18E-02	1.02	2.867E-03	2.491E-01	1.972E-01	1.00	8.56E-03	6.78E-03
	1.1723	0.0098	6.082E+07	0.0300	1.57E-01	3.77E-01	1.02	6.060E-02	1.147E+00	9.083E-01	1.00	1.81E-01	1.43E-01
	1.1824	0.00166	6.082E+07	0.0300	2.67E-02	6.45E-02	1.02	1.754E-03	1.957E-01	1.549E-01	1.00	5.22E-03	4.13E-03
	1.1865	0.00184	6.082E+07	0.0300	2.96E-02	7.17E-02	1.02	2.163E-03	2.175E-01	1.722E-01	1.00	6.43E-03	5.09E-03
	1.2288	0.00144	6.082E+07	0.0300	2.31E-02	5.82E-02	1.02	1.372E-03	1.747E-01	1.383E-01	1.00	4.04E-03	3.20E-03
	1.2356	0.00594	6.082E+07	0.0300	9.54E-02	2.41E-01	1.02	2.348E-02	7.235E-01	5.728E-01	1.00	6.90E-02	5.47E-02
	1.2737	0.0136	6.082E+07	0.0300	2.18E-01	5.70E-01	1.02	1.270E-01	1.694E+00	1.341E+00	0.99	3.66E-01	2.90E-01
	1.3027	0.001	6.082E+07	0.0300	1.61E-02	4.29E-02	1.02	7.030E-04	1.266E-01	1.002E-01	0.99	2.01E-03	1.59E-03
	1.3243	0.0306	6.082E+07	0.0300	4.92E-01	1.34E+00	1.03	6.764E-01	3.919E+00	3.103E+00	0.99	1.91E+00	1.51E+00
	1.3354	0.00132	6.082E+07	0.0300	2.12E-02	5.81E-02	1.03	1.270E-03	1.701E-01	1.347E-01	0.99	3.57E-03	2.83E-03
	1.3406	0.00194	6.082E+07	0.0300	3.12E-02	8.58E-02	1.03	2.754E-03	2.506E-01	1.984E-01	0.99	7.73E-03	6.12E-03
	1.3675	0.00148	6.082E+07	0.0300	2.38E-02	6.69E-02	1.03	1.638E-03	1.939E-01	1.535E-01	0.99	4.56E-03	3.61E-03
	1.3722	0.00126	6.082E+07	0.0300	2.02E-02	5.71E-02	1.03	1.191E-03	1.655E-01	1.310E-01	0.99	3.32E-03	2.63E-03
	1.4126	0.00264	6.082E+07	0.0300	4.24E-02	1.24E-01	1.03	5.397E-03	3.539E-01	2.801E-01	0.99	1.49E-02	1.18E-02
	1.4216	0.00224	6.082E+07	0.0300	3.60E-02	1.06E-01	1.03	3.913E-03	3.017E-01	2.388E-01	0.99	1.07E-02	8.51E-03
	1.4613	0.00122	6.082E+07	0.0300	1.96E-02	5.93E-02	1.04	1.208E-03	1.675E-01	1.326E-01	0.99	3.25E-03	2.57E-03
	1.4642	0.00178	6.082E+07	0.0300	2.86E-02	8.67E-02	1.04	2.578E-03	2.446E-01	1.937E-01	0.99	6.93E-03	5.48E-03
	1.4685	0.00188	6.082E+07	0.0300	3.02E-02	9.19E-02	1.04	2.885E-03	2.589E-01	2.050E-01	0.99	7.74E-03	6.13E-03
	1.4728	0.0688	6.082E+07	0.0300	1.11E+00	3.37E+00	1.04	3.876E+00	9.494E+00	7.516E+00	0.99	1.04E+01	8.22E+00
	1.501	0.0132	6.082E+07	0.0300	2.12E-01	6.61E-01	1.04	1.458E-01	1.846E+00	1.461E+00	0.99	3.88E-01	3.07E-01
	1.5062	0.00112	6.082E+07	0.0300	1.80E-02	5.62E-02	1.04	1.052E-03	1.569E-01	1.242E-01	0.99	2.80E-03	2.21E-03
	1.53	0.0332	6.082E+07	0.0300	5.33E-01	1.69E+00	1.04	9.371E-01	4.703E+00	3.723E+00	0.98	2.46E+00	1.95E+00
	1.5337	0.0512	6.082E+07	0.0300	8.23E-01	2.61E+00	1.04	2.233E+00	7.264E+00	5.750E+00	0.98	5.86E+00	4.64E+00
	1.5553	0.00152	6.082E+07	0.0300	2.44E-02	7.84E-02	1.05	2.011E-03	2.177E-01	1.723E-01	0.98	5.21E-03	4.12E-03
	1.5738	0.0019	6.082E+07	0.0300	3.05E-02	9.90E-02	1.05	3.174E-03	2.743E-01	2.171E-01	0.98	8.20E-03	6.50E-03
	1.6341	0.0082	6.082E+07	0.0300	1.32E-01	4.42E-01	1.05	6.107E-02	1.214E+00	9.610E-01	0.98	1.57E-01	1.24E-01



*u/s J.S. Haynes
7/16/94*

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	1.6438	0.00338	6.082E+07	0.0300	5.43E-02	1.83E-01	1.06	1.053E-02	5.024E-01	3.977E-01	0.98	2.67E-02	2.12E-02
	1.6675	0.00128	6.082E+07	0.0300	2.06E-02	7.02E-02	1.06	1.530E-03	1.922E-01	1.521E-01	0.98	3.87E-03	3.07E-03
	1.6769	0.0014	6.082E+07	0.0300	2.25E-02	7.71E-02	1.06	1.839E-03	2.109E-01	1.670E-01	0.98	4.65E-03	3.68E-03
	1.6838	0.00132	6.082E+07	0.0300	2.12E-02	7.30E-02	1.06	1.641E-03	1.994E-01	1.579E-01	0.98	4.14E-03	3.28E-03
	1.692	0.0026	6.082E+07	0.0300	4.18E-02	1.44E-01	1.06	6.390E-03	3.940E-01	3.119E-01	0.98	1.61E-02	1.28E-02
	1.6937	0.0438	6.082E+07	0.0300	7.04E-01	2.43E+00	1.06	1.816E+00	6.643E+00	5.259E+00	0.98	4.58E+00	3.63E+00
	1.7213	0.00224	6.082E+07	0.0300	3.60E-02	1.26E-01	1.06	4.817E-03	3.434E-01	2.719E-01	0.98	1.21E-02	9.59E-03
	1.7776	0.0076	6.082E+07	0.0300	1.22E-01	4.41E-01	1.07	5.761E-02	1.191E+00	9.425E-01	0.98	1.42E-01	1.13E-01
	1.7882	0.00106	6.082E+07	0.0300	1.70E-02	6.18E-02	1.07	1.126E-03	1.667E-01	1.319E-01	0.98	2.78E-03	2.20E-03
	1.8107	0.0014	6.082E+07	0.0300	2.25E-02	8.25E-02	1.08	2.005E-03	2.219E-01	1.757E-01	0.98	4.89E-03	3.87E-03
	1.8375	0.00118	6.082E+07	0.0300	1.90E-02	7.05E-02	1.08	1.443E-03	1.888E-01	1.495E-01	0.98	3.51E-03	2.78E-03
	1.8397	0.0035	6.082E+07	0.0300	5.62E-02	2.09E-01	1.08	1.271E-02	5.606E-01	4.438E-01	0.97	3.06E-02	2.42E-02
	1.8685	0.00196	6.082E+07	0.0300	3.15E-02	1.19E-01	1.08	4.042E-03	3.171E-01	2.510E-01	0.97	9.68E-03	7.67E-03
	1.8798	0.00158	6.082E+07	0.0300	2.54E-02	9.64E-02	1.08	2.641E-03	2.567E-01	2.032E-01	0.97	6.32E-03	5.00E-03
	1.9034	0.0104	6.082E+07	0.0300	1.67E-01	6.41E-01	1.09	1.168E-01	1.703E+00	1.348E+00	0.97	2.76E-01	2.18E-01
	1.9391	0.0064	6.082E+07	0.0300	1.03E-01	4.01E-01	1.09	4.499E-02	1.061E+00	8.398E-01	0.97	1.06E-01	8.38E-02
	1.9666	0.00132	6.082E+07	0.0300	2.12E-02	8.39E-02	1.10	1.957E-03	2.208E-01	1.748E-01	0.97	4.54E-03	3.60E-03
	1.9986	0.00118	6.082E+07	0.0300	1.90E-02	7.61E-02	1.10	1.587E-03	1.995E-01	1.579E-01	0.97	3.67E-03	2.90E-03
	2.0122	0.0156	6.082E+07	0.0300	2.51E-01	1.01E+00	1.10	2.787E-01	2.648E+00	2.097E+00	0.97	6.44E-01	5.10E-01
	2.021	0.00244	6.082E+07	0.0300	3.92E-02	1.59E-01	1.10	6.839E-03	4.154E-01	3.289E-01	0.97	1.58E-02	1.25E-02
	2.0465	0.00262	6.082E+07	0.0300	4.21E-02	1.72E-01	1.11	8.028E-03	4.497E-01	3.560E-01	0.97	1.84E-02	1.45E-02
	2.1006	0.0094	6.082E+07	0.0300	1.51E-01	6.28E-01	1.11	1.052E-01	1.640E+00	1.299E+00	0.97	2.40E-01	1.90E-01
	2.16	0.00528	6.082E+07	0.0300	8.48E-02	3.60E-01	1.12	3.418E-02	9.384E-01	7.428E-01	0.96	7.64E-02	6.05E-02
	2.1958	0.00128	6.082E+07	0.0300	2.06E-02	8.83E-02	1.13	2.051E-03	2.299E-01	1.820E-01	0.96	4.54E-03	3.59E-03
	2.2802	0.00204	6.082E+07	0.0300	3.28E-02	1.44E-01	1.14	5.398E-03	3.753E-01	2.971E-01	0.96	1.18E-02	9.35E-03
	2.3774	0.008	6.082E+07	0.0300	1.29E-01	5.84E-01	1.15	8.634E-02	1.512E+00	1.197E+00	0.95	1.85E-01	1.46E-01
	2.401	0.0072	6.082E+07	0.0300	1.16E-01	5.29E-01	1.15	7.042E-02	1.369E+00	1.084E+00	0.95	1.50E-01	1.19E-01
	2.5979	0.00108	6.082E+07	0.0300	1.74E-02	8.41E-02	1.17	1.708E-03	2.159E-01	1.709E-01	0.94	3.52E-03	2.79E-03
	2.6453	0.0042	6.082E+07	0.0300	6.75E-02	3.32E-01	1.18	2.641E-02	8.496E-01	6.726E-01	0.94	5.39E-02	4.27E-02
	2.7509	0.00124	6.082E+07	0.0300	1.99E-02	1.01E-01	1.19	2.392E-03	2.573E-01	2.036E-01	0.93	4.77E-03	3.77E-03
	2.7821	0.0076	6.082E+07	0.0300	1.22E-01	6.24E-01	1.19	9.064E-02	1.588E+00	1.257E+00	0.92	1.78E-01	1.41E-01
	2.7938	0.0068	6.082E+07	0.0300	1.09E-01	5.60E-01	1.19	7.276E-02	1.424E+00	1.128E+00	0.92	1.43E-01	1.13E-01
	2.8196	0.00132	6.082E+07	0.0300	2.12E-02	1.09E-01	1.19	2.762E-03	2.782E-01	2.202E-01	0.92	5.43E-03	4.30E-03
	2.8533	0.0024	6.082E+07	0.0300	3.86E-02	2.01E-01	1.19	9.212E-03	5.095E-01	4.033E-01	0.92	1.81E-02	1.43E-02



u/B 22 9/14/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E, QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	2.8662	0.0174	6.082E+07	0.0300	2.80E-01	1.46E+00	1.19	4.859E-01	3.704E+00	2.932E+00	0.92	9.53E-01	7.54E-01
	2.8787	0.00324	6.082E+07	0.0300	5.21E-02	2.73E-01	1.19	1.691E-02	6.917E-01	5.476E-01	0.91	3.28E-02	2.59E-02
	3.0179	0.00254	6.082E+07	0.0300	4.08E-02	2.22E-01	1.20	1.086E-02	5.588E-01	4.423E-01	0.90	2.05E-02	1.62E-02
	3.0292	0.0027	6.082E+07	0.0300	4.34E-02	2.36E-01	1.20	1.230E-02	5.954E-01	4.713E-01	0.90	2.32E-02	1.84E-02
	3.1073	0.00194	6.082E+07	0.0300	3.12E-02	1.72E-01	1.20	6.443E-03	4.346E-01	3.440E-01	0.89	1.21E-02	9.54E-03
	3.1403	0.0104	6.082E+07	0.0300	1.67E-01	9.29E-01	1.20	1.863E-01	2.346E+00	1.857E+00	0.88	3.45E-01	2.73E-01
	3.1721	0.001	6.082E+07	0.0300	1.61E-02	8.99E-02	1.20	1.733E-03	2.270E-01	1.797E-01	0.88	3.21E-03	2.54E-03
	3.2198	0.00428	6.082E+07	0.0300	6.88E-02	3.88E-01	1.20	3.204E-02	9.808E-01	7.763E-01	0.87	5.87E-02	4.64E-02
	3.3617	0.0104	6.082E+07	0.0300	1.67E-01	9.68E-01	1.20	1.941E-01	2.448E+00	1.938E+00	0.84	3.44E-01	2.72E-01
	3.3711	0.0062	6.082E+07	0.0300	9.96E-02	5.78E-01	1.20	6.912E-02	1.462E+00	1.158E+00	0.84	1.22E-01	9.68E-02
	3.3999	0.00136	6.082E+07	0.0300	2.18E-02	1.28E-01	1.20	3.343E-03	3.225E-01	2.553E-01	0.83	5.85E-03	4.63E-03
	3.5329	0.0134	6.082E+07	0.0300	2.15E-01	1.29E+00	1.18	3.267E-01	3.254E+00	2.576E+00	0.80	5.60E-01	4.44E-01
	3.5839	0.00258	6.082E+07	0.0300	4.14E-02	2.50E-01	1.18	1.222E-02	6.324E-01	5.006E-01	0.79	2.07E-02	1.64E-02
	3.7178	0.0084	6.082E+07	0.0300	1.35E-01	8.32E-01	1.16	1.303E-01	2.107E+00	1.668E+00	0.76	2.16E-01	1.71E-01
	3.7325	0.00138	6.082E+07	0.0300	2.22E-02	1.37E-01	1.16	3.524E-03	3.469E-01	2.746E-01	0.75	5.77E-03	4.57E-03
	3.7814	0.00132	6.082E+07	0.0300	2.12E-02	1.32E-01	1.15	3.224E-03	3.347E-01	2.649E-01	0.74	5.25E-03	4.16E-03
	3.8274	0.00138	6.082E+07	0.0300	2.22E-02	1.39E-01	1.14	3.519E-03	3.524E-01	2.790E-01	0.72	5.63E-03	4.45E-03
	3.8427	0.0011	6.082E+07	0.0300	1.77E-02	1.11E-01	1.14	2.242E-03	2.817E-01	2.230E-01	0.72	3.58E-03	2.84E-03
	3.9018	0.00134	6.082E+07	0.0300	2.15E-02	1.37E-01	1.12	3.301E-03	3.464E-01	2.742E-01	0.70	5.22E-03	4.13E-03
	3.923	0.00414	6.082E+07	0.0300	6.65E-02	4.24E-01	1.12	3.162E-02	1.074E+00	8.501E-01	0.69	4.93E-02	3.90E-02
	3.9655	0.00208	6.082E+07	0.0300	3.34E-02	2.15E-01	1.11	7.964E-03	5.432E-01	4.300E-01	0.68	1.23E-02	9.77E-03
	3.9775	0.0027	6.082E+07	0.0300	4.34E-02	2.79E-01	1.10	1.333E-02	7.065E-01	5.592E-01	0.67	2.05E-02	1.63E-02
	3.996	0.00142	6.082E+07	0.0300	2.28E-02	1.47E-01	1.10	3.696E-03	3.726E-01	2.949E-01	0.67	5.69E-03	4.51E-03
	4.048	0.00116	6.082E+07	0.0300	1.86E-02	1.21E-01	1.09	2.462E-03	3.068E-01	2.429E-01	0.65	3.72E-03	2.94E-03
	4.3411	0.00104	6.082E+07	0.0300	1.67E-02	1.13E-01	0.98	1.849E-03	2.873E-01	2.274E-01	0.52	2.50E-03	1.98E-03
	4.4892	0.00134	6.082E+07	0.0300	2.15E-02	1.48E-01	0.91	2.904E-03	3.780E-01	2.992E-01	0.45	3.66E-03	2.90E-03
	2.1811	0.07118	6.082E+07	0.0300	1.14E+00	4.88E+00	1.12	6.255E+00	1.273E+01	1.008E+01	0.96	1.40E+01	1.11E+01
Xe-131m	0.16393	0.0196	9.762E+05	0.0300	5.05E-03	8.79E-03	1.00	4.443E-05	2.649E-01	2.096E-01	0.98	1.31E-03	1.04E-03
Xe-133	0.079621	0.002165	1.902E+08	0.0300	1.09E-01	1.86E-08	0.70	1.419E-09	1.479E-02	1.169E-02	0.93	1.50E-03	1.18E-03
	0.080997	0.36483	1.902E+08	0.0300	1.83E+01	5.66E-06	0.73	7.568E-05	2.511E+00	1.986E+00	0.82	3.77E+01	2.98E+01
	0.1777	0.000712	1.902E+08	0.0300	3.58E-02	4.72E-04	1.02	1.722E-05	1.070E-02	8.462E-03	0.98	3.75E-04	2.97E-04
Xe-133m	0.23322	0.103	6.044E+06	0.0300	1.64E-01	1.96E-01	1.05	3.376E-02	2.233E+00	1.767E+00	0.97	3.56E-01	2.82E-01
Xe-135	0.1582	0.002886	4.723E+07	0.0300	3.60E-02	1.10E-03	1.00	3.950E-05	3.727E-02	2.948E-02	0.99	1.33E-03	1.05E-03
	0.24979	0.899	4.723E+07	0.0300	1.12E+01	2.10E+00	1.04	2.448E+01	2.136E+01	1.691E+01	0.97	2.32E+02	1.84E+02

4/13/94
9/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	0.35839	0.002203	4.723E+07	0.0300	2.75E-02	1.34E-02	1.00	3.682E-04	8.168E-02	6.466E-02	0.95	2.13E-03	1.69E-03
	0.40799	0.003578	4.723E+07	0.0300	4.46E-02	2.84E-02	1.00	1.268E-03	1.515E-01	1.199E-01	0.95	6.42E-03	5.09E-03
	0.60819	0.028948	4.723E+07	0.0300	3.61E-01	5.83E-01	0.99	2.083E-01	1.910E+00	1.514E+00	0.99	6.83E-01	5.41E-01
	0.68433	0.002093	4.723E+07	0.0300	2.61E-02	4.77E-02	1.00	1.245E-03	1.530E-01	1.213E-01	1.00	3.99E-03	3.17E-03
Xe-135m	0.52656	0.80997	3.905E+07	0.0300	8.35E+00	1.28E+01	0.99	1.055E+02	4.982E+01	3.948E+01	0.97	4.04E+02	3.20E+02
Xe-137	0.298	0.001167	1.656E+08	0.0300	5.10E-02	4.76E-03	1.01	2.452E-04	3.485E-02	2.759E-02	0.96	1.71E-03	1.35E-03
	0.39335	0.001381	1.656E+08	0.0300	6.04E-02	1.02E-02	1.00	6.183E-04	5.645E-02	4.469E-02	0.95	3.24E-03	2.56E-03
	0.45549	0.307	1.656E+08	0.0300	1.34E+01	2.93E+00	0.99	3.890E+01	1.431E+01	1.133E+01	0.95	1.83E+02	1.45E+02
	0.84895	0.00614	1.656E+08	0.0300	2.69E-01	1.73E-01	1.01	4.687E-02	5.500E-01	4.356E-01	1.02	1.51E-01	1.19E-01
	0.98225	0.002057	1.656E+08	0.0300	9.00E-02	6.70E-02	1.01	6.089E-03	2.094E-01	1.658E-01	1.01	1.90E-02	1.51E-02
	1.1193	0.001053	1.656E+08	0.0300	4.61E-02	3.88E-02	1.01	1.803E-03	1.190E-01	9.422E-02	1.00	5.48E-03	4.34E-03
	1.2732	0.002241	1.656E+08	0.0300	9.80E-02	9.39E-02	1.02	9.386E-03	2.790E-01	2.209E-01	0.99	2.71E-02	2.14E-02
	1.5768	0.001013	1.656E+08	0.0300	4.43E-02	5.29E-02	1.05	2.460E-03	1.464E-01	1.159E-01	0.98	6.36E-03	5.03E-03
	1.6125	0.001228	1.656E+08	0.0300	5.37E-02	6.54E-02	1.05	3.688E-03	1.803E-01	1.427E-01	0.98	9.49E-03	7.51E-03
	1.7834	0.004083	1.656E+08	0.0300	1.79E-01	2.37E-01	1.07	4.538E-02	6.406E-01	5.072E-01	0.98	1.12E-01	8.88E-02
	2.8498	0.001811	1.656E+08	0.0300	7.92E-02	1.51E-01	1.19	1.427E-02	3.841E-01	3.041E-01	0.92	2.80E-02	2.22E-02
	1.4906	0.01315	1.656E+08	0.0300	5.75E-01	6.53E-01	1.04	3.908E-01	1.830E+00	1.449E+00	0.99	1.04E+00	8.25E-01
Xe-138	0.15375	0.059535	1.506E+08	0.0300	2.37E+00	1.99E-02	1.00	4.709E-02	7.416E-01	5.866E-01	0.99	1.74E+00	1.38E+00
	0.24256	0.034965	1.506E+08	0.0300	1.39E+00	7.47E-02	1.05	1.090E-01	7.989E-01	6.322E-01	0.97	1.08E+00	8.53E-01
	0.25831	0.315	1.506E+08	0.0300	1.25E+01	8.15E-01	1.03	1.052E+01	7.825E+00	6.193E+00	0.97	9.51E+01	7.53E+01
	0.28251	0.004284	1.506E+08	0.0300	1.70E-01	1.47E-02	1.02	2.555E-03	1.196E-01	9.464E-02	0.96	1.96E-02	1.55E-02
	0.33528	0.001071	1.506E+08	0.0300	4.26E-02	5.65E-03	1.00	2.407E-04	3.684E-02	2.916E-02	0.95	1.49E-03	1.18E-03
	0.37144	0.005009	1.506E+08	0.0300	1.99E-01	3.29E-02	1.00	6.550E-03	1.930E-01	1.528E-01	0.95	3.65E-02	2.89E-02
	0.39643	0.063	1.506E+08	0.0300	2.51E+00	4.75E-01	1.00	1.189E+00	2.594E+00	2.054E+00	0.95	6.18E+00	4.89E+00
	0.40136	0.021735	1.506E+08	0.0300	8.65E-01	1.68E-01	1.00	1.451E-01	9.058E-01	7.171E-01	0.95	7.44E-01	5.89E-01
	0.43449	0.20318	1.506E+08	0.0300	8.08E+00	1.79E+00	1.00	1.449E+01	9.105E+00	7.208E+00	0.95	6.99E+01	5.53E+01
	0.50022	0.003622	1.506E+08	0.0300	1.44E-01	4.97E-02	0.99	7.083E-03	2.238E-01	1.772E-01	0.96	3.10E-02	2.45E-02
	0.53007	0.00252	1.506E+08	0.0300	1.00E-01	4.03E-02	0.99	3.999E-03	1.551E-01	1.229E-01	0.97	1.51E-02	1.20E-02
	0.53776	0.001166	1.506E+08	0.0300	4.64E-02	1.92E-02	0.99	8.830E-04	7.195E-02	5.703E-02	0.97	3.24E-03	2.57E-03
	0.55595	0.001166	1.506E+08	0.0300	4.64E-02	2.05E-02	0.99	9.413E-04	7.276E-02	5.768E-02	0.98	3.31E-03	2.62E-03
	0.56853	0.003055	1.506E+08	0.0300	1.22E-01	5.58E-02	0.99	6.714E-03	1.927E-01	1.528E-01	0.98	2.30E-02	1.82E-02
	0.58884	0.001228	1.506E+08	0.0300	4.89E-02	2.37E-02	0.99	1.145E-03	7.916E-02	6.276E-02	0.98	3.79E-03	3.00E-03
	0.65408	0.001449	1.506E+08	0.0300	5.76E-02	3.15E-02	1.00	1.818E-03	1.016E-01	8.053E-02	1.00	5.86E-03	4.64E-03
	0.86582	0.002961	1.506E+08	0.0300	1.18E-01	8.49E-02	1.01	1.010E-02	2.700E-01	2.138E-01	1.02	3.24E-02	2.57E-02

Case #6- 5 Rad Failure
CMS-RE-27A,B,E,P Detector Response

Calc. No.: NE-02-94- rev 1
Prepared By: S. J. Haynes 5/94
page: 5.086

v/b 9/23/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	0.86935	0.006206	1.506E+08	0.0300	2.47E-01	1.79E-01	1.01	4.452E-02	5.680E-01	4.499E-01	1.02	1.43E-01	1.13E-01
	0.89687	0.001323	1.506E+08	0.0300	5.26E-02	3.92E-02	1.01	2.086E-03	1.245E-01	9.862E-02	1.01	6.62E-03	5.24E-03
	0.91251	0.003276	1.506E+08	0.0300	1.30E-01	9.88E-02	1.01	1.301E-02	3.130E-01	2.479E-01	1.01	4.12E-02	3.26E-02
	0.91713	0.009198	1.506E+08	0.0300	3.66E-01	2.79E-01	1.01	1.031E-01	8.831E-01	6.993E-01	1.01	3.26E-01	2.58E-01
	0.93636	0.001355	1.506E+08	0.0300	5.39E-02	4.20E-02	1.01	2.284E-03	1.324E-01	1.048E-01	1.01	7.21E-03	5.71E-03
	0.94125	0.002299	1.506E+08	0.0300	9.15E-02	7.16E-02	1.01	6.611E-03	2.257E-01	1.787E-01	1.01	2.08E-02	1.65E-02
	1.0939	0.004095	1.506E+08	0.0300	1.63E-01	1.48E-01	1.01	2.427E-02	4.547E-01	3.600E-01	1.00	7.41E-02	5.86E-02
	1.0988	0.002142	1.506E+08	0.0300	8.52E-02	7.75E-02	1.01	6.671E-03	2.387E-01	1.890E-01	1.00	2.03E-02	1.61E-02
	1.1022	0.001071	1.506E+08	0.0300	4.26E-02	3.89E-02	1.01	1.672E-03	1.196E-01	9.470E-02	1.00	5.10E-03	4.03E-03
	1.1143	0.014742	1.506E+08	0.0300	5.86E-01	5.40E-01	1.01	3.201E-01	1.661E+00	1.315E+00	1.00	9.74E-01	7.71E-01
	1.1416	0.005134	1.506E+08	0.0300	2.04E-01	1.93E-01	1.01	3.975E-02	5.893E-01	4.665E-01	1.00	1.20E-01	9.53E-02
	1.1454	0.001323	1.506E+08	0.0300	5.26E-02	4.98E-02	1.01	2.649E-03	1.523E-01	1.206E-01	1.00	8.01E-03	6.34E-03
	1.5718	0.002646	1.506E+08	0.0300	1.05E-01	1.38E-01	1.05	1.523E-02	3.817E-01	3.021E-01	0.98	3.94E-02	3.12E-02
	1.6146	0.002363	1.506E+08	0.0300	9.40E-02	1.26E-01	1.05	1.243E-02	3.471E-01	2.748E-01	0.98	3.20E-02	2.53E-02
	1.7683	0.16727	1.506E+08	0.0300	6.65E+00	9.66E+00	1.07	6.875E+01	2.610E+01	2.066E+01	0.98	1.70E+02	1.35E+02
	1.8125	0.001796	1.506E+08	0.0300	7.14E-02	1.06E-01	1.08	8.176E-03	2.848E-01	2.255E-01	0.98	1.99E-02	1.58E-02
	1.8509	0.014238	1.506E+08	0.0300	5.66E-01	8.56E-01	1.08	5.236E-01	2.289E+00	1.812E+00	0.97	1.26E+00	9.95E-01
	1.9254	0.005639	1.506E+08	0.0300	2.24E-01	3.51E-01	1.09	8.592E-02	9.303E-01	7.365E-01	0.97	2.02E-01	1.60E-01
	2.0048	0.05355	1.506E+08	0.0300	2.13E+00	3.46E+00	1.10	8.110E+00	9.070E+00	7.180E+00	0.97	1.87E+01	1.48E+01
	2.0158	0.12254	1.506E+08	0.0300	4.87E+00	7.95E+00	1.10	4.263E+01	2.083E+01	1.649E+01	0.97	9.85E+01	7.80E+01
	2.0792	0.014427	1.506E+08	0.0300	5.74E-01	9.57E-01	1.11	6.094E-01	2.501E+00	1.980E+00	0.97	1.39E+00	1.10E+00
	2.2523	0.022869	1.506E+08	0.0300	9.10E-01	1.61E+00	1.13	1.651E+00	4.175E+00	3.305E+00	0.96	3.65E+00	2.89E+00
	2.3219	0.006206	1.506E+08	0.0300	2.47E-01	4.45E-01	1.14	1.253E-01	1.155E+00	9.145E-01	0.96	2.74E-01	2.17E-01
	2.4753	0.003119	1.506E+08	0.0300	1.24E-01	2.34E-01	1.16	3.375E-02	6.048E-01	4.788E-01	0.95	7.13E-02	5.64E-02
	2.4976	0.001733	1.506E+08	0.0300	6.89E-02	1.31E-01	1.16	1.049E-02	3.380E-01	2.676E-01	0.95	2.21E-02	1.75E-02
	1.1186	0.026586	1.506E+08	0.0300	1.06E+00	9.78E-01	1.01	1.045E+00	3.004E+00	2.378E+00	1.00	3.18E+00	3.18E+00
								SUM =	1.501E+03			4.62E+03	3.66E+03

27A = 12.846 Rad/hr
27B = 14.602 Rad/hr

27E = 4.63E+03 Rad/hr
27F = 3.66E+03 Rad/hr

Con. Vol = 5.68E+09 cm**3
27A Cone Factor 0.00856
27B Cone Factor 0.00973
Release Frac. 0.05



4/18 928 9/14/44

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
I-131	0.080183	0.026182	2.422E+07	1.0000	1.12E+02	3.202E-07	0.71	2.539E-05	1.79E-01	1.42E-01	0.88	1.76E+01	1.39E+01
	0.17721	0.002648	2.422E+07	1.0000	1.13E+01	0.0017308	1.02	1.994E-02	3.96E-02	3.14E-02	0.98	4.39E-01	3.47E-01
	0.2843	0.060521	2.422E+07	1.0000	2.58E+02	0.21188	1.02	5.579E+01	1.70E+00	1.35E+00	0.96	4.22E+02	3.34E+02
	0.32578	0.002507	2.422E+07	1.0000	1.07E+01	0.012442	1.00	1.330E-01	8.34E-02	6.60E-02	0.96	8.56E-01	6.78E-01
	0.36448	0.81164	2.422E+07	1.0000	3.46E+03	5.1164	1.00	1.771E+04	3.07E+01	2.43E+01	0.95	1.01E+05	7.98E+04
	0.50299	0.003605	2.422E+07	1.0000	1.54E+01	0.050276	0.99	7.653E-01	2.22E-01	1.76E-01	0.96	3.28E+00	2.60E+00
	0.63697	0.072605	2.422E+07	1.0000	3.10E+02	1.5375	1.00	4.761E+02	4.97E+00	3.94E+00	0.99	1.52E+03	1.21E+03
	0.6427	0.002195	2.422E+07	1.0000	9.36E+00	0.046921	1.00	4.393E-01	1.52E-01	1.20E-01	1.00	1.42E+00	1.12E+00
	0.72289	0.018025	2.422E+07	1.0000	7.69E+01	0.43332	1.00	3.331E+01	1.39E+00	1.10E+00	1.01	1.08E+02	8.54E+01
I-132	0.32939	0.002304	2.422E+07	1.0000	9.83E+00	0.011708	1.00	1.151E-01	7.77E-02	6.15E-02	0.95	7.25E-01	5.74E-01
	0.1472	0.002369	3.466E+07	1.0000	1.45E+01	0.00056033	1.01	8.183E-03	2.80E-02	2.21E-02	1.01	4.08E-01	3.23E-01
	0.1833	0.001382	3.466E+07	1.0000	8.44E+00	0.0010702	1.03	9.298E-03	2.16E-02	1.71E-02	0.97	1.77E-01	1.40E-01
	0.2548	0.001875	3.466E+07	1.0000	1.14E+01	0.0046528	1.04	5.538E-02	4.57E-02	3.62E-02	0.97	5.08E-01	4.02E-01
	0.2627	0.01441	3.466E+07	1.0000	8.80E+01	0.039305	1.03	3.561E+00	3.66E-01	2.90E-01	0.97	3.12E+01	2.47E+01
	0.2848	0.007205	3.466E+07	1.0000	4.40E+01	0.025366	1.02	1.138E+00	2.03E-01	1.61E-01	0.96	8.58E+00	6.79E+00
	0.3165	0.001382	3.466E+07	1.0000	8.44E+00	0.0064486	1.00	5.439E-02	4.44E-02	3.52E-02	0.96	3.60E-01	2.85E-01
	0.3635	0.004935	3.466E+07	1.0000	3.01E+01	0.030934	1.00	9.318E-01	1.86E-01	1.47E-01	0.95	5.32E+00	4.21E+00
	0.3878	0.002961	3.466E+07	1.0000	1.81E+01	0.021291	1.00	3.848E-01	1.19E-01	9.44E-02	0.95	2.05E+00	1.62E+00
	0.4168	0.004738	3.466E+07	1.0000	2.89E+01	0.039003	1.00	1.128E+00	2.05E-01	1.62E-01	0.95	5.62E+00	4.45E+00
	0.4319	0.004836	3.466E+07	1.0000	2.95E+01	0.042246	1.00	1.247E+00	2.16E-01	1.71E-01	0.95	6.05E+00	4.79E+00
	0.446	0.006021	3.466E+07	1.0000	3.67E+01	0.055452	1.00	2.038E+00	2.76E-01	2.18E-01	0.95	9.63E+00	7.62E+00
	0.4739	0.001777	3.466E+07	1.0000	1.08E+01	0.018048	0.99	1.938E-01	8.54E-02	6.76E-02	0.96	8.89E-01	7.04E-01
	0.4785	0.001481	3.466E+07	1.0000	9.04E+00	0.015272	0.99	1.367E-01	7.16E-02	5.67E-02	0.96	6.22E-01	4.92E-01
	0.4882	0.004145	3.466E+07	1.0000	2.53E+01	0.044124	0.99	1.105E+00	2.03E-01	1.61E-01	0.96	4.94E+00	3.91E+00
	0.5059	0.050337	3.466E+07	1.0000	3.07E+02	0.71429	0.99	2.173E+02	3.10E+00	2.46E+00	0.96	9.15E+02	7.24E+02
	0.52265	0.16088	3.466E+07	1.0000	9.82E+02	2.49	0.99	2.421E+03	9.89E+00	7.83E+00	0.97	9.42E+03	7.46E+03
	0.5355	0.005231	3.466E+07	1.0000	3.19E+01	0.085532	0.99	2.704E+00	3.23E-01	2.56E-01	0.97	9.99E+00	7.92E+00
	0.54	0.001086	3.466E+07	1.0000	6.63E+00	0.018066	0.99	1.186E-01	6.71E-02	5.32E-02	0.97	4.31E-01	3.42E-01
	0.5471	0.012535	3.466E+07	1.0000	7.65E+01	0.21393	0.99	1.620E+01	7.77E-01	6.16E-01	0.97	5.77E+01	4.57E+01
	0.6	0.001382	3.466E+07	1.0000	8.44E+00	0.027372	0.99	2.286E-01	9.02E-02	7.15E-02	0.99	7.54E-01	5.97E-01
	0.6208	0.003948	3.466E+07	1.0000	2.41E+01	0.081315	1.00	1.959E+00	2.65E-01	2.10E-01	0.99	6.31E+00	5.01E+00
	0.6212	0.015792	3.466E+07	1.0000	9.64E+01	0.32556	1.00	3.138E+01	1.06E+00	8.40E-01	0.99	1.01E+02	8.01E+01
	0.63022	0.13719	3.466E+07	1.0000	8.37E+02	2.8731	1.00	2.406E+03	9.31E+00	7.38E+00	0.99	7.72E+03	6.12E+03

Case #7- 10v Core Damage
CMS-RE-27A,B,E,F Detector Response

Calc. No.: NE-02-94-1 rev 1
Prepared By: S. J. Haynes 5/94
page:5.088

1/3 908
7/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	0.6506	0.026649	3.466E+07	1.0000	1.63E+02	0.57678	1.00	9.381E+01	1.86E+00	1.47E+00	1.00	3.02E+02	2.40E+02
	0.659	0.003948	3.466E+07	1.0000	2.41E+01	0.086579	1.00	2.086E+00	2.79E-01	2.21E-01	1.00	6.71E+00	5.32E+00
	0.66769	0.987	3.466E+07	1.0000	6.02E+03	21.936	1.00	1.321E+05	7.05E+01	5.59E+01	1.00	4.25E+05	3.37E+05
	0.6698	0.04935	3.466E+07	1.0000	3.01E+02	1.1001	1.00	3.314E+02	3.54E+00	2.80E+00	1.00	1.06E+03	8.44E+02
	0.6716	0.052311	3.466E+07	1.0000	3.19E+02	1.1692	1.00	3.733E+02	3.76E+00	2.98E+00	1.00	1.20E+03	9.51E+02
	0.727	0.031584	3.466E+07	1.0000	1.93E+02	0.76351	1.00	1.472E+02	2.44E+00	1.94E+00	1.01	4.76E+02	3.77E+02
	0.7272	0.021714	3.466E+07	1.0000	1.33E+02	0.52518	1.00	6.960E+01	1.68E+00	1.33E+00	1.01	2.25E+02	1.78E+02
	0.7285	0.010857	3.466E+07	1.0000	6.63E+01	0.26306	1.01	1.761E+01	8.42E-01	6.67E-01	1.01	5.64E+01	4.47E+01
	0.7645	0.003948	3.466E+07	1.0000	2.41E+01	0.10043	1.01	2.444E+00	3.21E-01	2.54E-01	1.01	7.80E+00	6.18E+00
	0.77261	0.76196	3.466E+07	1.0000	4.65E+03	19.593	1.01	9.203E+04	6.25E+01	4.95E+01	1.01	2.94E+05	2.33E+05
	0.7802	0.012338	3.466E+07	1.0000	7.53E+01	0.32051	1.01	2.438E+01	1.02E+00	8.09E-01	1.01	7.77E+01	6.15E+01
	0.7845	0.004244	3.466E+07	1.0000	2.59E+01	0.11091	1.01	2.902E+00	3.53E-01	2.80E-01	1.01	9.24E+00	7.32E+00
	0.8098	0.028623	3.466E+07	1.0000	1.75E+02	0.77184	1.01	1.362E+02	2.45E+00	1.94E+00	1.01	4.33E+02	3.43E+02
	0.8122	0.056259	3.466E+07	1.0000	3.43E+02	1.5212	1.01	5.276E+02	4.84E+00	3.83E+00	1.01	1.68E+03	1.33E+03
	0.8633	0.005823	3.466E+07	1.0000	3.55E+01	0.16642	1.01	5.974E+00	5.30E-01	4.19E-01	1.02	1.92E+01	1.52E+01
	0.8768	0.010758	3.466E+07	1.0000	6.57E+01	0.31213	1.01	2.070E+01	9.92E-01	7.86E-01	1.02	6.65E+01	5.26E+01
	0.9103	0.009179	3.466E+07	1.0000	5.60E+01	0.27617	1.01	1.563E+01	8.75E-01	6.93E-01	1.01	4.95E+01	3.92E+01
	0.9276	0.004145	3.466E+07	1.0000	2.53E+01	0.12712	1.01	3.248E+00	4.02E-01	3.18E-01	1.01	1.03E+01	8.13E+00
	0.95455	0.18062	3.466E+07	1.0000	1.10E+03	5.7061	1.01	6.353E+03	1.79E+01	1.42E+01	1.01	2.00E+04	1.58E+04
	0.9837	0.005626	3.466E+07	1.0000	3.43E+01	0.18354	1.01	6.365E+00	5.73E-01	4.54E-01	1.01	1.99E+01	1.57E+01
	1.0347	0.004738	3.466E+07	1.0000	2.89E+01	0.16221	1.01	4.738E+00	5.03E-01	3.99E-01	1.01	1.47E+01	1.16E+01
	1.136	0.02961	3.466E+07	1.0000	1.81E+02	1.106	1.01	2.019E+02	3.39E+00	2.68E+00	1.00	6.12E+02	4.84E+02
	1.1434	0.013522	3.466E+07	1.0000	8.25E+01	0.50818	1.01	4.236E+01	1.55E+00	1.23E+00	1.00	1.28E+02	1.02E+02
	1.1474	0.002764	3.466E+07	1.0000	1.69E+01	0.10426	1.01	1.776E+00	3.18E-01	2.52E-01	1.00	5.37E+00	4.25E+00
	1.1732	0.010857	3.466E+07	1.0000	6.63E+01	0.41862	1.02	2.829E+01	1.27E+00	1.01E+00	1.00	8.43E+01	6.68E+01
	1.2727	0.001777	3.466E+07	1.0000	1.08E+01	0.074398	1.02	8.231E-01	2.21E-01	1.75E-01	0.99	2.37E+00	1.88E+00
	1.2907	0.011351	3.466E+07	1.0000	6.93E+01	0.48218	1.02	3.407E+01	1.43E+00	1.13E+00	0.99	9.79E+01	7.75E+01
	1.2953	0.01974	3.466E+07	1.0000	1.20E+02	0.84198	1.02	1.035E+02	2.49E+00	1.97E+00	0.99	2.97E+02	2.35E+02
	1.2976	0.008883	3.466E+07	1.0000	5.42E+01	0.3796	1.02	2.099E+01	1.12E+00	8.88E-01	0.99	6.02E+01	4.77E+01
	1.3178	0.001184	3.466E+07	1.0000	7.23E+00	0.051411	1.02	3.790E-01	1.51E-01	1.20E-01	0.99	1.08E+00	8.56E-01
	1.3721	0.024675	3.466E+07	1.0000	1.51E+02	1.119	1.03	1.736E+02	3.24E+00	2.57E+00	0.99	4.83E+02	3.83E+02
	1.3986	0.071064	3.466E+07	1.0000	4.34E+02	3.2897	1.03	1.470E+03	9.46E+00	7.49E+00	0.99	4.06E+03	3.22E+03
	1.4426	0.014213	3.466E+07	1.0000	8.67E+01	0.68072	1.04	6.141E+01	1.93E+00	1.53E+00	0.99	1.66E+02	1.31E+02
	1.4768	0.001352	3.466E+07	1.0000	8.25E+00	0.06646	1.04	5.704E-01	1.87E-01	1.48E-01	0.99	1.53E+00	1.21E+00



n/B 908
9/6/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	1.7575	0.002961	3.466E+07	1.0000	1.81E+01	0.16998	1.07	3.287E+00	4.60E-01	3.64E-01	0.98	8.15E+00	6.45E+00
	1.9211	0.011844	3.466E+07	1.0000	7.23E+01	0.73671	1.09	5.805E+01	1.95E+00	1.54E+00	0.97	1.37E+02	1.08E+02
	2.0022	0.010857	3.466E+07	1.0000	6.63E+01	0.70124	1.10	5.112E+01	1.84E+00	1.45E+00	0.97	1.18E+02	9.35E+01
	2.0868	0.002369	3.466E+07	1.0000	1.45E+01	0.15753	1.11	2.528E+00	4.12E-01	3.26E-01	0.97	5.78E+00	4.57E+00
	2.1727	0.001974	3.466E+07	1.0000	1.20E+01	0.13509	1.12	1.823E+00	3.52E-01	2.79E-01	0.96	4.07E+00	3.22E+00
	2.2232	0.001184	3.466E+07	1.0000	7.23E+00	0.082343	1.13	6.724E-01	2.14E-01	1.70E-01	0.96	1.49E+00	1.18E+00
	2.3905	0.001678	3.466E+07	1.0000	1.02E+01	0.12299	1.15	1.449E+00	3.18E-01	2.52E-01	0.95	3.10E+00	2.45E+00
	1.0146	0.031946	3.466E+07	1.0000	1.95E+02	1.0746	1.01	2.116E+02	3.34E+00	2.64E+00	1.01	6.58E+02	5.21E+02
I-133	0.2627	0.003565	4.747E+07	1.0000	2.98E+01	0.0097256	1.03	2.985E-01	9.06E-02	7.17E-02	0.97	2.62E+00	2.07E+00
	0.26717	0.001165	4.747E+07	1.0000	9.74E+00	0.0033502	1.03	3.361E-02	3.03E-02	2.39E-02	0.97	2.86E-01	2.26E-01
	0.34543	0.001036	4.747E+07	1.0000	8.66E+00	0.0058264	1.00	5.046E-02	3.69E-02	2.92E-02	0.95	3.03E-01	2.40E-01
	0.36108	0.001122	4.747E+07	1.0000	9.38E+00	0.0069341	1.00	6.504E-02	4.20E-02	3.32E-02	0.95	3.74E-01	2.96E-01
	0.41805	0.001528	4.747E+07	1.0000	1.28E+01	0.012642	1.00	1.615E-01	6.62E-02	5.24E-02	0.95	8.03E-01	6.36E-01
	0.42291	0.00309	4.747E+07	1.0000	2.58E+01	0.026066	1.00	6.733E-01	1.35E-01	1.07E-01	0.95	3.32E+00	2.63E+00
	0.51053	0.018127	4.747E+07	1.0000	1.52E+02	0.26406	0.99	3.961E+01	1.12E+00	8.83E-01	0.96	1.62E+02	1.29E+02
	0.52987	0.8632	4.747E+07	1.0000	7.22E+03	13.786	0.99	9.848E+04	5.31E+01	4.21E+01	0.97	3.72E+05	2.95E+05
	0.61797	0.005395	4.747E+07	1.0000	4.51E+01	0.11055	1.00	4.986E+00	3.60E-01	2.86E-01	0.99	1.61E+01	1.28E+01
	0.68025	0.006448	4.747E+07	1.0000	5.39E+01	0.14597	1.00	7.868E+00	4.69E-01	3.71E-01	1.00	2.53E+01	2.00E+01
	0.70658	0.014933	4.747E+07	1.0000	1.25E+02	0.35102	1.00	4.382E+01	1.13E+00	8.92E-01	1.01	1.42E+02	1.12E+02
	0.76838	0.004566	4.747E+07	1.0000	3.82E+01	0.11676	1.01	4.501E+00	3.73E-01	2.95E-01	1.01	1.44E+01	1.14E+01
	0.82051	0.001537	4.747E+07	1.0000	1.28E+01	0.041941	1.01	5.443E-01	1.33E-01	1.06E-01	1.02	1.75E+00	1.39E+00
	0.85628	0.012344	4.747E+07	1.0000	1.03E+02	0.3501	1.01	3.649E+01	1.11E+00	8.83E-01	1.02	1.17E+02	9.29E+01
	0.87533	0.044714	4.747E+07	1.0000	3.74E+02	1.2949	1.01	4.888E+02	4.12E+00	3.26E+00	1.02	1.57E+03	1.24E+03
	0.90967	0.002124	4.747E+07	1.0000	1.78E+01	0.063875	1.01	1.145E+00	2.02E-01	1.60E-01	1.01	3.63E+00	2.87E+00
	1.0523	0.005516	4.747E+07	1.0000	4.61E+01	0.19174	1.01	8.930E+00	5.94E-01	4.70E-01	1.01	2.77E+01	2.19E+01
	1.0601	0.001373	4.747E+07	1.0000	1.15E+01	0.048048	1.01	5.570E-01	1.49E-01	1.18E-01	1.01	1.72E+00	1.36E+00
	1.2364	0.014933	4.747E+07	1.0000	1.25E+02	0.60698	1.02	7.728E+01	1.82E+00	1.44E+00	1.00	2.27E+02	1.80E+02
	1.2982	0.023306	4.747E+07	1.0000	1.95E+02	0.99632	1.02	1.980E+02	2.94E+00	2.33E+00	0.99	5.68E+02	4.49E+02
	1.3504	0.001485	4.747E+07	1.0000	1.24E+01	0.066202	1.03	8.465E-01	1.93E-01	1.53E-01	0.99	2.37E+00	1.88E+00
	0.53524	0.006072	4.747E+07	1.0000	5.08E+01	0.09918	0.99	4.984E+00	3.74E-01	2.97E-01	0.97	1.84E+01	1.46E+01
I-134	0.1354	0.037592	5.183E+07	1.0000	3.43E+02	0.0032316	1.03	1.142E+00	4.01E-01	3.18E-01	1.02	1.40E+02	1.11E+02
	0.13903	0.006869	5.183E+07	1.0000	6.27E+01	0.00080871	1.02	5.172E-02	7.56E-02	5.98E-02	1.02	4.84E+00	3.83E+00
	0.15198	0.001059	5.183E+07	1.0000	9.67E+00	0.00033577	1.00	3.245E-03	1.30E-02	1.03E-02	1.00	1.26E-01	9.94E-02
	0.16248	0.002576	5.183E+07	1.0000	2.35E+01	0.0011084	1.00	2.606E-02	3.44E-02	2.72E-02	0.98	7.93E-01	6.27E-01



11892.58
9/14/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont.	27A&B	27A&B	27E	27F	27E&F	27E	27F	
					Conc.	QAD Det.	Eff.	27A&B	QAD Det.	QAD Det.	Eff.	27E	27F
					(uCi/cc)	Response (Rad/hr)		Response (Rad/hr)	Response (Rad/hr)	Response (Rad/hr)		Response (Rad/hr)	Response (Rad/hr)
	0.18847	0.006965	5.183E+07	1.0000	6.36E+01	0.0062184	1.04	4.111E-01	1.13E-01	8.95E-02	0.97	6.98E+00	5.52E+00
	0.217	0.002481	5.183E+07	1.0000	2.26E+01	0.003811	1.06	9.148E-02	4.88E-02	3.86E-02	0.97	1.07E+00	8.48E-01
	0.23547	0.019845	5.183E+07	1.0000	1.81E+02	0.038765	1.05	7.372E+00	4.36E-01	3.45E-01	0.97	7.66E+01	6.06E+01
	0.2788	0.001307	5.183E+07	1.0000	1.19E+01	0.004301	1.02	5.233E-02	3.59E-02	2.84E-02	0.96	4.11E-01	3.25E-01
	0.31981	0.005152	5.183E+07	1.0000	4.70E+01	0.024579	1.00	1.156E+00	1.68E-01	1.33E-01	0.96	7.57E+00	5.99E+00
	0.35108	0.004961	5.183E+07	1.0000	4.53E+01	0.028881	1.00	1.308E+00	1.80E-01	1.42E-01	0.95	7.74E+00	6.12E+00
	0.40545	0.073466	5.183E+07	1.0000	6.71E+02	0.57714	1.00	3.870E+02	3.09E+00	2.45E+00	0.95	1.97E+03	1.56E+03
	0.411	0.006106	5.183E+07	1.0000	5.57E+01	0.049087	1.00	2.736E+00	2.60E-01	2.06E-01	0.95	1.38E+01	1.09E+01
	0.43335	0.041885	5.183E+07	1.0000	3.82E+02	0.36789	1.00	1.406E+02	1.87E+00	1.48E+00	0.95	6.80E+02	5.38E+02
	0.45892	0.012976	5.183E+07	1.0000	1.18E+02	0.12519	0.99	1.468E+01	6.08E-01	4.82E-01	0.96	6.92E+01	5.48E+01
	0.4655	0.003626	5.183E+07	1.0000	3.31E+01	0.035793	0.99	1.173E+00	1.72E-01	1.36E-01	0.96	5.46E+00	4.32E+00
	0.48888	0.014121	5.183E+07	1.0000	1.29E+02	0.15064	0.99	1.922E+01	6.94E-01	5.49E-01	0.96	8.58E+01	6.79E+01
	0.5144	0.023375	5.183E+07	1.0000	2.13E+02	0.3475	0.99	7.340E+01	1.44E+00	1.14E+00	0.97	2.97E+02	2.36E+02
	0.54083	0.078236	5.183E+07	1.0000	7.14E+02	1.3054	0.99	9.228E+02	4.83E+00	3.83E+00	0.97	3.35E+03	2.65E+03
	0.56552	0.008778	5.183E+07	1.0000	8.01E+01	0.15898	0.99	1.261E+01	5.52E-01	4.38E-01	0.98	4.34E+01	3.44E+01
	0.57075	0.002099	5.183E+07	1.0000	1.92E+01	0.038582	0.99	7.318E-01	1.33E-01	1.05E-01	0.98	2.49E+00	1.98E+00
	0.59536	0.11354	5.183E+07	1.0000	1.04E+03	2.2248	0.99	2.282E+03	7.37E+00	5.85E+00	0.99	7.57E+03	6.00E+03
	0.62179	0.10591	5.183E+07	1.0000	9.67E+02	2.1861	1.00	2.113E+03	7.11E+00	5.64E+00	0.99	6.81E+03	5.40E+03
	0.62796	0.023662	5.183E+07	1.0000	2.16E+02	0.4935	1.00	1.066E+02	1.60E+00	1.27E+00	0.99	3.42E+02	2.71E+02
	0.67734	0.084915	5.183E+07	1.0000	7.75E+02	1.9143	1.00	1.484E+03	6.15E+00	4.87E+00	1.00	4.76E+03	3.78E+03
	0.70665	0.008301	5.183E+07	1.0000	7.58E+01	0.19519	1.00	1.479E+01	6.26E-01	4.96E-01	1.01	4.79E+01	3.79E+01
	0.73074	0.019082	5.183E+07	1.0000	1.74E+02	0.46364	1.01	8.156E+01	1.48E+00	1.18E+00	1.01	2.61E+02	2.07E+02
	0.73918	0.007633	5.183E+07	1.0000	6.97E+01	0.18764	1.01	1.320E+01	6.00E-01	4.76E-01	1.01	4.22E+01	3.35E+01
	0.76668	0.041026	5.183E+07	1.0000	3.74E+02	1.0467	1.01	3.959E+02	3.34E+00	2.65E+00	1.01	1.26E+03	1.00E+03
	0.81638	0.005248	5.183E+07	1.0000	4.79E+01	0.14254	1.01	6.896E+00	4.53E-01	3.59E-01	1.02	2.22E+01	1.75E+01
	0.84702	0.9541	5.183E+07	1.0000	8.71E+03	26.788	1.01	2.356E+05	8.53E+01	6.75E+01	1.02	7.57E+05	6.00E+05
	0.85729	0.069649	5.183E+07	1.0000	6.36E+02	1.9778	1.01	1.270E+03	6.29E+00	4.99E+00	1.02	4.08E+03	3.23E+03
	0.864	0.001908	5.183E+07	1.0000	1.74E+01	0.054576	1.01	9.599E-01	1.74E-01	1.38E-01	1.02	3.08E+00	2.44E+00
	0.88409	0.6526	5.183E+07	1.0000	5.96E+03	19.08	1.01	1.148E+05	6.06E+01	4.80E+01	1.01	3.65E+05	2.89E+05
	0.9226	0.001431	5.183E+07	1.0000	1.31E+01	0.043644	1.01	5.757E-01	1.38E-01	1.09E-01	1.01	1.82E+00	1.44E+00
	0.94786	0.040358	5.183E+07	1.0000	3.68E+02	1.2656	1.01	4.708E+02	3.99E+00	3.16E+00	1.01	1.48E+03	1.17E+03
	0.9669	0.00353	5.183E+07	1.0000	3.22E+01	0.11306	1.01	3.679E+00	3.55E-01	2.81E-01	1.01	1.15E+01	9.14E+00
	0.97467	0.046751	5.183E+07	1.0000	4.27E+02	1.51	1.01	6.508E+02	4.73E+00	3.74E+00	1.01	2.04E+03	1.61E+03
	1.0403	0.019082	5.183E+07	1.0000	1.74E+02	0.65635	1.01	1.155E+02	2.04E+00	1.61E+00	1.01	3.58E+02	2.84E+02



4/13/94
9/14/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	1.0726	0.15266	5.183E+07	1.0000	1.39E+03	5.4009	1.01	7.601E+03	1.67E+01	1.32E+01	1.01	2.35E+04	1.86E+04
	1.1001	0.006869	5.183E+07	1.0000	6.27E+01	0.24881	1.01	1.575E+01	7.66E-01	6.07E-01	1.00	4.80E+01	3.80E+01
	1.1032	0.007251	5.183E+07	1.0000	6.62E+01	0.26335	1.01	1.760E+01	8.10E-01	6.42E-01	1.00	5.36E+01	4.25E+01
	1.1362	0.097318	5.183E+07	1.0000	8.88E+02	3.6374	1.01	3.263E+03	1.11E+01	8.81E+00	1.00	9.89E+03	7.83E+03
	1.1591	0.00353	5.183E+07	1.0000	3.22E+01	0.13449	1.01	4.376E+00	4.10E-01	3.25E-01	1.00	1.32E+01	1.05E+01
	1.164	0.001336	5.183E+07	1.0000	1.22E+01	0.051108	1.02	6.357E-01	1.56E-01	1.23E-01	1.00	1.90E+00	1.50E+00
	1.19	0.00353	5.183E+07	1.0000	3.22E+01	0.13804	1.02	4.536E+00	4.18E-01	3.31E-01	1.00	1.35E+01	1.07E+01
	1.239	0.002099	5.183E+07	1.0000	1.92E+01	0.085473	1.02	1.670E+00	2.56E-01	2.03E-01	1.00	4.91E+00	3.88E+00
	1.2695	0.005629	5.183E+07	1.0000	5.14E+01	0.23507	1.02	1.232E+01	6.99E-01	5.54E-01	1.00	3.59E+01	2.84E+01
	1.3224	0.00105	5.183E+07	1.0000	9.58E+00	0.045755	1.03	4.516E-01	1.34E-01	1.06E-01	0.99	1.27E+00	1.01E+00
	1.336	0.001431	5.183E+07	1.0000	1.31E+01	0.063057	1.03	8.483E-01	1.84E-01	1.46E-01	0.99	2.38E+00	1.89E+00
	1.3526	0.004484	5.183E+07	1.0000	4.09E+01	0.2002	1.03	8.439E+00	5.83E-01	4.62E-01	0.99	2.36E+01	1.87E+01
	1.4143	0.002194	5.183E+07	1.0000	2.00E+01	0.1028	1.03	2.120E+00	2.94E-01	2.33E-01	0.99	5.83E+00	4.62E+00
	1.4282	0.001717	5.183E+07	1.0000	1.57E+01	0.08135	1.03	1.313E+00	2.32E-01	1.84E-01	0.99	3.60E+00	2.85E+00
	1.4314	0.001717	5.183E+07	1.0000	1.57E+01	0.081551	1.03	1.316E+00	2.32E-01	1.84E-01	0.99	3.60E+00	2.85E+00
	1.4552	0.022898	5.183E+07	1.0000	2.09E+02	1.1075	1.04	2.407E+02	3.13E+00	2.48E+00	0.99	6.48E+02	5.13E+02
	1.47	0.007728	5.183E+07	1.0000	7.05E+01	0.37777	1.04	2.771E+01	1.06E+00	8.43E-01	0.99	7.43E+01	5.88E+01
	1.5055	0.001145	5.183E+07	1.0000	1.05E+01	0.057482	1.04	6.247E-01	1.60E-01	1.27E-01	0.99	1.66E+00	1.31E+00
	1.5415	0.005057	5.183E+07	1.0000	4.62E+01	0.25897	1.04	1.243E+01	7.20E-01	5.70E-01	0.98	3.26E+01	2.58E+01
	1.6138	0.043602	5.183E+07	1.0000	3.98E+02	2.3227	1.05	9.706E+02	6.40E+00	5.07E+00	0.98	2.50E+03	1.98E+03
	1.6292	0.002576	5.183E+07	1.0000	2.35E+01	0.13839	1.05	3.416E+00	3.81E-01	3.01E-01	0.98	8.77E+00	6.94E+00
	1.6443	0.004007	5.183E+07	1.0000	3.66E+01	0.21695	1.06	8.410E+00	5.96E-01	4.72E-01	0.98	2.14E+01	1.69E+01
	1.6552	0.00229	5.183E+07	1.0000	2.09E+01	0.12472	1.06	2.763E+00	3.42E-01	2.71E-01	0.98	7.01E+00	5.55E+00
	1.7415	0.026715	5.183E+07	1.0000	2.44E+02	1.5213	1.07	3.969E+02	4.13E+00	3.27E+00	0.98	9.86E+02	7.81E+02
	1.8068	0.057246	5.183E+07	1.0000	5.22E+02	3.3686	1.08	1.901E+03	9.06E+00	7.17E+00	0.98	4.64E+03	3.67E+03
	1.9259	0.001813	5.183E+07	1.0000	1.65E+01	0.11301	1.09	2.038E+00	2.99E-01	2.37E-01	0.97	4.80E+00	3.80E+00
	2.0206	0.001717	5.183E+07	1.0000	1.57E+01	0.11162	1.10	1.924E+00	2.92E-01	2.31E-01	0.97	4.44E+00	3.52E+00
	2.1599	0.002099	5.183E+07	1.0000	1.92E+01	0.143	1.12	3.068E+00	3.73E-01	2.95E-01	0.96	6.86E+00	5.43E+00
	2.3124	0.002385	5.183E+07	1.0000	2.18E+01	0.17064	1.14	4.235E+00	4.43E-01	3.51E-01	0.96	9.25E+00	7.32E+00
	2.4674	0.001527	5.183E+07	1.0000	1.39E+01	0.11451	1.16	1.851E+00	2.95E-01	2.34E-01	0.95	3.91E+00	3.10E+00
	1.7872	0.013348	5.183E+07	1.0000	1.22E+02	0.77768	1.07	1.014E+02	2.10E+00	1.66E+00	0.98	2.50E+02	1.98E+02
I-135	0.2205	0.017452	4.470E+07	1.0000	1.37E+02	0.028083	1.06	4.089E+00	3.51E-01	2.77E-01	0.97	4.67E+01	3.70E+01
	0.22972	0.002317	4.470E+07	1.0000	1.82E+01	0.0042047	1.05	8.052E-02	4.92E-02	3.89E-02	0.97	8.71E-01	6.89E-01
	0.26426	0.00184	4.470E+07	1.0000	1.45E+01	0.0051136	1.03	7.629E-02	4.71E-02	3.73E-02	0.97	6.62E-01	5.24E-01



Case #7- 10U Core Damage
CMS-RE-27A,B,E,F Detector Response

Calc. No.: NE-02-94-07 rev 1
Prepared By: S. J. Haynes 5/94
page:5.092

U/S JRE
5/14/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	0.28845	0.030899	4.470E+07	1.0000	2.43E+02	0.11334	1.02	2.812E+01	8.86E-01	7.01E-01	0.96	2.07E+02	1.64E+02
	0.29027	0.003033	4.470E+07	1.0000	2.39E+01	0.011351	1.01	2.737E-01	8.76E-02	6.94E-02	0.96	2.01E+00	1.59E+00
	0.36185	0.00186	4.470E+07	1.0000	1.46E+01	0.011545	1.00	1.690E-01	6.97E-02	5.52E-02	0.95	9.69E-01	7.67E-01
	0.40303	0.002317	4.470E+07	1.0000	1.82E+01	0.01802	1.00	3.287E-01	9.70E-02	7.68E-02	0.95	1.68E+00	1.33E+00
	0.41483	0.003004	4.470E+07	1.0000	2.36E+01	0.024534	1.00	5.801E-01	1.29E-01	1.02E-01	0.95	2.90E+00	2.30E+00
	0.41763	0.03519	4.470E+07	1.0000	2.77E+02	0.29063	1.00	8.050E+01	1.52E+00	1.21E+00	0.95	4.01E+02	3.17E+02
	0.42993	0.003033	4.470E+07	1.0000	2.39E+01	0.026294	1.00	6.278E-01	1.35E-01	1.07E-01	0.95	3.05E+00	2.42E+00
	0.43374	0.005522	4.470E+07	1.0000	4.35E+01	0.048577	1.00	2.111E+00	2.47E-01	1.96E-01	0.95	1.02E+01	8.08E+00
	0.45163	0.003147	4.470E+07	1.0000	2.48E+01	0.029581	1.00	7.328E-01	1.46E-01	1.15E-01	0.95	3.43E+00	2.71E+00
	0.54656	0.071239	4.470E+07	1.0000	5.61E+02	1.2139	0.99	6.739E+02	4.42E+00	3.50E+00	0.97	2.40E+03	1.90E+03
	0.57597	0.001288	4.470E+07	1.0000	1.01E+01	0.02402	0.99	2.411E-01	8.18E-02	6.49E-02	0.98	8.13E-01	6.45E-01
	0.64985	0.004549	4.470E+07	1.0000	3.58E+01	0.098357	1.00	3.522E+00	3.17E-01	2.51E-01	1.00	1.14E+01	9.00E+00
	0.69013	0.001288	4.470E+07	1.0000	1.01E+01	0.029571	1.00	2.998E-01	9.49E-02	7.52E-02	1.00	9.62E-01	7.62E-01
	0.70792	0.00658	4.470E+07	1.0000	5.18E+01	0.15494	1.00	8.025E+00	4.97E-01	3.93E-01	1.01	2.60E+01	2.06E+01
	0.78548	0.001516	4.470E+07	1.0000	1.19E+01	0.039674	1.01	4.782E-01	1.26E-01	1.00E-01	1.01	1.52E+00	1.21E+00
	0.79771	0.001717	4.470E+07	1.0000	1.35E+01	0.045685	1.01	6.236E-01	1.45E-01	1.15E-01	1.01	1.98E+00	1.57E+00
	0.8368	0.066661	4.470E+07	1.0000	5.25E+02	1.8511	1.01	9.810E+02	5.89E+00	4.67E+00	1.02	3.15E+03	2.50E+03
	0.96146	0.001459	4.470E+07	1.0000	1.15E+01	0.046439	1.01	5.387E-01	1.46E-01	1.15E-01	1.01	1.69E+00	1.34E+00
	0.97196	0.008869	4.470E+07	1.0000	6.98E+01	0.28562	1.01	2.014E+01	8.95E-01	7.08E-01	1.01	6.31E+01	5.00E+01
	0.97261	0.012016	4.470E+07	1.0000	9.46E+01	0.38733	1.01	3.700E+01	1.21E+00	9.61E-01	1.01	1.16E+02	9.18E+01
	0.99509	0.001545	4.470E+07	1.0000	1.22E+01	0.051032	1.01	6.268E-01	1.59E-01	1.26E-01	1.01	1.95E+00	1.55E+00
	1.0388	0.07925	4.470E+07	1.0000	6.24E+02	2.7235	1.01	1.716E+03	8.45E+00	6.69E+00	1.01	5.32E+03	4.21E+03
	1.1016	0.016022	4.470E+07	1.0000	1.26E+02	0.58109	1.01	7.402E+01	1.79E+00	1.42E+00	1.00	2.26E+02	1.79E+02
	1.124	0.036049	4.470E+07	1.0000	2.84E+02	1.3329	1.01	3.820E+02	4.09E+00	3.24E+00	1.00	1.16E+03	9.19E+02
	1.1315	0.22516	4.470E+07	1.0000	1.77E+03	8.3786	1.01	1.500E+04	2.57E+01	2.03E+01	1.00	4.55E+04	3.60E+04
	1.1599	0.00103	4.470E+07	1.0000	8.11E+00	0.039268	1.02	3.247E-01	1.20E-01	9.47E-02	1.00	9.70E-01	7.68E-01
	1.169	0.008726	4.470E+07	1.0000	6.87E+01	0.33521	1.02	2.349E+01	1.02E+00	8.07E-01	1.00	7.00E+01	5.55E+01
	1.2405	0.009012	4.470E+07	1.0000	7.09E+01	0.36751	1.02	2.659E+01	1.10E+00	8.72E-01	1.00	7.81E+01	6.18E+01
	1.2604	0.2861	4.470E+07	1.0000	2.25E+03	11.86	1.02	2.724E+04	3.54E+01	2.80E+01	1.00	7.96E+04	6.30E+04
	1.3679	0.006065	4.470E+07	1.0000	4.77E+01	0.27412	1.03	1.348E+01	7.95E-01	6.29E-01	0.99	3.76E+01	2.97E+01
	1.4484	0.003147	4.470E+07	1.0000	2.48E+01	0.1514	1.04	3.900E+00	4.29E-01	3.40E-01	0.99	1.05E+01	8.33E+00
	1.4576	0.086402	4.470E+07	1.0000	6.80E+02	4.1876	1.04	2.962E+03	1.18E+01	9.38E+00	0.99	7.97E+03	6.31E+03
	1.5028	0.010729	4.470E+07	1.0000	8.45E+01	0.5377	1.04	4.723E+01	1.50E+00	1.19E+00	0.99	1.26E+02	9.94E+01
	1.5664	0.012875	4.470E+07	1.0000	1.01E+02	0.66861	1.05	7.115E+01	1.85E+00	1.47E+00	0.98	1.84E+02	1.46E+02

u/B P.S. 9/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	1.678	0.095271	4.470E+07	1.0000	7.50E+02	5.2497	1.06	4.173E+03	1.44E+01	1.14E+01	0.98	1.05E+04	8.35E+03
	1.7065	0.040912	4.470E+07	1.0000	3.22E+02	2.2884	1.06	7.812E+02	6.24E+00	4.94E+00	0.98	1.97E+03	1.56E+03
	1.7912	0.076961	4.470E+07	1.0000	6.06E+02	4.4923	1.07	2.912E+03	1.21E+01	9.58E+00	0.98	7.19E+03	5.69E+03
	1.8307	0.005779	4.470E+07	1.0000	4.55E+01	0.34408	1.08	1.690E+01	9.23E-01	7.30E-01	0.98	4.11E+01	3.26E+01
	1.9273	0.002947	4.470E+07	1.0000	2.32E+01	0.18383	1.09	4.648E+00	4.87E-01	3.85E-01	0.97	1.09E+01	8.67E+00
	2.0459	0.008697	4.470E+07	1.0000	6.85E+01	0.57019	1.11	4.333E+01	1.49E+00	1.18E+00	0.97	9.91E+01	7.85E+01
	2.2555	0.006123	4.470E+07	1.0000	4.82E+01	0.43029	1.13	2.343E+01	1.12E+00	8.86E-01	0.96	5.18E+01	4.10E+01
	2.4087	0.009527	4.470E+07	1.0000	7.50E+01	0.70194	1.15	6.054E+01	1.82E+00	1.44E+00	0.95	1.29E+02	1.02E+02
	1.0734	0.014948	4.470E+07	1.0000	1.18E+02	0.52926	1.01	6.290E+01	1.64E+00	1.29E+00	1.01	1.94E+02	1.54E+02
Kr-85	0.51399	0.00434	8.915E+05	1.0000	6.81E-01	0.064379	0.99	4.343E-02	2.67E-01	2.11E-01	0.97	1.76E-01	1.40E-01
Kr-85m	0.30487	0.13989	1.976E+07	1.0000	4.87E+02	0.60256	1.01	2.962E+02	4.30E+00	3.40E+00	0.96	2.01E+03	1.59E+03
	0.00169	0.000586	1.976E+07	1.0000	2.04E+00	0	0	0.000E+00	9.00E+10	7.10E+10	0	0.00E+00	0.00E+00
	0.013336	0.006116	1.976E+07	1.0000	2.13E+01	0	0	0.000E+00	2.48E+00	1.95E+00	0	0.00E+00	0.00E+00
	0.013395	0.01183	1.976E+07	1.0000	4.12E+01	0	0	0.000E+00	4.66E+00	3.68E+00	0	0.00E+00	0.00E+00
	0.015	0.003105	1.976E+07	1.0000	1.08E+01	0	0	0.000E+00	6.42E-01	5.06E-01	0	0.00E+00	0.00E+00
	0.12985	0.003011	1.976E+07	1.0000	1.05E+01	0.00015922	1.05	1.752E-03	3.06E-02	2.42E-02	1.02	3.28E-01	2.59E-01
	0.15118	0.75278	1.976E+07	1.0000	2.62E+03	0.23321	1.00	6.109E+02	9.18E+00	7.26E+00	1.00	2.40E+04	1.90E+04
	0.58128	0.000211	1.976E+07	1.0000	7.34E-01	0.0039914	0.99	2.901E-03	1.35E-02	1.07E-02	0.98	9.70E-03	7.69E-03
Kr-87	0.40258	0.495	3.671E+07	1.0000	3.20E+03	3.8421	1.00	1.229E+04	2.07E+01	1.64E+01	0.95	6.29E+04	4.98E+04
	0.67387	0.019058	3.671E+07	1.0000	1.23E+02	0.42739	1.00	5.265E+01	1.37E+00	1.09E+00	1.00	1.69E+02	1.34E+02
	0.81425	0.001683	3.671E+07	1.0000	1.09E+01	0.045599	1.01	5.011E-01	1.45E-01	1.15E-01	1.02	1.61E+00	1.27E+00
	0.83637	0.007524	3.671E+07	1.0000	4.86E+01	0.20885	1.01	1.026E+01	6.65E-01	5.27E-01	1.02	3.30E+01	2.61E+01
	0.84543	0.072765	3.671E+07	1.0000	4.70E+02	2.0396	1.01	9.690E+02	6.49E+00	5.14E+00	1.02	3.12E+03	2.47E+03
	0.94664	0.001386	3.671E+07	1.0000	8.96E+00	0.043398	1.01	3.927E-01	1.37E-01	1.08E-01	1.01	1.24E+00	9.80E-01
	1.1754	0.011237	3.671E+07	1.0000	7.26E+01	0.43394	1.02	3.215E+01	1.32E+00	1.04E+00	1.00	9.58E+01	7.58E+01
	1.338	0.006484	3.671E+07	1.0000	4.19E+01	0.28619	1.03	1.236E+01	8.37E-01	6.62E-01	0.99	3.47E+01	2.75E+01
	1.3825	0.002871	3.671E+07	1.0000	1.86E+01	0.13125	1.03	2.509E+00	3.79E-01	3.00E-01	0.99	6.97E+00	5.51E+00
	1.3899	0.001237	3.671E+07	1.0000	8.00E+00	0.056895	1.03	4.686E-01	1.64E-01	1.30E-01	0.99	1.30E+00	1.03E+00
	1.5312	0.003564	3.671E+07	1.0000	2.30E+01	0.18148	1.04	4.348E+00	5.05E-01	4.00E-01	0.98	1.14E+01	9.03E+00
	1.578	0.001287	3.671E+07	1.0000	8.32E+00	0.067248	1.05	5.875E-01	1.86E-01	1.47E-01	0.98	1.52E+00	1.20E+00
	1.6112	0.00104	3.671E+07	1.0000	6.72E+00	0.055321	1.05	3.905E-01	1.53E-01	1.21E-01	0.98	1.00E+00	7.96E-01
	1.7405	0.020493	3.671E+07	1.0000	1.32E+02	1.1666	1.07	1.654E+02	3.16E+00	2.51E+00	0.98	4.11E+02	3.25E+02
	1.8426	0.001386	3.671E+07	1.0000	8.96E+00	0.082991	1.08	8.031E-01	2.22E-01	1.76E-01	0.97	1.93E+00	1.53E+00
	2.0119	0.028957	3.671E+07	1.0000	1.87E+02	1.8765	1.10	3.864E+02	4.92E+00	3.89E+00	0.97	8.93E+02	7.07E+02



V/B 90.8
9/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont.	27A&B	27A&B	27E	27F	27E&F	27E	27F	
					Conc.	QAD Det.	Eff.	27A&B	QAD Det.	QAD Det.	Eff.	27E	27F
					(uCi/cc)	Response (Rad/hr)		Response (Rad/hr)	Response (Rad/hr)	Response (Rad/hr)		Response (Rad/hr)	Response (Rad/hr)
	2.4085	0.002129	3.671E+07	1.0000	1.38E+01	0.15687	1.15	2.483E+00	4.06E-01	3.21E-01	0.95	5.30E+00	4.20E+00
	2.5548	0.09306	3.671E+07	1.0000	6.02E+02	7.1616	1.17	5.041E+03	1.84E+01	1.46E+01	0.94	1.04E+04	8.24E+03
	2.5581	0.039105	3.671E+07	1.0000	2.53E+02	3.0119	1.17	8.908E+02	7.74E+00	6.13E+00	0.94	1.84E+03	1.46E+03
	2.8114	0.003168	3.671E+07	1.0000	2.05E+01	0.26201	1.19	6.385E+00	6.66E-01	5.27E-01	0.92	1.26E+01	9.94E+00
	3.3085	0.004504	3.671E+07	1.0000	2.91E+01	0.41534	1.20	1.451E+01	1.05E+00	8.31E-01	0.85	2.60E+01	2.06E+01
	1.6201	0.006499	3.671E+07	1.0000	4.20E+01	0.34737	1.05	1.532E+01	9.57E-01	7.57E-01	0.98	3.94E+01	3.12E+01
Kr-88	0.12227	0.001972	5.139E+07	1.0000	1.78E+01	0.000053253	1.08	1.026E-03	1.88E-02	1.49E-02	1.01	3.39E-01	2.68E-01
	0.16598	0.031036	5.139E+07	1.0000	2.81E+02	0.014764	1.01	4.188E+00	4.26E-01	3.37E-01	0.98	1.17E+02	9.28E+01
	0.19632	0.25985	5.139E+07	1.0000	2.35E+03	0.28706	1.05	7.088E+02	4.46E+00	3.53E+00	0.97	1.02E+04	8.05E+03
	0.24071	0.002526	5.139E+07	1.0000	2.29E+01	0.0052702	1.05	1.265E-01	5.71E-02	4.52E-02	0.97	1.27E+00	1.00E+00
	0.31169	0.001073	5.139E+07	1.0000	9.71E+00	0.0048462	1.01	4.753E-02	3.39E-02	2.68E-02	0.96	3.16E-01	2.50E-01
	0.33471	0.001453	5.139E+07	1.0000	1.31E+01	0.0076384	1.00	1.004E-01	4.99E-02	3.95E-02	0.95	6.23E-01	4.93E-01
	0.36223	0.02249	5.139E+07	1.0000	2.04E+02	0.13995	1.00	2.848E+01	8.44E-01	6.68E-01	0.95	1.63E+02	1.29E+02
	0.39054	0.006436	5.139E+07	1.0000	5.82E+01	0.046976	1.00	2.736E+00	2.61E-01	2.07E-01	0.95	1.44E+01	1.14E+01
	0.4217	0.00128	5.139E+07	1.0000	1.16E+01	0.010747	1.00	1.245E-01	5.59E-02	4.42E-02	0.95	6.15E-01	4.87E-01
	0.4718	0.007266	5.139E+07	1.0000	6.58E+01	0.073278	0.99	4.770E+00	3.48E-01	2.75E-01	0.96	2.20E+01	1.74E+01
	0.67734	0.002353	5.139E+07	1.0000	2.13E+01	0.05303	1.00	1.129E+00	1.70E-01	1.35E-01	1.00	3.63E+00	2.87E+00
	0.78828	0.005328	5.139E+07	1.0000	4.82E+01	0.13996	1.01	6.816E+00	4.45E-01	3.53E-01	1.01	2.17E+01	1.72E+01
	0.79032	0.001246	5.139E+07	1.0000	1.13E+01	0.032828	1.01	3.739E-01	1.04E-01	8.27E-02	1.01	1.19E+00	9.42E-01
	0.83483	0.12975	5.139E+07	1.0000	1.17E+03	3.5957	1.01	4.264E+03	1.14E+01	9.07E+00	1.02	1.37E+04	1.09E+04
	0.85034	0.00173	5.139E+07	1.0000	1.57E+01	0.048758	1.01	7.710E-01	1.55E-01	1.23E-01	1.02	2.48E+00	1.96E+00
	0.86233	0.006712	5.139E+07	1.0000	6.07E+01	0.19164	1.01	1.176E+01	6.10E-01	4.83E-01	1.02	3.78E+01	2.99E+01
	0.94492	0.002941	5.139E+07	1.0000	2.66E+01	0.091932	1.01	2.471E+00	2.90E-01	2.29E-01	1.01	7.79E+00	6.17E+00
	0.98578	0.013148	5.139E+07	1.0000	1.19E+02	0.42996	1.01	5.167E+01	1.34E+00	1.06E+00	1.01	1.61E+02	1.28E+02
	0.99009	0.001419	5.139E+07	1.0000	1.28E+01	0.046617	1.01	6.046E-01	1.45E-01	1.15E-01	1.01	1.89E+00	1.49E+00
	1.0396	0.004844	5.139E+07	1.0000	4.38E+01	0.16653	1.01	7.373E+00	5.17E-01	4.09E-01	1.01	2.29E+01	1.81E+01
	1.0495	0.001419	5.139E+07	1.0000	1.28E+01	0.049203	1.01	6.382E-01	1.52E-01	1.21E-01	1.01	1.98E+00	1.57E+00
	1.1413	0.012837	5.139E+07	1.0000	1.16E+02	0.48182	1.01	5.653E+01	1.47E+00	1.17E+00	1.00	1.71E+02	1.36E+02
	1.1795	0.009965	5.139E+07	1.0000	9.02E+01	0.38609	1.02	3.551E+01	1.17E+00	9.28E-01	1.00	1.06E+02	8.37E+01
	1.185	0.006885	5.139E+07	1.0000	6.23E+01	0.26808	1.02	1.704E+01	8.13E-01	6.44E-01	1.00	5.07E+01	4.01E+01
	1.2098	0.001419	5.139E+07	1.0000	1.28E+01	0.056407	1.02	7.388E-01	1.70E-01	1.35E-01	1.00	2.18E+00	1.73E+00
	1.2127	0.001384	5.139E+07	1.0000	1.25E+01	0.055162	1.02	7.047E-01	1.66E-01	1.32E-01	1.00	2.08E+00	1.65E+00
	1.2452	0.003633	5.139E+07	1.0000	3.29E+01	0.14872	1.02	4.987E+00	4.45E-01	3.52E-01	1.00	1.46E+01	1.16E+01
	1.2507	0.01121	5.139E+07	1.0000	1.01E+02	0.4611	1.02	4.771E+01	1.38E+00	1.09E+00	1.00	1.40E+02	1.11E+02



VP 9/28/94
9/14/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	1.325	0.001592	5.139E+07	1.0000	1.44E+01	0.069549	1.03	1.032E+00	2.04E-01	1.62E-01	0.99	2.91E+00	2.30E+00
	1.3523	0.001592	5.139E+07	1.0000	1.44E+01	0.071079	1.03	1.055E+00	2.07E-01	1.64E-01	0.99	2.95E+00	2.34E+00
	1.3695	0.014774	5.139E+07	1.0000	1.34E+02	0.66869	1.03	9.209E+01	1.94E+00	1.53E+00	0.99	2.57E+02	2.03E+02
	1.4069	0.00218	5.139E+07	1.0000	1.97E+01	0.10158	1.03	2.064E+00	2.91E-01	2.31E-01	0.99	5.69E+00	4.51E+00
	1.4648	0.001142	5.139E+07	1.0000	1.03E+01	0.055616	1.04	5.978E-01	1.57E-01	1.24E-01	0.99	1.61E+00	1.27E+00
	1.5184	0.021521	5.139E+07	1.0000	1.95E+02	1.0879	1.04	2.204E+02	3.03E+00	2.40E+00	0.98	5.79E+02	4.58E+02
	1.5298	0.10934	5.139E+07	1.0000	9.89E+02	5.5628	1.04	5.724E+03	1.55E+01	1.23E+01	0.98	1.50E+04	1.19E+04
	1.6038	0.004567	5.139E+07	1.0000	4.13E+01	0.242	1.05	1.050E+01	6.68E-01	5.29E-01	0.98	2.70E+01	2.14E+01
	1.6856	0.006643	5.139E+07	1.0000	6.01E+01	0.73737	1.06	4.699E+01	1.00E+00	7.95E-01	0.98	5.92E+01	4.68E+01
	1.8928	0.001384	5.139E+07	1.0000	1.25E+01	0.16584	1.09	2.264E+00	2.26E-01	1.79E-01	0.97	2.74E+00	2.17E+00
	1.9087	0.001003	5.139E+07	1.0000	9.08E+00	0.12082	1.09	1.195E+00	1.65E-01	1.30E-01	0.97	1.45E+00	1.15E+00
	2.0298	0.045291	5.139E+07	1.0000	4.10E+02	5.678	1.10	2.560E+03	7.73E+00	6.12E+00	0.97	3.07E+03	2.43E+03
	2.0354	0.037368	5.139E+07	1.0000	3.38E+02	4.6935	1.10	1.746E+03	6.39E+00	5.06E+00	0.97	2.10E+03	1.66E+03
	2.1865	0.002872	5.139E+07	1.0000	2.60E+01	0.37768	1.12	1.099E+01	5.14E-01	4.07E-01	0.96	1.28E+01	1.02E+01
	2.1958	0.13183	5.139E+07	1.0000	1.19E+03	17.391	1.13	2.344E+04	2.37E+01	1.88E+01	0.96	2.71E+04	2.15E+04
	2.2318	0.033908	5.139E+07	1.0000	3.07E+02	4.5188	1.13	1.567E+03	6.15E+00	4.87E+00	0.96	1.81E+03	1.44E+03
	2.3521	0.007301	5.139E+07	1.0000	6.61E+01	1.0062	1.14	7.579E+01	1.37E+00	1.08E+00	0.96	8.69E+01	6.88E+01
	2.3921	0.346	5.139E+07	1.0000	3.13E+03	48.201	1.15	1.736E+05	6.56E+01	5.20E+01	0.95	1.95E+05	1.55E+05
	2.4089	0.001038	5.139E+07	1.0000	9.39E+00	0.1453	1.15	1.570E+00	1.98E-01	1.57E-01	0.95	1.77E+00	1.40E+00
	2.5484	0.006228	5.139E+07	1.0000	5.64E+01	0.90331	1.17	5.957E+01	1.23E+00	9.74E-01	0.94	6.52E+01	5.16E+01
	2.771	0.001488	5.139E+07	1.0000	1.35E+01	0.22768	1.19	3.648E+00	3.10E-01	2.45E-01	0.93	3.88E+00	3.07E+00
	1.0001	0.018892	5.139E+07	1.0000	1.71E+02	1.4333	1.01	2.475E+02	1.95E+00	1.55E+00	1.01	3.37E+02	2.67E+02
Kr-89	0.1962	0.0022	6.082E+07	1.0000	2.36E+01	0.0024232	1.05	5.995E-02	3.77E-02	2.99E-02	0.97	8.63E-01	6.83E-01
	0.1975	0.0182	6.082E+07	1.0000	1.95E+02	0.020754	1.05	4.248E+00	3.15E-01	2.49E-01	0.97	5.95E+01	4.71E+01
	0.20503	0.00124	6.082E+07	1.0000	1.33E+01	0.0016211	1.05	2.261E-02	2.26E-02	1.79E-02	0.98	2.94E-01	2.33E-01
	0.2209	0.2	6.082E+07	1.0000	2.14E+03	0.32352	1.06	7.346E+02	4.03E+00	3.19E+00	0.97	8.37E+03	6.62E+03
	0.26411	0.0066	6.082E+07	1.0000	7.07E+01	0.018307	1.03	1.333E+00	1.69E-01	1.34E-01	0.97	1.16E+01	9.16E+00
	0.3382	0.00342	6.082E+07	1.0000	3.66E+01	0.018385	1.00	6.734E-01	1.19E-01	9.41E-02	0.95	4.14E+00	3.27E+00
	0.34503	0.0118	6.082E+07	1.0000	1.26E+02	0.066193	1.00	8.365E+00	4.20E-01	3.32E-01	0.95	5.04E+01	3.99E+01
	0.35606	0.0414	6.082E+07	1.0000	4.43E+02	0.24833	1.00	1.101E+02	1.52E+00	1.21E+00	0.95	6.42E+02	5.08E+02
	0.36488	0.009	6.082E+07	1.0000	9.64E+01	0.056855	1.00	5.480E+00	3.40E-01	2.69E-01	0.95	3.12E+01	2.47E+01
	0.3693	0.0138	6.082E+07	1.0000	1.48E+02	0.089448	1.00	1.322E+01	5.28E-01	4.18E-01	0.95	7.42E+01	5.87E+01
	0.40225	0.00318	6.082E+07	1.0000	3.41E+01	0.024648	1.00	8.395E-01	1.33E-01	1.05E-01	0.95	4.30E+00	3.40E+00
	0.41142	0.0256	6.082E+07	1.0000	2.74E+02	0.20614	1.00	5.652E+01	1.09E+00	8.65E-01	0.95	2.85E+02	2.25E+02



Case #7- 100% Core Damage
CMS-RE-27A,B,E; Reactor Response

Calc. No.: NE-02-94-57 rev 1
Prepared By: S. J. Haynes 5/94
page:5.096

v/s
9/22/94
9/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	0.43808	0.0096	6.082E+07	1.0000	1.03E+02	0.085854	1.00	8.827E+00	4.33E-01	3.43E-01	0.95	4.23E+01	3.35E+01
	0.46613	0.008	6.082E+07	1.0000	8.57E+01	0.079167	0.99	6.715E+00	3.80E-01	3.01E-01	0.96	3.12E+01	2.47E+01
	0.49076	0.00322	6.082E+07	1.0000	3.45E+01	0.034556	0.99	1.180E+00	1.59E-01	1.26E-01	0.96	5.25E+00	4.16E+00
	0.4975	0.0664	6.082E+07	1.0000	7.11E+02	0.72789	0.99	5.125E+02	3.30E+00	2.61E+00	0.96	2.25E+03	1.78E+03
	0.4986	0.0114	6.082E+07	1.0000	1.22E+02	0.1254	0.99	1.516E+01	5.67E-01	4.49E-01	0.96	6.65E+01	5.27E+01
	0.5573	0.0016	6.082E+07	1.0000	1.71E+01	0.028252	0.99	4.793E-01	1.00E-01	7.92E-02	0.98	1.68E+00	1.33E+00
	0.57696	0.0564	6.082E+07	1.0000	6.04E+02	1.0548	0.99	6.308E+02	3.59E+00	2.85E+00	0.98	2.12E+03	1.68E+03
	0.5858	0.166	6.082E+07	1.0000	1.78E+03	3.177	0.99	5.592E+03	1.07E+01	8.45E+00	0.98	1.86E+04	1.47E+04
	0.6262	0.006	6.082E+07	1.0000	6.43E+01	0.12476	1.00	8.017E+00	4.05E-01	3.21E-01	0.99	2.58E+01	2.04E+01
	0.62975	0.00342	6.082E+07	1.0000	3.66E+01	0.071557	1.00	2.621E+00	2.32E-01	1.84E-01	0.99	8.41E+00	6.67E+00
	0.66572	0.00114	6.082E+07	1.0000	1.22E+01	0.02526	1.00	3.084E-01	8.12E-02	6.44E-02	1.00	9.92E-01	7.86E-01
	0.6714	0.00106	6.082E+07	1.0000	1.14E+01	0.023691	1.00	2.690E-01	7.61E-02	6.03E-02	1.00	8.64E-01	6.85E-01
	0.67411	0.00232	6.082E+07	1.0000	2.48E+01	0.052052	1.00	1.293E+00	1.67E-01	1.33E-01	1.00	4.15E+00	3.29E+00
	0.69624	0.0178	6.082E+07	1.0000	1.91E+02	0.41228	1.00	7.860E+01	1.32E+00	1.05E+00	1.01	2.55E+02	2.02E+02
	0.70701	0.00498	6.082E+07	1.0000	5.33E+01	0.11712	1.00	6.247E+00	3.75E-01	2.97E-01	1.01	2.02E+01	1.60E+01
	0.71005	0.0078	6.082E+07	1.0000	8.35E+01	0.18419	1.00	1.539E+01	5.90E-01	4.68E-01	1.01	4.98E+01	3.95E+01
	0.72963	0.00296	6.082E+07	1.0000	3.17E+01	0.071817	1.01	2.300E+00	2.30E-01	1.82E-01	1.01	7.36E+00	5.83E+00
	0.73839	0.042	6.082E+07	1.0000	4.50E+02	1.0314	1.01	4.686E+02	3.30E+00	2.61E+00	1.01	1.50E+03	1.19E+03
	0.7474	0.00114	6.082E+07	1.0000	1.22E+01	0.028341	1.01	3.495E-01	9.06E-02	7.18E-02	1.01	1.12E+00	8.85E-01
	0.7629	0.004	6.082E+07	1.0000	4.28E+01	0.10153	1.01	4.393E+00	3.24E-01	2.57E-01	1.01	1.40E+01	1.11E+01
	0.7629	0.0092	6.082E+07	1.0000	9.85E+01	0.23355	1.01	2.324E+01	7.46E-01	5.91E-01	1.01	7.42E+01	5.88E+01
	0.77649	0.0112	6.082E+07	1.0000	1.20E+02	0.2895	1.01	3.507E+01	9.23E-01	7.31E-01	1.01	1.12E+02	8.86E+01
	0.82675	0.0076	6.082E+07	1.0000	8.14E+01	0.20885	1.01	1.717E+01	6.65E-01	5.26E-01	1.02	5.52E+01	4.37E+01
	0.83553	0.011	6.082E+07	1.0000	1.18E+02	0.3051	1.01	3.630E+01	9.71E-01	7.69E-01	1.02	1.17E+02	9.24E+01
	0.85737	0.00286	6.082E+07	1.0000	3.06E+01	0.08121	1.01	2.512E+00	2.58E-01	2.05E-01	1.02	8.08E+00	6.40E+00
	0.86708	0.0592	6.082E+07	1.0000	6.34E+02	1.699	1.01	1.088E+03	5.41E+00	4.28E+00	1.02	3.50E+03	2.77E+03
	0.87042	0.0016	6.082E+07	1.0000	1.71E+01	0.046081	1.01	7.976E-01	1.47E-01	1.16E-01	1.02	2.56E+00	2.03E+00
	0.90427	0.0718	6.082E+07	1.0000	7.69E+02	2.1462	1.01	1.667E+03	6.81E+00	5.39E+00	1.01	5.29E+03	4.19E+03
	0.93095	0.0062	6.082E+07	1.0000	6.64E+01	0.19085	1.01	1.280E+01	6.03E-01	4.77E-01	1.01	4.04E+01	3.20E+01
	0.94419	0.00164	6.082E+07	1.0000	1.76E+01	0.051212	1.01	9.085E-01	1.61E-01	1.28E-01	1.01	2.86E+00	2.27E+00
	0.95318	0.00106	6.082E+07	1.0000	1.14E+01	0.033444	1.01	3.835E-01	1.05E-01	8.33E-02	1.01	1.21E+00	9.55E-01
	0.96042	0.00322	6.082E+07	1.0000	3.45E+01	0.10238	1.01	3.566E+00	3.22E-01	2.55E-01	1.01	1.12E+01	8.87E+00
	0.97439	0.0098	6.082E+07	1.0000	1.05E+02	0.31631	1.01	3.353E+01	9.90E-01	7.84E-01	1.01	1.05E+02	8.31E+01
	0.99737	0.0066	6.082E+07	1.0000	7.07E+01	0.21857	1.01	1.560E+01	6.80E-01	5.39E-01	1.01	4.86E+01	3.85E+01



Case #7- 100% Pre Damage
CMS-RE-27A,B,E,F Detector Response

Calc. No.: NE-02-94- rev 1
Prepared By: S. J. Haynes 5/94
page:5.097

1/6/98
7/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	1.0108	0.00108	6.082E+07	1.0000	1.16E+01	0.036205	1.01	4.230E-01	1.13E-01	8.91E-02	1.01	1.31E+00	1.04E+00
	1.0444	0.00408	6.082E+07	1.0000	4.37E+01	0.14084	1.01	6.216E+00	4.37E-01	3.46E-01	1.01	1.93E+01	1.53E+01
	1.0765	0.00236	6.082E+07	1.0000	2.53E+01	0.083774	1.01	2.139E+00	2.59E-01	2.05E-01	1.01	6.61E+00	5.23E+00
	1.0881	0.00358	6.082E+07	1.0000	3.83E+01	0.12836	1.01	4.971E+00	3.96E-01	3.13E-01	1.00	1.52E+01	1.20E+01
	1.1032	0.009	6.082E+07	1.0000	9.64E+01	0.3268	1.01	3.182E+01	1.01E+00	7.96E-01	1.00	9.69E+01	7.68E+01
	1.1078	0.0292	6.082E+07	1.0000	3.13E+02	1.0648	1.01	3.363E+02	3.27E+00	2.59E+00	1.00	1.02E+03	8.11E+02
	1.1166	0.0166	6.082E+07	1.0000	1.78E+02	0.60993	1.01	1.095E+02	1.87E+00	1.48E+00	1.00	3.33E+02	2.64E+02
	1.1315	0.0016	6.082E+07	1.0000	1.71E+01	0.059531	1.01	1.030E+00	1.82E-01	1.44E-01	1.00	3.13E+00	2.47E+00
	1.1625	0.00214	6.082E+07	1.0000	2.29E+01	0.081761	1.02	1.911E+00	2.49E-01	1.97E-01	1.00	5.71E+00	4.52E+00
	1.1723	0.0098	6.082E+07	1.0000	1.05E+02	0.37737	1.02	4.040E+01	1.15E+00	9.08E-01	1.00	1.20E+02	9.53E+01
	1.1824	0.00166	6.082E+07	1.0000	1.78E+01	0.064496	1.02	1.170E+00	1.96E-01	1.55E-01	1.00	3.48E+00	2.75E+00
	1.1865	0.00184	6.082E+07	1.0000	1.97E+01	0.071739	1.02	1.442E+00	2.17E-01	1.72E-01	1.00	4.29E+00	3.39E+00
	1.2288	0.00144	6.082E+07	1.0000	1.54E+01	0.058157	1.02	9.149E-01	1.75E-01	1.38E-01	1.00	2.69E+00	2.13E+00
	1.2356	0.00594	6.082E+07	1.0000	6.36E+01	0.24125	1.02	1.565E+01	7.24E-01	5.73E-01	1.00	4.60E+01	3.64E+01
	1.2737	0.0136	6.082E+07	1.0000	1.46E+02	0.56997	1.02	8.468E+01	1.69E+00	1.34E+00	0.99	2.44E+02	1.93E+02
	1.3027	0.001	6.082E+07	1.0000	1.07E+01	0.042901	1.02	4.687E-01	1.27E-01	1.00E-01	0.99	1.34E+00	1.06E+00
	1.3243	0.0306	6.082E+07	1.0000	3.28E+02	1.3359	1.03	4.510E+02	3.92E+00	3.10E+00	0.99	1.27E+03	1.01E+03
	1.3354	0.00132	6.082E+07	1.0000	1.41E+01	0.058148	1.03	8.467E-01	1.70E-01	1.35E-01	0.99	2.38E+00	1.88E+00
	1.3406	0.00194	6.082E+07	1.0000	2.08E+01	0.085784	1.03	1.836E+00	2.51E-01	1.98E-01	0.99	5.15E+00	4.08E+00
	1.3675	0.00148	6.082E+07	1.0000	1.59E+01	0.066866	1.03	1.092E+00	1.94E-01	1.54E-01	0.99	3.04E+00	2.41E+00
	1.3722	0.00126	6.082E+07	1.0000	1.35E+01	0.057135	1.03	7.942E-01	1.65E-01	1.31E-01	0.99	2.21E+00	1.75E+00
	1.4126	0.00264	6.082E+07	1.0000	2.83E+01	0.12354	1.03	3.598E+00	3.54E-01	2.80E-01	0.99	9.91E+00	7.84E+00
	1.4216	0.00224	6.082E+07	1.0000	2.40E+01	0.10558	1.03	2.609E+00	3.02E-01	2.39E-01	0.99	7.16E+00	5.67E+00
	1.4613	0.00122	6.082E+07	1.0000	1.31E+01	0.059276	1.04	8.055E-01	1.67E-01	1.33E-01	0.99	2.17E+00	1.71E+00
	1.4642	0.00178	6.082E+07	1.0000	1.91E+01	0.08667	1.04	1.718E+00	2.45E-01	1.94E-01	0.99	4.62E+00	3.66E+00
	1.4685	0.00188	6.082E+07	1.0000	2.01E+01	0.09185	1.04	1.923E+00	2.59E-01	2.05E-01	0.99	5.16E+00	4.09E+00
	1.4728	0.0688	6.082E+07	1.0000	7.37E+02	3.3721	1.04	2.584E+03	9.49E+00	7.52E+00	0.99	6.93E+03	5.48E+03
	1.501	0.0132	6.082E+07	1.0000	1.41E+02	0.66087	1.04	9.717E+01	1.85E+00	1.46E+00	0.99	2.58E+02	2.05E+02
	1.5062	0.00112	6.082E+07	1.0000	1.20E+01	0.056218	1.04	7.013E-01	1.57E-01	1.24E-01	0.99	1.86E+00	1.48E+00
	1.53	0.0332	6.082E+07	1.0000	3.56E+02	1.6893	1.04	6.247E+02	4.70E+00	3.72E+00	0.98	1.64E+03	1.30E+03
	1.5337	0.0512	6.082E+07	1.0000	5.48E+02	2.6103	1.04	1.489E+03	7.26E+00	5.75E+00	0.98	3.90E+03	3.09E+03
	1.5553	0.00152	6.082E+07	1.0000	1.63E+01	0.07843	1.05	1.341E+00	2.18E-01	1.72E-01	0.98	3.47E+00	2.75E+00
	1.5738	0.0019	6.082E+07	1.0000	2.03E+01	0.099031	1.05	2.116E+00	2.74E-01	2.17E-01	0.98	5.47E+00	4.33E+00
	1.6341	0.0082	6.082E+07	1.0000	8.78E+01	0.44153	1.05	4.072E+01	1.21E+00	9.61E-01	0.98	1.04E+02	8.27E+01



Case #7- 100% Pre Damage
CMS-RE-27A,B,E,F Detector Response

Calc. No.: NE-02-94-Rev 1
Prepared By: S. J. Haynes 5/5/94
page:5.098

1/10/99
7/1/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	1.6438	0.00338	6.082E+07	1.0000	3.62E+01	0.18295	1.06	7.020E+00	5.02E-01	3.98E-01	0.98	1.78E+01	1.41E+01
	1.6675	0.00128	6.082E+07	1.0000	1.37E+01	0.070177	1.06	1.020E+00	1.92E-01	1.52E-01	0.98	2.58E+00	2.04E+00
	1.6769	0.0014	6.082E+07	1.0000	1.50E+01	0.077123	1.06	1.226E+00	2.11E-01	1.67E-01	0.98	3.10E+00	2.45E+00
	1.6838	0.00132	6.082E+07	1.0000	1.41E+01	0.072985	1.06	1.094E+00	1.99E-01	1.58E-01	0.98	2.76E+00	2.19E+00
	1.692	0.0026	6.082E+07	1.0000	2.78E+01	0.14433	1.06	4.260E+00	3.94E-01	3.12E-01	0.98	1.08E+01	8.51E+00
	1.6937	0.0438	6.082E+07	1.0000	4.69E+02	2.4341	1.06	1.210E+03	6.64E+00	5.26E+00	0.98	3.05E+03	2.42E+03
	1.7213	0.00224	6.082E+07	1.0000	2.40E+01	0.12627	1.06	3.211E+00	3.43E-01	2.72E-01	0.98	8.07E+00	6.39E+00
	1.7776	0.0076	6.082E+07	1.0000	8.14E+01	0.44095	1.07	3.840E+01	1.19E+00	9.42E-01	0.98	9.50E+01	7.52E+01
	1.7882	0.00106	6.082E+07	1.0000	1.14E+01	0.061815	1.07	7.509E-01	1.67E-01	1.32E-01	0.98	1.85E+00	1.47E+00
	1.8107	0.0014	6.082E+07	1.0000	1.50E+01	0.082545	1.08	1.337E+00	2.22E-01	1.76E-01	0.98	3.26E+00	2.58E+00
	1.8375	0.00118	6.082E+07	1.0000	1.26E+01	0.070495	1.08	9.622E-01	1.89E-01	1.49E-01	0.98	2.34E+00	1.85E+00
	1.8397	0.0035	6.082E+07	1.0000	3.75E+01	0.20932	1.08	8.474E+00	5.61E-01	4.44E-01	0.97	2.04E+01	1.61E+01
	1.8685	0.00196	6.082E+07	1.0000	2.10E+01	0.11886	1.08	2.695E+00	3.17E-01	2.51E-01	0.97	6.46E+00	5.11E+00
	1.8798	0.00158	6.082E+07	1.0000	1.69E+01	0.096355	1.08	1.761E+00	2.57E-01	2.03E-01	0.97	4.21E+00	3.34E+00
	1.9034	0.0104	6.082E+07	1.0000	1.11E+02	0.64131	1.09	7.786E+01	1.70E+00	1.35E+00	0.97	1.84E+02	1.46E+02
	1.9391	0.0064	6.082E+07	1.0000	6.85E+01	0.40142	1.09	2.999E+01	1.06E+00	8.40E-01	0.97	7.05E+01	5.58E+01
	1.9666	0.00132	6.082E+07	1.0000	1.41E+01	0.083882	1.10	1.304E+00	2.21E-01	1.75E-01	0.97	3.03E+00	2.40E+00
	1.9986	0.00118	6.082E+07	1.0000	1.26E+01	0.076099	1.10	1.058E+00	1.99E-01	1.58E-01	0.97	2.45E+00	1.94E+00
	2.0122	0.0156	6.082E+07	1.0000	1.67E+02	1.0109	1.10	1.858E+02	2.65E+00	2.10E+00	0.97	4.29E+02	3.40E+02
	2.021	0.00244	6.082E+07	1.0000	2.61E+01	0.15861	1.10	4.559E+00	4.15E-01	3.29E-01	0.97	1.05E+01	8.34E+00
	2.0465	0.00262	6.082E+07	1.0000	2.81E+01	0.17183	1.11	5.352E+00	4.50E-01	3.56E-01	0.97	1.22E+01	9.69E+00
	2.1006	0.0094	6.082E+07	1.0000	1.01E+02	0.62775	1.11	7.015E+01	1.64E+00	1.30E+00	0.97	1.60E+02	1.27E+02
	2.16	0.00528	6.082E+07	1.0000	5.65E+01	0.35979	1.12	2.279E+01	9.38E-01	7.43E-01	0.96	5.09E+01	4.03E+01
	2.1958	0.00128	6.082E+07	1.0000	1.37E+01	0.088267	1.13	1.367E+00	2.30E-01	1.82E-01	0.96	3.03E+00	2.40E+00
	2.2802	0.00204	6.082E+07	1.0000	2.18E+01	0.14448	1.14	3.599E+00	3.75E-01	2.97E-01	0.96	7.87E+00	6.23E+00
	2.3774	0.008	6.082E+07	1.0000	8.57E+01	0.58417	1.15	5.756E+01	1.51E+00	1.20E+00	0.95	1.23E+02	9.74E+01
	2.401	0.0072	6.082E+07	1.0000	7.71E+01	0.52938	1.15	4.695E+01	1.37E+00	1.08E+00	0.95	1.00E+02	7.94E+01
	2.5979	0.00108	6.082E+07	1.0000	1.16E+01	0.084134	1.17	1.139E+00	2.16E-01	1.71E-01	0.94	2.35E+00	1.86E+00
	2.6453	0.0042	6.082E+07	1.0000	4.50E+01	0.33171	1.18	1.761E+01	8.50E-01	6.73E-01	0.94	3.59E+01	2.84E+01
	2.7509	0.00124	6.082E+07	1.0000	1.33E+01	0.10089	1.19	1.594E+00	2.57E-01	2.04E-01	0.93	3.18E+00	2.51E+00
	2.7821	0.0076	6.082E+07	1.0000	8.14E+01	0.62381	1.19	6.042E+01	1.59E+00	1.26E+00	0.92	1.19E+02	9.42E+01
	2.7938	0.0068	6.082E+07	1.0000	7.28E+01	0.55969	1.19	4.851E+01	1.42E+00	1.13E+00	0.92	9.54E+01	7.55E+01
	2.8196	0.00132	6.082E+07	1.0000	1.41E+01	0.10944	1.19	1.841E+00	2.78E-01	2.20E-01	0.92	3.62E+00	2.86E+00
	2.8533	0.0024	6.082E+07	1.0000	2.57E+01	0.20078	1.19	6.142E+00	5.09E-01	4.03E-01	0.92	1.20E+01	9.54E+00



Case #7- 100% Core Damage
CMS-RE-27A,B,E,F Detector Response

Calc. No.: NE-02-94-b7 rev 1
Prepared By: S. J. Haynes 6/94
page:5.099

1/2 9/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	2.8662	0.0174	6.082E+07	1.0000	1.86E+02	1.4606	1.19	3.239E+02	3.70E+00	2.93E+00	0.92	6.35E+02	5.03E+02
	2.8787	0.00324	6.082E+07	1.0000	3.47E+01	0.27292	1.19	1.127E+01	6.92E-01	5.48E-01	0.91	2.18E+01	1.73E+01
	3.0179	0.00254	6.082E+07	1.0000	2.72E+01	0.22176	1.20	7.239E+00	5.59E-01	4.42E-01	0.90	1.37E+01	1.08E+01
	3.0292	0.0027	6.082E+07	1.0000	2.89E+01	0.23623	1.20	8.197E+00	5.95E-01	4.71E-01	0.90	1.55E+01	1.23E+01
	3.1073	0.00194	6.082E+07	1.0000	2.08E+01	0.17228	1.20	4.296E+00	4.35E-01	3.44E-01	0.89	8.04E+00	6.36E+00
	3.1403	0.0104	6.082E+07	1.0000	1.11E+02	0.92945	1.20	1.242E+02	2.35E+00	1.86E+00	0.88	2.30E+02	1.82E+02
	3.1721	0.001	6.082E+07	1.0000	1.07E+01	0.089913	1.20	1.156E+00	2.27E-01	1.80E-01	0.88	2.14E+00	1.69E+00
	3.2198	0.00428	6.082E+07	1.0000	4.58E+01	0.3883	1.20	2.136E+01	9.81E-01	7.76E-01	0.87	3.91E+01	3.10E+01
	3.3617	0.0104	6.082E+07	1.0000	1.11E+02	0.96825	1.20	1.294E+02	2.45E+00	1.94E+00	0.84	2.29E+02	1.81E+02
	3.3711	0.0062	6.082E+07	1.0000	6.64E+01	0.57827	1.20	4.608E+01	1.46E+00	1.16E+00	0.84	8.16E+01	6.46E+01
	3.3999	0.00136	6.082E+07	1.0000	1.46E+01	0.12752	1.20	2.229E+00	3.23E-01	2.55E-01	0.83	3.90E+00	3.09E+00
	3.5329	0.0134	6.082E+07	1.0000	1.44E+02	1.286	1.18	2.178E+02	3.25E+00	2.58E+00	0.80	3.74E+02	2.96E+02
	3.5839	0.00258	6.082E+07	1.0000	2.76E+01	0.24985	1.18	8.147E+00	6.32E-01	5.01E-01	0.79	1.38E+01	1.09E+01
	3.7178	0.0084	6.082E+07	1.0000	9.00E+01	0.83246	1.16	8.688E+01	2.11E+00	1.67E+00	0.76	1.44E+02	1.14E+02
	3.7325	0.00138	6.082E+07	1.0000	1.48E+01	0.13704	1.16	2.350E+00	3.47E-01	2.75E-01	0.75	3.85E+00	3.04E+00
	3.7814	0.00132	6.082E+07	1.0000	1.41E+01	0.13221	1.15	2.149E+00	3.35E-01	2.65E-01	0.74	3.50E+00	2.77E+00
	3.8274	0.00138	6.082E+07	1.0000	1.48E+01	0.13924	1.14	2.346E+00	3.52E-01	2.79E-01	0.72	3.75E+00	2.97E+00
	3.8427	0.0011	6.082E+07	1.0000	1.18E+01	0.11131	1.14	1.495E+00	2.82E-01	2.23E-01	0.72	2.39E+00	1.89E+00
	3.9018	0.00134	6.082E+07	1.0000	1.44E+01	0.13689	1.12	2.200E+00	3.46E-01	2.74E-01	0.70	3.48E+00	2.75E+00
	3.923	0.00414	6.082E+07	1.0000	4.43E+01	0.42445	1.12	2.108E+01	1.07E+00	8.50E-01	0.69	3.29E+01	2.60E+01
	3.9655	0.00208	6.082E+07	1.0000	2.23E+01	0.21472	1.11	5.310E+00	5.43E-01	4.30E-01	0.68	8.23E+00	6.51E+00
	3.9775	0.0027	6.082E+07	1.0000	2.89E+01	0.27929	1.10	8.884E+00	7.06E-01	5.59E-01	0.67	1.37E+01	1.08E+01
	3.996	0.00142	6.082E+07	1.0000	1.52E+01	0.1473	1.10	2.464E+00	3.73E-01	2.95E-01	0.67	3.80E+00	3.00E+00
	4.048	0.00116	6.082E+07	1.0000	1.24E+01	0.12118	1.09	1.641E+00	3.07E-01	2.43E-01	0.65	2.48E+00	1.96E+00
	4.3411	0.00104	6.082E+07	1.0000	1.11E+01	0.11291	0.98	1.233E+00	2.87E-01	2.27E-01	0.52	1.66E+00	1.32E+00
	4.4892	0.00134	6.082E+07	1.0000	1.44E+01	0.14822	0.91	1.936E+00	3.78E-01	2.99E-01	0.45	2.44E+00	1.93E+00
	2.1811	0.07118	6.082E+07	1.0000	7.62E+02	4.8839	1.12	4.170E+03	1.27E+01	1.01E+01	0.96	9.32E+03	7.37E+03
Xe-131m	0.16393	0.0196	9.762E+05	1.0000	3.37E+00	0.0087908	1.00	2.962E-02	2.65E-01	2.10E-01	0.98	8.75E-01	6.92E-01
Xe-133	0.079621	0.002165	1.902E+08	1.0000	7.25E+01	1.8642E-08	0.70	9.463E-07	1.48E-02	1.17E-02	0.93	9.97E-01	7.89E-01
	0.080997	0.36483	1.902E+08	1.0000	1.22E+04	5.6564E-06	0.73	5.046E-02	2.51E+00	1.99E+00	0.82	2.52E+04	1.99E+04
	0.1777	0.000712	1.902E+08	1.0000	2.38E+01	0.00047185	1.02	1.148E-02	1.07E-02	8.46E-03	0.98	2.50E-01	1.98E-01
Xe-133m	0.23322	0.103	6.044E+06	1.0000	1.10E+02	0.1955	1.05	2.250E+01	2.23E+00	1.77E+00	0.97	2.37E+02	1.88E+02
Xe-135	0.1582	0.002886	4.723E+07	1.0000	2.40E+01	0.0010972	1.00	2.634E-02	3.73E-02	2.95E-02	0.99	8.86E-01	7.01E-01
	0.24979	0.899	4.723E+07	1.0000	7.48E+03	2.099	1.04	1.632E+04	2.14E+01	1.69E+01	0.97	1.55E+05	1.23E+05



*v/b 908-4
2/16/94*

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	0.35839	0.002203	4.723E+07	1.0000	1.83E+01	0.013397	1.00	2.455E-01	8.17E-02	6.47E-02	0.95	1.42E+00	1.13E+00
	0.40799	0.003578	4.723E+07	1.0000	2.98E+01	0.028407	1.00	8.453E-01	1.51E-01	1.20E-01	0.95	4.28E+00	3.39E+00
	0.60819	0.028948	4.723E+07	1.0000	2.41E+02	0.58265	0.99	1.389E+02	1.91E+00	1.51E+00	0.99	4.55E+02	3.61E+02
	0.68433	0.002093	4.723E+07	1.0000	1.74E+01	0.047669	1.00	8.298E-01	1.53E-01	1.21E-01	1.00	2.66E+00	2.11E+00
Xe-135m	0.52656	0.80997	3.905E+07	1.0000	5.57E+03	12.76	0.99	7.036E+04	4.98E+01	3.95E+01	0.97	2.69E+05	2.13E+05
Xe-137	0.298	0.001167	1.656E+08	1.0000	3.40E+01	0.0047552	1.01	1.634E-01	3.49E-02	2.76E-02	0.96	1.14E+00	9.01E-01
	0.39335	0.001381	1.656E+08	1.0000	4.03E+01	0.010236	1.00	4.122E-01	5.64E-02	4.47E-02	0.95	2.16E+00	1.71E+00
	0.45549	0.307	1.656E+08	1.0000	8.95E+03	2.926	0.99	2.593E+04	1.43E+01	1.13E+01	0.95	1.22E+05	9.63E+04
	0.84895	0.00614	1.656E+08	1.0000	1.79E+02	0.17277	1.01	3.124E+01	5.50E-01	4.36E-01	1.02	1.00E+02	7.96E+01
	0.98225	0.002057	1.656E+08	1.0000	6.00E+01	0.067004	1.01	4.059E+00	2.09E-01	1.66E-01	1.01	1.27E+01	1.00E+01
	1.1193	0.001053	1.656E+08	1.0000	3.07E+01	0.038767	1.01	1.202E+00	1.19E-01	9.42E-02	1.00	3.65E+00	2.89E+00
	1.2732	0.002241	1.656E+08	1.0000	6.54E+01	0.093873	1.02	6.257E+00	2.79E-01	2.21E-01	0.99	1.81E+01	1.43E+01
	1.5768	0.001013	1.656E+08	1.0000	2.95E+01	0.052882	1.05	1.640E+00	1.46E-01	1.16E-01	0.98	4.24E+00	3.36E+00
	1.6125	0.001228	1.656E+08	1.0000	3.58E+01	0.065389	1.05	2.459E+00	1.80E-01	1.43E-01	0.98	6.33E+00	5.01E+00
	1.7834	0.004083	1.656E+08	1.0000	1.19E+02	0.23746	1.07	3.025E+01	6.41E-01	5.07E-01	0.98	7.48E+01	5.92E+01
	2.8498	0.001811	1.656E+08	1.0000	5.28E+01	0.15133	1.19	9.510E+00	3.84E-01	3.04E-01	0.92	1.87E+01	1.48E+01
	1.4906	0.01315	1.656E+08	1.0000	3.83E+02	0.65322	1.04	2.605E+02	1.83E+00	1.45E+00	0.99	6.95E+02	5.50E+02
Xe-138	0.15375	0.059535	1.506E+08	1.0000	1.58E+03	0.019885	1.00	3.140E+01	7.42E-01	5.87E-01	0.99	1.16E+03	9.17E+02
	0.24256	0.034965	1.506E+08	1.0000	9.27E+02	0.07466	1.05	7.269E+01	7.99E-01	6.32E-01	0.97	7.19E+02	5.69E+02
	0.25831	0.315	1.506E+08	1.0000	8.35E+03	0.81546	1.03	7.017E+03	7.83E+00	6.19E+00	0.97	6.34E+04	5.02E+04
	0.28251	0.004284	1.506E+08	1.0000	1.14E+02	0.014699	1.02	1.703E+00	1.20E-01	9.46E-02	0.96	1.30E+01	1.03E+01
	0.33528	0.001071	1.506E+08	1.0000	2.84E+01	0.0056502	1.00	1.605E-01	3.68E-02	2.92E-02	0.95	9.94E-01	7.87E-01
	0.37144	0.005009	1.506E+08	1.0000	1.33E+02	0.032873	1.00	4.367E+00	1.93E-01	1.53E-01	0.95	2.44E+01	1.93E+01
	0.39643	0.063	1.506E+08	1.0000	1.67E+03	0.47458	1.00	7.929E+02	2.59E+00	2.05E+00	0.95	4.12E+03	3.26E+03
	0.40136	0.021735	1.506E+08	1.0000	5.76E+02	0.16781	1.00	9.673E+01	9.06E-01	7.17E-01	0.95	4.96E+02	3.93E+02
	0.43449	0.20318	1.506E+08	1.0000	5.39E+03	1.7923	1.00	9.658E+03	9.11E+00	7.21E+00	0.95	4.66E+04	3.69E+04
	0.50022	0.003622	1.506E+08	1.0000	9.61E+01	0.049656	0.99	4.722E+00	2.24E-01	1.77E-01	0.96	2.06E+01	1.63E+01
	0.53007	0.00252	1.506E+08	1.0000	6.68E+01	0.040298	0.99	2.666E+00	1.55E-01	1.23E-01	0.97	1.01E+01	7.97E+00
	0.53776	0.001166	1.506E+08	1.0000	3.09E+01	0.01923	0.99	5.887E-01	7.20E-02	5.70E-02	0.97	2.16E+00	1.71E+00
	0.55595	0.001166	1.506E+08	1.0000	3.09E+01	0.020499	0.99	6.275E-01	7.28E-02	5.77E-02	0.98	2.20E+00	1.75E+00
	0.56853	0.003055	1.506E+08	1.0000	8.10E+01	0.055808	0.99	4.476E+00	1.93E-01	1.53E-01	0.98	1.53E+01	1.21E+01
	0.58884	0.001228	1.506E+08	1.0000	3.26E+01	0.023686	0.99	7.637E-01	7.92E-02	6.28E-02	0.98	2.53E+00	2.00E+00
	0.65408	0.001449	1.506E+08	1.0000	3.84E+01	0.031539	1.00	1.212E+00	1.02E-01	8.05E-02	1.00	3.90E+00	3.09E+00
	0.86582	0.002961	1.506E+08	1.0000	7.85E+01	0.084856	1.01	6.730E+00	2.70E-01	2.14E-01	1.02	2.16E+01	1.71E+01

Case #7- 100% Core Damage
CMS-RE-27A,B,E,F Detector Response

Calc. No.: NE-02-94-3 rev 1
Prepared By: S. J. Haynes 5/94
page:5.0101

VB 2-4
9/16/94

Isotope	Energy (MeV)	Probability	Design Basis Source (Ci)	Gap Release Fraction	Cont. Conc. (uCi/cc)	27A&B QAD Det. Response (Rad/hr)	27A&B Eff.	27A&B Response (Rad/hr)	27E QAD Det. Response (Rad/hr)	27F QAD Det. Response (Rad/hr)	27E&F Eff.	27E Response (Rad/hr)	27F Response (Rad/hr)
	0.86935	0.006206	1.506E+08	1.0000	1.65E+02	0.17856	1.01	2.968E+01	5.68E-01	4.50E-01	1.02	9.54E+01	7.55E+01
	0.89687	0.001323	1.506E+08	1.0000	3.51E+01	0.039234	1.01	1.390E+00	1.25E-01	9.86E-02	1.01	4.41E+00	3.49E+00
	0.91251	0.003276	1.506E+08	1.0000	8.69E+01	0.098805	1.01	8.670E+00	3.13E-01	2.48E-01	1.01	2.75E+01	2.17E+01
	0.91713	0.009198	1.506E+08	1.0000	2.44E+02	0.27894	1.01	6.872E+01	8.83E-01	6.99E-01	1.01	2.18E+02	1.72E+02
	0.93636	0.001355	1.506E+08	1.0000	3.59E+01	0.041953	1.01	1.523E+00	1.32E-01	1.05E-01	1.01	4.81E+00	3.81E+00
	0.94125	0.002299	1.506E+08	1.0000	6.10E+01	0.071573	1.01	4.407E+00	2.26E-01	1.79E-01	1.01	1.39E+01	1.10E+01
	1.0939	0.004095	1.506E+08	1.0000	1.09E+02	0.14754	1.01	1.618E+01	4.55E-01	3.60E-01	1.00	4.94E+01	3.91E+01
	1.0988	0.002142	1.506E+08	1.0000	5.68E+01	0.077519	1.01	4.448E+00	2.39E-01	1.89E-01	1.00	1.36E+01	1.07E+01
	1.1022	0.001071	1.506E+08	1.0000	2.84E+01	0.038859	1.01	1.115E+00	1.20E-01	9.47E-02	1.00	3.40E+00	2.69E+00
	1.1143	0.014742	1.506E+08	1.0000	3.91E+02	0.54048	1.01	2.134E+02	1.66E+00	1.31E+00	1.00	6.49E+02	5.14E+02
	1.1416	0.005134	1.506E+08	1.0000	1.36E+02	0.19269	1.01	2.650E+01	5.89E-01	4.67E-01	1.00	8.02E+01	6.35E+01
	1.1454	0.001323	1.506E+08	1.0000	3.51E+01	0.049826	1.01	1.766E+00	1.52E-01	1.21E-01	1.00	5.34E+00	4.23E+00
	1.5718	0.002646	1.506E+08	1.0000	7.02E+01	0.13777	1.05	1.015E+01	3.82E-01	3.02E-01	0.98	2.62E+01	2.08E+01
	1.6146	0.002363	1.506E+08	1.0000	6.27E+01	0.12595	1.05	8.288E+00	3.47E-01	2.75E-01	0.98	2.13E+01	1.69E+01
	1.7683	0.16727	1.506E+08	1.0000	4.44E+03	9.6566	1.07	4.584E+04	2.61E+01	2.07E+01	0.98	1.13E+05	8.98E+04
	1.8125	0.001796	1.506E+08	1.0000	4.76E+01	0.10596	1.08	5.451E+00	2.85E-01	2.25E-01	0.98	1.33E+01	1.05E+01
	1.8509	0.014238	1.506E+08	1.0000	3.78E+02	0.85593	1.08	3.490E+02	2.29E+00	1.81E+00	0.97	8.38E+02	6.64E+02
	1.9254	0.005639	1.506E+08	1.0000	1.50E+02	0.3514	1.09	5.728E+01	9.30E-01	7.36E-01	0.97	1.35E+02	1.07E+02
	2.0048	0.05355	1.506E+08	1.0000	1.42E+03	3.4612	1.10	5.407E+03	9.07E+00	7.18E+00	0.97	1.25E+04	9.89E+03
	2.0158	0.12254	1.506E+08	1.0000	3.25E+03	7.9505	1.10	2.842E+04	2.08E+01	1.65E+01	0.97	6.57E+04	5.20E+04
	2.0792	0.014427	1.506E+08	1.0000	3.83E+02	0.95655	1.11	4.062E+02	2.50E+00	1.98E+00	0.97	9.28E+02	7.35E+02
	2.2523	0.022869	1.506E+08	1.0000	6.06E+02	1.6057	1.13	1.100E+03	4.18E+00	3.30E+00	0.96	2.43E+03	1.92E+03
	2.3219	0.006206	1.506E+08	1.0000	1.65E+02	0.44537	1.14	8.356E+01	1.16E+00	9.15E-01	0.96	1.83E+02	1.44E+02
	2.4753	0.003119	1.506E+08	1.0000	8.27E+01	0.23449	1.16	2.250E+01	6.05E-01	4.79E-01	0.95	4.75E+01	3.76E+01
	2.4976	0.001733	1.506E+08	1.0000	4.60E+01	0.13116	1.16	6.993E+00	3.38E-01	2.68E-01	0.95	1.48E+01	1.17E+01
	1.1186	0.026586	1.506E+08	1.0000	7.05E+02	0.97844	1.01	6.968E+02	3.00E+00	2.38E+00	1.00	2.12E+03	2.12E+03
SUM =								1.264E+06				3.95E+06	3.13E+06


27A = 1.08E+04 Rad/hr

27E = 3.96E+06 Rad/hr

27B = 1.23E+04 Rad/hr

27F = 3.13E+06 Rad/hr

Con. Vol= 5.68E+09 cm**3
27A Cone Factor 0.00856
27B Cone Factor 0.00973
Release Frac. 1

		VERIFY PRIOR TO USE
		DATE
WNP-2 PLANT PROCEDURES MANUAL		
PROCEDURE NUMBER 13.1.1	APPROVED BY	DATE
VOLUME NAME EMERGENCY PLAN IMPLEMENTING PROCEDURES		
SECTION EMERGENCY CLASSIFICATION		
TITLE CLASSIFYING THE EMERGENCY		

1.0 PURPOSE

The purpose of this procedure is to provide the Shift Manager, Plant Emergency Director, and plant operations personnel with the necessary information to guide them in properly identifying and classifying an emergency situation.

This procedure should be referred to whenever conditions at or near the Plant are out of the ordinary. Refer to PPM 13.1.1.A for the Technical Bases for this procedure.

2.0 REFERENCES

NOTE: Regulatory commitments made in:

Letter GO2-92-013, Supply System to NRC, dated January 12, 1993
 Letter GO2-83-237, Supply System to NRC, dated March 15, 1983, and
 Letter GO2-83-997, Supply System to NRC, dated October 31, 1983 are no longer valid in light of conversion from NUREG 0654 to NUMARC NESP-007 criteria in this procedure. Consequently these commitments will no longer be tracked nor 'belled' in this procedure.

2.1 WNP-2 Technical Specifications

2.2 WNP-2 Offsite Dose Calculation Manual

PROCEDURE NUMBER 13.1.1	REVISION	PAGE 1 of 19
----------------------------	----------	-----------------



1. The first part of the document is a list of names and titles, including "Mr. J. H. Smith, President, American Association of University Professors, 1234 Main Street, New York, N. Y. 10001." and "Mr. J. H. Smith, President, American Association of University Professors, 1234 Main Street, New York, N. Y. 10001." The list continues with several other names and titles, including "Mr. J. H. Smith, President, American Association of University Professors, 1234 Main Street, New York, N. Y. 10001." and "Mr. J. H. Smith, President, American Association of University Professors, 1234 Main Street, New York, N. Y. 10001." The list ends with "Mr. J. H. Smith, President, American Association of University Professors, 1234 Main Street, New York, N. Y. 10001."

2. The second part of the document is a list of names and titles, including "Mr. J. H. Smith, President, American Association of University Professors, 1234 Main Street, New York, N. Y. 10001." and "Mr. J. H. Smith, President, American Association of University Professors, 1234 Main Street, New York, N. Y. 10001." The list continues with several other names and titles, including "Mr. J. H. Smith, President, American Association of University Professors, 1234 Main Street, New York, N. Y. 10001." and "Mr. J. H. Smith, President, American Association of University Professors, 1234 Main Street, New York, N. Y. 10001." The list ends with "Mr. J. H. Smith, President, American Association of University Professors, 1234 Main Street, New York, N. Y. 10001."

3. The third part of the document is a list of names and titles, including "Mr. J. H. Smith, President, American Association of University Professors, 1234 Main Street, New York, N. Y. 10001." and "Mr. J. H. Smith, President, American Association of University Professors, 1234 Main Street, New York, N. Y. 10001." The list continues with several other names and titles, including "Mr. J. H. Smith, President, American Association of University Professors, 1234 Main Street, New York, N. Y. 10001." and "Mr. J. H. Smith, President, American Association of University Professors, 1234 Main Street, New York, N. Y. 10001." The list ends with "Mr. J. H. Smith, President, American Association of University Professors, 1234 Main Street, New York, N. Y. 10001."

- 2.3 WNP-2 FSAR Section 1.5.2, SBO Coping Study
- 2.4 WNP-2 FSAR Section 8.3.2.1, Batteries
- 2.5 WNP-2 FSAR Table 9.5-8, Location of Emergency Lighting
- 2.6 PPM 4.12.1.1 Control Room Evacuation and Remote Cooldown
- 2.7 PPM 4.12.4.2 Flood
- 2.8 PPM 4.12.4.3 Earthquake
- 2.9 PPM 4.12.4.8 Tornado/High Winds
- 2.10 PPM 4.12.4.10 Reactor Building 422 Area Flooding
- 2.11 PPM 5.0.10 EOP Flowchart Training Manual
- 2.12 PPM 5.1.2 RPV Control-ATWS
- 2.13 PPM 5.1.7 Primary Containment Flooding
- 2.14 PPM 9.3.22 Core Damage Evaluation
- 2.15 Calculation CE-02-93-16
- 2.16 Calculation 2.05.01 (Battery Size Calc)
- 2.17 NUMARC NESP-007, Rev. 2
- 2.18 NUMARC/NRC "Questions & Answers", June 1993
- 2.19 NUREG/CR-4982 "Severe Accident in Spent Fuel Pools in Support of Generic Safety Issue 82"
- 2.20 NUREG 0737 "Clarification of TMI Action Plan Requirements"
- 2.21 10CFR20
- 2.22 10CFR50
- 2.23 EPA 400 "Manual of Protective Action Guidelines and Protective Actions for Nuclear Incidents"

PROCEDURE NUMBER	REVISION	PAGE
13.1.1		2 of 19



1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110 111 112 113 114 115 116 117 118 119 120 121 122 123 124 125 126 127 128 129 130 131 132 133 134 135 136 137 138 139 140 141 142 143 144 145 146 147 148 149 150 151 152 153 154 155 156 157 158 159 160 161 162 163 164 165 166 167 168 169 170 171 172 173 174 175 176 177 178 179 180 181 182 183 184 185 186 187 188 189 190 191 192 193 194 195 196 197 198 199 200 201 202 203 204 205 206 207 208 209 210 211 212 213 214 215 216 217 218 219 220 221 222 223 224 225 226 227 228 229 230 231 232 233 234 235 236 237 238 239 240 241 242 243 244 245 246 247 248 249 250 251 252 253 254 255 256 257 258 259 260 261 262 263 264 265 266 267 268 269 270 271 272 273 274 275 276 277 278 279 280 281 282 283 284 285 286 287 288 289 290 291 292 293 294 295 296 297 298 299 300 301 302 303 304 305 306 307 308 309 310 311 312 313 314 315 316 317 318 319 320 321 322 323 324 325 326 327 328 329 330 331 332 333 334 335 336 337 338 339 340 341 342 343 344 345 346 347 348 349 350 351 352 353 354 355 356 357 358 359 360 361 362 363 364 365 366 367 368 369 370 371 372 373 374 375 376 377 378 379 380 381 382 383 384 385 386 387 388 389 390 391 392 393 394 395 396 397 398 399 400 401 402 403 404 405 406 407 408 409 410 411 412 413 414 415 416 417 418 419 420 421 422 423 424 425 426 427 428 429 430 431 432 433 434 435 436 437 438 439 440 441 442 443 444 445 446 447 448 449 450 451 452 453 454 455 456 457 458 459 460 461 462 463 464 465 466 467 468 469 470 471 472 473 474 475 476 477 478 479 480 481 482 483 484 485 486 487 488 489 490 491 492 493 494 495 496 497 498 499 500 501 502 503 504 505 506 507 508 509 510 511 512 513 514 515 516 517 518 519 520 521 522 523 524 525 526 527 528 529 530 531 532 533 534 535 536 537 538 539 540 541 542 543 544 545 546 547 548 549 550 551 552 553 554 555 556 557 558 559 560 561 562 563 564 565 566 567 568 569 570 571 572 573 574 575 576 577 578 579 580 581 582 583 584 585 586 587 588 589 590 591 592 593 594 595 596 597 598 599 600 601 602 603 604 605 606 607 608 609 610 611 612 613 614 615 616 617 618 619 620 621 622 623 624 625 626 627 628 629 630 631 632 633 634 635 636 637 638 639 640 641 642 643 644 645 646 647 648 649 650 651 652 653 654 655 656 657 658 659 660 661 662 663 664 665 666 667 668 669 670 671 672 673 674 675 676 677 678 679 680 681 682 683 684 685 686 687 688 689 690 691 692 693 694 695 696 697 698 699 700 701 702 703 704 705 706 707 708 709 710 711 712 713 714 715 716 717 718 719 720 721 722 723 724 725 726 727 728 729 730 731 732 733 734 735 736 737 738 739 740 741 742 743 744 745 746 747 748 749 750 751 752 753 754 755 756 757 758 759 760 761 762 763 764 765 766 767 768 769 770 771 772 773 774 775 776 777 778 779 780 781 782 783 784 785 786 787 788 789 790 791 792 793 794 795 796 797 798 799 800 801 802 803 804 805 806 807 808 809 810 811 812 813 814 815 816 817 818 819 820 821 822 823 824 825 826 827 828 829 830 831 832 833 834 835 836 837 838 839 840 841 842 843 844 845 846 847 848 849 850 851 852 853 854 855 856 857 858 859 860 861 862 863 864 865 866 867 868 869 870 871 872 873 874 875 876 877 878 879 880 881 882 883 884 885 886 887 888 889 890 891 892 893 894 895 896 897 898 899 900 901 902 903 904 905 906 907 908 909 910 911 912 913 914 915 916 917 918 919 920 921 922 923 924 925 926 927 928 929 930 931 932 933 934 935 936 937 938 939 940 941 942 943 944 945 946 947 948 949 950 951 952 953 954 955 956 957 958 959 960 961 962 963 964 965 966 967 968 969 970 971 972 973 974 975 976 977 978 979 980 981 982 983 984 985 986 987 988 989 990 991 992 993 994 995 996 997 998 999 1000

2.24 FSAR, Chapter 13.3, Emergency Preparedness Plan, Section 6

2.25 NUREG-0654, FEMA-REP-1, Rev. 1, Appendix 1

2.26 PPM 13.1.2, Plant Emergency Director Duties

2.27 PPM 13.4.1, Notifications

2.28 WNP-2 Safeguards Contingency Plan

3.0 PROCEDURE

3.1 Plant Emergency Director Responsibilities

Maintain the sole responsibility for timely classification and declaration of any WNP-2 emergency situation. Utilize guidance specified in this procedure, and the recommendations of the Operations Manager, Shift Manager, Control Room Supervisor, Shift Technical Advisor, Radiological Protection Manager, and Recovery Manager.

Given the abnormal conditions at or near the Plant, utilize Attachment 4.1, Emergency Classification Table for guidance in determining the proper emergency classification.

Refer to PPM 13.1.2 for actions and responsibilities necessary after the emergency has been classified, and PPM 13.4.1, for responsibilities to notify offsite emergency authorities.

3.2 Shift Manager Responsibilities

Function as the Plant Emergency Director until relieved.

Maintain primary responsibility for monitoring the status of plant parameters and other initiating conditions upon which emergency classification depends.

Recommend an appropriate emergency classification to the Plant Emergency Director for any observed WNP-2 emergency conditions. Utilize guidance specified in this procedure, and the recommendations of the Control Room Supervisor, Shift Technical Advisor, and Reactor Operators.

PROCEDURE NUMBER	REVISION	PAGE
13.1.1		3 of 19



3.3 Control Room Supervisor, Shift Technical Advisor, Reactor Operator Responsibilities

Monitor the status of Plant parameters and other initiating conditions upon which the emergency classification depends, and inform the Shift Manager if any parameter approaches or exceeds emergency action levels as specified in this procedure. Refer to Attachment 4.1, Emergency Classification Table for examples, and to PPM 13.1.1A for the basis of each emergency action level.

3.4 Technical Support Center (TSC) Staff and Recovery Manager Responsibilities

Recommend an emergency classification to the Plant Emergency Director based upon plant conditions and the guidance provided in this procedure.

3.5 Use of Plant Instruments and Indications

Plant instrumentation described in each EAL in Attachment 4.1 is the primary instrumentation to be used. This does not preclude use of other instruments as alternate indication, as appropriate, to properly classify the emergency.

An indication or report condition is considered to be valid or confirmed when it is conclusively verified by:

- an instrument channel check; or
- indications on related or redundant indicators; or
- by direct observation by plant personnel, such that doubt related to the indicator's operability, the condition's existence, or the report's truth is removed.

Implicit in this definition is the need for timely assessment.

3.6 Emergency Class Description

The following is a description of the four classes of emergency.

NOTIFICATION OF UNUSUAL EVENT: Unusual events are in process or have occurred which indicate a potential degradation of the level of safety of the plant. No releases of radioactive material requiring offsite response or monitoring are expected unless further degradation of safety systems occurs.

ALERT: Events are in process or have occurred which involve an actual or potential substantial degradation of the level of safety of the plant. Any releases are expected to be limited to small fractions of the EPA Protective Action Guideline exposure levels.

SITE AREA EMERGENCY: Events are in process or have occurred which involve actual or likely major failures of plant functions needed for protection of the public.

PROCEDURE NUMBER	REVISION	PAGE
13.1.1		4 of 19

1. The first part of the document is a list of names and addresses of the members of the committee.

2. The second part of the document is a list of names and addresses of the members of the committee.

3. The third part of the document is a list of names and addresses of the members of the committee.

4. The fourth part of the document is a list of names and addresses of the members of the committee.

5. The fifth part of the document is a list of names and addresses of the members of the committee.

Any releases are not expected to result in exposure levels which exceed EPA Protective Action Guideline exposure levels except near the site boundary.

GENERAL EMERGENCY: Events are in process or have occurred which involve actual or imminent substantial core degradation or melting with potential for loss of containment integrity. Releases can be reasonably expected to exceed EPA Protective Action Guideline exposure levels offsite for more than the immediate site area.

3.7 Mode Applicability

The operational conditions (modes) in which Initiating conditions are applicable are indicated by a series of boxes as follows;

1	2	3	4	5	Def
---	---	---	---	---	-----

where the numbers indicate operational conditions as defined in Technical Specifications and Def indicates "Defueled" or all fuel removed from the reactor vessel.

4.0 ATTACHMENTS

4.1 Emergency Classification Table

PROCEDURE NUMBER 13.1.1	REVISION	PAGE 5 of 19
----------------------------	----------	-----------------

2. The second part of the report is a detailed account of the work done during the year.

3. The third part of the report is a summary of the work done during the year.

4. The fourth part of the report is a summary of the work done during the year.

5. The fifth part of the report is a summary of the work done during the year.

6. The sixth part of the report is a summary of the work done during the year.

7. The seventh part of the report is a summary of the work done during the year.

8. The eighth part of the report is a summary of the work done during the year.

9. The ninth part of the report is a summary of the work done during the year.

WNP-2 EMERGENCY CLASSIFICATION TABLE

CATEGORY	UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
CATEGORY A FISSION PRODUCT BARRIER DEGRADATION	<p>AU1 Fuel Clad Degradation</p> <p>1 2 3 4</p> <p>Confirmed "SIAE CONDSR OUTLET RAD HH" alarm annunciated on P802.</p> <p>OR</p> <p>Laboratory analysis confirms Reactor Coolant System (RCS) sample activity greater than or equal to limits specified in Tech. Spec. 3.4.5.</p>	<p>AA1 Loss OR Potential Loss of Fuel Clad</p> <p>1 2 3</p> <p>Loss OR Potential Loss of the Fuel Clad as indicated by Fission Product Barrier Degradation Table</p>	<p>AS1 Loss OR Potential Loss of ANY two Fission Product Barriers</p> <p>1 2 3</p> <p>Loss OR Potential Loss of ANY TWO Fission Product Barriers as indicated by Fission Product Barrier Degradation Table</p>	<p>AG1 Loss of ANY two Barriers AND a loss or potential loss of the Third Barrier</p> <p>1 2 3</p> <p>Loss of any TWO fission product barriers as indicated by Fission Product Barrier Degradation Table AND Loss OR Potential Loss of the third barrier as indicated by Fission Product Barrier Degradation Table</p>
	<p>AU2 Reactor Coolant System Leakage</p> <p>1 2 3</p> <p>Valid unidentified leakage greater than or equal to 10 gpm or upscale high indicated on Recorder EDR-FRS-623, Drywell Floor Drain Sump F/R Rate and Sump Level, on Panel P832 OR Valid identified leakage greater than or equal to 25 gpm indicated on Recorder EDR-FRS-623, Drywell Equipment Drain Sump F/R Rate and Sump Level, on Panel P832</p>	<p>AA2 Loss OR Potential Loss of Reactor Coolant System (RCS)</p> <p>1 2 3</p> <p>Loss OR Potential Loss of the RCS barrier as indicated by Fission Product Barrier Degradation Table</p>		
	<p>AU3 Loss OR Potential Loss of Containment</p> <p>1 2 3</p> <p>Loss OR Potential Loss of the Primary Containment barrier as indicated by Fission Product Barrier Degradation Table</p>		<p>AS2 Loss of Water Level in the Reactor Vessel that has or will uncover fuel in the Reactor Vessel</p> <p>1 2 3 4 5</p> <p>RPV level is less than -161 inches</p>	

PROCEDURE NUMBER
13.1.1

REVISION

PAGE
6 of 19

Attachment 4.1



WNP-2 EMERGENCY CLASSIFICATION TABLE
FISSION PRODUCT BARRIER DEGRADATION

INDICATOR	FUEL CLAD		REACTOR COOLANT SYSTEM		PRIMARY CONTAINMENT SYSTEM	
	POTENTIAL LOSS	LOSS	POTENTIAL LOSS	LOSS	POTENTIAL LOSS	LOSS
RPV LEVEL	Level is less than -181"	Entry into PPM 5.1.7		Level is less than -181"	Entry into PPM 5.1.7	
DRYWELL/CONTAINMENT RADIATION MONITORS		Containment Radiation Monitor CMS-RIS-27E and CMS-RIS-27F reading greater than 3,600 R/hr		Containment Radiation Monitor CMS-RIS-27E and CMS-RIS-27F reading greater than 70 R/hr	Containment Radiation Monitor CMS-RIS-27E and CMS-RIS-27F reading greater than 14,000 R/hr	
DRYWELL/CONTAINMENT PRESSURE				Drywell pressure greater than 1.68 psig WITH indications of RCS leak inside drywell	Containment pressure greater than 39 psig and increasing OR Containment H ₂ & O ₂ concentration greater than 8% H ₂ and 5% O ₂	Rapid unexplained decrease of containment pressure following an initial increase
CONTAINMENT ISOLATION VALVES					Wetwell pressure exceeds PSP	Drywell Pressure Response not consistent with LOCA conditions Failure of BOTH containment isolation valves (as listed in T.S. Table 3.8.3-1) in any one line to close following AUTO or MANUAL initiation AND Downstream pathway to the environment exists OR Unstable primary system discharging outside primary containment as indicated by any area temperature or radiation level above Maximum Safe Operating values (PPM 5.3.1) OR Intentional venting per PPM 5.2.1
COOLANT ACTIVITY		Coolant activity greater than 300 uCi/gm Dose Equivalent iodine				
RCS LEAK RATE			Unstable primary system discharging outside primary containment as indicated by any area temperature or radiation level above Maximum Safe Operating values (PPM 5.3.1) OR RCS Leakage GT 30 gpm inside containment or EDR FRS-623 upscale high			
OTHER					Cannot maintain plant parameters below the HCTL or SRVPLL or above the HCTL	
PEO JUDGEMENT	Any condition that in the judgement of the PEO/Shift Manager indicates LOSS or POTENTIAL LOSS of the Fuel Clad Barrier		Any condition that in the judgement of the PEO/Shift Manager indicates LOSS or POTENTIAL LOSS of the RCS Barrier		Any condition that in the judgement of the PEO/Shift Manager indicates LOSS or POTENTIAL LOSS of the Primary Containment Barrier	

PROCEDURE NUMBER
13.1.1

REVISION

Attachment 4.1

PAGE
7 of 19

1. The first part of the document is a list of names and addresses of the members of the committee.

2. The second part of the document is a list of names and addresses of the members of the committee.

3. The third part of the document is a list of names and addresses of the members of the committee.

4. The fourth part of the document is a list of names and addresses of the members of the committee.

5. The fifth part of the document is a list of names and addresses of the members of the committee.

6. The sixth part of the document is a list of names and addresses of the members of the committee.

7. The seventh part of the document is a list of names and addresses of the members of the committee.

8. The eighth part of the document is a list of names and addresses of the members of the committee.

WNP-2 EMERGENCY CLASSIFICATION TABLE

CATEGORY	UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
CATEGORY B LOSS OF SHUTDOWN OR COOLDOWN FUNCTIONS	BU1 Inability to Reach Shutdown Within Technical Specification Limits <div>123</div> Plant is not brought to required operating mode within Technical Specification LCO Action Statement Time.	BA1 Inability to Maintain Plant in Cold Shutdown <div>46</div> Inability to maintain a reactor temperature of less than 200°F per PPM 4.4.2.1	BS1 Complete Loss of Functions Needed to Achieve Cold Shutdown <div>123</div> RPV pressure and suppression pool temperature cannot be maintained below the Heat Capacity Temperature Limit	

PROCEDURE NUMBER
13.1.1

REVISION

PAGE
8 of 19

Attachment 4.1

WNP-2 EMERGENCY CLASSIFICATION TABLE

CATEGORY	UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
CATEGORY C ANTICIPATED TRANSIENT WITHOUT SCRAM		<p>CA1 Failure of Reactor Protection System (RPS) Instrumentation to Complete or Initiate a Reactor Scram AND Manual Scram Was Successful.</p> <p>112</p> <p>One or more Reactor Protection System setpoint(s) have been exceeded per Tech. Spec. 2.2</p> <p>AND</p> <p>Automatic RPS actuation failed to result in a control rod pattern which alone always assures reactor shutdown.</p>	<p>CS1 Failure of RPS Instrumentation to Complete or Initiate an Automatic Reactor Scram AND Manual Scram with Continued Power Generation.</p> <p>112</p> <p>One or more Reactor Protection System setpoint(s) have been exceeded per Tech. Spec. 2.2</p> <p>AND</p> <p>Automatic and manual RPS actuation failed to result in a control rod pattern which alone always assures reactor shutdown</p> <p>AND either</p> <p>Reactor power GT 5%</p> <p>OR</p> <p>Wetwell temperature GT 110°F</p>	<p>CG1 Failure of the RPS to Complete an Automatic Scram AND Manual Scram Was NOT Successful AND There is Indication of an Extreme Challenge to the Ability to Cool the Core</p> <p>112</p> <p>One or more Reactor Protection System setpoint(s) have been exceeded per Tech. Spec. 2.2</p> <p>AND</p> <p>Automatic and manual RPS actuation failed to result in a control rod pattern which alone always assures reactor shutdown</p> <p>AND either</p> <p>Wetwell temperature cannot be maintained less than the HCTL</p> <p>OR</p> <p>Entry into Primary Containment Flooding, PPM 5.1.7, is required</p>

13.1.1

PROCEDURE NUMBER

REVISION

9 of 19

PAGE

Attachment 4.1



WNP-2 EMERGENCY CLASSIFICATION TABLE

CATEGORY	UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
CATEGORY D A.C. POWER LOSS	DU1 Loss of ALL Off-Site Power to Critical AC Busses for Greater Than 15 Minutes <div>1 2 3 4 5 Def</div> Power is unavailable to SM-7 and SM-8 from Offsite AC sources for greater than 15 minutes	DA1 Loss of ALL Off Site Power AND Loss of ALL On-Site Power to Critical AC Busses for Greater Than 15 Minutes <div>4 5 Def</div> Complete loss of all power to Bus SM-7 and to Bus SM-8 for greater than 15 minutes	DS1 Loss of ALL Off-Site Power AND Loss of ALL On-Site Power to Critical AC Busses for Greater Than 15 Minutes <div>1 2 3</div> Complete loss of all power to Bus SM-7 and to Bus SM-8 for greater than 15 minutes	DG1 PROLONGED Loss of ALL Off-Site Power AND PROLONGED Loss of ALL On-Site Power to Critical AC Busses <div>1 2 3</div> <div>Complete loss of all power to Bus SM-7 and to Bus SM-8</div> AND power to either Bus SM-7 or SM-8 is not likely to be restored within 4 hours OR RPV level is less than -161"
		DA2 Power Capability to Critical Busses Reduced to a Single Power Source for Greater Than 15 Minutes Such That Any Additional Single Failure Would Result in a Station Blackout <div>1 2 3</div> <div>Complete loss of all power to Bus SM-7 for greater than 15 minutes. AND Bus SM-8 has only one of the following power sources: <ul style="list-style-type: none"> SM-3 TR-8 DG-2 </div> OR <div>Complete loss of all power to Bus SM-8 for greater than 15 minutes. AND Bus SM-7 has only one of the following power sources: <ul style="list-style-type: none"> SM-1 TR-8 DG-1 </div>		

13.1.1

PROCEDURE NUMBER

REVISION

10 of 19

PAGE

Attachment 4.1



WNP-2 EMERGENCY CLASSIFICATION TABLE

CATEGORY	UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
CATEGORY E D.C. POWER LOSS	<p>EU1 Degradation of All Critical DC Power for Greater Than 15 Minutes</p> <p>4 6</p> <p>Degradation of Division 1 Critical DC voltage as indicated by Bus Voltage less than 110 VDC on 125 V Dist. Panel S1-1 voltmeter located on B4, C for greater than 15 minutes</p> <p>AND</p> <p>Degradation of Division 2 Critical DC voltage as indicated by Bus Voltage less than 110 VDC on 125 V Dist. Panel S1-2 voltmeter located on B4, C for greater than 15 minutes</p>		<p>ES1 Degradation of All Critical DC Power for Greater Than 15 Minutes</p> <p>1 2 3</p> <p>Degradation of Division 1 Critical DC voltage as indicated by Bus Voltage less than 110 VDC on 125 V Dist. Panel S1-1 voltmeter located on B4, C for greater than 15 minutes</p> <p>AND</p> <p>Degradation of Division 2 Critical DC voltage as indicated by Bus Voltage less than 110 VDC on 125 V Dist. Panel S2-1 voltmeter located on B4, C for greater than 15 minutes</p>	

PROCEDURE NUMBER
13.1.1

REVISION

PAGE
11 of 19

Attachment 4.1



WNP-2 EMERGENCY CLASSIFICATION TABLE

CATEGORY	UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
CATEGORY F INCREASED PLANT RADIATION RELEASE	FU1 Unexpected Increase in Plant Radiation Levels <div>12345Def</div> Any of the following Area Radiation Monitors exceeding 5,000 mR/hr: ARM-RIS- 4 ARM-RIS- 5 ARM-RIS- 6 ARM-RIS- 7 ARM-RIS- 8 ARM-RIS- 9 ARM-RIS-10 ARM-RIS-11 ARM-RIS-12 ARM-RIS-13 ARM-RIS-14 ARM-RIS-15 ARM-RIS-16 ARM-RIS-17 ARM-RIS-18 ARM-RIS-20 ARM-RIS-21 ARM-RIS-22 ARM-RIS-23 ARM-RIS-24 ARM-RIS-25 ARM-RIS-26 ARM-RIS-27 ARM-RIS-28 ARM-RIS-29 ARM-RIS-30 ARM-RIS-32 ARM-RIS-33	FA1 Major Damage to Irradiated Fuel OR Loss of Water Level That Has or Will Result in the Uncovering of Irradiated Fuel Outside the RPV <div>123456Def</div> A confirmed HIGH alarm on ARM-RIS-1 Fuel Pool Radiation Monitor resulting from uncontrolled fuel storage or handling <		

PROCEDURE NUMBER
13.1.1

REVISION

PAGE
12 of 19

Attachment 4.1



WNP-2 EMERGENCY CLASSIFICATION TABLE

CATEGORY	UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
CATEGORY G INCREASED RADIATION RELEASE TO THE ENVIRONMENT	<p>GU1 Any Unplanned Release of Gaseous or Liquid Radioactivity to the Environment That Exceeds Two Times the Radiological Technical Specifications for 60 minutes or longer</p> <p>1 2 3 4 5 Def</p> <p>A valid reading on one or more of the following monitors that exceeds the value shown for 60 minutes or longer AND assessment in accordance with PPM 13.8.1 or 13.8.2 using isotopic source term obtained from effluent grab sampling and laboratory analysis confirms Site Boundary dose rates equal to or greater than 0.1 mrem/hr TEDE or 0.3 mrem/hr thyroid CDE:</p> <p>PRM-RE-18 905,000 CPS TEA-RIS-13 18,750 CPM WEA-RIS-14 120,000 CPM</p> <p>NOTE: If the monitor reading(s) is sustained for longer than 60 minutes and the required assessments cannot be completed within this period, then the declaration must be made based on the valid reading.</p> <p>OR</p> <p>Assessment in accordance with PPM 13.8.1 or 13.8.2 using isotopic source term obtained from effluent grab sampling and laboratory analysis confirms Site Boundary dose rates equal to or greater than 0.1 mrem/hr TEDE or 0.3 mrem/hr thyroid CDE.</p> <p>OR</p> <p>A valid reading on one or more of the following monitors that exceeds the value shown AND sample analysis indicates greater than TWO times ODCM 8.2.1.1 limits for 60 minutes or longer:</p> <p>SWRE-4 SW Loop A Process Rad Monitor 200 CPS SWRE-5 SW Loop B Process Rad Monitor 200 CPS FDR-RE-8 Radwaste Effluent 2 X High Alarm TSW-RE-5 TSW Effluent 3900 CPM</p> <p>NOTE: If the monitor reading is sustained for longer than 60 minutes and the required assessments cannot be completed within this period, then the declaration must be made based on the valid reading.</p> <p>OR</p> <p>Sample analysis indicates greater than TWO times ODCM 8.2.1.1 limits for 60 minutes or longer.</p>	<p>GA1 Any Unplanned Release of Gaseous or Liquid Radioactivity to the Environment That Exceeds 200 Times the Radiological Technical Specifications for 15 minutes or longer</p> <p>1 2 3 4 5 Def</p> <p>A valid reading on one or more of the following monitors that exceeds the value shown for 15 minutes or longer AND assessment in accordance with PPM 13.8.1 or 13.8.2 confirms Site Boundary dose rates equal to or greater than 10 mrem/hr TEDE or 50 mrem/hr thyroid CDE:</p> <p>PRM-RE-1C 850 CPS TEA-RIS-13 440,000 CPM WEA-RIS-14 187,000 CPM</p> <p>NOTE: If the monitor reading(s) is sustained for longer than 15 minutes and the required assessments cannot be completed within this period, then the declaration must be made based on the valid reading.</p> <p>OR</p> <p>Offsite dose calculations indicate greater than 10 mrem/hr TEDE or greater than 50 mrem/hr CDE to the thyroid and the release continues at or above that level for 15 minutes or longer.</p> <p>OR</p> <p>A valid reading on one or more of the following monitors that exceeds the value shown AND sample analysis indicates greater than 200 times ODCM 8.2.1.1 limit for 15 minutes or longer:</p> <p>SWRE-4 SW Loop A Process Rad Monitor 20,000 CPS SWRE-5 SW Loop B Process Rad Monitor 20,000 CPS FDR-RE-8 Radwaste Effluent Monitor 200 X High Alarm TSW-RE-5 TSW Effluent Monitor 390,000 CPM</p> <p>NOTE: If the monitor reading is sustained for longer than 15 minutes and the required assessment cannot be completed within this period, then the declaration must be made based on the valid reading.</p> <p>OR</p> <p>Sample analysis indicates greater than 200 times ODCM limits for 15 minutes or longer.</p>	<p>GS1 Boundary Dose Resulting from an Actual or Imminent Release of Gaseous Radioactivity That Exceeds 100 mrem Total Effective Dose Equivalent or 500 mrem Thyroid Committed Dose Equivalent for the Actual OR Projected Duration of the Release</p> <p>1 2 3 4 5 Def</p> <p>A valid reading on one or more of the following monitors that exceeds or is expected to exceed the value shown:</p> <p>PRM-RE-1C 8500 CPS TEA-RIS-13 440,000 CPM WEA-RIS-14 1,870,000 CPM</p> <p>AND</p> <p>Assessment in accordance with PPM 13.8.1 or 13.8.2 indicates offsite doses greater than 100 mrem TEDE or 500 mrem thyroid CDE for the actual or projected duration of the release.</p> <p>NOTE: If the monitor reading is sustained for longer than 15 minutes and the required assessment cannot be completed within this period, then the declaration must be made based on the valid reading.</p> <p>OR</p> <p>Valid dose assessment indicates dose consequences greater than 100 mrem TEDE or 500 mrem thyroid CDE</p> <p>OR</p> <p>Field survey results indicate Protected Area Boundary dose rates exceeding 100 mrem/hr and are expected to continue for more than one hour</p> <p>OR</p> <p>Analyses of field survey samples indicate thyroid CDE of 500 mrem for one hour of inhalation</p>	<p>GG1 Boundary Dose Resulting from an Actual or Imminent Release of Gaseous Radioactivity That Exceeds 1800 mrem Total Effective Dose Equivalent or 5000 mrem Thyroid Committed Dose Equivalent for the Actual OR Projected Duration of the Release Using Actual Meteorology</p> <p>1 2 3 4 5 Def</p> <p>A valid reading on one or more of the following monitors that exceeds or is expected to exceed the value shown:</p> <p>PRM-RE-1C 85,000 CPS TEA-RIS-13A 8 PMU WEA-RIS-14A 28 PMU</p> <p>AND</p> <p>Assessment in accordance with PPM 13.8.1 or 13.8.2 indicates offsite doses greater than 1000 mrem TEDE or 5000 mrem thyroid CDE for the actual or projected duration of the release.</p> <p>NOTE: If the monitor reading(s) is sustained for longer than 15 minutes and the required assessment cannot be completed within this period,</p> <p>OR</p> <p>Valid dose assessment capability indicates dose consequences greater than 1000 mrem TEDE or 5000 mrem thyroid CDE</p> <p>OR</p> <p>Field survey results indicate Protected Area Boundary dose rates exceeding 1000 mrem/hr and are expected to continue for more than one hour</p> <p>OR</p> <p>Analyses of field survey samples indicate thyroid CDE of 5000 mrem for one hour of inhalation</p>

13.1.1

PROCEDURE NUMBER

REVISION

Attachment 4.1

13 of 19

PAGE

THE UNITED STATES OF AMERICA
DEPARTMENT OF THE INTERIOR
BUREAU OF LAND MANAGEMENT

WATER RESOURCES DIVISION
NATIONAL CENTER FOR WATER RESEARCH
WASHINGTON, D. C. 20004

WATER RESOURCES DIVISION
NATIONAL CENTER FOR WATER RESEARCH

WATER RESOURCES DIVISION
NATIONAL CENTER FOR WATER RESEARCH

WATER RESOURCES DIVISION
NATIONAL CENTER FOR WATER RESEARCH

WATER RESOURCES DIVISION
NATIONAL CENTER FOR WATER RESEARCH

WNP-2 EMERGENCY CLASSIFICATION TABLE

CATEGORY	UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
<p>CATEGORY H FIRE</p>	<p>HU1 Fire Within the Protected Area Boundary Not Extinguished within 15 minutes of Detection OR an Explosion Within the Protected Area Boundary</p> <p>1 2 3 4 5 Def</p> <p>Fire within or adjacent to any Safe Shutdown Building Table 1, which is <u>not</u> extinguished within 15 minutes of a valid alarm.</p> <p>OR</p> <p>Fire within or adjacent to any Safe Shutdown Building Table 1, which is <u>not</u> extinguished within 15 minutes of Control Room notification by plant personnel.</p> <p>OR</p> <p>Report by plant personnel of an unplanned explosion within the protected area boundary resulting in visible damage to permanent structures or equipment.</p>	<p>HA1 Fire or Explosion Affecting the Operability of Plant Safety Systems Required to Establish or Maintain Safe Shutdown</p> <p>1 2 3 4 5 Def</p> <p>Confirmed fire or explosion in a safe shutdown building Table 1</p> <p>AND</p> <p>Affected safe shutdown system parameters indicate degraded performance</p> <p>OR</p> <p>Report by plant personnel of visible damage to the safe shutdown building or equipment contained within the safe shutdown building</p>	<p>Table 1</p> <p>Safe Shutdown Buildings</p> <ul style="list-style-type: none"> • Vast portions of the Radwaste/Control Building • Reactor Building • Turbine Building • Standby Service Water Pump Houses • Diesel Generator Building • Diesel Generator Fuel Oil Storage Area 	
<p>CATEGORY I CONTROL ROOM EVACUATION</p>		<p>IA1 Control Room Evacuation has been Initiated</p> <p>1 2 3 4 5 Def</p> <p>Entry into PPM 4.12.1.1, "Control Room Evacuation and Remote Cooledown"</p>	<p>IS1 Control Room Evacuation has been Initiated, BUT Plant Control Cannot Be Established</p> <p>1 2 3 4 5 Def</p> <p>Control room evacuation has been initiated PPM 4.12.1.1, "Control Room Evacuation and Remote Cooledown"</p> <p>AND</p> <p>Control of plant equipment needed to maintain adequate core cooling cannot be established at either the Division 1 or Division 2 Remote Shutdown Panels in accordance with PPM 4.12.1.1 within 15 minutes of the SRO in charge of the Control Room physically leaving the Control Room</p>	

PROCEDURE NUMBER
13.1.1

REVISION

Attachment 4.1

PAGE
14 of 19

WNP-2 EMERGENCY CLASSIFICATION TABLE

CATEGORY	UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
CATEGORY J LOSS OF ANNUNCIATORS OR INDICATIONS	<p>JU1 Unplanned Loss of Most or All Safety System Annunciators or Indications on Panels P601, P602, P603 & Bd C for Greater Than 15 minutes</p> <p>1 2 3</p> <p>Unplanned Loss of most or all annunciators on P601, P602, P603 and Bd C associated with safety related equipment for greater than 15 minutes</p> <p>AND</p> <p>Compensatory nonalarming indications ARE available (Plant Computer System, GDS or other installed monitors).</p> <p>AND</p> <p>In the opinion of the Shift Manager/PED, the loss of the indications or annunciators requires increased surveillance to safely operate the plant</p>	<p>JA1 Unplanned Loss of Most or All Safety System Annunciators or Indications on Panels P601, P602, P603 & Bd C With Either: (1) A Significant Transient in Progress; OR (2) Compensatory Non-Alerting Indications Are Unavailable</p> <p>1 2 3</p> <p>Unplanned loss of most or all annunciators on P601, P602, P603 and Bd C associated with safety related equipment for greater than 15 minutes</p> <p>AND</p> <p>In the opinion of the Shift Manager/PED, the loss of the indications or annunciators requires increased surveillance to safely operate the plant</p> <p>AND</p> <p>A significant plant transient is in progress.</p> <p>OR</p> <p>Compensatory nonalarming indications are NOT available (Plant Computer System, GDS or other installed monitors).</p>	<p>JS1 Inability to Monitor a Significant Transient in Progress</p> <p>1 2 3</p> <p>Loss of most or all annunciators on P601, P602, P603, and Bd C associated with safety related equipment</p> <p>AND</p> <p>Compensatory non-alerting indications are unavailable (Process Computer System, GDS or other installed monitors).</p> <p>AND</p> <p>Loss of indications needed to monitor any of the following plant critical safety parameters: Reactor power, RPV level, RPV pressure, Wetwell pressure, Drywell pressure, Drywell temperature, Wetwell/Drywell H2O2 concentrations, Wetwell level, Wetwell temperature, Radioactive Gaseous Effluents</p> <p>AND</p> <p>Significant transient in progress</p>	

13.1.1

PROCEDURE NUMBER

REVISION

15 of 19

PAGE

Attachment 4.1



THE UNIVERSITY OF CHICAGO

THE UNIVERSITY OF CHICAGO



THE UNIVERSITY OF CHICAGO

THE UNIVERSITY OF CHICAGO

THE UNIVERSITY OF CHICAGO



WNP-2 EMERGENCY CLASSIFICATION TABLE

CATEGORY	UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
CATEGORY K LOSS OF COMMUNICATIONS	<p>KU1 Significant Loss of On-Site OR Off-Site Communication Capabilities</p> <p>1 2 3 4 5 Def</p> <p>Unplanned loss of all of the following on-site communications capability: Plant Public Address (PA) System Plant Telephone System Plant Radio System Operations and Security Channels</p> <p>OR</p> <p>Unplanned loss of the following off-site communications capability: State/County Notification (CRASH) System Offsite calling capability from the Control Room via direct telephone and fax lines Long distance calling capability on the Plant ("2000") Switch and Plant Support Facility/Plant Engineering Center ("8000") Switch</p>			

PROCEDURE NUMBER
13.1.1

REVISION

PAGE
16 of 19

Attachment 4.1



WNP-2 EMERGENCY CLASSIFICATION TABLE

CATEGORY	UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
CATEGORY I NATURAL AND DESTRUCTIVE PHENOMENA	<p>LU1 Natural and Destructive Phenomena Affecting the Protected Area Boundary</p> <p>1 2 3 4 5 Def</p> <p>Maximum Seismic Earthquake Exceeded (H13-P851-S1-2.5) AND Control Room receives report from plant personnel who have felt an earthquake</p> <p>OR</p> <p>Report by plant personnel confirming the occurrence of a tornado striking within the Protected Area Boundary</p> <p>OR</p> <p>Vehicle crash into or projectile which impacts plant structures or systems within Protected Area boundary.</p> <p>OR</p> <p>Weather Service projected winds GT 80, or Control Room measured winds GT 68 mph (5 min. average at 33 ft.)</p> <p>OR</p> <p>Range fires near the plant which threaten to reduce the normal level of safety</p> <p>OR</p> <p>Turbine failure resulting in casing penetration or damage to turbine or generator seals</p> <p>OR</p> <p>Visible ash fallout from volcanic activity</p> <p>OR</p> <p>Floods where the river pump house is observed to be in danger of inundation</p>	<p>LA1 Natural and Destructive Phenomena Affecting Plant Safe Shutdown Buildings</p> <p>1 2 3 4 5 Def</p> <p>Operating Basis Earthquake Exceeded (H13-P851-S1-5.1) AND Control Room receives report from plant personnel who have felt an earthquake</p> <p>OR</p> <p>Report by plant personnel confirming the occurrence of a tornado striking a plant Safe Shutdown building, Table 1</p> <p>OR</p> <p>Vehicle crash or projectile impact which impedes access to or damages equipment in plant vital areas.</p> <p>OR</p> <p>Weather Service projected winds GT 100, or Control Room measured winds GT 78 mph (5 min. average at 33 ft.)</p> <p>OR</p> <p>Ash fallout from volcanic activity which is severe enough to warrant plant shutdown</p> <p>OR</p> <p>Missiles generated from the turbine failure have resulted in visible structural damage to or penetration of a safe shutdown building</p> <p>OR</p> <p>Report by plant personnel of an event causing visible structural damage to a safe shutdown building Table 1</p> <p>OR</p> <p>Report by plant personnel confirming the occurrences of plant internal flooding in a safe shutdown building AND Affected safe shutdown system parameters indicate degraded performance</p>	<p>Table 1</p> <p>Safe Shutdown Buildings</p> <ul style="list-style-type: none"> Vital portions of the Redwaste/Control Building Reactor Building Turbine Building Standby Service Water Pump Houses Diesel Generator Building Diesel Generator Fuel Oil Storage Area 	

13.1.1

PROCEDURE NUMBER

REVISION

Attachment 4.1

17 of 19

PAGE

WNP-2 EMERGENCY CLASSIFICATION TABLE

CATEGORY	UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
CATEGORY M RELEASE OF TOXIC/FLAMMABLE GAS	<p>MU1 Release of Toxic or Flammable Gases Affecting the Protected Area Boundary Deemed Detrimental to Safe Operation of the Plant</p> <p>1 2 3 4 5 Def</p> <p>Report or detection of toxic or flammable gases that could enter or have entered within the Protected Area boundary in amounts that could affect the health of plant personnel or safe plant operation</p> <p>OR</p> <p>Report by local, county or state officials for potential evacuation of site personnel based on offsite event</p>	<p>MA1 Release of Toxic or Flammable Gases Within a Facility Structure Which Jeopardizes Operation of Systems Required to Maintain Safe Operations or to Establish or Maintain Cold Shutdown</p> <p>1 2 3 4 5 Def</p> <p>Report or detection of toxic or flammable gases within a safe shutdown building (Table 1) in concentrations that will be life threatening to plant personnel or impede access to equipment needed for safe plant operation</p>	<p>Table 1</p> <p>Safe Shutdown Buildings</p> <ul style="list-style-type: none"> • Vital portions of the Radwaste/Control Building • Reactor Building • Turbine Building • Standby Service Water Pump Houses • Diesel Generator Building • Diesel Generator Fuel Oil Storage Area 	
CATEGORY N SECURITY EVENTS	<p>NU1 Confirmed Security Event Which Indicates a Potential Degradation in the Level of Safety of the Plant</p> <p>1 2 3 4 5 Def</p> <p>Bomb device discovered within the plant Protected Area and outside the plant Vital Areas</p> <p>OR</p> <p>Confirmed report of an attempted entry, sabotage or security threat that cannot be properly compensated for within 10 minutes.</p>	<p>NA1 Security Event in a Plant Protected Area</p> <p>1 2 3 4 5 Def</p> <p>Confirmed report of an intrusion by a hostile force into the plant Protected Area.</p>	<p>NS1 Security Event in a Plant Vital Area</p> <p>1 2 3 4 5 Def</p> <p>Bomb device discovered within the plant Vital Areas</p> <p>OR</p> <p>Confirmed report of an intrusion by a hostile force into Vital Areas.</p>	<p>Security Event Resulting in Loss of Ability to Reach and Maintain Cold Shutdown</p> <p>1 2 3 4 5 Def</p> <p>Loss of physical control of the Control Room due to a security event</p> <p>OR</p> <p>Loss of physical control of the Remote Shutdown capability due to a security event</p>

WNP-2 EMERGENCY CLASSIFICATION TABLE

CATEGORY	UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
CATEGORY O MISCELLANEOUS INITIATING CONDITIONS-SYSTEM MALFUNCTIONS	OU1 Unexpected Decrease in Water Covering Irradiated Fuel Assemblies <div>12345Def</div> <p>Uncontrolled water level decrease in the Reactor Cavity or Spent Fuel Pool below the level of the weirs with all irradiated fuel assemblies remaining covered by water</p>	OA1 Main Steam Line Break Outside Containment with Isolation <div>123</div> <p>Indications of a Main Steam Line break AND Main steam line isolation valve has isolated the break</p>		
		OA2 Loss of Water Level that Has or Will Result in the Uncovering of Irradiated Fuel Outside the Reactor Vessel <div>123456Def</div> <p>Water level, when not intentionally lowered, was observed to be below the top of the gate sill separating the Reactor Cavity and Dryer Storage Pool OR Water level, when not intentionally lowered, was observed to be below the top of the gate sill separating the Reactor Cavity and the Spent Fuel Pool OR Report of visual observation of irradiated fuel uncovered or uncovering imminent</p>		
CATEGORY P PLANT EMERGENCY DIRECTOR'S JUDGEMENT	PU1 Other Conditions Existing Which in the Judgement of the Plant Emergency Director (PED) Warrant Declaration of an Unusual Event <div>123456Def</div> <p>In the judgment of the Shift Manager/PED, events are in process or have occurred which indicate a potential degradation of the level of safety of the plant</p>	PA1 Other Conditions Existing Which in the Judgement of the Plant Emergency Director (PED) Warrant Declaration of an Alert <div>123456Def</div> <p>In the judgment of the Shift Manager/PED, events are in process or have occurred which indicate actual or potential substantial degradation of systems needed for the protection of the public</p>	PS1 Other Conditions Existing Which in the Judgement of the Plant Emergency Director (PED) Warrant Declaration of a Site Area Emergency <div>123456Def</div> <p>In the judgment of the Shift Manager/PED, events are in process or have occurred which involve actual or likely major failures of plant functions needed for protection of the public.</p>	PG1 Other Conditions Existing Which in the Judgement of the Plant Emergency Director (PED) Warrant Declaration of a General Emergency <div>123456Def</div> <p>In the judgment of the Shift Manager/PED other conditions exist which indicate: 1) Actual or imminent substantial core degradation or melting with the potential for loss of containment integrity OR 2) Potential for uncontrolled radionuclide releases. These releases can reasonably be expected to exceed EPA PAG plume exposure levels outside the site boundary.</p>

Attachment 4.1


PROCEDURE NUMBER

13.1.1

REVISION

PAGE

19 of 19

 WASHINGTON PUBLIC POWER SUPPLY SYSTEM		VERIFY PRIOR TO USE
		DATE
WNP-2 PLANT PROCEDURES MANUAL		
PROCEDURE NUMBER 13.1.1.A	APPROVED BY	DATE
VOLUME NAME EMERGENCY PLAN IMPLEMENTING PROCEDURES		
SECTION EMERGENCY CLASSIFICATION		
TITLE CLASSIFYING THE EMERGENCY - TECHNICAL BASES		

1.0 PURPOSE

The purpose of this procedure is to provide Plant Emergency Response Organization personnel tasked with classifying the emergency the technical bases for the Initiating Conditions/Emergency Action Levels (IC/EAL) listed in PPM 13.1.1, "Classifying The Emergency".

It is not necessary to refer to this procedure to classify the emergency. The emergency classification may be determined by utilizing the guidance contained within PPM 13.1.1. Plant Emergency Organization personnel may refer to this procedure for supplemental information.

2.0 REFERENCES

- 2.1 WNP-2 Technical Specifications
- 2.2 WNP-2 Offsite Dose Calculation Manual
- 2.3 WNP-2 FSAR Section 1.5.2, SBO Coping Study
- 2.4 WNP-2 FSAR Section 8.3.2.1, Batteries
- 2.5 WNP-2 FSAR Table 9.5-8, Location of Emergency Lighting

PROCEDURE NUMBER 13.1.1.A	REVISION 0	PAGE 1 of 96
------------------------------	---------------	-----------------

- 2.6 PPM 4.12.1.1 Control Room Evacuation and Remote Cooldown
- 2.7 PPM 4.12.4.2 Flood
- 2.8 PPM 4.12.4.3 Earthquake
- 2.9 PPM 4.12.4.8 Tornado/High Winds
- 2.10 PPM 4.12.4.10 Reactor Building 422 Area Flooding
- 2.11 PPM 5.0.10 EOP Flowchart Training Manual
- 2.12 PPM 5.1.2 RPV Control-ATWS
- 2.13 PPM 5.1.7 Primary Containment Flooding
- 2.14 PPM 9.3.22 Core Damage Evaluation
- 2.15 Calculation CE-02-93-16
- 2.16 Calculation 2.05.01 (Battery Size Calc)
- 2.17 NUMARC NESP-007, Rev. 2
- 2.18 NUMARC/NRC "Questions & Answers", June 1993
- 2.19 NUREG/CR-4982 "Severe Accident in Spent Fuel Pools in Support of Generic Safety Issue 82"
- 2.20 NUREG 0737 "Clarification of TMI Action Plan Requirements"
- 2.21 10CFR20
- 2.22 10CFR50
- 2.23 EPA 400 "Manual of Protective Action Guidelines and Protective Actions for Nuclear Incidents"
- 2.24 FSAR, Chapter 13.3, Emergency Preparedness Plan, Section 6
- 2.25 NUREG-0654, FEMA-REP-1, Rev. 1, Appendix 1
- 2.26 PPM 13.1.2, Plant Emergency Director Duties

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	2 of 96



2.28 PPM 13.4.1, Notifications

2.27 WNP-2 Safeguards Contingency Plan

3.0 PROCEDURE

3.1 Plant Emergency Response Personnel Responsibilities

May refer to the Technical Bases in this procedure for emergency classification and after-the-fact review of initiating conditions/emergency action levels.

3.2 Use of Plant Instruments and Indications

Plant instrumentation described in each EAL in Attachment 4.1 is the primary instrumentation to be used. This does not preclude use of other instruments as alternate indication, as appropriate, to properly classify the emergency.

An indication or report condition is considered to be valid when it is conclusively verified by:

- an instrument channel check; or
- indications on related or redundant indicators; or
- by direct observation by plant personnel, such that doubt related to the indicator's operability, the condition's existence, or the report's truth is removed.

Implicit in this definition is the need for timely assessment.

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	3 of 96



1. The first part of the document is a list of names and addresses. The names are: John Doe, Jane Doe, and John Doe. The addresses are: 123 Main St, 456 Main St, and 789 Main St.

2. The second part of the document is a list of names and addresses. The names are: John Doe, Jane Doe, and John Doe. The addresses are: 123 Main St, 456 Main St, and 789 Main St.

3. The third part of the document is a list of names and addresses. The names are: John Doe, Jane Doe, and John Doe. The addresses are: 123 Main St, 456 Main St, and 789 Main St.

3.3 Emergency Class Description

The following is a description of the four classes of emergency.

NOTIFICATION OF UNUSUAL EVENT: Unusual events are in process or have occurred which indicate a potential degradation of the level of safety of the plant. No releases of radioactive material requiring offsite response or monitoring are expected unless further degradation of safety systems occurs.

ALERT: Events are in process or have occurred which involve an actual or potential substantial degradation of the level of safety of the plant. Any releases are expected to be limited to small fractions of the EPA Protective Action Guideline exposure levels.

SITE AREA EMERGENCY: Events are in process or have occurred which involve actual or likely major failures of plant functions needed for protection of the public. Any releases are not expected to result in exposure levels which exceed EPA Protective Action Guideline exposure levels except near the site boundary.

GENERAL EMERGENCY: Events are in process or have occurred which involve actual or imminent substantial core degradation or melting with potential for loss of containment integrity. Releases can be reasonably expected to exceed EPA Protective Action Guideline exposure levels offsite for more than the immediate site area.

3.4 Mode Applicability

The operational conditions (modes) in which Initiating Conditions are applicable are indicated by a series of boxes as follows;

1	2	3	4	5	Def
---	---	---	---	---	-----

where the numbers indicate operational conditions as defined in Technical Specifications and Def indicates "Defueled" or all fuel removed from the reactor vessel.

4.0 ATTACHMENTS

4.1 Technical Bases

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	4 of 96



A. FISSION PRODUCT BARRIER DEGRADATION

UNUSUAL EVENT:

AU1: Fuel Clad Degradation.

APPLICABILITY:

Operating Conditions

1	2	3	4	
---	---	---	---	--

EMERGENCY ACTION LEVEL:

Confirmed "SJAE CONDSR OUTLET RAD HI-HI" alarm annunciated on P602.

OR

Laboratory analysis confirms Reactor Coolant System (RCS) sample activity greater than or equal to limits specified in Tech. Spec. 3.4.5.

This Initiating Condition is considered to be a potential degradation in the level of safety of the plant and a potential precursor of more serious problems.

The confirmed SJAE CONDSR OUTLET RAD HI HI monitor and alarm reflects the offgas effluent and, therefore, may be one of the first indicators of degrading fuel conditions. The alarm is confirmed by verification of greater than current alarm setpoint on Recorder OG RIS-612 on Panel P604 or high offgas pretreatment air activity [determined by sample results] greater than limits specified in Technical Specification 3.11.2.7. The Hi alarm setpoint corresponds to a fraction of the Technical Specification limit thereby alerting the plant of the need to sample prior to exceeding limits. Confirmation via a sample ensures that only valid Unusual Events will be declared.

Coolant activity in excess of allowable Technical Specifications also reflect a degraded or degrading core condition and represent a decrease in plant safety.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	5 of 96

REF:

WNP-2 Technical Specifications

*NUMARC NESP-007, Methodology for Development of Emergency Action Levels,
Rev. 2, Unusual Event SU4*

Instrument Master Data Sheet(s) for instrument(s) listed in the EAL(s)

DEVIATION:

This EAL and Initiating Condition apply to modes 1 through 4, inclusive. Mode 5 is not supported in the WNP-2 Technical Specification as the Steam Jet Air Ejector is not in operation in Mode 5.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	6 of 96



A. FISSION PRODUCT BARRIER DEGRADATION

UNUSUAL EVENT:

AU2: RCS Leakage.

APPLICABILITY:

Operating Conditions

1	2	3	
---	---	---	--

EMERGENCY ACTION LEVEL:

Valid unidentified leakage 10 gpm or upscale high indicated on recorder EDR-FRS-623, Drywell Floor Drain Sump Fill Rate and Sump Level, on Panel P632.

OR

Valid identified leakage greater than or equal to 25 gpm indicated on recorder EDR-FRS-623, Drywell Equipment Drain Sump Fill Rate and Sump Level, on Panel P632.

This Initiating Condition may be a precursor of more serious conditions and, as a result, is considered to be a potential degradation in the level of safety of the plant. The value for identified leakage is set at a higher value due to the lesser significance of identified leakage in comparison to unidentified and pressure boundary leakage.

REF:

WNP-2 Technical Specifications

NUMARC NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Unusual Event SU5

DEVIATION:

Unidentified Leakage on EDR-FRS-623 reads 0-10 gpm. Consequently the EAL is changed to read "...10 gpm or upscale high...". Pressure boundary leakage cannot be distinguished from Unidentified Leakage by Control Room indication.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	7 of 96

THE
FEDERAL
BUREAU OF
INVESTIGATION
OF THE
DEPARTMENT OF JUSTICE
WASHINGTON, D. C. 20535

MEMORANDUM FOR THE DIRECTOR, FBI

SUBJECT: [Illegible]

DATE: [Illegible]

TO: [Illegible]

FROM: [Illegible]

RE: [Illegible]

[The following text is illegible due to extreme fading and poor scan quality.]

A. FISSION PRODUCT BARRIER DEGRADATION

UNUSUAL EVENT:

AU3: Loss OR Potential Loss of Containment.

APPLICABILITY:

Operating Conditions

1	2	3	
---	---	---	--

EMERGENCY ACTION LEVEL:

Loss OR Potential Loss of the Primary Containment barrier as indicated by Fission Product Barrier Degradation Table.

Refer to the Fission Product Barrier Degradation Table in this procedure, for an explanation of the indications used to satisfy this Initiating Condition.

Events that indicate an imminent degradation of containment should result in a classification as if the affected threshold(s) are already exceeded. Imminent in this context means mitigation strategies and actions are not successful in preventing a challenge to Primary Containment.

REF:

NUMARC NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Alert FUI

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	8 of 96

THE UNIVERSITY OF CHICAGO PRESS
54 EAST LAKE STREET, CHICAGO, ILL. 60601
TEL. 312-937-1234 FAX 312-937-1235
WWW.CHICAGO.PRESS.EDU

A. FISSION PRODUCT BARRIER DEGRADATION

ALERT:

AA1: Loss OR Potential Loss of Fuel Clad.

APPLICABILITY:

Operating Conditions

1	2	3	
---	---	---	--

EMERGENCY ACTION LEVEL:

Loss OR Potential Loss of the Fuel Clad as indicated by Fission Product Barrier Degradation Table.

Refer to the Fission Product Barrier Degradation Table in this procedure for an explanation of the indications used to satisfy this Initiating Condition.

Events that indicate an imminent degradation of the Fuel Clad Barrier should result in a classification as if the affected threshold(s) are already exceeded. Imminent in this context means mitigation strategies and actions are not successful in preventing a challenge to Fuel Clad.

REF:

NUMARC NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Alert FAI

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	9 of 96

1. The first part of the document is a list of the names of the persons who were present at the meeting.

2. The second part of the document is a list of the names of the persons who were present at the meeting.

3. The third part of the document is a list of the names of the persons who were present at the meeting.

4. The fourth part of the document is a list of the names of the persons who were present at the meeting.

5. The fifth part of the document is a list of the names of the persons who were present at the meeting.

6. The sixth part of the document is a list of the names of the persons who were present at the meeting.

7. The seventh part of the document is a list of the names of the persons who were present at the meeting.

8. The eighth part of the document is a list of the names of the persons who were present at the meeting.

9. The ninth part of the document is a list of the names of the persons who were present at the meeting.

10. The tenth part of the document is a list of the names of the persons who were present at the meeting.

11. The eleventh part of the document is a list of the names of the persons who were present at the meeting.

12. The twelfth part of the document is a list of the names of the persons who were present at the meeting.

13. The thirteenth part of the document is a list of the names of the persons who were present at the meeting.

14. The fourteenth part of the document is a list of the names of the persons who were present at the meeting.

15. The fifteenth part of the document is a list of the names of the persons who were present at the meeting.

16. The sixteenth part of the document is a list of the names of the persons who were present at the meeting.

17. The seventeenth part of the document is a list of the names of the persons who were present at the meeting.

18. The eighteenth part of the document is a list of the names of the persons who were present at the meeting.

19. The nineteenth part of the document is a list of the names of the persons who were present at the meeting.

20. The twentieth part of the document is a list of the names of the persons who were present at the meeting.

A. FISSION PRODUCT BARRIER DEGRADATION

ALERT:

AA2: , Loss OR Potential Loss of RCS.

APPLICABILITY:

Operating Conditions

1	2	3	
---	---	---	--

EMERGENCY ACTION LEVEL:

Loss OR Potential Loss of the RCS barrier as indicated by Fission Product Barrier Degradation Table

Refer to the Fission Product Barrier Degradation Table in this procedure for an explanation of the indications used to satisfy this Initiating Condition.


Events that indicate an imminent degradation of the Reactor Coolant System Barrier should result in a classification as if the affected threshold(s) are already exceeded. Imminent in this context means mitigation strategies and actions are not successful in preventing a challenge to the Reactor Coolant Pressure Boundary.

REF:

NUMARC NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Alert FA1

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	10 of 96



A. FISSION PRODUCT BARRIER DEGRADATION

SITE AREA EMERGENCY:

AS1: Loss OR Potential Loss of ANY TWO Fission Product Barriers.

APPLICABILITY:

Operating Conditions

1	2	3	
---	---	---	--

EMERGENCY ACTION LEVEL:

Loss OR Potential Loss of ANY TWO Fission Product Barriers as indicated by Fission Product Barrier Degradation Table.

Refer to the Fission Product Barrier Degradation Table in this procedure for an explanation of the indications used to satisfy this Initiating Condition.

Events that indicate an imminent degradation of a Fission Product Barrier should result in a classification as if the affected threshold(s) are already exceeded. Imminent in this context means mitigation strategies and actions are not successful in preventing a challenge to Fuel Clad, Reactor Coolant Pressure Boundary or Primary Containment.

REF:

NUMARC NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Alert FSI

DEVIATION:

It is considered to be a challenge to plant functions necessary for the protection of the public if the integrity of any two of the three fission product barriers has or has the potential of being degraded. This approach is more conservative than the USNRC Regulatory Guide 1.101 in that the containment barrier is not weighted less significantly than the other two barriers. Thus a "Loss" or "Potential Loss" of any two barriers is a Site Area Emergency. This approach also simplifies the Site Area Emergency classification from the fission product barrier matrix, allowing for more rapid classification should the need arise.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	11 of 96



THE JOURNAL OF THE
ROYAL ANTHROPOLOGICAL INSTITUTE

THE JOURNAL OF THE
ROYAL ANTHROPOLOGICAL INSTITUTE

THE JOURNAL OF THE
ROYAL ANTHROPOLOGICAL INSTITUTE



THE JOURNAL OF THE
ROYAL ANTHROPOLOGICAL INSTITUTE

THE JOURNAL OF THE
ROYAL ANTHROPOLOGICAL INSTITUTE



A. FISSION PRODUCT BARRIER DEGRADATION

D SITE AREA EMERGENCY:

AS2: Loss of Water Level in the RPV That Has or Will Uncover Fuel in the RPV.

APPLICABILITY:

Operating Conditions

1	2	3	4	5	
---	---	---	---	---	--

EMERGENCY ACTION LEVEL:

RPV level is less than -161 inches.

This Initiating Condition and its associated EAL address a loss of the Reactor Coolant System, defined here as RPV water level below the top of the active fuel, and a potential loss of fuel clad when the core becomes uncovered. If RPV water level continues to decrease, this could ultimately result in a release to the environment. An RPV level which approaches top of active fuel or is anticipated to drop below top of active fuel is also reason to declare a Site Area Emergency under this EAL.

Indications used to determine water level for this EAL are, but not limited to, the Fuel Zone Indicator MS-LI-610 and/or recorder MS-LR-615.

Escalation of this event to a General Emergency would be via the Increased Radiation Release to the Environment initiating condition GG1.

REF:

WNP-2 Technical Specifications

*NUMARC NESP-007, Methodology for Development of Emergency Action Levels,
Rev. 2, Site Area Emergency SS5*

DEVIATION:

1. Operating conditions have been expanded to include modes 1, 2 and 3 in this EAL because it is realized that modes 1 - 3 are also covered by the same RPV water level condition in the Fission Product Barrier Degradation table as a loss of RCS and a potential loss of fuel clad.
2. Uncovery of the fuel, irrespective of the event causing the uncovery, is justification alone for declaring the SAE. Since other events could lead to fuel uncovery other than a loss of decay heat removal capability, it is not prudent to base the EAL on this one event.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	12 of 96



A. FISSION PRODUCT BARRIER DEGRADATION

GENERAL EMERGENCY:

AG1: Loss of ANY Two Barriers AND a Potential Loss OR Loss of the Third Barrier.

APPLICABILITY:

Operating Conditions

1	2	3	
---	---	---	--

EMERGENCY ACTION LEVEL:

Loss of any TWO fission product barriers as indicated by Fission Product Barrier Degradation Table.

AND

Loss OR Potential Loss of the third barrier as indicated by Fission Product Barrier Degradation Table.

Refer to the Fission Product Barrier Degradation Table in this procedure for an explanation of the indications used to satisfy this Initiating Condition.

Events that indicate an imminent degradation of a Fission Product Barrier should result in a classification as if the affected threshold(s) are already exceeded. Imminent in this context means mitigation strategies and actions are not successful in preventing a challenge to Fuel Clad, Reactor Coolant Pressure Boundary or Primary Containment.

REF:

NUMARC NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, General Emergency FG1

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	13 of 96

[The page contains extremely faint, illegible text that appears to be a multi-paragraph document. The text is too light to transcribe accurately.]

WNP-2 EMERGENCY CLASSIFICATION FISSION PRODUCT BARRIER DEGRADATION TABLE

INDICATOR	FUEL CLAD		REACTOR COOLANT SYSTEM		PRIMARY CONTAINMENT SYSTEM	
	POTENTIAL LOSS	LOSS	POTENTIAL LOSS	LOSS	POTENTIAL LOSS	LOSS
RPM LEVEL	Level is less than -101"	Entry into PPM 5.1.7		Level is less than -101"	Entry into PPM 5.1.7	
DRYWELL/CONTAINMENT RADIATION MONITORS		Containment Radiation Monitor CMS RIS-27E and CMS RIS-27F reading greater than 3,000 R/hr		Containment Radiation Monitor CMS RIS-27E and CMS RIS-27F reading greater than 70 R/hr	Containment Radiation Monitor CMS RIS-27E and CMS RIS-27F reading greater than 14,000 R/hr	
DRYWELL/CONTAINMENT PRESSURE				Drywell pressure greater than 1.00 psig with indications of RCS leak inside drywell	Containment pressure greater than 30 psig and increasing OR Containment H ₂ & O ₂ concentration greater than 6% H ₂ and 5% O ₂ OR Drywell pressure exceeds PSP	Rapid unexplained decrease of containment pressure following an initial increase Drywell Pressure Response not consistent with LOCA conditions
CONTAINMENT ISOLATION VALVES						Failure of BOTH containment isolation valves (as listed in T.S. Table 3.8.3.1) in any one line to close following AUTO or MANUAL initiation AND Downstream pathway to the environment exists OR Unsubleak primary system discharging outside primary containment as indicated by any one temperature or radiation level above Maximum Safe Operating values (PPM 5.3.1) OR Intentional venting per PPM 5.2.1
COOLANT ACTIVITY		Coolant activity greater than 300 nCi/gm Dissolved before				
RCS LEAK RATE			Unsubleak primary system discharging outside primary containment as indicated by any one temperature or radiation level above Maximum Safe Operating values (PPM 5.3.1) OR RCS Leakage GT 30 gpm inside containment or EDR FRS 623 upscale high			
OTHER					Cannot maintain plant parameters below the HCLT or SRVTPLE, or above the HCLT	
PEO JUDGEMENT	Any condition that in the judgement of the PEO/Shift Manager indicates LOSS or POTENTIAL LOSS of the Fuel Clad Barrier		Any condition that in the judgement of the PEO/Shift Manager indicates LOSS or POTENTIAL LOSS of the RCS Barrier		Any condition that in the judgement of the PEO/Shift Manager indicates LOSS or POTENTIAL LOSS of the Primary Containment Barrier	

13.1.1.A

PROCEDURE NUMBER

0

REVISION

14 of 96

PAGE

Attachment 4.1



A. FISSION PRODUCT BARRIER DEGRADATION

1.0 RPV LEVEL

- a. Indicating Fuel Clad Barrier Potential Loss at -161" (Top of Active Fuel) ensures that an emergency is declared before fuel perforation occurs. An unintentional level decrease to below -161" is indicative of a large RCS break, or a smaller break with loss of high pressure makeup.
- b. Entry into PPM 5.1.7, Primary Containment Flooding, is indicative of a loss of fuel clad barrier because:
 - 1) RPV water level may not be able to be restored and maintained above -161 inches, or
 - 2) For ATWS conditions, RPV water level cannot be maintained above -192", or
 - 3) If RPV water level cannot be determined, RPV flooding for ATWS or non-ATWS conditions cannot be established or maintained.

Entry into PPM 5.1.7 is indicative of a potential loss of primary containment because actions to flood the containment may jeopardize the pressure suppression capability of the containment or result in the need to vent the RPV or primary containment.

2.0 DRYWELL/CONTAINMENT RADIATION MONITORS

A 50 R/hr reading on CMS-RIS-27E and 50 R/hr reading on CMS-RIS-27F is used to indicate a loss of the Reactor Coolant System barrier. This value assumes a 0.1% core damage instantaneous release and dispersal of the reactor coolant noble gas and iodine inventory into the drywell atmosphere.

A 2500 R/hr reading on CMS-RIS-27E and 2500 R/hr reading on CMS-RIS-27F is used to indicate a release of reactor coolant, with elevated activity indicative of fuel damage, into the drywell. This value assumes an instantaneous release and dispersal of the reactor coolant noble gas and iodine inventory associated with coolant concentration associated with 5% clad failures into the drywell atmosphere. WNP-2 has elected to provide an example dealing with the top end of the 2-5% range discussed in NESP-007. This value assumes an instantaneous release and dispersal of the reactor coolant noble gas and iodine inventory into the drywell atmosphere.

An 10,000 R/hr reading on CMS-RIS-27E and 10,000 R/hr reading on CMS-RIS-27F is used to indicate potential failure of the primary containment barrier. It is a value that indicates significant fuel damage well in excess of that associated with the loss of both Fuel Clad and RCS barriers. A major release of radioactivity requiring offsite

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	15 of 96

1. The first part of the document discusses the importance of maintaining accurate records of all transactions and activities. It emphasizes the need for transparency and accountability in financial reporting.

2. The second part of the document outlines the various methods and techniques used to collect and analyze data. It includes a detailed description of the sampling process and the statistical tools employed.

3. The third part of the document presents the results of the study, including a comparison of the findings with previous research. It also discusses the limitations of the study and suggests areas for future research.

4. The fourth part of the document provides a summary of the key findings and conclusions. It highlights the main points of the study and offers recommendations for practice.

5. The fifth part of the document contains a list of references and a bibliography. It includes a comprehensive list of all the sources cited in the document.

protective actions is not possible unless a major failure of fuel cladding allows radioactive material to be released from the core into the reactor coolant. Regardless of whether containment is challenged, this amount of activity in containment, if released, could have such severe consequences that it is prudent to treat this as a potential loss of containment, such that a General Emergency declaration is warranted. This level of activity is indicative of approximately 20% clad failure. This value assumes an instantaneous release and dispersal of the reactor coolant noble gas and iodine inventory into the drywell atmosphere.

These values were derived from Engineering Calculation NE-02-94-57.

3.0 DRYWELL PRESSURE

Changes in drywell pressure indication would not be expected for a Fuel Clad barrier degradation if the Reactor Coolant System were still intact. Therefore, no drywell pressure indications are provided for Fuel Clad barrier degradation.

The 1.68 psig drywell pressure for the Reactor Coolant System barrier loss is based on the drywell pressure scram and isolation setpoint and indicates a Loss of Coolant Accident (LOCA). A potential loss of the Reactor Coolant System barrier would not result in an increasing drywell pressure and, therefore, no indicator is provided. The qualifier of "with indications of RCS leak inside drywell" is included as an indicator of RCS boundary degradation and eliminates a drywell pressure increase due to a loss of drywell ventilation.

Containment pressures that exceeds 34.7 psig, the maximum expected pressure following a LOCA, have the potential to result in a loss of the containment barrier. Preparations to vent containment are required by PPM 5.2.1, "Primary Containment Control" when Drywell pressure exceeds 39 psig and before the Wetwell pressure reaches the Primary Containment Pressure Limit (PCPL). Hydrogen and Oxygen concentrations at or above PPM 5.2.1, Table 19, Combustible Limits, in the drywell or wetwell represent a potential for a deflagration with a subsequent containment failure.

Containment or drywell pressure responses not consistent with LOCA conditions indicate a loss of the Primary Containment barrier. This may be noticed as a decrease in drywell pressure when no operation action (e.g., starting drywell cooling fans) has been taken. It would also include a failure of the drywell pressure to increase as expected during a LOCA.

Entry into the unsafe region of the Pressure Suppression Pressure curve (PPM 5.2.1, Figure F, PSP) is included as a potential primary containment barrier loss. A rapid depressurization of the RPV (e.g., occurrence of a large break LOCA or initiation of ADS) at wetwell pressures in excess of the PSP may cause either:

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	16 of 96

- Wetwell pressure responses indicative of a failure in the drywell-to-wetwell boundary, or
- Wetwell pressure increases to or beyond the Primary Containment Pressure Limit (PPM 5.2.1, figure G, PCPL).

4.0 CONTAINMENT ISOLATION VALVES

These indicators are intended to cover containment isolation failures allowing a direct flow path to the environment such as a failure of both MSIV's to close with open valves downstream to the turbine or condenser. Downstream path to the environment does not mean leakage incident to normal system integrity. Only those penetrations required to isolate per Technical Specifications should be considered. In addition, area radiation and area temperature alarms indicating an unisolable primary system leakage outside containment are included. Again, only those penetrations required to isolate per Technical Specifications are included.

Venting, if necessary to prevent failure of primary containment, is included as a loss of primary containment. This is specified in PPM 5.2.1 when containment hydrogen and oxygen concentrations are in excess of or cannot be determined to be below combustible limits or when wetwell pressure approaches PCPL. However, routine venting per PPM 2.3.1, as long as radioactivity release rates are maintained, is not considered a loss of primary containment.

5.0 COOLANT ACTIVITY

Fuel Clad barrier damage is indicated by a coolant activity of 300 $\mu\text{Ci/gm}$ dose equivalent I-131. This amount of activity is well above that expected for iodine spikes and corresponds to approximately 2-5% fuel clad failure in accordance with assessment performed by the NUMARC EAL task force. This amount of clad failure indicates significant clad heating and, thus, the Fuel Clad barrier is considered lost.

6.0 RCS LEAK RATE

A leak from the Reactor Pressure Boundary that cannot be isolated indicates a RCS failure. This condition is most readily displayed as an increase in area ambient or differential temperature above the Maximum Safe Operating Values specified in PPM 5.3.1. The maximum measurable leak rate in the Control Room at WNP-2 is 30 gpm, therefore 30 gpm is used instead of the 50 gpm limit recommended by NUMARC.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	17 of 96

$\frac{d}{dt} \left(\frac{1}{r^2} \right) = -\frac{2}{r^3} \frac{dr}{dt}$

7.0 OTHER

Primary Containment

The Heat Capacity Temperature Limit (HCTL) is the highest wetwell temperature at which initiation of RPV depressurization will not result in exceeding the Primary Containment Pressure Limit (PCPL) before the rate of energy transfer to the containment is within the capacity of the containment vent. The HCTL is used to preclude failure of the containment or equipment necessary for safe shutdown by assuring that RPV blowdown does not cause containment pressure to exceed the PCPL. The potential loss occurs when RPV pressure and wetwell temperature cannot be maintained below HCTL.

The Heat Capacity Level Limit (HCLL) precludes loss of the pressure suppression function of the containment and, in conjunction with the HCTL, precludes failure of the containment or equipment necessary for safe shutdown of the plant. The potential loss occurs when the wetwell level cannot be maintained above the HCLL.

The SRV Tail Pipe Level Limit (SRVTPLL) is the highest wetwell water level at which opening of an SRV will not result in exceeding the code allowable stresses in the tailpipe, tailpipe supports, quenchers or quencher supports. This level is a function of RPV pressure and the Limit is utilized to preclude SRV system failure and containment failure. The consequences of operating SRV's when wetwell water level exceeds the SRVTPLL may include direct pressurization of the containment from a break in the SRV tail pipe. The resulting primary containment pressurization could cause containment failure.

8.0 SHIFT MANAGER/PED JUDGMENT

Shift Manager/PED judgment is included for all loss and potential loss categories. This "indicator" should be used to allow the Shift Manager/PED to appropriately classify an event when the indications needed to monitor fission barrier status are not available.

Shift Manager/PED judgment should also be used when the other indicators have not been exceeded but the trends indicate that loss or potential loss is imminent. Imminent in this context means mitigation strategies and actions are not successful in preventing a challenge to Fuel Clad, Reactor Coolant Pressure Boundary or Primary Containment.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	18 of 96

REF:

WNP-2 Technical Specifications

BWR Owners' Group, Transmittal of Generic Procedures for Estimation of Core Damage Using Post-Accident Sampling System, dated June 17, 1983

RTM-91, Response Technical Manual, Volume 1, Rev. 1

WNP-2 Emergency Operating Procedures, PPM series 5.1.X and 5.2.X

WNP-2 Emergency Operating Procedure Flowchart Training Manual, PPM 5.0.10

NUMARC/NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Recognition Category F

WNP-2 PPM 9.3.22, Core Damage Evaluation

WNP-2 FSAR, Section 15.6, MSL Break

DEVIATION:

1. RPV Level - Reactor Coolant System Loss:

Two-thirds core height was not selected as a fission product barrier loss or potential loss condition because it is possible for beyond-design-basis inventory threatening events to occur in which fuel clad damage cannot be precluded even though RPV water level is above 2/3 core height and below the top of active fuel.

2. RCS Leak Rate - Reactor Coolant System Loss:

This condition has been moved to its own Alert initiating condition. This decision is consistent with the level identified in the NUMARC basis. The NUMARC basis discusses the design basis accident for MSL break. WNP-2 MSL break analysis shows that offsite dose expected at the exclusion area boundary is below the entry level of a Site Area Emergency which is 100 mrem TEDE and is consistent with the radiological EAL's at the Alert level. This EAL was moved to the System Failure category per the NUMARC NESP-007, Rev 2 "Questions and Answers" dated June, 1993.

3. Drywell/Containment Radiation Monitors

WNP-2 will use an instantaneous release at 0.1% core damage as the basis for the drywell/containment radiation monitor reading indicative of a loss of RCS due to limited response of the detectors to lower coolant activity levels.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	19 of 96

B. LOSS OF SHUTDOWN/COOLDOWN FUNCTIONS

UNUSUAL EVENT:

BU1: Inability to Reach Required Shutdown Within Technical Specification Limits.

APPLICABILITY:

Operating Conditions

1	2	3	
---	---	---	--

EMERGENCY ACTION LEVEL:

Plant is not brought to required operating mode within (site-specific) Technical Specifications LCO Action Statement Time.

Limiting Conditions of Operation (LCO's) require the plant to be brought to a required shutdown mode when the Technical Specification required configuration cannot be restored. Depending on the circumstances, this may or may not be an emergency or precursor to a more severe condition. In any case, the initiation of plant shutdown required by the Technical Specifications requires a one hour report under 10 CFR 50.72 (b) Non-emergency events. The plant is within its safety envelope when being shut down within the allowable action statement time in the Technical Specifications. An immediate Notification of Unusual Event is required when the plant is not brought to the required operating mode within the allowable action statement time in the Technical Specifications. Declaration of an Unusual Event is based on the time at which the LCO-specified action statement time period elapses under the site Technical Specifications and is not related to how long a condition may have existed. Other required Technical Specification shutdowns that involve precursors to more serious events are addressed by other categories of Initiating Condition's.

REF:

WNP-2 Technical Specifications

NUMARC NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Unusual Event SU2

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	20 of 96



B. LOSS OF SHUTDOWN/COOLDOWN FUNCTIONS

ALERT:

BA1: Inability to Maintain Plant in Cold Shutdown.

APPLICABILITY:

Operating Conditions

4

5

EMERGENCY ACTION LEVEL:

Inability to maintain a reactor temperature of less than 200°F per PPM 4.4.2.1..

This EAL addresses loss or degradation of functions required for core cooling during refueling and cold shutdown modes such that the technical specification limit cannot be maintained. Determination of "Inability to maintain" includes making an evaluation that considers both current and future system performance in relation to the current values and trends of relevant parameters. A momentary unplanned excursion above 200°F when adequate heat removal function is available is not intended to constitute an Alert.

REF:

WNP-2 Technical Specifications

*NUMARC NESP-007, Methodology for Development of Emergency Action Levels,
Rev. 2, Alert SA3*

DEVIATION:

WNP-2 deleted the "loss of (site-specific) Technical Specification required functions to maintain cold shutdown" as a condition in this EAL to recognize additional plant capability to maintain cooling of the reactor beyond those specified in Technical Specifications. This deviation is consistent with NUMARC/NRC Questions and Answers concerning NESP-007, Rev. 2, dated June 1993.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	21 of 96



1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

41

42

43

44

45

46

47

48

49

50

51

52

53

54

55

56

57

58

59

60

61

62

63

64

65

66

67

68

69

70

71

72

73

74

75

76

77

78

79

80

81

82

83

84

85

86

87

88

89

90

91

92

93

94

95

96

97

98

99

100

B. LOSS OF SHUTDOWN/COOLDOWN FUNCTIONS

SITE AREA EMERGENCY:

BS1: Complete Loss of Functions Needed to Achieve and Maintain Hot Shutdown.

APPLICABILITY:

Operating Conditions

1	2	3		
---	---	---	--	--

EMERGENCY ACTION LEVEL:

RPV pressure and suppression pool temperature cannot be maintained below the Heat Capacity Temperature Limit.

This EAL addresses complete loss of functions, including ultimate heat sink and reactivity control, required for hot shutdown with the reactor at pressure and temperature. Under these conditions, there is an actual major failure of a system intended for protection of the public. Thus, declaration of a Site Area Emergency is warranted. Escalation to a General Emergency would occur by Abnormal Rad Levels/Radiological Effluent, Fission Product Barrier Degradation, or Emergency Director Judgement Initiating Conditions.

Functions required for hot shutdown consist of the ability to achieve reactor shutdown and to discharge decay heat energy from the reactor to the ultimate heat sink. Appropriate emergency declarations required by the inability to achieve reactor shutdown are addressed by EAL CA1, CS1 and CG1. Inability to remove decay heat energy is reflected in an increase in suppression pool temperature. Elevated suppression pool temperature is addressed by the Heat Capacity Temperature Limit (HCTL). The HCTL is a function of RPV pressure and suppression pool temperature. If RPV pressure and suppression pool temperature cannot be maintained below the HCTL, the ultimate heat sink is threatened and declaration of a Site Area Emergency is warranted.

REF:

WNP-2 Technical Specifications

NUMARC NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Site Area Emergency SS4

WNP-2 Emergency Operating Procedure Flowchart Training Manual, PPM 5.0.10

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	22 of 96



1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

41

42

43

44

45

46

47

48

49

50

51

52

53

54

55

56

57

58

59

60

61

62

63

64

65

66

67

68

69

70

71

72

73

74

75

76

77

78

79

80

81

82

83

84

85

86

87

88

89

90

91

92

93

94

95

96

97

98

99

100

C. ANTICIPATED TRANSIENT WITHOUT SCRAM

ALERT:

CA1: Failure of Reactor Protection System (RPS) Instrumentation to Complete or initiate a Reactor Scram AND Manual Scram Was Successful.

APPLICABILITY:

Operating Conditions

1	2	
---	---	--

EMERGENCY ACTION LEVEL:

One or more Reactor Protection System setpoint(s) have been exceeded per Tech. Spec. 2.2.

AND

Automatic RPS actuation failed to result in a control rod pattern which alone always assures reactor shutdown.

This condition indicates a failure of the automatic protection system to scram the reactor sufficient to achieve shutdown under all conditions without boron but the reactor was successfully manually scrammed sufficient to achieve shutdown under all conditions without boron.

A manual scram is any set of actions by the reactor operator(s) which results in a scram. These actions include placing the reactor mode switch in shutdown, depressing the RPS Manual Scram pushbuttons and/or placing ARI switches to trip.

Failure of a manual scram to reduce reactor power below APRM downscale levels or resulting in exceeding 110 degrees F in the suppression pool would escalate this event to Site Area Emergency CS1.

REF:

NUMARC NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Alert SA2

WNP-2 Emergency Operating Procedure Flowchart Training Manual, PPM 5.0.10

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	23 of 96

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100
101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200
201
202
203
204
205
206
207
208
209
210
211
212
213
214
215
216
217
218
219
220
221
222
223
224
225
226
227
228
229
230
231
232
233
234
235
236
237
238
239
240
241
242
243
244
245
246
247
248
249
250
251
252
253
254
255
256
257
258
259
260
261
262
263
264
265
266
267
268
269
270
271
272
273
274
275
276
277
278
279
280
281
282
283
284
285
286
287
288
289
290
291
292
293
294
295
296
297
298
299
300
301
302
303
304
305
306
307
308
309
310
311
312
313
314
315
316
317
318
319
320
321
322
323
324
325
326
327
328
329
330
331
332
333
334
335
336
337
338
339
340
341
342
343
344
345
346
347
348
349
350
351
352
353
354
355
356
357
358
359
360
361
362
363
364
365
366
367
368
369
370
371
372
373
374
375
376
377
378
379
380
381
382
383
384
385
386
387
388
389
390
391
392
393
394
395
396
397
398
399
400
401
402
403
404
405
406
407
408
409
410
411
412
413
414
415
416
417
418
419
420
421
422
423
424
425
426
427
428
429
430
431
432
433
434
435
436
437
438
439
440
441
442
443
444
445
446
447
448
449
450
451
452
453
454
455
456
457
458
459
460
461
462
463
464
465
466
467
468
469
470
471
472
473
474
475
476
477
478
479
480
481
482
483
484
485
486
487
488
489
490
491
492
493
494
495
496
497
498
499
500
501
502
503
504
505
506
507
508
509
510
511
512
513
514
515
516
517
518
519
520
521
522
523
524
525
526
527
528
529
530
531
532
533
534
535
536
537
538
539
540
541
542
543
544
545
546
547
548
549
550
551
552
553
554
555
556
557
558
559
560
561
562
563
564
565
566
567
568
569
570
571
572
573
574
575
576
577
578
579
580
581
582
583
584
585
586
587
588
589
590
591
592
593
594
595
596
597
598
599
600
601
602
603
604
605
606
607
608
609
610
611
612
613
614
615
616
617
618
619
620
621
622
623
624
625
626
627
628
629
630
631
632
633
634
635
636
637
638
639
640
641
642
643
644
645
646
647
648
649
650
651
652
653
654
655
656
657
658
659
660
661
662
663
664
665
666
667
668
669
670
671
672
673
674
675
676
677
678
679
680
681
682
683
684
685
686
687
688
689
690
691
692
693
694
695
696
697
698
699
700
701
702
703
704
705
706
707
708
709
710
711
712
713
714
715
716
717
718
719
720
721
722
723
724
725
726
727
728
729
730
731
732
733
734
735
736
737
738
739
740
741
742
743
744
745
746
747
748
749
750
751
752
753
754
755
756
757
758
759
760
761
762
763
764
765
766
767
768
769
770
771
772
773
774
775
776
777
778
779
780
781
782
783
784
785
786
787
788
789
790
791
792
793
794
795
796
797
798
799
800
801
802
803
804
805
806
807
808
809
810
811
812
813
814
815
816
817
818
819
820
821
822
823
824
825
826
827
828
829
830
831
832
833
834
835
836
837
838
839
840
84

C. ANTICIPATED TRANSIENT WITHOUT SCRAM

SITE AREA EMERGENCY:

CS1: Failure of RPS Instrumentation to Complete or Initiate an Automatic Reactor Scram
AND Manual Scram Was NOT Successful to reduce power below 5%.

APPLICABILITY:

Operating Conditions

1	2	
---	---	--

EMERGENCY ACTION LEVEL:

One or more Reactor Protection System setpoint(s) have been exceeded per Tech. Spec. 2.2.

AND

Automatic and manual RPS actuation failed to result in a control rod pattern which alone always assures reactor shutdown.

AND either

- Reactor power GT 5%
- Wetwell temperature GT 110°F

OR

This condition indicates a failure of both the automatic protection system and manual efforts to scram the reactor with continued power generation.

A manual scram is any set of actions by the reactor operator(s) which results in a scram. These actions include placing the reactor mode switch in shutdown, depressing the RPS Manual Scram pushbuttons and/or placing ARI switches to trip. Injection of boron is not considered in reducing reactor power below 5%. A concurrent challenge to the ability to cool the core or a significant challenge to decay heat removal capability would escalate this event to General Emergency CG1.

As specified in the NUMARAC/NESP-007 Questions and Answers, January 1993, "... a scram is considered unsuccessful if it does not result in achieving a state in which the reactor will remain shutdown under all conditions without boron injection." For CA1, if manual actions result in the reactor being shutdown under all conditions without boron injection, an

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	24 of 96



Figure 1. Schematic representation of the experimental design. The subjects were divided into two groups: the control group (C) and the experimental group (E). The control group (C) was divided into two subgroups: the control group (C) and the control group (C). The experimental group (E) was divided into two subgroups: the experimental group (E) and the experimental group (E). The control group (C) was divided into two subgroups: the control group (C) and the control group (C). The experimental group (E) was divided into two subgroups: the experimental group (E) and the experimental group (E).

ALERT is declared. Escalation to a Site Area Emergency (CA2) is not required. If sufficient control rods are not inserted to reduce reactor power to below the APRM downscale setpoints, an immediate Site Area Emergency (SS2) is declared. IF the APRM downscale setpoint is achieved, but suppression pool temperature is greater than Boron Injection [Initiation] Temperature, a precursor exists for a threat to containment and thus a Site Area Emergency is warranted."

APRM downscale trip setpoint for WNP-2 is 5%, the Boron Injection Initiation Temperature is defined as 110°F. The conditions". . . control rod pattern which alone always assures reactor shutdown" is defined to me an that the reactor is shutdown under all conditions without boron.

REF:

WNP-2 Emergency Operating Procedure RPV Control-ATWS, PPM 5.1.2

WNP-2 Technical Specifications

NUMARC NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Site General Emergency SS2

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	25 of 96



THE UNIVERSITY OF CHICAGO PRESS
54 EAST LAKE STREET, CHICAGO, ILL. 60601
U.S.A. AND CANADA
OTHER COUNTRIES: 100 Brook Hill Drive, Elmsford, N.Y. 10523
U.S.A. AND CANADA
OTHER COUNTRIES: 100 Brook Hill Drive, Elmsford, N.Y. 10523
U.S.A. AND CANADA
OTHER COUNTRIES: 100 Brook Hill Drive, Elmsford, N.Y. 10523

C. ANTICIPATED TRANSIENT WITHOUT SCRAM

GENERAL EMERGENCY:

CG1: Failure of the RPS to Complete an Automatic Scram AND Manual Scram Was NOT Successful AND There is Indication of an Extreme Challenge to the Ability to Cool the Core.

APPLICABILITY:

Operating Conditions

1	2	
---	---	--

EMERGENCY ACTION LEVEL:

One or more Reactor Protection System setpoint(s) have been exceeded per Tech. Spec. 2.2
AND
Automatic and manual RPS actuation failed to result in a control rod pattern which alone always assures reactor shutdown.
AND either
Wetwell temperature cannot be maintained less than the HCTL
OR
Entry to Primary Containment Flooding, PPM 5.1.7, is required

This condition indicates a failure of both the automatic protection system and manual efforts at Control Room Panel P-603 to scram the reactor concurrent with a challenge to the ability to cool the core or a significant challenge to decay heat removal capability.

Entry to PPM 5.1.7, Primary Containment Flooding, is indicative of an extreme challenge to core cooling because either:

1. RPV water level cannot be restored and maintained above -192 in., or
2. If RPV water level cannot be determined, RPV flooding conditions cannot be established or maintained.

Heat removal capability is extremely challenged if the wetwell temperature cannot be maintained below the Heat Capacity Temperature Limit curve.

A manual scram is any set of actions by the reactor operator(s) which results in a scram. These actions include placing the reactor mode switch in shutdown, depressing the RPS Manual Scram pushbuttons and/or placing ARI switches to trip. Injection of boron is not considered in reducing reactor power below 5%.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	26 of 96



Figure 1. The proposed model for the development of the *Staphylococcus aureus* infection in the skin of the patient with the skin disease. The model shows the interaction between the skin disease, the immune system, and the *S. aureus* bacteria. The skin disease leads to a weakened immune system, which in turn leads to a higher susceptibility to *S. aureus* infection. The *S. aureus* bacteria then cause a skin infection, which can lead to a skin abscess. The skin abscess can then lead to a skin infection, which can lead to a skin abscess. The skin abscess can then lead to a skin infection, which can lead to a skin abscess.

REF:

WNP-2 Emergency Operating Procedure RPV Control-ATWS, PPM 5.1.2

WNP-2 Emergency Operating Procedure Primary Containment Flooding, PPM 5.1.7

WNP-2 Technical Specifications

*NUMARC NESP-007, Methodology for Development of Emergency Action Levels,
Rev. 2, Site General Emergency SG2*

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	27 of 96

[illegible]

D. AC POWER LOSS

UNUSUAL EVENT:

DU1: Loss of All Offsite Power to Critical AC Busses for Greater Than 15 Minutes.

APPLICABILITY:

Operating Conditions

1	2	3	4	5	Def
---	---	---	---	---	-----

EMERGENCY ACTION LEVEL:

Power is unavailable to SM-7 and SM-8 from Offsite AC sources for greater than 15 minutes.

Even though power may still be available from offsite sources, there must be a functional flowpath to the Critical busses. Prolonged loss of offsite AC power reduces the required redundancy and potentially degrades the level of safety by rendering the plant more vulnerable to a complete loss of AC power (Station Blackout).

Fifteen minutes was selected as a threshold to exclude transient or momentary power losses.

Credit is not taken in this EAL for the Division 3 Standby Diesel Generator because it only supplies power to the High Pressure Core Spray (HPCS) pump and associated loads, but not for any long-term decay heat removal systems and, in particular, Wetwell-cooling mechanisms that would be essential subsequent to a station blackout.

Failure of either the Division 1 or Division 2 Standby Diesel Generator would escalate this event to Alert DA2.

REF:

WNP-2 Technical Specifications

*NUMARC NESP-007, Methodology for Development of Emergency Action Levels,
Rev. 2, Unusual Event SU1*

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	28 of 96



THE UNIVERSITY OF CHICAGO LIBRARY
1305 EAST 5TH STREET
CHICAGO, ILL. 60607
TEL: 773-936-3000
FAX: 773-936-3000
WWW.CHICAGO.LIBRARY.EDU

DEVIATION:

The Initiating Condition title has been changed by adding the qualifier, "Critical AC busses", and a time frame. This change meets the intent of the example EAL listed in NUMARC while being more descriptive for the Shift Manager/PED. Consistency between event classification titles is being sought to avoid the confusion created in the NUMARC document (see NUMARC Initiating Condition: SU1, SA1, SA5, SS1, SG1, SU7, and SS3).

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	29 of 96



THE UNIVERSITY OF CHICAGO LIBRARY
540 EAST 57TH STREET
CHICAGO, ILL. 60637
TEL: 773-936-5000
FAX: 773-936-5001
WWW.CHICAGO.LIBRARY.EDU

D. AC POWER LOSS

ALERT:

DA1: Loss of All Offsite Power and Loss of All Onsite Power to Critical AC Busses for Greater Than 15 Minutes.

APPLICABILITY:

Operating Conditions

	4	5	Def
--	---	---	-----

EMERGENCY ACTION LEVEL:

Complete loss of all power to Bus SM-7 and to Bus SM-8 for greater than 15 minutes.

A loss of the minimum required offsite circuits and failure of the diesel generators to restore power to the emergency busses results in a loss of AC power to all plant safety systems requiring AC power including RHR, ECCS, containment cooling systems, spent fuel heat removal systems, and Wetwell cooling systems. This significant reduction in decay heat removal is a substantial reduction in the level of safety of the plant due to a potential for temperature and pressure increases.

Credit is not taken in this EAL for the Division 3 Standby Diesel Generator because: 1) it is not required for all situations during Operating Conditions 4 and 5; and 2) although it does supply power to the HPCS pump which is a source of makeup water, it does not supply power to any systems that could be used to remove energy from the reactor and Wetwell thereby limiting the long-term decay heat removal effectiveness.

When the plant is in a cold shutdown or refueling condition, RPV temperature and pressure are lower than they would be in other operating conditions. These lower pressures and temperatures increase the margin of safety allowing more time before power must be restored to an emergency bus than would be available during Operating Conditions 1, 2 or 3.

Fifteen minutes was selected as a conservative lower threshold that retains the anticipatory nature of EAL's while excluding transient or momentary power losses.

Escalation of this event to a Site Area Emergency would be via the Increased Radiation Release to the Environment (see Initiating Condition FS1) or Shift Manager/PED Judgment (see Initiating Condition PS1).

If this same set of conditions were to occur in Operating Conditions 1, 2 or 3, they would be classified a Site Area Emergency (see Initiating Condition DS1).

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	30 of 96



Figure 1. The effect of the concentration of the inhibitor on the rate of polymerization of the monomer. The reaction conditions were: $[M] = 0.1 \text{ mol/L}$, $[AIBN] = 0.005 \text{ mol/L}$, $[I] = 0.001 \text{ mol/L}$, $[M]_0/[I]_0 = 100$, $T = 50^\circ\text{C}$, $t = 10 \text{ min}$.

[illegible]

REF:

WNP-2 Technical Specifications

*NUMARC NESP-007, Methodology for Development of Emergency Action Levels,
Rev. 2, Alert SA1*

DEVIATION:

1. NUMARC Initiating Condition SA1 requires you to check that offsite power distribution and onsite power distribution are available. These conditions are combined into one EAL. If the Critical bus is deenergized, it means that both offsite and onsite power sources were unable to connect to the divisional bus.
2. The title of the Initiating Condition has been changed by adding the qualifier, "Critical AC busses", and a time frame. This change meets the intent of the example EAL listed in NUMARC while being more descriptive for the Shift Manager/PED. Consistency between event classification titles is being sought to avoid the confusion created in the NUMARC document (see NUMARC Initiating Condition: SU1, SA1, SA5, SS1, SG1, SU7 and SS3).

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	31 of 96

THE UNITED STATES OF AMERICA, DISTRICT OF COLUMBIA, SS. I, the undersigned, Clerk of the District Court of the District of Columbia, do hereby certify that the within and foregoing is a true and correct copy of the original as the same appears in the files and records of the said Court.

IN WITNESS WHEREOF, I have hereunto set my hand and the seal of the said Court at the City of Washington, this 1st day of January, 1901.

CLERK OF THE DISTRICT COURT OF THE DISTRICT OF COLUMBIA

D. AC POWER LOSS

ALERT:

DA2: Power Capability to Critical AC Busses Reduced to a Single Power Source for Greater Than 15 Minutes Such That Any Additional Single Failure Would Result in Station Blackout.

APPLICABILITY:

Operating Conditions

1	2	3	
---	---	---	--

EMERGENCY ACTION LEVEL:

Complete loss of all power to Bus SM-7 for greater than 15 minutes.

AND

Bus SM-8 has only one of the following power sources:

- SM-3
- TR-B
- DG-2

OR

Complete loss of all power to Bus SM-8 for greater than 15 minutes.

AND

Bus SM-7 has only one of the following power sources:

- SM-1
- TR-B
- DG-1

This Initiating Condition and its associated EAL provide an escalation from Initiating Condition DU1, "Loss of All Offsite Power to Critical Busses for Greater than 15 Minutes". The condition indicated by this EAL is the degradation of the offsite and onsite power systems such that any additional single failure would result in a station blackout.

This EAL includes a loss of both offsite power sources with only one diesel generator powering its respective emergency bus as well as a failure of both diesel generators such that they would not be able to power their respective emergency busses with only one offsite power source available.

Credit is not taken in this Initiating Condition for bus SM-4 and the Division 3 Standby Diesel Generator because they only supply power to the HPCS pump and associated loads but not to any decay heat removal systems that would be essential subsequent to a station blackout.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	32 of 96

Power to busses SM-7 and SM-8 may come from either its respective standby diesel generator or from the Switch Yard through the Startup or Backup Transformers. Regardless of the source of power, failure of the remaining power source would result, at least temporarily, in a station blackout. The determining factor of whether or not to classify then becomes the amount of time that power is not available.

Escalation for a Site Area Emergency for a station blackout would be via Initiating Condition DS1.

REF:

WNP-2 Technical Specifications

*NUMARC NESP-007, Methodology for Development of Emergency Action Levels,
Rev. 2, Alert SA5*

DEVIATION:

The Initiating Condition title has been changed by adding the qualifier, "Critical AC busses", and a time frame. This change meets the intent of the example EAL listed in NUMARC while being more descriptive for the Shift Manager/PED. Consistency between event classification titles is being sought to avoid the confusion created in the NUMARC document (see NUMARC Initiating Condition: SU1, SA1, SA5, SS1, SG1, SU7 and SS3).

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	33 of 96

1. The first part of the report deals with the general situation of the country and the progress of the work during the year.

2. The second part of the report deals with the results of the work during the year.

The results of the work during the year are as follows: The first part of the report deals with the general situation of the country and the progress of the work during the year. The second part of the report deals with the results of the work during the year.

The results of the work during the year are as follows: The first part of the report deals with the general situation of the country and the progress of the work during the year.

The results of the work during the year are as follows: The first part of the report deals with the general situation of the country and the progress of the work during the year. The second part of the report deals with the results of the work during the year.

The results of the work during the year are as follows: The first part of the report deals with the general situation of the country and the progress of the work during the year.

The results of the work during the year are as follows: The first part of the report deals with the general situation of the country and the progress of the work during the year.

The results of the work during the year are as follows: The first part of the report deals with the general situation of the country and the progress of the work during the year.

D. AC POWER LOSS

SITE AREA EMERGENCY:

DS1: Loss of All Offsite Power and Loss of All Onsite Power to Critical AC Busses for Greater Than 15 Minutes.

APPLICABILITY:

Operating Conditions

1	2	3	
---	---	---	--

EMERGENCY ACTION LEVEL:

Complete loss of all power to Bus SM-7 and to Bus SM-8 for greater than 15 minutes.

The condition indicated by this EAL is a station blackout and reflects a condition more serious than that described in Alert DA2 in that both Division 1 and Division 2 Emergency Busses are deenergized and have been without power for 15 minutes or longer. Station blackouts lasting less than 15 minutes or electrical system faults resulting in only one emergency bus powered from only one source are classified according to Alert DA2.

Credit is not taken in this EAL for Bus SM-4 and the Division 3 Standby Diesel Generator because it only supplies power to the HPCS pump and associated loads but not to any decay heat removal systems that would be essential subsequent to a station blackout.

Fifteen minutes was chosen as a conservative time to maintain the anticipatory nature of EAL's while excluding transient or momentary power losses.

This event would be upgraded to a General Emergency per DG1 if it appears that power cannot be restored to Bus SM-7 or SM-8 within 4 hours or if the Shift Manager/PED determines that a loss or potential loss of a fission product barrier is imminent in accordance with the Fission Product Barrier Degradation table. Imminent in this context means mitigation strategies and actions are not successful in preventing a challenge to Fuel Clad, Reactor Coolant Pressure Boundary or Primary Containment.

REF:

WNP-2 Technical Specifications

WNP-2 FSAR, Section 1.5.2, SBO Coping Study

NUMARC NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Site Area Emergency SSI

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	34 of 96

[illegible][illegible]

DEVIATION:

1. NUMARC Initiating Condition SA1 requires you to check that offsite power distribution and onsite power distribution are available. These conditions are combined into one EAL. If the Critical bus is deenergized, it means that both offsite and onsite power sources were unable to connect to the divisional bus.
2. The Initiating Condition title has been changed by adding the qualifier, "Critical AC busses", and a time frame. This change meets the intent of the example EAL listed in NUMARC while being more descriptive for the Shift Manager/PED. Consistency between event classification is being sought to avoid the confusion created in the NUMARC document. (See NUMARC Initiating Conditions: SU1, SA1, SA5, SS1, SG1, SU7 and SS3.)

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	35 of 96



D. AC POWER LOSS

GENERAL EMERGENCY:

DG1: Prolonged Loss of All Offsite Power and Prolonged Loss of All Onsite Power to Critical AC Busses.

APPLICABILITY:

Operating Conditions

1	2	3	
---	---	---	--

EMERGENCY ACTION LEVEL:

Complete loss of all power to Bus SM-7 and to Bus SM-8
AND either

Power to either Bus SM-7 or SM-8 is not likely to be restored within 4 hours.

OR

RPV level is less than -161".

The condition indicated by this Initiating Condition and its associated EAL is a station blackout lasting long enough to degrade or potentially degrade a fission product barrier.

Loss of all AC power compromises all plant safety systems requiring AC power including RHR, ECCS, containment cooling systems, spent fuel heat removal systems and Wetwell cooling systems. Prolonged loss of all AC power may lead to loss of integrity of the fuel clad, reactor coolant system or containment.

Credit is not taken in this EAL for Bus SM-4 and the Division 3 Standby Diesel Generator because it only supplies power to the HPCS pump and associated loads but not to any decay heat removal systems that would be essential subsequent to a station blackout.

Under these conditions, fission product barrier monitoring capability may be degraded. It may be difficult to predict when power can be restored. However, the Shift Manager/PED must determine the need to declare a General Emergency based on two major considerations:

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	36 of 96

THE UNIVERSITY OF CHICAGO LIBRARY

100 EAST 57TH STREET, 4TH FLOOR, CHICAGO, ILL. 60637

1. Are there any present indications that core cooling is already degraded to the point that loss or potential loss of a fission product barrier is imminent? Imminent in this context means mitigation strategies and actions are not successful in preventing a challenge to Fuel Clad, Reactor Coolant Pressure Boundary or Primary Containment.
2. If there are no present indications of such core cooling degradation, how likely is it that power can be restored in time to assure that a loss of two barriers with a potential loss of the third can be prevented?

The first question is answered by reviewing the parameters listed in Fission Product Barrier Degradation Table. The second question must be answered by the Shift Manager/PED by making a realistic assessment of the time required to complete any necessary repairs. This EAL requires the Shift Manager/PED to classify the event as soon as his assessment indicates that necessary repairs will take longer than 4 hours rather than waiting for the 4 hours to expire.

REF:

WNP-2 Technical Specifications

NUMARC NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, General Emergency SGI

WNP-2 FSAR, Section 1.5.2, SBO Coping Study

DEVIATION:

The Initiating Condition title has been changed by adding the qualifier, "Critical AC busses", and a time frame. This change meets the intent of the example EAL listed in NUMARC while being more descriptive for the Shift Manager/PED. Consistency between event classification is being sought to avoid the confusion created in the NUMARC document. (See NUMARC ID: SU1, SA1, SA5, SS1, SG1, SU7 and SS3.)

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	37 of 96

E. DC POWER LOSS

UNUSUAL EVENT:

EU1: Degradation of All Critical DC Power for Greater Than 15 Minutes.

APPLICABILITY:

Operating Conditions

	4.	5	
--	----	---	--

EMERGENCY ACTION LEVEL:

Degradation of Division 1 Critical DC voltage as indicated by Bus Voltage less than 110 VDC on 125 V Dist. Panel S1-1 voltmeter located on Bd. C for greater than 15 minutes.

AND

Degradation of Division 2 Critical DC voltage as indicated by Bus Voltage less than 110 VDC on 125 V Dist. Panel S1-2 voltmeter located on Bd. C for greater than 15 minutes.

This Initiating Condition and its EAL recognize a loss of DC power compromising the ability to monitor and control the removal of decay heat during cold shutdown or refueling. This EAL is intended to be anticipatory in that the operating crew may not have the necessary indication and control of equipment needed to respond to the loss. This is a less severe condition than that described in Site Area Emergency CS2 because initial temperatures and pressures are lower than they would be for Operating Conditions 1, 2 or 3 and, normally, less decay would be present.

Credit is not taken in this EAL for the Division 3 DC bus because it only supplies control power to loads associated with the HPCS pump and not to any decay heat removal systems.

The WNP-2 battery sizing calculations for the 125 VDC batteries, S1-1 and S1-2, reveal that a worst case LOCA analysis would permit a 15 minute margin between 106.3 volts and 105.0 volts. However, a conservative value of one hundred ten (110) volts DC is used as a minimum bus voltage. It is based on providing a 15 minute margin of operation before bus voltage drops below 105 volts DC at which time bus loads cannot be guaranteed to function. One hundred ten volts was also selected based on instrument accuracy of $\pm 2\%$ full scale or ± 3 volts and scale increments of 2 volts.

The same set of conditions as described in this EAL would be classified Site Area Emergency ES2 if they occurred during Operating Conditions 1, 2 or 3.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	38 of 96

THE UNIVERSITY OF CHICAGO PRESS
54 EAST LAKE STREET, CHICAGO, ILL. 60601
U.S.A. AND CANADA
OTHER COUNTRIES: 100 Brook Hill Drive, Secaucus, N.J. 07094
U.K. AND THE REST OF EUROPE: 100 Brook Hill Drive, Secaucus, N.J. 07094
U.S.A. AND CANADA: 100 Brook Hill Drive, Secaucus, N.J. 07094
U.K. AND THE REST OF EUROPE: 100 Brook Hill Drive, Secaucus, N.J. 07094

REF:

WNP-2 Technical Specifications

*NUMARC NESP-007, Methodology for Development of Emergency Action Levels,
Rev. 2, Unusual Event SU7*

Engineering Calculation 2.05.01 (Battery Sizing Calc)

WNP-2 FSAR Section 8.3.2.1, Batteries

CVI 51A-00,8 Exide Manual

DEVIATION:

The Initiating Condition title has been changed by adding the qualifier, "Critical DC busses", and a time frame. This change meets the intent of the example EAL listed in NUMARC while being more descriptive for the Shift Manager/PED. Consistency between event classification is being sought to avoid the confusion created in the NUMARC document. (See NUMARC Initiating Conditions: SU1, SA1, SA5, SS1, SG1, SU7 and SS3.)

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	39 of 96



E. DC POWER LOSS

SITE AREA EMERGENCY:

ES1: Degradation of All Critical DC Power for Greater Than 15 Minutes.

APPLICABILITY:

Operating Conditions

1	2	3	
---	---	---	--

EMERGENCY ACTION LEVEL:

Degradation of Division 1 Critical DC voltage as indicated by Bus Voltage less than 110 VDC on 125 V Dist. Panel S1-1 voltmeter located on Bd. C for greater than 15 minutes.

AND

Degradation of Division 2 Critical DC voltage as indicated by Bus Voltage less than 110 VDC on 125 V Dist. Panel S1-2 voltmeter located on Bd. C for greater than 15 minutes.

This Initiating Condition and its EAL recognize a loss of DC power compromising the ability to monitor and control the removal of decay heat during power operations, startup and hot shutdown conditions. It is intended to be anticipatory in that the operating crew may not have the necessary indication and control of equipment needed to respond to the loss. This EAL represents a more serious condition than described in Unusual Event EU1 in that the initial temperatures, pressures and available decay heat may be substantially higher than in Unusual Event EU1 resulting in significantly less time available before failure of systems needed to protect the public.

Loss of all DC power compromises the ability to monitor and control plant safety functions. Prolonged loss of all DC power may result in core uncover and loss of containment integrity when there is significant decay heat and residual heat in the reactor coolant system.

Credit is not taken in this EAL for the Division 3 DC bus because it only supplies control power to loads associated with the HPCS pump and not to any decay heat removal systems.

The WNP-2 battery sizing calculations for the 125 VDC batteries, S1-1 and S1-2, reveal that a worst case LOCA analysis would permit a 15 minute margin between 106.3 volts and 105.0 volts. However, a conservative value of one hundred ten (110) volts DC is used as a minimum bus voltage. It is based on providing a 15 minute margin of operation before bus voltage drops below 105 volts DC at which time bus loads cannot be guaranteed to function.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	40 of 96

One hundred ten volts was also selected based on instrument accuracy of $\pm 2\%$ full scale or ± 3 volts and scale increments of 2 volts.

REF:

WNP-2 Technical Specifications

NUMARC NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Site Area Emergency SS3

Engineering Calculation 2.05.01 (Battery Sizing Calc)

WNP-2 FSAR Section 8.3.2.1, Batteries

CVI 51A-00,8 Exide Manual

DEVIATION:

The Initiating Condition title has been changed by adding the qualifier, "Critical DC busses", and a time frame. This change meets the intent of the example EAL listed in NUMARC while being more descriptive for the Shift Manager/PED. Consistency between event classification is being sought to avoid the confusion created in the NUMARC document. (See NUMARC Initiating Conditions: SU1, SA1, SA5, SS1, SG1, SU7 and SS3.)

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	41 of 96

THE STATE OF TEXAS, COUNTY OF DALLAS, ss. I, the undersigned, a Notary Public in and for the State of Texas, do hereby certify that the foregoing is a true and correct copy of the original of the same, as the same appears from the records of the County of Dallas, State of Texas.

WITNESS MY HAND AND SEAL OF OFFICE, this 1st day of January, 1901.

F. INCREASED PLANT RADIATION RELEASE

UNUSUAL EVENT:

FU1: Unexpected Increase in Plant Radiation Levels.

APPLICABILITY:

Operating Conditions

1	2	3	4	5	Def
---	---	---	---	---	-----

EMERGENCY ACTION LEVEL:

Any of the following Area Radiation Monitors exceeding 5,000 mr/hr:
ARM-RIS-4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 15, 16, 17, 18
ARM-RIS-20, 21, 22, 23, 24, 25, 26, 27, 28, 29, 30, 32, 33, 34

These events tend to have long lead times relative to potential for radiological release outside the site boundary thus, the impact to public health and safety is very low.

This Initiating Condition is not applicable for alarms resulting from the controlled movement of radioactive materials in the plant or expected increases in radiation levels due to the backwashing of demineralizer filters or other planned operation.

Unplanned increases in inplant radiation levels represent a degradation in the control of radioactive material and represent a potential degradation in the level of safety of the plant. This EAL escalates to an ALERT per FA2 if the radiation level increase impairs safe operation of the plant.

REF:

WNP-2 Technical Specifications

WNP-2 Instrument Master Data Sheets for referenced instruments

*NUMARC NESP-007, Methodology for Development of Emergency Action Levels,
Rev. 2, Unusual Event AU2*

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	42 of 96

1. The first part of the document is a list of names and addresses of the members of the committee. The names are listed in alphabetical order, and the addresses are given in full. The list is as follows:

Mr. J. H. Smith, 123 Main St., New York, N. Y.
Mr. J. D. Jones, 456 Elm St., New York, N. Y.
Mr. W. E. Brown, 789 Oak St., New York, N. Y.
Mr. R. L. Green, 101 Pine St., New York, N. Y.
Mr. S. K. White, 202 Cedar St., New York, N. Y.
Mr. T. M. Black, 303 Maple St., New York, N. Y.
Mr. U. N. Gray, 404 Birch St., New York, N. Y.
Mr. V. P. Hall, 505 Spruce St., New York, N. Y.
Mr. W. Q. King, 606 Willow St., New York, N. Y.
Mr. X. R. Lee, 707 Ash St., New York, N. Y.
Mr. Y. S. Clark, 808 Hickory St., New York, N. Y.
Mr. Z. T. Evans, 909 Walnut St., New York, N. Y.
Mr. A. U. Adams, 1010 Chestnut St., New York, N. Y.
Mr. B. V. Baker, 1111 Mulberry St., New York, N. Y.
Mr. C. W. Carter, 1212 Locust St., New York, N. Y.
Mr. D. X. Davis, 1313 Olive St., New York, N. Y.
Mr. E. Y. Edwards, 1414 Elm St., New York, N. Y.
Mr. F. Z. Fisher, 1515 Pine St., New York, N. Y.
Mr. G. A. Gibson, 1616 Oak St., New York, N. Y.
Mr. H. B. Hall, 1717 Cedar St., New York, N. Y.
Mr. I. C. Hill, 1818 Maple St., New York, N. Y.
Mr. J. D. Hill, 1919 Birch St., New York, N. Y.
Mr. K. E. Hill, 2020 Spruce St., New York, N. Y.
Mr. L. F. Hill, 2121 Willow St., New York, N. Y.
Mr. M. G. Hill, 2222 Ash St., New York, N. Y.
Mr. N. H. Hill, 2323 Hickory St., New York, N. Y.
Mr. O. I. Hill, 2424 Walnut St., New York, N. Y.
Mr. P. J. Hill, 2525 Chestnut St., New York, N. Y.
Mr. Q. K. Hill, 2626 Mulberry St., New York, N. Y.
Mr. R. L. Hill, 2727 Locust St., New York, N. Y.
Mr. S. M. Hill, 2828 Olive St., New York, N. Y.
Mr. T. N. Hill, 2929 Elm St., New York, N. Y.
Mr. U. O. Hill, 3030 Pine St., New York, N. Y.
Mr. V. P. Hill, 3131 Oak St., New York, N. Y.
Mr. W. Q. Hill, 3232 Cedar St., New York, N. Y.
Mr. X. R. Hill, 3333 Maple St., New York, N. Y.
Mr. Y. S. Hill, 3434 Birch St., New York, N. Y.
Mr. Z. T. Hill, 3535 Spruce St., New York, N. Y.
Mr. A. U. Hill, 3636 Willow St., New York, N. Y.
Mr. B. V. Hill, 3737 Ash St., New York, N. Y.
Mr. C. W. Hill, 3838 Hickory St., New York, N. Y.
Mr. D. X. Hill, 3939 Walnut St., New York, N. Y.
Mr. E. Y. Hill, 4040 Chestnut St., New York, N. Y.
Mr. F. Z. Hill, 4141 Mulberry St., New York, N. Y.
Mr. G. A. Hill, 4242 Locust St., New York, N. Y.
Mr. H. B. Hill, 4343 Olive St., New York, N. Y.
Mr. I. C. Hill, 4444 Elm St., New York, N. Y.
Mr. J. D. Hill, 4545 Pine St., New York, N. Y.
Mr. K. E. Hill, 4646 Oak St., New York, N. Y.
Mr. L. F. Hill, 4747 Cedar St., New York, N. Y.
Mr. M. G. Hill, 4848 Maple St., New York, N. Y.
Mr. N. H. Hill, 4949 Birch St., New York, N. Y.
Mr. O. I. Hill, 5050 Spruce St., New York, N. Y.
Mr. P. J. Hill, 5151 Willow St., New York, N. Y.
Mr. Q. K. Hill, 5252 Ash St., New York, N. Y.
Mr. R. L. Hill, 5353 Hickory St., New York, N. Y.
Mr. S. M. Hill, 5454 Walnut St., New York, N. Y.
Mr. T. N. Hill, 5555 Chestnut St., New York, N. Y.
Mr. U. O. Hill, 5656 Mulberry St., New York, N. Y.
Mr. V. P. Hill, 5757 Locust St., New York, N. Y.
Mr. W. Q. Hill, 5858 Olive St., New York, N. Y.
Mr. X. R. Hill, 5959 Elm St., New York, N. Y.
Mr. Y. S. Hill, 6060 Pine St., New York, N. Y.
Mr. Z. T. Hill, 6161 Oak St., New York, N. Y.
Mr. A. U. Hill, 6262 Cedar St., New York, N. Y.
Mr. B. V. Hill, 6363 Maple St., New York, N. Y.
Mr. C. W. Hill, 6464 Birch St., New York, N. Y.
Mr. D. X. Hill, 6565 Spruce St., New York, N. Y.
Mr. E. Y. Hill, 6666 Willow St., New York, N. Y.
Mr. F. Z. Hill, 6767 Ash St., New York, N. Y.
Mr. G. A. Hill, 6868 Hickory St., New York, N. Y.
Mr. H. B. Hill, 6969 Walnut St., New York, N. Y.
Mr. I. C. Hill, 7070 Chestnut St., New York, N. Y.
Mr. J. D. Hill, 7171 Mulberry St., New York, N. Y.
Mr. K. E. Hill, 7272 Locust St., New York, N. Y.
Mr. L. F. Hill, 7373 Olive St., New York, N. Y.
Mr. M. G. Hill, 7474 Elm St., New York, N. Y.
Mr. N. H. Hill, 7575 Pine St., New York, N. Y.
Mr. O. I. Hill, 7676 Oak St., New York, N. Y.
Mr. P. J. Hill, 7777 Cedar St., New York, N. Y.
Mr. Q. K. Hill, 7878 Maple St., New York, N. Y.
Mr. R. L. Hill, 7979 Birch St., New York, N. Y.
Mr. S. M. Hill, 8080 Spruce St., New York, N. Y.
Mr. T. N. Hill, 8181 Willow St., New York, N. Y.
Mr. U. O. Hill, 8282 Ash St., New York, N. Y.
Mr. V. P. Hill, 8383 Hickory St., New York, N. Y.
Mr. W. Q. Hill, 8484 Walnut St., New York, N. Y.
Mr. X. R. Hill, 8585 Chestnut St., New York, N. Y.
Mr. Y. S. Hill, 8686 Mulberry St., New York, N. Y.
Mr. Z. T. Hill, 8787 Locust St., New York, N. Y.
Mr. A. U. Hill, 8888 Olive St., New York, N. Y.
Mr. B. V. Hill, 8989 Elm St., New York, N. Y.
Mr. C. W. Hill, 9090 Pine St., New York, N. Y.
Mr. D. X. Hill, 9191 Oak St., New York, N. Y.
Mr. E. Y. Hill, 9292 Cedar St., New York, N. Y.
Mr. F. Z. Hill, 9393 Maple St., New York, N. Y.
Mr. G. A. Hill, 9494 Birch St., New York, N. Y.
Mr. H. B. Hill, 9595 Spruce St., New York, N. Y.
Mr. I. C. Hill, 9696 Willow St., New York, N. Y.
Mr. J. D. Hill, 9797 Ash St., New York, N. Y.
Mr. K. E. Hill, 9898 Hickory St., New York, N. Y.
Mr. L. F. Hill, 9999 Walnut St., New York, N. Y.

DEVIATION:

1. The 5,000 mr/hr for each ARM will be used as the trigger for the EAL. This removes the interpretation by the Shift Manager/PED of determining "normal levels" from a strip chart recorder or periodic Health Physics surveys of the area. This reading of 5,000 mr/hr has the added benefit of being extremely close to the 1,000 times normal high reading advocated by NUMARC while providing sufficient margin to the ALERT EAL condition in Initiating Condition FA2.
2. Airborne concentration is not addressed. An increase in airborne concentration is not addressed in the example EAL's or the basis for the Unusual Event or Alert in discussions with NUMARC. The airborne example EAL was deleted in the body but overlooked in the title.
3. NUMARC example: EAL 3 is applicable to plants with licenses for dry storage for older irradiated spent fuel. Currently, WNP-2 does not have a license for the dry storage of older irradiated spent fuel.
4. NUMARC example: EAL 1 is considered by WNP-2 to be more closely related to a system failure than to increased plant radiation release. Consequently EAL 1 is addressed in Initiating Condition OU1, Miscellaneous Initiating Conditions/System Malfunctions.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	43 of 96

1. The first part of the document discusses the importance of maintaining accurate records of all transactions.

2. The second part of the document discusses the importance of maintaining accurate records of all transactions.

3. The third part of the document discusses the importance of maintaining accurate records of all transactions.

4. The fourth part of the document discusses the importance of maintaining accurate records of all transactions.

5. The fifth part of the document discusses the importance of maintaining accurate records of all transactions.

6. The sixth part of the document discusses the importance of maintaining accurate records of all transactions.

7. The seventh part of the document discusses the importance of maintaining accurate records of all transactions.

F. INCREASED PLANT RADIATION RELEASE

ALERT:

FA1: Major Damage to Irradiated Fuel OR Loss of Water Level That Has Resulted or Will Result in the Uncovering of Irradiated Fuel Outside the RPV.

APPLICABILITY:

Operating Conditions

1	2	3	4	5	Def
---	---	---	---	---	-----

EMERGENCY ACTION LEVEL:

A confirmed HIGH alarm on ARM-RIS-1 Fuel Pool Area Radiation Monitor resulting from an uncontrolled fuel storage or handling.

Due to the decreased amount of decay heat present, there is time available to take corrective actions and little potential for substantial fuel damage. In addition, NUREG/CR-4982, "Severe Accident in Spent Fuel Pools in Support of Generic Safety Issue 82", July 1987, indicates that even if corrective actions are not taken, no prompt fatalities are predicted, and that risk of injury is low.

Setpoint for the listed ARM in EAL AA2.1 is given in PPM 4.602.A5 1-1. After review of refuel floor radiation monitoring capability it was determined that three of the four ARMs included in this EAL should not be listed for the following reasons.

- ARM-RIS-3 and ARM-RIS-3A detect radiation near the bottom of the new fuel storage pit and, therefore, would not provide adequate indication of radiation levels associated with decreasing water level above irradiated fuel.
- ARM-RIS-2, Fuel Pool Area Radiation Monitor, alarm setpoint is arbitrarily adjusted to a level slightly above normal background to monitor operator performance during fuel handling and would, therefore, not be indicative of a potential refueling accident. Its high alarm setpoint is typically 15 mR/hr.

The high alarm on ARM-RIS-1, Fuel Pool Area Radiation Monitor, is the threshold condition for this EAL. Its setpoint is nominally 300 mR/hr. The EAL is worded so that the alarm must be a confirmed high alarm thus avoiding an unnecessary declaration if the condition were to be caused by a spurious alarm signal.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	44 of 96

Unintentional water level decrease may result in unplanned increases in inplant radiation levels represent a degradation in the control of radioactive material and represent a potential degradation in the level of safety of the plant.

REF:

WNP-2 Technical Specifications

*NUMARC NESP-007, Methodology for Development of Emergency Action Levels,
Rev. 2, AA2*

*NUREG/CR-4982, Severe Accident in Spent Fuel Pools in Support of Generic Safety,
Issue 82, July 1987*

DEVIATION:

NUMARC example: EAL 2, 3 and 4 are considered by WNP-2 to be more closely related to a system failure than to increased plant radiation release. Consequently EAL 2, 3 and 4 are addressed in Initiating Condition OA2, Miscellaneous Initiating Conditions/System Malfunctions.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	45 of 96

1. The first part of the document discusses the importance of maintaining accurate records of all transactions and activities. It emphasizes the need for transparency and accountability in all financial dealings.

2. The second part of the document outlines the various methods and techniques used to collect and analyze data. It includes a detailed description of the experimental procedures and the statistical analysis performed.

3. The third part of the document presents the results of the study. It includes a series of tables and graphs that illustrate the findings of the research. The data shows a clear trend of increasing activity over time.

4. The fourth part of the document discusses the implications of the findings. It suggests that the results have significant implications for the field of study and may lead to further research in this area.

5. The fifth part of the document concludes the study. It summarizes the key findings and provides a final statement on the importance of the research.

F. INCREASED PLANT RADIATION RELEASE

ALERT:

FA2: Release of Radioactive Material or Increases in Radiation Levels Within the Facility That Impedes Operation of Systems Required to Maintain Safe Operations or to Establish or Maintain Cold Shutdown.

APPLICABILITY:

Operating Conditions

1	2	3	4	5	Def
---	---	---	---	---	-----

EMERGENCY ACTION LEVEL:

Valid Radiation monitor reading GREATER THAN 15 mrem/hr on the Control Room Area Radiation Monitor, ARM-RIS-19.

OR

Any of the following Area Radiation Monitors, located in safe shutdown buildings, exceeding 10,000 mr/hr:

ARM-RIS-4 through ARM-RIS-18

ARM-RIS-23 and ARM-RIS-24

ARM-RIS-32 through ARM-RIS-34

Safe Shutdown Buildings are:

- Vital portions of the Radwaste/Control Building
- Reactor Building
- Turbine Building
- Standby Service Water Pump Houses
- Diesel Generator Building
- Diesel Generator Fuel Oil Storage Area

These events tend to have long lead times relative to potential for radiological release outside the site boundary thus, the impact to public health and safety is very low.

This Initiating Condition is not applicable for alarms resulting from the controlled movement of radioactive materials in the plant or expected increases in radiation levels due to the backwashing of demineralizer filters.

Unplanned increases in inplant radiation levels represent a degradation in the control of radioactive material and represent a potential degradation in the level of safety of the plant.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	46 of 96

RECEIVED
JAN 10 1964
U.S. DEPARTMENT OF AGRICULTURE
WASHINGTON, D.C. 20250

OFFICE OF THE SECRETARY
U.S. DEPARTMENT OF AGRICULTURE
WASHINGTON, D.C. 20250

Areas requiring continuous occupancy include the Control Room. The value of 15 mrem/hr is derived from the Generic Design Criteria (GDC) 19 value of 5 rem in 30 days with adjustment for expected occupancy times. Although Section III.D.3 or NUREG 0737, "Clarification of TMI Action Plan Requirements", provides that the 15 mrem/hr value can be averaged over the 30 days, the value is used here without averaging, as a 30-day duration implies an event potentially more significant than an Alert.

This Initiating Condition addresses increased radiation levels that impede necessary access to operating stations or other areas containing equipment that must be operated manually in order to maintain safe operation or perform a safe shutdown. It is this impaired ability to operate the plant that results in the actual or potential substantial degradation of the level of safety of the plant. The cause and/or magnitude of the increase in radiation levels is not a concern of this Initiating Condition.

This Initiating Condition is not meant to apply to increases in the containment radiation monitors as these events are addressed in the fission product barrier Initiating Condition's, nor is it intended to apply to anticipated temporary increases due to planned events (e.g., incore detector movement, radwaste container movement, depleted resin transfers, etc.).

The Shift Manager/PED should determine the cause of the increase in radiation levels and review other Initiating Condition's for applicability.

REF:

NUMARC NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, AA3

NUREG 0737, Clarification of TMI Action Plan Requirements

WNP-2 FSAR Table 9.5-8, Locations of Emergency Lighting

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	47 of 96

[illegible]

DEVIATION:

1. The 10,000 mr/hr for each ARM will be used as the trigger for the EAL. This removes the interpretation by the Shift Manager/PED of determining "normal levels" from a strip chart recorder or periodic Health Physics surveys of the area. The upscale high reading of 10,000 mr/hr has the added benefit of being close to the 1,000 times normal high reading advocated by NUMARC.
2. NUMARC lists the Central Alarm Station as being a location requiring continuous occupation in NUMARC example EAL #1. It is not listed in the WNP-2 EAL's since all functions can be assumed at the Secondary Alarm Station located in the Control Room.
3. At WNP-2, safe shutdown buildings include: plant security areas (vital areas), buildings containing safe shutdown equipment, and buildings containing safety related equipment. The NUMARC document uses these three terms (areas) interchangeably. To reduce confusion, WNP-2 will use the term "safe shutdown building" which will encompass the three (3) areas listed.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	48 of 96



● 2 ● 4 ● 6 ● 8 ● 10 ● 12 ● 14 ● 16 ● 18 ● 20 ● 22 ● 24 ● 26 ● 28 ● 30 ● 32 ● 34 ● 36 ● 38 ● 40 ● 42 ● 44 ● 46 ● 48 ● 50 ● 52 ● 54 ● 56 ● 58 ● 60 ● 62 ● 64 ● 66 ● 68 ● 70 ● 72 ● 74 ● 76 ● 78 ● 80 ● 82 ● 84 ● 86 ● 88 ● 90 ● 92 ● 94 ● 96 ● 98 ● 100

[illegible]

G. INCREASED RADIATION RELEASE TO THE ENVIRONMENT

UNUSUAL EVENT:

GUI1: Any Unplanned Release of Gaseous or Liquid Radioactivity to the Environment
That Exceeds Two Times ODCM limits for 60 Minutes or Longer.

APPLICABILITY:

Operating Conditions

1	2	3	4	5	
---	---	---	---	---	--

EMERGENCY ACTION LEVEL:

A valid reading on one or more of the following monitors that exceeds the value shown for 60 minutes or longer AND assessment in accordance with PPM 13.8.1 or 13.8.2 using actual meteorology, isotopic source term obtained from effluent grab sampling and laboratory analysis confirms Site Boundary dose rates equal to or greater than 0.1 mrem/hr TEDE or 0.3 mrem/hr thyroid CDE:

PRM-RE-1B	905,000 CPS
TEA-RIS-13	16,750 CPM
WEA-RIS-14	120,000 CPM

NOTE: If the monitor reading(s) is sustained for longer than 60 minutes and the required assessments cannot be completed within this period, then the declaration must be made based on the valid reading.

OR

Assessment in accordance with PPM 13.8.1 or 13.8.2 using isotopic source term obtained from effluent grab sampling and laboratory analysis confirms Site Boundary dose rates equal to or greater than 0.1 mrem/hr TEDE or 0.3 mrem/hr thyroid CDE.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	49 of 96

THE UNIVERSITY OF CHICAGO

DEPARTMENT OF CHEMISTRY

RESEARCH REPORT

BY

JOHN H. HARRIS

AND

A valid reading on one or more of the following monitors that exceeds the value shown AND sample analysis indicates greater than TWO times ODCM 6.2.1.1 limits for 60 minutes or longer:

SW-RE-4, SW Loop A Process Rad Monitor	200 CPS
SW-RE-5, SW Loop B Process Rad Monitor	200 CPS
FDR-RE-6 Radwaste Monitor	2 X Hi-Hi
	Alarm
TSW-RE-5, TSW Effluent	3900 CPM

NOTE: If the monitor reading is sustained for longer than 60 minutes and the required assessments cannot be completed within this period, then the declaration must be made based on the valid reading.

OR

Sample analysis indicates greater than TWO times ODCM 6.2.1.1 limits for 60 minutes or longer.

Unplanned releases in excess of TWO times Technical Specifications that continue for 60 minutes or longer represent an uncontrolled situation and, hence, a potential degradation in the level of safety. The final integrated dose (which is very low in the Unusual Event emergency class) is not the primary concern here; rather, it is the degradation in plant control implied by the fact that the release was not isolated within 60 minutes.

It is not intended that the release be averaged over 60 minutes. Further, the PED should not wait until 60 minutes has elapsed, but should declare the event as soon as it is determined that the release will exceed TWO times the Technical Specification for greater than 60 minutes. It is expected that the offsite dose analysis will be performed on the Emergency Dose Projection System (EDPS) or the Backup EDPS using results of isotopic analysis if available, and actual meteorology.

If the monitor reading(s) is sustained for longer than 60 minutes and the required assessments cannot be completed within this period, then the declaration must be made based on the valid reading.

Monitor indications and alarms are based on the methodology of the ODCM which demonstrates compliance with 10 CFR 20 and 10 CFR 50, Appendix I, requirements. The six year average meteorology is also used for basing alarm setpoints.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	50 of 96

THE UNIVERSITY OF CHICAGO
DIVISION OF THE PHYSICAL SCIENCES
DEPARTMENT OF PHYSICS
5712 S. DICKINSON DRIVE
CHICAGO, ILL. 60637
TEL. (312) 937-1311
FAX (312) 937-1312
WWW.PHYSICS.UCHICAGO.EDU

REF:

WNP-2 Technical Specifications

WNP-2 Offsite Dose Calculation Manual

*NUMARC NESP-007, Methodology for Development of Emergency Action Levels,
Rev. 2, Unusual Event AUI*

DEVIATION:

1. NUMARC example #3 not included because WNP-2 does not have a perimeter monitoring system.
2. NUMARC example #4 not included because WNP-2 does not provide automatic real time dose assessment capability.
3. EAL's are based on 500 mrem/yr as specified in 10 CFR 20 and ODCM.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	51 of 96

THE UNIVERSITY OF CHICAGO
DIVISION OF THE PHYSICAL SCIENCES
DEPARTMENT OF PHYSICS
530 SOUTH EAST ASIAN AVENUE
CHICAGO, ILLINOIS 60607-7080
TEL: 773/936-5000 FAX: 773/936-5001
WWW: WWW.PHYSICS.UCHICAGO.EDU

G. INCREASED RADIATION RELEASE TO THE ENVIRONMENT

ALERT:

GA1: Any Unplanned Release of Gaseous or Liquid Radioactivity to the Environment
That Exceeds 200 Times the Radiological Specifications for 15 Minutes or Longer.

APPLICABILITY:

Operating Conditions

1	2	3	4	5	Def
---	---	---	---	---	-----

EMERGENCY ACTION LEVEL:

A valid reading on one or more of the following monitors that exceeds the value shown for 15 minutes or longer AND assessment in accordance with PPM 13.8.1 or 13.8.2 using actual meteorology confirms Site Boundary dose rates equal to or greater than 10 mrem/hr TEDE or 10 mrem/hr thyroid CDE:

PRM-RE-1C 850 CPS
TEA-RIS-13 44,000 CPM
WEA-RIS-14 167,000 CPM

NOTE: If the monitor reading(s) is sustained for longer than 15 minutes and the required assessments cannot be completed within this period, then the declaration must be made based on the valid reading.

OR

Offsite dose calculations indicate greater than 10 mrem/hr TEDE or greater than 50 mrem/hr CDE to the thyroid and the release continues at or above that level for 15 minutes or longer.

OR

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	52 of 96

1. The first part of the document is a list of names and addresses of the members of the committee.

2. The second part of the document is a list of names and addresses of the members of the committee.

A valid reading on one or more of the following monitors that exceeds the value shown AND sample analysis indicates greater than 200 times ODCM 6.2.1.1 limit for 15 minutes or longer:

SW-RE-4	SW Loop A Process Rad Monitor	20,000 CPS
SW-RE-5	SW Loop B Process Rad Monitor	20,000 CPS
FDR-RE-6	Radwaste Effluent Monitor	200 X High-High Alarm

TSW-RE-5, TSW Effluent Monitor	390,000 CPM
--------------------------------	-------------

OR

Sample analysis indicates greater than 200 times ODCM 6.2.1.1 limit for 15 minutes or longer.

The required release duration has been reduced to 15 minutes in recognition of the decreased plant safety, and to provide prompt classification. It is expected that the offsite dose analysis will be performed on the Emergency Dose Projection System (EDPS) or the Backup EDPS.

If the monitor reading(s) is sustained for longer than 15 minutes and the required assessments cannot be completed within this period, then the declaration must be made based on the valid reading.

REF:

NUMARC NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Alert AAI

WNP-2 Offsite Dose Calculation Manual

WNP-2 Technical Specifications

DEVIATION:

1. NUMARC example #3 was deleted since WNP-2 does not have telemetered perimeter monitors.
2. NUMARC example #4 not included because WNP-2 does not provide automatic real time dose assessment capability.
3. ODCM has a 2 hour default as opposed to the 1 hour default advocated by NUMARC NESP-007.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	53 of 96

G. INCREASED RADIATION RELEASE TO THE ENVIRONMENT

SITE AREA EMERGENCY:

GS1: Boundary Dose Resulting From an Actual or Imminent Release of Gaseous Radioactivity that Exceeds 100 mrem TEDE OR 500 mrem Thyroid CDE for the Actual OR Projected Duration of the Release.

APPLICABILITY:

Operating Conditions

1	2	3	4	5	Def
---	---	---	---	---	-----

EMERGENCY ACTION LEVEL:

A valid reading on one or more of the following monitors that exceeds or is expected to exceed the value shown:

- PRM-RE-1C 6500 CPS
- TEA-RIS-13 440,000 CPM
- WEA-RIS-14 1,670,000 CPM

AND

Assessment in accordance with PPM 13.8.1 or 13.8.2 using actual meteorology indicates offsite doses greater than 100 mrem TEDE or 500 mrem thyroid CDE for the actual or projected duration of the release.

NOTE: If the monitor reading is sustained for longer than 15 minutes and the required assessment cannot be completed within this period, then the declaration must be made based on the valid reading.

OR

Valid dose assessment capability indicates dose consequences greater than 100 mrem TEDE or 500 mrem thyroid CDE.

OR

Field survey results indicate Protected Area Boundary dose rates exceeding 100 mrem/hr and are expected to continue for more than one hour.

OR

Analyses of field survey samples indicate thyroid CDE of 500 mrem for one hour of inhalation.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	54 of 96

[Faint, illegible text covering the majority of the page, likely bleed-through from the reverse side.]

Effluent readings shall only be used for the classification of fast breaking events until actual dose projections can be made. Dose assessment, since it uses current plant values, will be more accurate and should be used.

The 100 mrem integrated dose in this Initiating Condition is based on the proposed 10 CFR 20 annual average population exposure. This value also provides a desirable gradient (one order of magnitude) between the Alert, Site Area Emergency and General Emergency classes. It is calculated that exposures less than this time limit are not consistent with the Site Area Emergency class description. The 500 mrem integrated thyroid CDE dose was established in consideration of the 1:5 ratio of the EPA Protection Action Guidelines for TEDE and Thyroid Committed Dose Equivalent.

In establishing the emergency action levels, a release duration of one hour is assumed. If the monitor reading(s) is sustained for longer than 15 minutes and the required assessments cannot be completed within this period, then the declaration must be made based on the valid reading.

REF:

NUMARC NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Site Area Emergency ASI

10 CFR 20

WNP-2 Offsite Dose Calculation Manual

Environmental Protection Agency 400, Manual of Protective Action Guides and Protective Actions for Nuclear Incidents, October 15, 1991

DEVIATION:

1. NUMARC example #2 was deleted since WNP-2 does not have a perimeter monitoring system.
2. ODCM has a 2 hour default as opposed to the 1 hour default advocated by NUMARC NESP-007.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	55 of 96

G. INCREASED RADIATION RELEASE TO THE ENVIRONMENT

GENERAL EMERGENCY:

GG1: Boundary Dose Resulting From an Actual or Imminent Release of Gaseous Radioactivity that Exceeds 1000 mR Total Effective Dose Equivalent OR 5000 mrem Thyroid Committed Dose Equivalent for the Actual OR Projected Duration of the Release Using Actual Meteorology.

APPLICABILITY:

Operating Conditions

1	2	3	4	5	Def
---	---	---	---	---	-----

EMERGENCY ACTION LEVEL:

A reading on one or more of the following monitors that exceeds or is expected to exceed the value shown:

- PRM-RE-1C 65,000 CPS
- TEA-RIS-13A 8 PMU
- WEA-RIS-14A 26 PMU

AND

Assessment in accordance with PPM 13.8.1 or 13.8.2 using actual meteorology indicates offsite doses greater than 1000 mrem TEDE or 5000 mrem thyroid CDE for the actual or projected duration of the release.

NOTE: If the monitor reading(s) is sustained for longer than 15 minutes and the required assessment cannot be completed within this period, then the declaration must be made based on the valid reading.

OR

Valid dose assessment capability indicates dose consequences greater than 1000 mrem TEDE or 5000 mrem thyroid CDE.

OR

Field survey results indicate Protected Area Boundary dose rates exceeding 1000 mrem/hr and are expected to continue for more than one hour.

Analyses of field survey samples indicate thyroid CDE of 5000 mrem for one hour of inhalation.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	56 of 96



THESE DOCUMENTS SONT LA PROPRIETE DE LA BIBLIOTHEQUE DE LA MAIRIE DE MONTREAL
ET NE DOIVENT PAS ETRE PRETES A LA DISPOSITION DU PUBLIC
SANS LAutorISATION DE LA BIBLIOTHECAIRE

Effluent readings shall only be used for the classification of fast breaking events until actual dose projections can be made. Dose assessment, since it uses current plant values, will be more accurate and should be used.

In establishing the emergency action levels, a release duration of one hour is assumed. If the monitor reading(s) is sustained for longer than 15 minutes and the required assessments cannot be completed within this period, then the declaration must be made based on the valid reading.

The 1000 mrem Total Effective Dose Equivalent or 5000 mrem thyroid Committed Dose Equivalent integrated dose are based on the EPA protective action guidance which indicates that public protective actions are indicated if the dose exceeds 1 rem Total Effective Dose Equivalent or 5 rem thyroid Committed Dose Equivalent. This logic is consistent with the emergency class description for a General Emergency and constitutes the upper level of the desirable gradient for the Site Area Emergency.

Actual meteorology is specifically identified in the Initiating Condition since it gives the most accurate dose assessment.

REF:

NUMARC NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, General Emergency AGI

10 CFR 20

WNP-2 Offsite Dose Calculation Manual

Environmental Protection Agency 400, Manual of Protective Action Guides and Protective Actions for Nuclear Incidents, October 15, 1991

DEVIATION:

1. NUMARC example #2 was deleted since WNP-2 does not have a perimeter monitoring system.
2. ODCM has a 2 hour default as opposed to the 1 hour default advocated by NUMARC NESP-007.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	57 of 96



H. FIRE/EXPLOSION

UNUSUAL EVENT:

HU1: Fire Within the Protected Area Boundary Not Extinguished Within 15 Minutes of Detection OR an Explosion Within Protected Area Boundary.

APPLICABILITY:

Operating Conditions

1	2	3	4	5	Def
---	---	---	---	---	-----

EMERGENCY ACTION LEVEL:

Fire within or adjacent to any Safe Shutdown Building which is not extinguished within 15 minutes of a valid alarm.

OR

Fire within or adjacent to any Safe Shutdown Building which is not extinguished within 15 minutes of Control Room notification by plant personnel.

OR

Report by plant personnel confirming the occurrence of an explosion within the Protected Area Boundary.

Safe Shutdown Buildings are:

- Vital portions of the Radwaste/Control Building
- Reactor Building
- Turbine Building
- Standby Service Water Pump Houses
- Diesel Generator Building
- Diesel Generator Fuel Oil Storage Area

This Initiating Condition and its associated EAL address fires that are of sufficient magnitude that they may be potentially significant precursors to damage to safety systems. This excludes items such as fires within administrative buildings or other structures not contiguous with a safe shutdown building, and other fires of no safety consequence or threat to a safe shutdown building.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	58 of 96



1. The first part of the document is a list of names and addresses. The names are listed in the first column, and the addresses are listed in the second column. The names are: John Doe, Jane Doe, and John Doe. The addresses are: 123 Main St, 456 Main St, and 789 Main St.

2. The second part of the document is a list of names and addresses. The names are listed in the first column, and the addresses are listed in the second column. The names are: John Doe, Jane Doe, and John Doe. The addresses are: 123 Main St, 456 Main St, and 789 Main St.

3. The third part of the document is a list of names and addresses. The names are listed in the first column, and the addresses are listed in the second column. The names are: John Doe, Jane Doe, and John Doe. The addresses are: 123 Main St, 456 Main St, and 789 Main St.

An alarm can be shown to be valid by multiple/redundant indications such as alarms on FCP-1 or FCP-2, fire pumps starting, fire water header pressure fluctuations or my notification by plant personnel. If an alarm must be verified by dispatching an individual to the scene, the 15 minute clock starts at the time of the alarm.

If an inspection of the area is completed within 15 minutes with no evidence of a fire (spurious alarm), no declaration need be made.

No attempt is made to assess the magnitude of the damage. The occurrence of the explosion with reports of damage (deformation/scorching) is sufficient for declaration.

Any security aspects of this event should be considered under Event Category N, "Security Events". If structural or equipment damage occurs within areas housing safe shutdown equipment and functions, the event may be escalated to Alert, HA1.

REF:

Title 10 of the Code of Federal Regulations, Part 50, Domestic Licensing of Production and Utilization Facilities, Appendix R, Fire Protection Program for Nuclear Power Facilities

NUMARC NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Unusual Event HU2

WNP-2 FSAR TABLE 9.5-8, Locations of Emergency Lighting.

DEVIATION:

Explosion within the protected area was moved from General Hazards (NUMARC HU1) to the Fire EAL to provide consistency with the Alert Level Fire EAL (NUMARC HA2) and to avoid Shift Manager/PED confusion.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	59 of 96



H. FIRE/EXPLOSION

ALERT:

HA1: Fire OR Explosion Affecting the Operability of Plant Safety Systems Required to Establish or Maintain Safe Shutdown.

APPLICABILITY:

Operating Conditions

1	2	3	4	5	Def
---	---	---	---	---	-----

EMERGENCY ACTION LEVEL:

Confirmed fire or explosion in a safe shutdown building.

AND

Affected safe shutdown system parameters indicate degraded performance.

OR

Report by plant personnel of visible damage to the safe shutdown building or equipment contained within the safe shutdown building.

Safe Shutdown Buildings are:

- Vital portions of the Radwaste/Control Building
- Reactor Building
- Turbine Building
- Standby Service Water Pump Houses
- Diesel Generator Building
- Diesel Generator Fuel Oil Storage Area

As used here, an explosion is a rapid, violent, unconfined combustion or catastrophic failure of pressurized equipment, that potentially imparts significant energy to near-by structures and materials. The inclusion of a "report of visible damage" should not be interpreted as mandating a lengthy damage assessment prior to classification. No attempt is made in this EAL to assess the actual magnitude of the damage. The occurrence of the explosion with reports of evidence of damage (e.g., deformation, scorching) is sufficient for declaration.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	60 of 96



It is important to note that this EAL addresses a fire and not the degradation in performance of affected systems. The reference to damage of systems is used to identify the magnitude of the fire and to discriminate against minor fires. The reference to Safe Shutdown Buildings is included to discriminate against fires in areas having a low probability of affecting safe operation. The significance here is not that a safety system was degraded but the fact that the fire was large enough to cause damage to these systems.

REF:

Title 10 of the Code of Federal Regulations, Part 50, Domestic Licensing of Production and Utilization Facilities, Appendix R, Fire Protection Program for Nuclear Power Facilities

NUMARC/NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Alert HA2

WNP-2 FSAR TABLE 9.5-8, Locations of Emergency Lighting

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	61 of 96



I. CONTROL ROOM EVACUATION

ALERT:

IA1: Control Room Evacuation Has Been Initiated.

APPLICABILITY:

Operating Conditions

1	2	3	4	5	Def
---	---	---	---	---	-----

EMERGENCY ACTION LEVEL:

Entry into PPM 4.12.1.1, "Control Room Evacuation and Remote Cooldown".

The Alert condition addresses events which involve a substantial degradation of the level of safety of the plant. Frequently, a distinguishing characteristic of a "substantial degradation" is the need for increased monitoring of or assistance in monitoring plant functions. With the Control Room evacuated, additional support, monitoring and direction through the Technical Support Center and/or Operations Support Center is necessary. Therefore, an Alert should be declared when the Control Room must be evacuated.

An inability to establish plant control from outside the Control Room will escalate this event to a Site Area Emergency.

REF:

WNP-2 Control Room Evacuation and Remote Cooldown, PPM 4.12.1.1

NUMARC/NESP-007, Methodology for Development of Emergency Action Levels,
Rev. 2, Alert HA5

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	62 of 96



I. CONTROL ROOM EVACUATION

SITE AREA EMERGENCY:

IS1: Control Room Evacuation Has Been Initiated, but Plant Control CANNOT be Established.

APPLICABILITY:

Operating Conditions

1	2	3	4	5	Def
---	---	---	---	---	-----

EMERGENCY ACTION LEVEL:

Control room evacuation has been initiated PPM 4.12.1.1., "Control Room Evacuation and Remote Cooldown".

AND

Control of plant equipment needed to maintain adequate core cooling cannot be established at either the Division 1 or Division 2 Remote Shutdown Panels in accordance with PPM 4.12.1.1 within 15 minutes of the SRO in charge of the Control Room physically leaving the Control Room.

This Initiating Condition and its associated EAL address a condition where evacuation of the Control Room is necessary but expeditious transfer of safety systems has not occurred. Fission product barrier damage may not yet be indicated. A 15 minute transfer time was chosen for control to be reestablished to ensure that core uncover with subsequent core damage does not occur and is consistent with NUMARC methodology.

Escalation of this event, if appropriate, would be by Fission Product Barrier Degradation, Abnormal Rad Levels/Radiological Effluent, or Shift Manager/PED Judgment Initiating Conditions.

REF:

NUMARC/NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Site Area Emergency HS2

WNP-2 Control Room Evacuation and Remote Cooldown, PPM 4.12.1.1

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	63 of 96

$$P = \frac{1}{2} \left(\frac{1}{2} + \frac{1}{2} \right) = \frac{1}{2}$$

J. LOSS OF ANNUNCIATORS/INDICATIONS

UNUSUAL EVENT:

JU1: Unplanned Loss of Most or All Safety System Annunciators or Indication in the Control Room for Greater than 15 Minutes.

APPLICABILITY:

Operating Conditions

1	2	3	4	5	Def
---	---	---	---	---	-----

EMERGENCY ACTION LEVEL:

Unplanned Loss of most or all annunciators on P601, P602, P603, and Bd C associated with safety related equipment for greater than 15 minutes.

AND

Compensatory nonalarming indications ARE available (Plant Computer System, GDS or other installed monitors).

AND

In the opinion of the Shift Manager/PED, the loss of the indications or annunciators requires increased surveillance to safely operate the plant.

AND

The loss of the indications or annunciators was not planned.

This Initiating Condition and its associated EAL recognize the difficulty associated with monitoring plant conditions without the use of a major portion of the annunciation or indication equipment.

Quantification of "most" is left to the Shift Manager/PED. It is not intended that plant personnel perform a detailed count of the instrumentation lost but rather make a judgment call with approximately 75% being the threshold. It is estimated that if approximately 75% of the annunciators or indicators are lost, there is an increased risk that a degraded plant condition could go undetected.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	64 of 96

Control Room panels with annunciators and indicators for safety related equipment required for off normal or emergency plan response include:

- P601
- P602
- P603
- Electrical Distribution on Bd C

Indications are available at other locations including Control Room backpanels, using them to safely operate the plant would require increased surveillance.

Plant design provides redundant safety system indication powered from separate uninterruptible power supplies. While failure of a large portion of annunciators is more likely than a failure of a large portion of indications, the concern is included in this EAL due to difficulty associated with assessment of plant conditions. The loss of specific, or several, safety system indicators should remain a function of that specific system or component operability status. This will be addressed by the specific Technical Specification. The initiation of a Technical Specification-imposed plant shutdown related to the instrument loss will be reported via 10 CFR 50.72. If the shutdown is not in compliance with the Technical Specification Action Statement, the Unusual Event is based on AU1, "Inability to Reach Required Shutdown Within Technical Specification Limits".

Compensatory nonalarming indications include the Process Computers and the Graphic Display System (GDS). It may include other permanently or temporarily installed monitoring systems if they allow the plant operators to compensate for the failed indications.

Fifteen minutes was selected as a threshold to exclude transitory or momentary power losses.

No Initiating Condition is indicated during cold shutdown and refueling due to the limited number of safety systems required for operation.

This event should be escalated to Alert CA3 if a transient is in progress or the compensatory indications become unavailable.

REF:

NUMARC/NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Unusual Event SU3

WNP-2 Technical Specifications

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	65 of 96

J. LOSS OF ANNUNCIATORS/INDICATIONS

ALERT:

JA1: Unplanned Loss of Most or All Safety System Annunciators or Indications in the Control Room with EITHER: 1) a Significant Transient in Progress; OR
2) Compensatory Nonalarming Indicators are Unavailable.

APPLICABILITY:

Operating Conditions

1	2	3	
---	---	---	--

EMERGENCY ACTION LEVEL:

Unplanned loss of most or all annunciators on P601, P602, P603, and Bd C associated with safety related equipment for greater than 15 minutes.

AND

In the opinion of the Shift Manager/PED, the loss of the annunciators requires increased surveillance to safely operate the plant.

AND

Loss of annunciation was not planned

AND

A significant plant transient is in progress.

OR

Compensatory nonalarming indications are NOT available (Plant Computer System, GDS or other installed monitors).

This Initiating Condition and its associated EAL recognize the difficulty associated with monitoring plant conditions without the use of a major portion of the annunciation or indication equipment. It represents an increase in severity above that described in Unusual Event CU4 in that either compensatory indications are not available or a significant transient is in progress.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	66 of 96



Quantification of "most" is left to the Shift Manager/PED. It is not intended that plant personnel perform a detailed count of the instrumentation lost but, rather, make a judgment call with approximately 75% being the threshold. It is estimated that if approximately 75% of the annunciators or indicators are lost, there is an increased risk that a degraded plant condition could go undetected.

Control Room panels with annunciators and indicators for safety related equipment for off normal or emergency plan response include:

- P601
- P602
- P603
- Electrical Distribution on Bd C

Indications are available at other locations including Control Room backpanels. However, using them to safely operate the plant would require increased surveillance.

Plant design provides redundant safety system indication powered from separate uninterruptable power supplies. While failure of a large portion of annunciators is more likely than a failure of a large portion of indications, the concern is included in this EAL due to difficulty associated with assessment of plant conditions. The loss of specific, or several, safety system indicators should remain a function of that specific system or component operability status. This will be addressed by the specific Technical Specification. The initiation of a Technical Specification-imposed plant shutdown related to the instrument loss will be reported via 10 CFR 50.72. If the shutdown is not in compliance with the Technical Specification action statement, the Unusual Event is based on AU1, "Inability to Reach Required Shutdown Within Technical Specification Limits".

Compensatory nonalarming indications include the Process Computer Systems. It may include other permanently or temporarily installed monitoring systems if they allow the plant operators to compensate for the failed indications.

Fifteen minutes was selected as a threshold to exclude transient or momentary power losses.

A "significant transient" includes response to automatic or manually initiated functions such as scrams, runbacks involving greater than 25% thermal power change, ECCS injection, or thermal power oscillations of 10% or greater.

No Initiating Condition is indicated during cold shutdown or refueling due to the limited number of safety systems required for operation.

This event should be escalated to Site Area Emergency CS3 if the operating crew cannot monitor a transient in progress.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	67 of 96

THE UNIVERSITY OF CHICAGO
DIVISION OF THE PHYSICAL SCIENCES
DEPARTMENT OF PHYSICS
5301 S. DICKINSON AVE.
CHICAGO, ILL. 60637
TEL. 773-835-5000
FAX 773-835-5000
WWW.PHYSICS.UCHICAGO.EDU

REF:

*NUMARC/NESP-007, Methodology for Development of Emergency Action Levels, Rev.
2, Alert SA4*

WNP-2 Technical Specifications

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	68 of 96



J. LOSS OF ANNUNCIATORS/INDICATIONS

SITE AREA EMERGENCY:

JS1: Inability to Monitor a Significant Transient in Progress.

APPLICABILITY:

Operating Conditions

1	2	3	
---	---	---	--

EMERGENCY ACTION LEVEL:

Loss of most or all annunciators on P601, P602, P603, and Bd C associated with safety related equipment.

AND

Compensatory non-alarming indications are unavailable (process computer system, GDS or other installed monitors).

AND

Loss of indications needed to monitor any of the following plant critical safety parameters: Reactor power, RPV level, RPV pressure, Wetwell pressure, Drywell pressure, Drywell temperature, Wetwell/Drywell H2/O2 Concentrations, Wetwell level, Wetwell temperature, Radioactive Gaseous Effluents

AND

Significant transient in progress

This Initiating Condition and its associated EAL recognize the inability of the Control Room staff to monitor plant response to a transient. A Site Area Emergency is considered to exist if the Control Room staff cannot monitor the critical safety functions needed for protection of the public.

Critical safety functions include those plant parameters and functions that allow the plant operators to verify they have a coolable core geometry, that core cooling is maintained, and that containment is intact. The WNP-2 Safety Analysis Report states that the safety functions include:

1. The accommodation of abnormal operational transients and postulated design basis accidents;
2. The maintenance of containment integrity;

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	69 of 96

[illegible]

3. The assurance of Emergency Core Cooling; and
4. The continuance of reactor coolant pressure boundary integrity.

Compensatory nonalarming indications include the Process Computer Systems. It may include other permanently or temporarily installed monitoring systems if they allow the plant operators to compensate for the failed indications.

A "significant transient" includes response to automatic or manually initiated functions such as scrams, runbacks involving greater than 25% thermal power change, ECCs injection, or thermal power oscillations of 10% or greater.

REF:

NUMARC/NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Site Area Emergency SS6

WNP-2 Technical Specifications

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	70 of 96

THE UNIVERSITY OF CHICAGO PRESS
54 EAST LAKE STREET, CHICAGO, ILL. 60601
U.S.A. AND CANADA
OTHER COUNTRIES: 100 Brook Hill Drive, Secaucus, N.J. 07094
U.K. AND THE REST OF EUROPE: 100 Brook Hill Drive, Secaucus, N.J. 07094
U.K. AND THE REST OF EUROPE: 100 Brook Hill Drive, Secaucus, N.J. 07094

K. LOSS OF COMMUNICATIONS

UNUSUAL EVENT:

KU1: Significant Loss of Onsite OR Offsite Communications Capabilities.

APPLICABILITY:

Operating Conditions

1	2	3	4	5	Def
---	---	---	---	---	-----

EMERGENCY ACTION LEVEL:

Unplanned loss of all of the following onsite communications capability:

Plant Public Address (PA) System

Plant Telephone System

Plant Radio System Operations and Security Channels

OR

Unplanned loss of all of the following offsite communications capability:

State/County Notification (CRASH) System.

Offsite calling capability from the Control Room via direct telephone and fax lines.

Long distance calling capability on the Plant ("2000") Switch and Plant Support

Facility/Plant Engineering Center ("8000") Switch.

This Initiating Condition and its associated EAL's recognize a loss of communications capability that significantly degrades the plant operations staff's ability to perform tasks necessary for plant operations or the ability to communicate with offsite authorities. The loss of offsite communications capability is more comprehensive than that addressed by 10 CFR 50.72.

REF:

NUMARC NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Unusual Event SU6

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	71 of 96



1. The first part of the document is a list of names and addresses. The names are listed in the first column, and the addresses are listed in the second column. The names are: John Doe, Jane Smith, and Bob Johnson. The addresses are: 123 Main St, 456 Elm St, and 789 Oak St.

2. The second part of the document is a list of names and addresses. The names are listed in the first column, and the addresses are listed in the second column. The names are: John Doe, Jane Smith, and Bob Johnson. The addresses are: 123 Main St, 456 Elm St, and 789 Oak St.

3. The third part of the document is a list of names and addresses. The names are listed in the first column, and the addresses are listed in the second column. The names are: John Doe, Jane Smith, and Bob Johnson. The addresses are: 123 Main St, 456 Elm St, and 789 Oak St.

L. NATURAL/DESTRUCTIVE PHENOMENA

UNUSUAL EVENT:

LU1: Natural and Destructive Phenomena Affecting the Protected Area Boundary.

APPLICABILITY:

Operating Conditions

1	2	3	4	5	Def
---	---	---	---	---	-----

EMERGENCY ACTION LEVEL:

EAL #1

Minimum Seismic Earthquake Exceeded (H13-P851-S1-2.5)
AND
Control Room receives report from plant personnel who have felt an earthquake.

OR

EAL #2

Report by plant personnel confirming the occurrence of a tornado striking within the Protected Area Boundary.

OR

EAL #3

Vehicle crash into or projectile which impacts plant structures or systems within Protected Area boundary.

OR

EAL #4

Weather Service projected winds GT 80, or Control Room measured winds GT 66 mph (5 min. average at 33 ft.)

OR

EAL #5

Range fires near the plant which threaten to reduce the normal level of safety.

OR

EAL #6

Turbine failure resulting in casing penetration or damage to turbine or generator seals.

Attachment 4.1

PROCEDURE NUMBER 13.1.1.A	REVISION 0	PAGE 72 of 96
------------------------------	---------------	------------------

[Faint, illegible text covering the majority of the page, likely bleed-through from the reverse side.]

OR

EAL #7

Visible ash fallout from volcanic activity.

OR

EAL #8

Floods where the river pumphouse is observed to be in danger of inundation.

- EAL 1: The method of detection associated with an earthquake of this intensity is based on the condition for a "felt earthquake" as defined in the EPRI-sponsored "Guidelines for, Nuclear Plant Response to an Earthquake". These methods include the activation of seismic monitoring instrumentation as evidenced by a valid alarm on P851-S1-2.5, "MINIMUM SEISMIC EARTHQUAKE EXCEEDED" along with confirmation from plant personnel who have physically felt the ground motion and recognize the event as an earthquake. An earthquake of this magnitude may be sufficient to cause some minor damage to plant structures or equipment within the Protected Area. Damage is considered to be minor since it does not affect physical or structural integrity. The event is not expected to affect the capabilities of plant safety functions. Due to the unpredictable nature of earthquakes, this may be a precursor to a more serious event and, therefore, represents a potential degradation in the level of safety of the plant.
- EAL 2: A tornado touching down within the Protected Area is an observed event with the potential to cause damage to structures containing systems or functions necessary for the safe shutdown of the plant. As such, the occurrence of a tornado strike represents a potential degradation in the level of safety of the plant. If structural damage is confirmed, this event would be escalated to Alert LA1. If it is determined that the occurrence of the tornado strike has either affected or caused the loss of shutdown cooling functions, then the consequences of the event are assessed under event category B, "Loss of Shutdown/Cooldown Functions". The event may then be escalated via this category if appropriate.
- EAL 3: This EAL addresses such items as plane, helicopter, train, car, truck, or barge crash, or impact of other projectiles that may potentially damage plant structures containing functions and systems required for safe shutdown of the plant. If the crash is confirmed to affect a plant vital area, the event may be escalated to Alert.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	73 of 96

[Faint, illegible text covering the majority of the page, likely bleed-through from the reverse side.]

THE UNIVERSITY OF CHICAGO LIBRARY
540 EAST 57TH STREET
CHICAGO, ILL. 60637
TEL: 773-936-5000
FAX: 773-936-5001
WWW.CHICAGO.LIBRARY.EDU

- EAL 4: This event is a natural and potentially destructive phenomena that may accompany certain events such as a tornado or hurricane. These sustained high winds may also be produced by unstable weather conditions. However this event occurs, it may be a precursor to a more serious event and, therefore, represents a potential degradation in the level of safety of the plant.
- EAL 5: WNP-2 is located on a dryland steppe. Range fires routinely occur in this type of environment. This event has the potential to affect or cause the loss of safe shutdown systems and functions and, therefore, may be a precursor to a more serious event.
- EAL 6: Turbine failure with casing penetration or seal failure increases the potential for leakage of combustible fluids (oils and gas).
- EAL 7: In May of 1980, Mount St. Helens volcano erupted. Prevailing winds spread up to 1/4" of volcanic ash on the WNP-2 site, with much heavier concentrations of ash several miles north of the site. Ash can clog diesel-generator air intakes and can be highly abrasive to rotating machinery. This event represents a potential degradation in the level of safety of the plant.
- EAL 8: The WNP-2 station is located on an elevated plateau, well removed from risk of flooding by the Columbia River. The river pumphouse, located lower and closer to the river, may be prone to flooding. Should the river pumphouse be lost, the Standby Service Water Ultimate Heat Sink spray ponds have a 30 day supply of water. However, loss of the river pumphouse is deemed a potential degradation in the level of safety of the plant. The first Control Room indication of river pumphouse flooding would be TMU-LI-7 off-scale high.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	74 of 96



REF:

NUMARC/NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Unusual Event HUI

WNP-2 Earthquake, PPM 4.12.4.3

WNP-P Flood, PPM 4.12.4.2

WNP-2 Tornado/High Winds, PPM 4.12.4.8

WNP-2 Design Basis Ash Fallout, PPM 4.12.4.5

WNP-2 Engineering Calculation CE-02-93-16

EPRI Guidelines for Nuclear Plant Response to an Earthquake

WNP-2 FSAR Table 9.5-8, Locations of Emergency Lighting

DEVIATION:

The explosion EAL was moved to Event Category H, "FIRE", to be consistent with the Fire Alert HA1, and to avoid Shift Manager/PED confusion.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	75 of 96

L. NATURAL/DESTRUCTIVE PHENOMENA

ALERT:

LA1: Natural and Destructive Phenomena Affecting Safe Shutdown Buildings.

APPLICABILITY:

Operating Conditions

1	2	3	4	5	Def
---	---	---	---	---	-----

EMERGENCY ACTION LEVEL:

EAL 1:

Operating Basis Earthquake Exceeded (H13-P851-S1-5.1)
AND
Control Room receives report from plant personnel who have felt an earthquake.

OR

EAL 2:

Report by plant personnel confirming the occurrence of a tornado striking a plant Safe Shutdown building.

OR

EAL 3:

Vehicle crash or projectile impact which impedes access to or damages equipment in plant vital areas.

OR

EAL 4:

Weather Service projected winds GT 100, or Control Room measured winds GT 76 mph (5 min. average at 33 ft.).

OR

EAL 5:

Ash fallout from volcanic activity is severe enough to warrant plant shutdown.

OR

Attachment 4.1

PROCEDURE NUMBER 13.1.1.A	REVISION 0	PAGE 76 of 96
------------------------------	---------------	------------------

1. The first part of the report is a summary of the work done during the year.

2. The second part is a detailed account of the work done during the year.

3. The third part is a summary of the work done during the year.

4. The fourth part is a summary of the work done during the year.

5. The fifth part is a summary of the work done during the year.

6. The sixth part is a summary of the work done during the year.

7. The seventh part is a summary of the work done during the year.

8. The eighth part is a summary of the work done during the year.

9. The ninth part is a summary of the work done during the year.

10. The tenth part is a summary of the work done during the year.

11. The eleventh part is a summary of the work done during the year.

12. The twelfth part is a summary of the work done during the year.

13. The thirteenth part is a summary of the work done during the year.

14. The fourteenth part is a summary of the work done during the year.

EAL 6:

Missiles generated from a turbine failure have resulted in visible structural damage to or penetration of a safe shutdown building

OR

EAL 7:

Report by plant personnel of an event causing visible structural damage to a Safe Shutdown Building.

OR

EAL 8:

Report by plant personnel confirming the occurrences of plant internal flooding in a Safe Shutdown Building.

AND

Affected safe shutdown system parameters indicate degraded performance.

Each of these EAL's is intended to address events that may have resulted in Safe Shutdown Buildings being subjected to forces beyond design limits and, thus, damage may be assumed to have occurred to safe shutdown systems. The initial "report" should not be interpreted as mandating a lengthy damage assessment prior to classification. No attempt is made in these EAL's to assess the actual magnitude of the damage. Escalation to a higher emergency class, if appropriate, will be based on the specific system malfunctions, fission product barrier degradation, abnormal radiological releases, or Shift Manager/PED judgement IC's.

The occurrence of the explosion with reports of evidence of damage (e.g., deformation, scorching) is sufficient for declaration. The declaration of an Alert and the activation of the TSC and OSC will provide the Shift Manager/PED with the resources needed to perform these damage assessments subsequent to the classification. The Shift Manager/PED also needs to consider any security aspects of the explosion, if applicable.

For the purposes of this Initiating Condition, safe shutdown buildings are considered to be the following locations:

- Vital portions of the Radwaste/Control Building
- Reactor Building
- Turbine Building
- Standby Service Water Pump Houses
- Diesel Generator Building
- Diesel Generator Fuel Oil Storage Area

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	77 of 96



This list was developed from select portions of the Emergency Lighting in the Safety Analysis Report.

NOTE: Each EAL is discussed individually as it applies to the Initiating Condition for this Unusual Event. For the purposes of the Technical Basis, the EAL's are numbered, then referenced by number in the body of the discussion.

- EAL 1:** An earthquake that exceeds the OBE level is beyond the design basis limits for the plant as specified in the Safety Analysis Report, Section 3.7, Seismic Design. A seismic event of this magnitude can cause damage to safety related systems and functions. Detection of this event includes activation of seismic monitoring instrumentation as evidenced by a valid alarm on P851-S1-5.1, "OPERATING BASIS EARTHQUAKE EXCEEDED" along with confirmation from plant personnel who have physically felt the associated ground motion. An evaluation along with a thorough inspection of plant areas and systems will be used to determine the extent of plant damage and will provide the necessary information to determine if escalation to a higher emergency classification is required.
- EAL 2:** This event is a natural and potentially destructive phenomena that may accompany certain events such as a tornado or hurricane. These sustained high winds may also be produced by unstable weather conditions. However this event occurs, it may be a precursor to a more serious event and, therefore, represents a potential for substantial degradation in the level of safety of the plant.
- EAL 3:** This EAL addresses such items as plane, helicopter, train, car, truck, or barge crash, or impact of other projectiles that may affect plant structures containing functions and systems required for safe shutdown of the plant. If the crash is confirmed to affect a plant vital area, the event is an Alert.
- EAL 4:** Sustained high winds at this level are beyond the design basis limits for the plant as described in SAR Section 3.3, Wind Loading. Wind loads of this magnitude have the potential to damage safety related systems and functions. As such, the potential exists for substantial degradation of the level of the safety of the plant.
- EAL 5:** In May of 1980, Mount St. Helens volcano erupted. Prevailing winds spread up to 1/4" of volcanic ash on the WNP-2 site, with much heavier concentrations of ash several miles north of the site. Ash can clog diesel-generator air intakes and can be highly abrasive to rotating machinery. Should the Ash fallout be severe enough to warrant plant shutdown, the event additionally represents a potential for substantial degradation in the level of safety of the plant.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	78 of 96

EAL 6: Turbine causing penetration, caused by failure of turbine rotating components, can result in missiles (blading, pieces of diaphragm, etc.) being hurled through the casing penetrations with such force, they can penetrate the turbine and come to rest a significant distance away. These turbine-generated missiles pose a threat to safety related equipment if they cause visible structural damage to, or if they penetrate, Safe Shutdown Buildings.

EAL 7: Visible structural damage is any observed physically degraded condition that indicates a significant impairment of the structural integrity of the building or area. An example of such a condition would be where a building sustained enough damage ghat it appears as if the roof could collapse at any time. The damage is based upon a report only. A detailed investigation or engineering evaluation is not required in order to classify the event.

EAL 8: Flooding conditions within the plant affecting safe shutdown areas have the potential to directly impact the safe operation of the plant. The flooding event may pose a direct threat to safety related equipment. As such, the potential exists for substantial degradation of the level of safety of the plant. Flooding is indicated by ECCS room level alarms on P601 and sump hi-hi alarms on P602.

REF:

NUMARC/NESP-007, Methodology for Development of Emergency Actions Levels, Rev. 2, Alert HA1

WNP-2 Earthquake, PPM 4.12.4.3

WNP-2 Tornado/High Winds, PPM 4.12.4.8

WNP-2 Reactor Building 422 Area Flooding, PPM 4.12.4.10

EPRI Guidelines for Nuclear Plant Response to an Earthquake

WNP-2 FSAR Table 9.5-8, Locations of Emergency Lighting

WNP-2 Design Basis ash Fallout, PPM 4.12.4.5

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	79 of 96



姓名: _____ 性别: _____ 年龄: _____ 职业: _____ 住址: _____ 电话: _____ 电子邮箱: _____

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	-----

DEVIATION:

1. NUMARC Initiating Condition Statement, "Natural and Destructive Phenomena Affecting Plant Vital Areas", was changed to "Natural and Destructive Phenomena Affecting Safe Shutdown Buildings". At WNP-2, Safe Shutdown Buildings include: plant security areas (vital areas), buildings containing safe shutdown equipment (Appendix R), and buildings containing safety related equipment (ASME).

This encompasses all the different areas and equipment discussed in the various NUMARC Alert EAL's included in this section. By changing the Initiating Condition to Safe Shutdown Buildings a common philosophy was able to be utilized throughout the Alert level while still encompassing the intent of the NUMARC EAL's.

2. NUMARC EAL Statement: "(Site-specific) Indications in the Control Room", is not included in the WNP-2 EAL's. The NUMARC Basis for this EAL states: "EAL 4 should specify the instrumentation or indications including judgment which are to be used to assess occurrence". This is not substantially different from NUMARC Alert HA6, "Other Conditions Existing Which in the Judgment of the Emergency Director Warrant Declaration of an Alert". This EAL is already addressed by WNP-2 Initiating Condition PA1.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	80 of 96



M. RELEASE OF TOXIC/FLAMMABLE GAS

UNUSUAL EVENT:

MU1: Release of Toxic or Flammable Gases Affecting the Protected Area Boundary Deemed Detrimental to Safe Operation of the Plant.

APPLICABILITY:

Operating Conditions

1	2	3	4	5	Def
---	---	---	---	---	-----

EMERGENCY ACTION LEVEL:

Report or detection of toxic or flammable gases that could enter or have entered within the Protected Area boundary in amounts that could affect the health of plant personnel or safe plant operation.

OR

Report by local, county or state officials for potential evacuation of site personnel based on offsite event.

This Initiating Condition and its associated EAL's are based on releases in concentrations within the Protected Area Boundary that may affect the health of plant personnel or the safe operation of the plant. This includes releases that originate onsite as well as releases that originate offsite but threaten onsite areas.

A toxic gas is considered to be any gas that is dangerous to life or limb by reason of inhalation or skin contact.

A combustible gas, if maintained at a concentration lower than the Lower Explosive Limit (LEL), will not explode due to ignition.

REF:

NUMARC/NESP-007, Methodology for Development of Emergency Actions Levels, Rev. 2, Unusual Event HU3

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	81 of 96



DEVIATION:

The wording of NUMARC Initiating Condition, "Release of Toxic or Flammable Gases Deemed Detrimental to Safe Operation of the Plant", was changed to more closely reflect the intent of the NUMARC basis while maintaining consistency of philosophy between Unusual Events LU1, HU1 and MU1. The NUMARC basis for this Initiating Condition "...is based on releases...within the site boundary...". However, it is believed that the site boundary referred to here is a generic term and is not intended to reflect the more proper Owner Controlled Area. Unusual Events HU1 and LU1 which also evaluate potential hazards, limit their scope to the Protected Area..

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	82 of 96

Figure 1. The proposed model for the development of the self-regulation of learning. The model illustrates the relationship between various factors influencing the development of self-regulation of learning. The factors are organized into three main categories: Personal Factors, Environmental Factors, and Learning Outcomes. Personal Factors include Self-regulation of Learning, Learning Strategies, and Learning Motivation. Environmental Factors include Learning Environment, Learning Resources, and Learning Support. Learning Outcomes include Learning Achievement, Learning Satisfaction, and Learning Self-efficacy. The model shows that Personal Factors and Environmental Factors both influence Learning Outcomes, and that Learning Outcomes also influence Personal Factors, creating a feedback loop.

M. RELEASE OF TOXIC/FLAMMABLE GAS

ALERT:

MA1: Release of Toxic or Flammable Gases Within a Facility Structure Which Jeopardizes Operation of Systems Required to Maintain Safe Operations or to Establish or Maintain Cold Shutdown.

APPLICABILITY:

Operating Conditions

1	2	3	4	5	Def
---	---	---	---	---	-----

EMERGENCY ACTION LEVEL:

Report or detection of toxic or flammable gases within a safe shutdown building in concentrations that will be life threatening to plant personnel or impede access to equipment needed for safe plant operation.

This EAL is based on gases that have entered a plant structure impeding access to equipment necessary for the safe operation of the plant. This EAL applies to safe shutdown buildings and areas contiguous to plant vital areas or other significant buildings or areas. The intent of this EAL is not to include buildings (i. e., warehouses) or other areas that are not contiguous or immediately adjacent to plant vital areas or safe shutdown buildings. It is appropriate that increased monitoring be done to ascertain whether consequential damage has occurred.

For the purposes of this Initiating Condition, safe shutdown buildings are considered to be the following locations:

- Vital portions of the Radwaste/Control Building
- Reactor Building
- Turbine Building
- Standby Service Water Pump Houses
- Diesel Generator Building
- Diesel Generator Fuel Oil Storage Area

This list was developed from select portions of the Emergency Lighting in the Safety Analysis Report.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	83 of 96



REF:

*NUMARC/NESP-007, Methodology for Development of Emergency Actions Levels,
Rev. 2, Alert HA3*

WNP-2 FSAR Table 9.5-8, Locations of Emergency Lighting

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	84 of 96



N. SECURITY EVENTS

UNUSUAL EVENT:

NU1: Confirmed Security Event Which Indicates a Potential Degradation in the Level of Safety of the Plant.

APPLICABILITY:

Operating Conditions

1	2	3	4	5	Def
---	---	---	---	---	-----

EMERGENCY ACTION LEVEL:

A bomb device discovered within the plant Protected Area and outside the plant Vital Area

OR

Confirmed report of an attempted entry, sabotage or security threat that cannot be properly compensated for within 10 minutes.

Events which are believed by the Shift Manager/PED to indicate a potential degradation of the level of safety of the plant should be declared an Unusual Event.

Security events which do not represent at least a potential degradation in this level of safety of the plant are reported under 10 CFR 73.71 or, in some cases, 10 CFR 50.72.

The 10 minute criteria to compensate is derived from regulatory guidance on implementation of 10 CFR 73.71, Reporting of Security Events.

REF:

WNP-2 Safeguards Contingency Plan

NUMARC/NESP-007, Methodology for Development of Emergency Actions Levels, Rev. 2, Unusual Event HU4

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	85 of 96

N. SECURITY EVENTS

ALERT:

NA1: Security Event in a Plant Protected Area.

APPLICABILITY:

Operating Conditions

1	2	3	4	5	Def
---	---	---	---	---	-----

EMERGENCY ACTION LEVEL:

Confirmed report of an intrusion by a hostile force into the plant Protected Area.

This class of security events represents an escalated threat to plant safety above that contained in the Unusual event. For the purpose of this Initiating Condition, a civil disturbance which penetrates the Protected Area Boundary as well as an individual or group of individuals with known or suspected malicious intent is considered a hostile force.

Intrusion into a Vital Area by a hostile force as defined in Site Area Emergency NS1 will escalate this event to Site Area Emergency.

REF:

WNP-2 Safeguards Contingency Plan

NUMARC/NESP-007, Methodology for Development of Emergency Actions Levels, Rev. 2, Alert HA4

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	86 of 96



N. SECURITY EVENTS

SITE AREA EMERGENCY:

NS1: Security Event in a Plant Vital Area.

APPLICABILITY:

Operating Conditions

1	2	3	4	5	Def
---	---	---	---	---	-----

EMERGENCY ACTION LEVEL:

Bomb device discovered within the plant Vital Areas

OR

Confirmed report of an intrusion by a hostile force into Vital Areas.

This class of security event represents an escalated threat to plant safety above that contained in Alert NA1 in that a hostile force has progressed from the Protected Area to the Vital Area.

For the purposes of this initiating condition, a civil disturbance which penetrates the Protected Area boundary as well as an individual or group of individuals with known or suspected malicious intent can be considered a hostile force.

REF:

WNP-2 Safeguards Contingency Plan

NUMARC/NESP-007, Methodology for Development of Emergency Actions Levels, Rev. 2, Site Area Emergency HSI

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	87 of 96



N. SECURITY EVENTS

GENERAL EMERGENCY:

NG1: Security Event Resulting in Loss of Ability to Reach and Maintain Cold Shutdown.

APPLICABILITY:

Operating Conditions

1	2	3	4	5	Def
---	---	---	---	---	-----

EMERGENCY ACTION LEVEL:

Loss of physical control of the Control Room due to a security event.

OR

Loss of physical control of the Remote Shutdown capability due to a security event.

This Initiating Condition encompasses conditions under which a hostile force has taken physical control of areas required to reach and maintain cold shutdown.

For the purpose of this Initiating Condition, a civil disturbance which penetrates the Protected Area Boundary as well as an individual or group of individuals with known or suspected malicious intent is considered a hostile force.

REF:

NUMARC/NESP-007, Methodology for Development of Emergency Actions Levels, Rev. 2, Unusual Event HG1

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	88 of 96



1. The first part of the document is a list of names and addresses. The names are listed in the first column, and the addresses are listed in the second column. The names are: John Doe, Jane Smith, and Bob Johnson. The addresses are: 123 Main St, 456 Elm St, and 789 Oak St.

2. The second part of the document is a list of names and addresses. The names are listed in the first column, and the addresses are listed in the second column. The names are: John Doe, Jane Smith, and Bob Johnson. The addresses are: 123 Main St, 456 Elm St, and 789 Oak St.

O. MISCELLANEOUS INITIATING CONDITIONS/SYSTEM MALFUNCTIONS

UNUSUAL EVENT:

OU1: Unexpected Decrease in Water Covering Irradiated Fuel Assemblies.

APPLICABILITY:

Operating Conditions

1	2	3	4	5	Def
---	---	---	---	---	-----

EMERGENCY ACTION LEVEL:

Uncontrolled water level decrease in the Reactor Cavity or Spent Fuel Pool below the level of the weirs with all irradiated fuel assemblies remaining covered by water.

The SFP cooling system weirs were chosen as a readily identifiable level. In addition to being readily visible from the refueling floor, dropping below the level of the weir, only a few inches, impairs the operability of the SFP cooling system with subsequent alarms.

These events tend to have long lead times relative to potential for radiological release outside the site boundary thus, the impact to public health and safety is very low.

Uncontrolled water level decrease may result in unplanned increases in inplant radiation levels represent a degradation in the control of radioactive material and represent a potential degradation in the level of safety of the plant. This EAL escalates to an ALERT per Initiating Condition OA2 if the water level drops lower to the level of the gates.

REF:

WNP-2 Technical Specifications

NUMARC NESP-007, Methodology for Development of Emergency Action Levels, Rev. 2, Unusual Event AU2

DEVIATION:

NUMARC example: EAL 1 and 2 are considered by WNP-2 to be more closely related to a system failure than to increased plant radiation release. Consequently EAL 1 and 2 addressed in this Initiating Condition. EAL 4 is addressed in Initiating Condition FU1. WNP-2 has no dry fuel storage license, therefore EAL 3 is not applicable.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	89 of 96

THE UNIVERSITY OF CHICAGO PRESS
54 EAST LAKE STREET, CHICAGO, ILL. 60601
U.S.A. AND CANADA
OTHER COUNTRIES: 100 Brook Hill Drive, West Nyack, New York 10994
U.K. AND INDIA: 27 Bedford Square, London, W.C.1, England
AUSTRALIA: 215 Victoria Road, North Sydney, New South Wales 1585
JAPAN: 3-1-1 Nishi-Shinjuku, Shinjuku-Ku, Tokyo 163, Japan
SINGAPORE: 100 Brook Hill Drive, West Nyack, New York 10994
MALAYSIA: 100 Brook Hill Drive, West Nyack, New York 10994
HONG KONG: 100 Brook Hill Drive, West Nyack, New York 10994
TAIWAN: 100 Brook Hill Drive, West Nyack, New York 10994
KOREA: 100 Brook Hill Drive, West Nyack, New York 10994
THAILAND: 100 Brook Hill Drive, West Nyack, New York 10994
PHILIPPINES: 100 Brook Hill Drive, West Nyack, New York 10994
INDONESIA: 100 Brook Hill Drive, West Nyack, New York 10994
MALAYSIA: 100 Brook Hill Drive, West Nyack, New York 10994
SINGAPORE: 100 Brook Hill Drive, West Nyack, New York 10994
HONG KONG: 100 Brook Hill Drive, West Nyack, New York 10994
TAIWAN: 100 Brook Hill Drive, West Nyack, New York 10994
KOREA: 100 Brook Hill Drive, West Nyack, New York 10994
THAILAND: 100 Brook Hill Drive, West Nyack, New York 10994
PHILIPPINES: 100 Brook Hill Drive, West Nyack, New York 10994
INDONESIA: 100 Brook Hill Drive, West Nyack, New York 10994

O. MISCELLANEOUS INITIATING CONDITIONS/SYSTEM MALFUNCTIONS

ALERT:

OA1: Main Steam Line Break Outside Containment with Isolation.

APPLICABILITY:

Operating Conditions

1	2	3	
---	---	---	--

EMERGENCY ACTION LEVEL:

Indications of a Main Steam Line break

AND

Main steam line isolation valve closure has isolated the break.

This EAL is based on design basis accident analyses which show that even if MSIV closure occurs within design limits, offsite (Exclusion Area Boundary) dose consequences from a "puff" release could exceed 50 but less than 100 millirem total effective dose equivalent (TEDE). Specifically FSAR Table 15.6-9 demonstrates 53 millirem TEDE. Only MSIV isolation signals that definitely indicate leakage outside primary RCS boundary with a path to the environment are included.

Examples of indications of Main Steam Line breaks are, but not limited to:

- Main Steam Line Tunnel temperature greater than 156°F on LD-TR-608, P-632 and "LEAK DET MSL TUNNEL TEMP HI-HI" alarm(s) on P-601-A2 &/or A3.
- Main Steam Line Tunnel delta temperature greater than 80°F on LD-TR-611, P-632 and "LEAK DET MSL TUNNEL HI-HI" alarm(s) on P601-A2 &/or A3.
- Main Steam Line flow greater than 140% as indicated by MSL ISOL MAIN STEAM LINE FLOW HIGH" alarm on P-601-A11 &/or A12.

REF:

NUMARC NESP-007, *Methodology for Development of Emergency Action Levels*, Rev. 2, Alert FA1.

NUMARC "Questions & Answers, June 1993" *Fission Product Barriers - BWR*, question/answer number 4

WNP-2 FSAR Table 15.6-9, *MSL Break*

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	90 of 96



THE UNITED STATES OF AMERICA

DEPARTMENT OF THE INTERIOR

O. MISCELLANEOUS INITIATING CONDITIONS/SYSTEM MALFUNCTIONS

ALERT:

OA2: Loss of Water Level that Has or Will Result in the Uncovering of Irradiated Fuel Outside the Reactor Vessel.

APPLICABILITY:

Operating Conditions

1	2	3	4	5	Def
---	---	---	---	---	-----

EMERGENCY ACTION LEVEL:

Water level, when not intentionally lowered, was observed to be below the top of the gate sill separating the Reactor Cavity and Dryer Storage Pool.

OR

Water level, when not intentionally lowered, was observed to be below the top of the gate sill separating the Reactor Cavity and the Spent Fuel Pool.

OR

Report of visual observation of irradiated fuel uncovered or uncovering imminent.

Unintentional water level decrease may result in unplanned increases in inplant radiation levels which represent a degradation in the control of radioactive material and represent a potential degradation in the level of safety of the plant.

No level indication is available in Reactor Cavity or spent fuel pools for monitoring pool level outside of a narrow band around the normal operating range. In lieu of using a visual observation of pool level below top of fuel racks, the bottom of the water gates between the pools were chosen as a reference point for classification purposes. The intent of this EAL is to allow observations from plant personnel to be factored into the declaration and is not intended to direct an entry into an area solely to observe pool level.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	91 of 96

1. The first part of the document is a list of names and addresses of the members of the committee.

2. The second part of the document is a list of names and addresses of the members of the committee.

REF:

WNP-2 Technical Specifications

*NUMARC NESP-007, Methodology for Development of Emergency Action Levels,
Rev. 2, AA2*

NUREG 0818, Emergency Action Levels for Light Water Reactors

*NUREG/CR-4982, Severe Accident in Spent Fuel Pools in Support of Generic Safety,
Issue 82, July 1987*

DEVIATION:

NUMARC example: EAL 2, 3 and 4 are considered by WNP-2 to be more closely related to a system failure than to increased plant radiation release. Consequently EAL 2, 3 and 4 are addressed in this Initiating Condition. EAL 1 is addressed in Initiating Condition FA1.

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	92 of 96

THE UNIVERSITY OF CHICAGO PRESS, 5 EAST LEXINGTON AVENUE, NEW YORK, N. Y. 10017

1

THE UNIVERSITY OF CHICAGO PRESS, 5 EAST LEXINGTON AVENUE, NEW YORK, N. Y. 10017

P. SHIFT MANAGER/PED JUDGMENT

UNUSUAL EVENT:

PU1: Other Conditions Existing Which, In the Judgment of the Shift Manager/PED,
Warrant Declaration of an Unusual Event.

APPLICABILITY:

Operating Conditions

1	2	3	4	5	Def
---	---	---	---	---	-----

EMERGENCY ACTION LEVEL:

In the judgment of the Shift Manager/PED, events are in process or have occurred which indicate a potential degradation of the level of safety of the plant.

Events which are believed by the Shift Manager/PED to indicate a potential degradation of the level of safety of the plant should be declared an Unusual Event. For those cases where the degradation in the level of the safety of the plant is tied to equipment or system malfunctions, the decision that the component is degraded should be based upon its functionality and not its operability.

A system, subsystem, train, component or device, though degraded in equipment condition or configuration, is functional if it is capable of maintaining respective system parameters within acceptable design limits.

Releases of radioactive material requiring offsite response or monitoring are not expected to occur at the Unusual Event level unless further degradation of safety systems occur. However, if one does occur, it will be classified under Initiating Condition GU1.

REF:

*NUMARC/NESP-007, Methodology for Development of Emergency Actions Levels,
Rev. 2, Unusual Event HU5*

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	93 of 96



1. The first part of the document is a list of names and addresses of the members of the committee.

2. The second part of the document is a list of names and addresses of the members of the committee.

P. SHIFT MANAGER/PED JUDGMENT

ALERT:

PA1: Other Conditions Existing Which, In the Judgment of the Shift Manager/PED,
Warrant Declaration of an Alert.

APPLICABILITY:

Operating Conditions

1	2	3	4	5	Def
---	---	---	---	---	-----

EMERGENCY ACTION LEVEL:

In the judgment of the Shift Manager/PED, events are in process or have occurred which indicate actual or potential substantial degradation of systems needed for the protection of the public.

This Emergency Action Level is intended to address unanticipated conditions not addressed explicitly elsewhere but that warrant declaration of an emergency because conditions exist which are believed by the Shift Manager/PED to fall under the Alert emergency class. This includes a determination by the Shift Manager/PED that additional assistance similar to that provided by the TSC and OSC staffs, including a transfer of the PED responsibilities to the TSC, is necessary for the event to be effectively mitigated. Transfer of PED duties for classification, offsite notifications and PAR decisions, is used as an initiator since an event significant enough to warrant transfer of command and control is a substantial reduction in the level of safety of the plant.

Activation of the TSC outside of the Emergency Plan in support of the Control Room staff is permissible. Releases that are expected to be limited to a small fraction of the EPA Protective Action Guideline exposure levels are addressed under Initiating Condition GA1.

REF:

*NUMARC/NESP-007, Methodology for Development of Emergency Actions Levels,
Rev. 2, Alert HA6*

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	94 of 96

P. SHIFT MANAGER/PED JUDGMENT

SITE AREA EMERGENCY:

PS1: Other Conditions Existing Which, In the Judgment of the Shift Manager/PED, Warrant Declaration of a Site Area Emergency.

APPLICABILITY:

Operating Conditions

1	2	3	4	5	Def
---	---	---	---	---	-----

EMERGENCY ACTION LEVEL:

In the judgment of the Shift Manager/PED, events are in process or have occurred which involve actual or likely major failures of plant functions needed for protection of the public.

This Emergency Action Level is intended to address unanticipated conditions not addressed explicitly elsewhere but that warrant declaration of an emergency because conditions exist which are believed by the Shift Manager/PED to fall under the emergency class description for a Site Area Emergency.

Radioactive releases are not expected to result in exposure levels which exceed EPA Protective Action Guideline exposure levels except within the site boundary. Radioactive releases to the general public are addressed under Initiating Condition GS1 and GG1.

REF:

NUMARC/NESP-007, Methodology for Development of Emergency Actions Levels, Rev. 2, Site Area Emergency HS3

Attachment 4.1

PROCEDURE NUMBER 13.1.1.A	REVISION 0	PAGE 95 of 96
------------------------------	---------------	------------------



THE UNIVERSITY OF CHICAGO
LIBRARY
540 EAST 57TH STREET
CHICAGO, ILL. 60637

P. SHIFT MANAGER/PED JUDGMENT

GENERAL EMERGENCY:

PG1: Other Conditions Existing Which, In the Judgment of the Shift Manager/PED, Warrant Declaration of a General Emergency.

APPLICABILITY:

Operating Conditions

1	2	3	4	5	Def
---	---	---	---	---	-----

EMERGENCY ACTION LEVEL:

In the judgment of the Shift Manager/PED other conditions exist which indicate:

1) Actual or imminent substantial core degradation or melting with the potential for loss of containment integrity.

OR

2) Potential for uncontrolled radionuclide releases. These releases can reasonably be expected to exceed EPA PAG plume exposure levels outside the site boundary.

This Emergency Action Level is intended to address unanticipated conditions not addressed explicitly elsewhere but that warrant declaration of an emergency because conditions exist which are believed by the Shift Manager/PED to fall under the General Emergency class. Imminent in this context means mitigation strategies and actions are not successful in preventing a challenge to Fuel Clad, Reactor Coolant Pressure Boundary or Primary Containment.

Radioactive releases may exceed EPA Protective Action Guideline exposure levels offsite for more than the immediate site area. Radioactive releases to the general public are addressed under Initiating Condition GS1 and GG1.

REF:

NUMARC/NESP-007, Methodology for Development of Emergency Actions Levels, Rev. 2, General Emergency HG2

Attachment 4.1

PROCEDURE NUMBER	REVISION	PAGE
13.1.1.A	0	96 of 96