

PRIORITY 1
(ACCELERATED RIDS PROCESSING)

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9504070111 DOC.DATE: 94/12/31 NOTARIZED: NO DOCKET #
FACIL:50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397
AUTH.NAME AUTHOR AFFILIATION
PARRISH,J.V. Washington Public Power Supply System
RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: "1994 Annual Environ Operating Rept." W/950331 ltr.

DISTRIBUTION CODE: IE25D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 2
TITLE: Environmental Monitoring Rept (per Tech Specs)

NOTES:

| | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL |
|-----------|---------------------------|---------------------|---------------------------|---------------------|
| | PD4-2 LA | 3 3 | PD4-2 PD | 1 1 |
| | CLIFFORD,J | 1 1 | | |
| INTERNAL: | ACRS | 1 1 | FILE CENTER 301 | 1 1 |
| | NRR/ADAR/PDLR | 1 1 | RGN4 DRSS/RPB | 1 1 |
| | RGN4 FILE 02 | 1 1 | | |
| EXTERNAL: | LITCO AKERS,D | 1 1 | NRC PDR | 1 1 |

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL
DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM
DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 12 ENCL 12

P
R
I
O
R
I
T
Y

1

D
O
C
U
M
E
N
T

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352-0968 • (509) 372-5000

March 31, 1995
GO2-95-063

Docket No. 50-397

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Subject: **WNP-2, OPERATING LICENSE NPF-21**
1994 ANNUAL ENVIRONMENTAL OPERATING REPORT

This letter is submitted per reporting requirements of Section 5.4.1 of the WNP-2 Environmental Protection Plan (EPP; Appendix B to OL).

No design or operational changes or tests in 1994 involved an unreviewed environmental question. The only proposed change for which an environmental evaluation was prepared was a proposed 4.9% increase in WNP-2 thermal power. This proposal, which requires a change to the operating license, was submitted (letter dated July 9, 1993) for review by NRC staff. No non-routine nonradiological reports (within the context of EPP Section 5.4.2) were required for 1994. A summary of the effluent data reported to the State of Washington on the monthly discharge monitoring reports is attached.

Should you have any questions or desire additional information regarding this matter, please call me or D. W. Coleman (509) 377-4342.

Sincerely,



J. V. Parrish (Mail Drop 1023)
Vice-President, Nuclear Operations

JPC/ml

Attachment: Table of 1994 effluent data

cc: LJ Callan - NRC RIV
KE Perkins, Jr. - NRC RIV, Walnut Creek Field Office
NS Reynolds - Winston & Strawn
JW Clifford - NRC
DL Williams - BPA/399
JJ Zeller (EFSEC)
NRC Sr. Resident Inspector - 927N

070038

9504070111 941231
PDR ADDCK 05000397
R PDR

JE25

WNP-2 COOLING WATER BLOWDOWN DISCHARGES, 1994

| Month | Days of Discharge | pH | | TRC (mg/l) | Discharge Volume (millions of gallons) | | |
|--------------|-------------------|-----|------|------------|--|------|-------|
| | | Low | High | | Total | Ave* | Max** |
| Jan | 30 | 7.4 | 8.6 | ≤0.1 | 104.7 | 3.49 | 5.94 |
| Feb | 28 | 7.6 | 8.4 | ≤0.1 | 108.6 | 3.88 | 6.98 |
| Mar | 31 | 7.5 | 8.5 | ≤0.1 | 134.9 | 4.35 | 9.07 |
| Apr | 29 | 7.3 | 8.8 | ≤0.1 | 114.3 | 3.94 | 6.91 |
| May | 27 | 7.7 | 8.8 | ≤0.1 | 58.4 | 2.16 | 2.67 |
| Jun | 23 | 7.3 | 8.2 | ≤0.1 | 56.2 | 2.44 | 2.79 |
| Jul | 30 | 6.7 | 8.4 | ≤0.1 | 72.1 | 2.40 | 3.46 |
| Aug | 31 | 7.6 | 8.7 | ≤0.1 | 64.8 | 2.09 | 5.83 |
| Sep | 30 | 6.9 | 8.8 | ≤0.1 | 46.4 | 1.55 | 5.83 |
| Oct | 31 | 6.9 | 8.7 | ≤0.1 | 55.6 | 1.80 | 3.67 |
| Nov | 30 | 7.5 | 8.7 | ≤0.1 | 57.5 | 1.92 | 3.89 |
| Dec | 31 | 7.8 | 8.5 | ≤0.1 | 56.8 | 1.83 | 3.46 |
| Permit Limit | | 6.5 | 9.0 | 0.1 | | 5.00 | 9.40 |

* Average daily discharge during the month.

** Maximum daily discharge during the month.

