

# CATEGORY 1

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9601190110      DOC. DATE: 95/12/31      NOTARIZED: NO      DOCKET #  
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Power      05000397  
 AUTH. NAME      AUTHOR AFFILIATION  
 EMBREE, D.G.      Washington Public Power Supply System  
 PARRISH, J.V.      Washington Public Power Supply System  
 RECIP. NAME      RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Dec 1995 for WNP-2.W/960111 ltr.

DISTRIBUTION CODE: IE24D      COPIES RECEIVED: LTTR 1 ENCL 1      SIZE: 4  
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD4-2 PD	1    1	CLIFFORD, J	1    1
INTERNAL: ACRS	10    10	AEOD/SPD/RRAB	1    1
<u>FILE CENTER 01</u>	1    1	NRR/DRPM/PECB	1    1
RGN4	1    1		
EXTERNAL: LITCO BRYCE, J H	1    1	NOAC	1    1
NRC PDR	1    1		

NOTE TO ALL "RIDS" RECIPIENTS:  
 PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM OWFN 5D-5 (EXT. 415-2083) TO ELIMINATE YOUR NAME FROM  
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 19 ENCL 19

C  
A  
T  
E  
G  
O  
R  
Y  
  
1  
  
D  
O  
C  
U  
M  
E  
N  
T



WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352

January 11, 1996  
G02-96-008

Docket No. 50-397


U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D. C. 20555

Gentlemen:

Subject: **WNP-2 OPERATING LICENSE NPF-21  
MONTHLY OPERATING REPORT  
DECEMBER 1995**

Transmitted herewith is the Monthly Operating Report for the month of December 1995 as required by Technical Specification 6.9.1.6.

Sincerely,



J. V. Parrish (Mail Drop 1023)  
Vice President, Nuclear Operations

JVP:DGE

cc: LJ Callan, NRC R IV  
NRC Sr. Resident Inspector (927N)  
INPO  
ANI Library  
Utility Data Institute  
BPA (399)

9601190110 951231  
PDR ADDCK 05000397  
R PDR

180073

IF24  
11

120018

**Date:** January 1, 1996

**Date:** January 1, 1996

- Note:** Cumulative Unit Capacity Factors (MDC & DER) are calculated with weighted averages.

## AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO.: 50-397  
UNIT: WNP-2  
DATE: January 1, 1996  
COMPLETED BY: D. G. Embree  
TELEPHONE: (509) 377-8448

REPORT PERIOD: DECEMBER 1995

DAY	AVERAGE DAILY POWER LEVEL (Net MWe)
1	1119
2	681
3	697
4	893
5	1143
6	1147
7	1080
8	670
9	676
10	675
11	676
12	673
13	672
14	676
15	679

DAY	AVERAGE DAILY POWER LEVEL (Net MWe)
16	680
17	682
18	680
19	680
20	681
21	682
22	684
23	684
24	685
25	684
26	682
27	870
28	1151
29	1154
30	1156
31	1158

### INSTRUCTIONS

On this form, list the average daily unit power level in MWe (net) for each day in the reporting month. Compute to the nearest whole megawatt.

These figures will be used to plot a graph for each reporting month. Note that when maximum dependable capacity is used for the net electrical rating of the unit, there may be occasions when the daily average power level exceeds the 100% line (or the restricted power level line). In such cases, the average daily unit power output sheet should be footnoted to explain the apparent anomaly.

# UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO.: 50-397  
 UNIT NAME: WNP-2  
 DATE: January 1, 1996  
 COMPLETED BY: D.G. Embree  
 TELEPHONE: (509) 377-8448

REPORT PERIOD: NOVEMBER 1995

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause and Corrective Action To Prevent Recurrence
95-12	12/01/95	S	72.0	H	5	NA	ZZ	ZZZZZZ	Economic dispatch (load following) at the request of the BPA.
95-13	12/07/95	S	489.9	H	5	NA	ZZ	ZZZZZZ	Economic dispatch (load following) at the request of the BPA.

**SUMMARY:** At the beginning of the month, the plant was operating near full power. The plant was placed in economic dispatch (load following) at the request of the BPA for most of the month. The plant returned to full power operation at the end of the month.

TYPE	REASON	METHOD	SYSTEM & COMPONENT
F - Forced S - Scheduled	A - Equipment Failure B - Maintenance or Test C - Refueling D - Regulatory Restriction	E - Operator Training & License Examination F - Administration G - Operational Error H - Other	1 - Manual 2 - Manual Scram 3 - Auto Scram 4 - Continued 5 - Reduced Load 9 - Other NUREG-0161 Exhibits F & H

15  
14  
13  
12  
11  
10  
9  
8  
7  
6  
5  
4  
3  
2  
1

1