

WNP-2 COOLING WATER BLOWDOWN DISCHARGES, 1995

Month	Days of Discharge	pH		TRC (mg/l)	Discharge Volume (millions of gallons)		
		Low	High		Total	Ave*	Max**
Jan	31	7.9	8.7	≤0.1	49.5	1.60	2.59
Feb	24	7.9	8.6	≤0.1	55.8	2.33	7.86
Mar	30	7.9	8.5	≤0.1	68.5	2.28	5.11
Apr	24	7.6	8.7	≤0.1	58.9	2.45	5.10
May	27	7.3	8.6	≤0.1	53.9	1.99	3.26
Jun	24	7.5	8.7	≤0.1	32.1	1.34	2.38
Jul	29	7.8	8.7	≤0.1	34.4	1.19	2.43
Aug	31	8.0	8.5	≤0.1	31.6	1.02	2.07
Sep	30	8.0	8.7	≤0.1	31.8	1.06	2.20
Oct	30	7.9	8.7	≤0.1	35.5	1.18	2.38
Nov	26	7.8	8.7	≤0.1	34.6	1.33	2.38
Dec	16	7.6	8.4	≤0.1	18.5	1.16	2.81
Permit Limit		6.5	9.0	0.1		5.60	9.40

* Average daily discharge during the month.

** Maximum daily discharge during the month.

