

BEFORE THE  
UNITED STATES NUCLEAR REGULATORY COMMISSION

In the Matter of the Facility Operating License)  
of )  
PUBLIC SERVICE COMPANY OF COLORADO )

Application for Amendment to  
Appendix A of Facility Operating License  
License No. DPR-34

OF THE  
PUBLIC SERVICE COMPANY OF COLORADO  
FOR THE  
FORT ST. VRAIN NUCLEAR GENERATING STATION

This application for Amendment to the Facility  
Operating License and Appendix A of the Facility  
Operating License, License No. DPR-34, is  
submitted for NRC review and approval.

Respectfully submitted,

PUBLIC SERVICE COMPANY OF COLORADO

By A. Clegg Crawford  
Vice President  
Electric Production

KELLY, STANSFIELD & O'DONNELL  
James K. Tarpey  
Mark A. Davidson  
Public Service Company Building  
Denver, Colorado 80202

Attorneys for Applicant



UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter

Public Service Company of Colorado  
Fort St. Vrain Unit No. 1

)  
)  
)  
)

Docket No. 50-267

AFFIDAVIT

A. Clegg Crawford, being first duly sworn, deposes and says: That he is Vice President, Electric Production, of Public Service Company of Colorado, the Licensee herein, that he has read the foregoing Application for Amendment to the Facility Operating License and Appendix A of the Facility Operating License, and knows the contents thereof, and that the statements and matters set forth therein are true and correct to the best of his knowledge, information and belief.

A. Clegg Crawford / by Alvin W. Wrenn  
A. Clegg Crawford  
Vice President  
Electric Production

STATE OF Colorado )  
COUNTY OF Weld )

Subscribe and sworn to before me, a Notary Public on this  
18th day of May, 1993.

Margaret O. Collins  
Notary Public

My commission expires 11-14, 1996

**ATTACHMENT 1**

**TO P-93046**

**SUMMARY OF PROPOSED CHANGES**

## SUMMARY OF PROPOSED CHANGES

<u>DTS Section</u>	<u>Summary of Change</u>
Definition 2.2	Revise Definition of Activated Graphite Blocks to include all in-core graphite components except for defueling elements.
3.1 Bases	Revise Bases for LC 3.1 Applicability, to reflect change in Activated Graphite Block definition. The Bases provides the explanation for excluding defueling elements from the Activated Graphite Block definition.
SR 3.2.3	Revise Reactor Building HEPA filter leakage test acceptance criteria from less than 1 percent to less than 0.05 percent.
SR 3.2.3 Bases	Revise Bases for Reactor Building HEPA filter leak test acceptance criteria to reflect a HEPA filter efficiency of 99 percent versus the current 95 percent.