

CATEGORY 1

REGULAR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9609230116 DOC. DATE: 96/08/31 NOTARIZED: NO DOCKET #
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397
 AUTH. NAME AUTHOR AFFILIATION
 KASKO, B. Washington Public Power Supply System
 SMITH, G.O. Washington Public Power Supply System
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Aug 1996 for WNP-2.
W/960912 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD4-2 PD	1 1	COLBURN, T	1 1
INTERNAL: ACRS	1 1	AEOD/SPD/RRAB	1 1
<u>FILE CENTER</u> 01	1 1	NRR/DRPM/PECB	1 1
RGN4	1 1		
EXTERNAL: LITCO BRYCE, J H	1 1	NOAC	1 1
NRC PDR	1 1		

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T

NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM OWFN 5D-5 (EXT. 415-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 10 ENCL 10



WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352-0968 • (509) 372-5000

September 12, 1996
G02-96-182

Docket No. 50-397

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Gentlemen:

Subject: **WNP-2 OPERATING LICENSE NPF-21
MONTHLY OPERATING REPORT
AUGUST 1996**

Transmitted herewith is the Monthly Operating Report for the month of August 1996 as required by Technical Specification 6.9.1.6.

Respectfully,

G. O. Smith
Plant General Manager
Mail Drop 9270

cc: LJ Callan - NRC RIV
TG Colburn - NRR
KE Perkins, Jr. - NRC RIV, WCFO
NRC Sr. Resident Inspector - 927N
NS Reynolds - Winston & Strawn
INPO
ANI Library
Utility Data Institute
DL Williams - BPA / 399

9609230116 960831
PDR ADDCK 05000397
R PDR

230038

JE24
1/1

OPERATING STATUS REPORT for WNP-2

Date: September 1, 1996

1. Docket: 50-397
2. Reporting Period: **AUGUST 1996** Outage + On-line Hours: 744.0
3. Utility Contact: **Bernice Kasko (509) 377-4473**
4. Licensed Thermal Power (MW_t): 3486
5. Nameplate Rating (Gross MW_e): 1199
6. Design Electrical Rating (Net MW_e): 1153
7. Maximum Dependable Capacity - summer (Gross MW_e): 1153
8. Maximum Dependable Capacity - summer (Net MW_e): 1107
9. If changes occur above since last report, give reasons: none
10. Power to which restricted, if any (Net MW_e): none
11. Reasons for restrictions, if any:

	<u>MONTH</u>	<u>YEAR</u>	<u>CUMULATIVE</u>
12. Report Period Hours	744.0	5,855.0	102,703.2
13. Hours Reactor Critical	744.0	3,307.8	72,943.6
14. Rx Reserve Shutdown Hours	0.0	985.9	1,730.8
15. Hours Generator On-Line	744.0	3,070.6	70,321.1
16. Unit Reserve Shutdown Hours	0.0	997.4	1,956.2
17. Gross Thermal Energy (MWH)	1,665,767	7,804,875	208,262,425
18. Gross Electrical Energy (MWH)	532,550	2,563,200	70,140,680
19. Net Electrical Energy (MWH)	507,382	2,424,801	67,183,119
20. Unit Service Factor	100.0%	52.4%	68.5%
21. Unit Availability Factor	100.0%	69.5%	70.4%
22. Unit Capacity Factor (MDC Net)	61.6%	37.4%	59.9%
23. Unit Capacity Factor (DER Net)	59.1%	35.9%	59.0%
24. Unit Forced Outage Rate	0.0%	3.9%	10.7%
25. Forced Outage Hours	0.0	123.3	8,443.0

26. Shutdowns scheduled over the next 6 months (type, date, duration): None

27. If currently shutdown, estimated startup date:

Note: Cumulative Unit Capacity Factors (MDC & DER) are calculated with weighted averages.

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO.: 50-397

UNIT: WNP-2

DATE: September 1, 1996

COMPLETED BY: B Kasko

TELEPHONE: (509) 377-4473

REPORT PERIOD: AUGUST 1996

DAY	AVERAGE DAILY POWER LEVEL (Net MWe)
1	635
2	647
3	692
4	694
5	697
6	695
7	691
8	689
9	677
10	666
11	686
12	702
13	682
14	677
15	678

DAY	AVERAGE DAILY POWER LEVEL (Net MWe)
16	678
17	682
18	686
19	685
20	679
21	683
22	680
23	678
24	677
25	674
26	673
27	668
28	711
29	679
30	669
31	729

INSTRUCTIONS

On this form, list the average daily unit power level in MWe (net) for each day in the reporting month. Compute to the nearest whole megawatt.

These figures will be used to plot a graph for each reporting month. Note that when maximum dependable capacity is used for the net electrical rating of the unit, there may be occasions when the daily average power level exceeds the 100% line (or the restricted power level line). In such cases, the average daily unit power output sheet should be footnoted to explain the apparent anomaly.

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO.: 50-397
UNIT NAME: WNP-2
DATE: September 1, 1996
COMPLETED BY: B Kasko
TELEPHONE: (509) 377-4473

REPORT PERIOD: AUGUST 1996

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause and Corrective Action To Prevent Recurrence
-----	------	------	-------	--------	--------	------------	--------	-----------	---

None

SUMMARY:

WNP-2 ramped up to 68% power and held there due to problems encountered during testing of the newly installed ASDs and Digital Feedwater Control Systems. At the end of the month WNP-2 was operating at 69% power and continuing with the ASD and Digital Feedwater test plan.

TYPE	REASON	METHOD	SYSTEM & COMPONENT
F - Forced S - Scheduled	A - Equipment Failure B - Maintenance or Test C - Refueling D - Regulatory Restriction	E - Operator Training & License Examination F - Administration G - Operational Error H - Other	1 - Manual 2 - Manual Scram 3 - Auto Scram 4 - Continued 5 - Reduced Load 9 - Other NUREG-0161 Exhibits F & H

