

OPERATING STATUS REPORT
for WNP-2

Date: June 1, 1997

1. Docket: 50-397
2. Reporting Period: MAY 1997
3. Utility Contact: Bernice Kasko (509) 377-4473
4. Design Electrical Rating (Net MW_e): 1153
5. Maximum Dependable Capacity - summer (Gross MW_e): 1153

	<u>MONTH</u>	<u>YEAR</u>	<u>CUMULATIVE</u>
6. Hours Reactor Critical	0.0	2,049.2	77,921.8
7. Hours Generator On-Line	0.0	2,049.2	75,299.3
8. Unit Reserve Shutdown Hours	48.0	552.0	2,508.2
9. Net Electrical Energy (MWH)	-6,342	1,707,985	72,016,260

10. Challenges to safety/relief valves: None

9706190444 970612
PDR ADDCK 05000397
R PDR

UNIT SHUTDOWNS

DOCKET NO.: 50-397
UNIT NAME: WNP-2
DATE: June 1, 1997
COMPLETED BY: B Kasko
TELEPHONE: (509) 377-4473

REPORT PERIOD: MAY 1997

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason (1)	Method (2)	Cause and Corrective Action To Prevent Recurrence
97-012	970419	S	744.0	C	4	Plant entered annual refueling and maintenance outage (R-12) on April 19, 1997.

SUMMARY: The plant entered the month in the annual planned refueling/maintenance outage which began on April 19, 1997.

(1) REASON

A - Equipment Failure
B - Maintenance or Test
C - Refueling
D - Regulatory Restriction

E - Operator Training &
License Examination
F - Administration
G - Operational Error
H - Other

(2) METHOD

1 - Manual
2 - Manual Scram
3 - Auto Scram
4 - Continued
5 - Reduced Load
9 - Other



Handwritten marks and scribbles in the top right corner.

Faint horizontal line of text or markings across the middle of the page.

Faint horizontal line of text or markings near the bottom of the page.

Small handwritten marks or initials in the bottom right corner.

Small handwritten mark or signature near the bottom center.

A single vertical line drawn at the bottom center of the page.