

CATEGORY 1

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9707220092 DOC. DATE: 97/06/30 NOTARIZED: NO DOCKET #
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Power 05000397
 AUTH. NAME AUTHOR AFFILIATION
 KASKO, B. Washington Public Power Supply System
 SMITH, G. O. Washington Public Power Supply System
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for June 1997 for WNP-2.W/970715 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD4-2 PD	1 1	COLBURN, T	1 1
INTERNAL:	ACRS	1 1	AEOD/SPD/RRAB	1 1
	FILE CENTER 01	1 1	NRR/DRPM/PECB	1 1
	OC/DBA/PAD	1 1	RGN4	1 1
EXTERNAL:	LITCO BRYCE, J H	1 1	NOAC	1 1
	NRC PDR	1 1		

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T

NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM OWFN 5D-5 (EXT. 415-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 11 ENCL 11



WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • Richland, Washington 99352-0968

July 15, 1997
G02-97-142

Docket No. 50-397

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Gentlemen:

Subject: **WNP-2 OPERATING LICENSE NPF-21
MONTHLY OPERATING REPORT
JUNE 1997**

Transmitted herewith is the Monthly Operating Report for the month of June 1997 as required by Technical Specification 5.6.4.

In accordance with the guidance contained in Generic Letter 97-02, the format of this report has been amended.

Respectfully,

G. O. Smith
Plant General Manager
Mail Drop 9270

1/1
Tezy

cc: EW Merschoff - NRC RIV
TG Colburn - NRR
KE Perkins, Jr. - NRC RIV, WCFO
NRC Sr. Resident Inspector - 927N
PD Robinson - Winston & Strawn
INPO
ANI Library
Utility Data Institute
DL Williams - BPA / 399

220010
9707220092 970630
PDR ADDCK 05000397
R PDR



OPERATING STATUS REPORT
for WNP-2

Date: July 1, 1997

1. Docket: 50-397
2. Reporting Period: JUNE 1997
3. Utility Contact: Bernice Kasko (509) 377-4473
4. Design Electrical Rating (Net MW_e): 1153
5. Maximum Dependable Capacity - summer (Gross MW_e): 1153

	<u>MONTH</u>	<u>YEAR</u>	<u>CUMULATIVE</u>
6. Hours Reactor Critical	0.0	2,049.2	77,921.8
7. Hours Generator On-Line	0.0	2,049.2	75,299.3
8. Unit Reserve Shutdown Hours	696.0	1,248.0	3,204.2
9. Net Electrical Energy (MWH)	-8,485	1,699,500	72,007,775

10. Challenges to safety/relief valves: See Attached Table

UNIT SHUTDOWNS

DOCKET NO.: 50-397
UNIT NAME: WNP-2
DATE: July 1, 1997
COMPLETED BY: B Kasko
TELEPHONE: (509) 377-4473

REPORT PERIOD: JUNE 1997

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason (1)	Method (2)	Cause and Corrective Action To Prevent Recurrence
97-012	970419	S	720.0	C	4	Plant entered annual refueling and maintenance outage (R-12) on April 19, 1997.

SUMMARY: The plant continued the month in the annual planned refueling/maintenance outage which began on April 19, 1997.

(1) REASON

A - Equipment Failure
B - Maintenance or Test
C - Refueling
D - Regulatory Restriction

E - Operator Training &
License Examination
F - Administration
G - Operational Error
H - Other

(2) METHOD

1 - Manual
2 - Manual Scram
3 - Auto Scram
4 - Continued
5 - Reduced Load
9 - Other

SRV CHALLENGES

<u>COMPONENT</u>	<u>DATE</u>	<u>TYPE</u>	<u>REASON</u>
MS-RV-1B	6/17/97	B	C
MS-RV-1D	6/17/97	B	C
MS-RV-2A	6/17/97	B	C
MS-RV-2B	6/17/97	B	C
MS-RV-2D	6/17/97	B	C
MS-RV-3A	6/17/97	B	C
MS-RV-4A	6/17/97	B	C
MS-RV-4C	6/17/97	B	C
MS-RV-4D	6/17/97	B	C
MS-RV-5C	6/17/97	B	C

Type of Actuation

A = Automatic
 B = Remote Manual
 C = Spring

Reason

A = Overpressure
 B = ADS or other safety
 C = Test
 D = Inadvertent (Accidental/Spurious)
 E = Manual Relief

All of the MSRVs functioned normally. There were no other MSRV challenges during the period.

