

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9902180029 DOC.DATE: 99/01/31 NOTARIZED: NO DOCKET #
 FACIL:50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397
 AUTH.NAME: KASKO,B. AUTHOR AFFILIATION: Washington Public Power Supply System
 SMITH,G.O. Washington Public Power Supply System
 RECIP.NAME: RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Jan 1999 for WNP-2.With 990210
 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 3
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT		COPIES		
	ID CODE/NAME		LTTR	ENCL	
	PD4-2 PD		1	1	
INTERNAL: ACRS			1	1	
	FILE CENTER 01		1	1	
	RGN4		1	1	
EXTERNAL: LITCO BRYCE,J H			1	1	
	NRC PDR		1	1	

MICROFILMED

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 10 ENCL 10

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • Richland, Washington 99352-0968

February 10, 1999
GO2-99-028

Docket No. 50-397


U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Gentlemen:

Subject: **WNP-2 OPERATING LICENSE NPF-21**
 MONTHLY OPERATING REPORT
 JANUARY 1999

Transmitted herewith is the Monthly Operating Report for the month of January 1999 as required by Technical Specification 5.6.4.

Respectfully,


G. O. Smith
Vice President, Generation
Mail Drop 927M

cc: EW Merschoff - NRC RIV
 C Poslusny, Jr. - NRR
 LJ Smith - NRC RIV
 NRC Sr. Resident Inspector - 927N
 PD Robinson - Winston & Strawn
 INPO
 ANI Library
 Utility Data Institute
 DL Williams - BPA / 1399

9902180029 990131
PDR ADDCK 05000397
R PDR

//

Tery

OPERATING STATUS REPORT
for WNP-2

Date: February 1, 1999

1. Docket: 50-397
2. Reporting Period: JANUARY 1999
3. Utility Contact: Bernice Kasko (509) 377-4473
4. Design Electrical Rating (Net MW_e): 1153
5. Maximum Dependable Capacity - summer (Net MW_e): 1107

	<u>MONTH</u>	<u>YEAR</u>	<u>CUMULATIVE</u>
6. Hours Reactor Critical	744.0	744.0	89,585.3
7. Hours Generator On-Line	744.0	744.0	86,618.2
8. Unit Reserve Shutdown Hours	0.0	0.0	3,037.5
9. Net Electrical Energy (MWH)	818,635	818,635	84,148,566
10. Challenges to safety/relief valves:			None

UNIT SHUTDOWNS

DOCKET NO.: 50-397
UNIT NAME: WNP-2
DATE: February 1, 1999
COMPLETED BY: R Kasko
TELEPHONE: (509) 377-4473

REPORT PERIOD: JANUARY 1999

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason (1)	Method (2)	Cause and Corrective Action To Prevent Recurrence
NA						

SUMMARY:

The plant entered the month at 65% power due to economic dispatch. On January 4th the reactor was returned to full power. On January 25th ASD channel 1B/1 tripped off line causing an immediate runback to 95% power, both recirculation pumps were adjusted to run at the same speed resulting in a reduced power level of 89%. The plant ended the month at 100% power

(1) REASON

A - Equipment Failure
B - Maintenance or Test
C - Refueling
D - Regulatory Restriction

E - Operator Training &
License Examination
F - Administration
G - Operational Error
H - Other

(2) METHOD

1 - Manual
2 - Manual Scram
3 - Auto Scram
4 - Continued
5 - Reduced Load
9 - Other