

1998 ANNUAL ENVIRONMENTAL OPERATING REPORT

Attachmest

WNP-2 COOLING WATER BLOWDOWN DISCHARGES, 1998

Month	Days of Discharge	pH		TRC (mg/l)	Total Copper (µg/l)	Discharge Volume (millions of gallons)		
		Low	High			Total	Ave*	Max**
Jan	30	8.1	8.7	<0.1	35	42.0	1.4	2.9
Feb	28	8.3	8.6	<0.1	61	44.8	1.6	3.2
Mar	31	8.2	8.8	<0.1	21	117.8	3.8	6.7
Apr	29	7.4	8.8	<0.1	21	104.4	3.6	7.4
May	27	7.6	8.2	<0.1	24	67.5	2.5	3.0
Jun	25	8.1	8.6	<0.1	50	100.0	4.0	4.9
Jul	30	7.6	8.8	<0.1	68	75.0	2.5	4.8
Aug	31	8.1	8.7	<0.1	77	49.6	1.6	4.6
Sep	29	8.3	8.9	<0.1	51/69	49.3	1.7	2.3
Oct	30	8.3	8.6	<0.1	30	51.0	1.7	5.8
Nov	30	8.2	8.7	<0.1	62	48.0	1.6	2.9
Dec	30	8.0	8.6	<0.1	48	42.0	1.4	2.5
Permit Limit	--	6.5	9.0	0.1	338	--	5.6	9.4

* Average daily discharge during the month.

** Maximum daily discharge during the month.

9903220261 990316
PDR ADCK 05000397
R PDR