

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9904220239 DOC.DATE: 99/03/31 NOTARIZED: NO DOCKET #
FACIL:50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397
AUTH.NAME AUTHOR AFFILIATION
KASKO,B. Washington Public Power Supply System
SMITH,G.O. Washington Public Power Supply System
RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Mar 1999 for WNP-2.With 990413
ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 3
TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	LPD4-2 PD	1 1	CUSHING,J	1 1
INTERNAL:	ACRS	1 1	AEOD/SPD/RRAB	1 1
	FILE CENTER 04	1 1	OC/DBA/PAD	1 1
	RGN4	1 1		
EXTERNAL:	LIMITCO MARSHALL	1 1	NOAC	1 1
	NRC PDR	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 10 ENCL 10

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • Richland, Washington 99352-0968

April 13, 1999
GO2-99-069

Docket No. 50-397


U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Gentlemen:

Subject: **WNP-2 OPERATING LICENSE NPF-21**
 MONTHLY OPERATING REPORT
 MARCH 1999

Transmitted herewith is the Monthly Operating Report for the month of March 1999 as required by Technical Specification 5.6.4.

Respectfully,



G. O. Smith
Vice President, Generation
Mail Drop 927M

cc: EW Merschoff - NRC RIV
 JS Cushing - NRR
 NRC Sr. Resident Inspector - 927N
 PD Robinson - Winston & Strawn
 INPO
 ANI Library 910055
 Utility Data Institute
 DL Williams - BPA / 1399

9904220239 990331
PDR ADDCK 05000397
R PDR

1/1
IE24

OPERATING STATUS REPORT
for WNP-2

Date: April 1, 1999

1. Docket: 50-397
2. Reporting Period: **MARCH 1999**
3. Utility Contact: **Bernice Kasko (509) 377-4473**
4. Design Electrical Rating (Net MW_e): 1153
5. Maximum Dependable Capacity - summer (Net MW_e): 1107

	<u>MONTH</u>	<u>YEAR</u>	<u>CUMULATIVE</u>
6. Hours Reactor Critical	744.0	2,160.0	91,001.3
7. Hours Generator On-Line	744.0	2,160.0	88,034.2
8. Unit Reserve Shutdown Hours	0.0	0.0	3,037.5
9. Net Electrical Energy (MWH)	749,990	2,270,192	85,600,123

10. Challenges to safety/relief valves: None

UNIT SHUTDOWNS

DOCKET NO.: 50-397
UNIT NAME: WNP-2
DATE: April 1, 1999
COMPLETED BY: B Kasko
TELEPHONE: (509) 377-4473

REPORT PERIOD: MARCH 1999

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason (1)	Method (2)	Cause and Corrective Action To Prevent Recurrence
NA						

SUMMARY:

Due to economic dispatch the plant operated at 100% power during the day Monday - Friday and reduced power in the evenings to 85%. During the weekends power was reduced to 65%. Following an increase in power to 88% on March 29, the plant was reduced to 70% power to recover a repaired ASD channel. The plant was returned to 100% power on March 30th.

(1) REASON

A - Equipment Failure
B - Maintenance or Test
C - Refueling
D - Regulatory Restriction

E - Operator Training &
License Examination
F - Administration
G - Operational Error
H - Other

(2) METHOD

1 - Manual
2 - Manual Scram
3 - Auto Scram
4 - Continued
5 - Reduced Load
9 - Other