

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8101060504 DOC. DATE: 80/12/24 NOTARIZED: NO DOCKET #
 FACIL: STN-50-529 Palo Verde Nuclear Station, Unit 2, Arizona Publ 05000529
 AUTH. NAME AUTHOR AFFILIATION
 VAN BRUNT, E.E. Arizona Public Service Co.
 RECIP. NAME RECIPIENT AFFILIATION
 SPENCER, G.S. Region 5, San Francisco, Reactor Construction & Engineer

SUBJECT: Interim deficiency rept re concrete void in unit control bldg sump. Caused by lack of complete concrete consolidation due to reinforcement steel density. Final rept will be submitted by 810315. *m/A*

DISTRIBUTION CODE: B019S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3
 TITLE: Construction Deficiency Report (10CFR50.55E)

NOTES: Standardized Plant.

05000529

ACTION:	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTTR	ENCL		LTTR	ENCL
ACTION:	A/D LICENSNG 04	1	1	MIRAGLIA, F. 05	1	1
	LEE, J. 06	1	1	KERRIGAN, J. 07	1	1
INTERNAL:	AD/RCI/IE 17	1	1	AEOD 18	1	1
	ASLBP/J.HARD	1	1	D/DIR HUM FAC15	1	1
	DIR, DIV OF LIC	1	1	EDO & STAFF 19	1	1
	EQUIP QUAL BR11	1	1	HYD/GEO BR 22	1	1
	I&E 09	1	1	LIC QUAL BR 12	1	1
	MPA 20	1	1	NRC PDR 02	1	1
	OELD 21	1	1	PROG/TST REV 13	1	1
	QA BR 14	1	1	<u>REG FILE</u> 01	1	1
	RUTHERFORD, W. IE	1	1	STANDARDS DEV 21	1	1
	EXTERNAL:	ACRS 16	16	16	LPDR 03	1
	NSIC 08	1	1			

JAN 7 1981

TOTAL NUMBER OF COPIES REQUIRED: LTTR 40 ENCL 40



ARIZONA



PUBLIC SERVICE COMPANY

P. O. BOX 21666 • PHOENIX, ARIZONA 85036

December 24, 1980
ANPP-16957-BSK/JAR

U. S. Nuclear Regulatory Commission
Region V
Walnut Creek Plaza - Suite 202
1990 North California Boulevard
Walnut Creek, California 94596

Attention: Mr. G. S. Spencer, Chief
Reactor Construction and
Engineering Support Branch

Subject: A 50.55(e) Potentially Reportable Deficiency Relating
to a Concrete Void in Unit 2 Control Building Sump
Interim Report
File: 80-019-026
D.4.33.2

Reference: Telephone Conversation between J. Eckhardt and
B. S. Kaplan on November 25, 1980 (DER 80-37)

Dear Sir:

The NRC was notified of a potentially reportable deficiency in the referenced telephone conversation. At that time, it was estimated that a determination of reportability would be made within thirty (30) days.

Due to the extensive investigation and evaluation required, an interim report is attached. It is now expected that this information will be finalized by March 15, 1981, at which time a complete report will be submitted.

Very truly yours,

E. E. Van Brunt, Jr.
APS Vice President
Nuclear Projects
ANPP Project Manager

EEVBJr/BSK:skc

Attachment

DISTRIBUTION
SERVICES UNIT

1981 JAN 25 PM 2:40

US NRC
DISTRIBUTION SERVICES
BRANCH

Boia
5-11

8101060504 S

U. S. Nuclear Regulatory Commission
Region V
Attention: Mr. G. S. Spencer, Chief
ANPP-16957-BSK/JAR
December 24, 1980
Page 2

cc: Victor Stello, Jr., Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

A. C. Gehr
Snell & Wilmer

R. L. Robb
D. B. Fasnacht
B. S. Kaplan
W. E. Ide
J. M. Allen
A. C. Rogers
W. H. Wilson
W. G. Bingham
W. J. Stubblefield
R. L. Patterson
R. W. Welcher
R. M. Grant
D. R. Hawkinson
J. A. Brand

INTERIM REPORT
POTENTIAL REPORTABLE DEFICIENCY
ARIZONA PUBLIC SERVICE COMPANY (APS)
PVNGS UNIT #2

I. Potential Problem

A concrete void in Unit 2 Control Building sump exists in the basemat adjacent to the West wall of the sump. The void retains water when the sump is filled and releases water when the sump is emptied; however, the size of the void has not been determined. The cause is attributed to lack of complete concrete consolidation due to reinforcement steel density. This condition was not found and corrected during inspection and acceptance of the concrete placement because no surface indication was apparent.

II. Approach To and Status Of Proposed Resolution

The condition is to be repaired by chipping existing concrete from the area of the void to facilitate inspection and to determine the type and extent of concrete repair required. Once the size and extent of the void is determined, a decision on its safety significance can be made.

III. Projected Completion of Corrective Action and Submittal of
Date of the Final Report

The evaluation and necessary repair are forecast to be completed by March 1, 1981.

The final report will be submitted by March 15, 1981.

