REGULATO[illegible] INFORMATION DISTRIBUTION [illegible]STEM (RIDS)

ACCESSION NBR:8304190507 DOC.DATE: 83/04/15 NOTARIZED: NO DOCKET #
FACIL:STN-50-528 Palo Verde Nuclear Station, Unit 1, Arizona Publi 05000528
STN-50-529 Palo Verde Nuclear Station, Unit 2, Arizona Publi 05000529
STN-50-530 Palo Verde Nuclear Station, Unit 3, Arizona Publi 05000530
AUTH.NAME AUTHOR AFFILIATION
VAN BRUNT,E.E. Arizona Public Service Co.
RECIP.NAME RECIPIENT AFFILIATION
KNIGHTON,G. Licensing Branch 3

SUBJECT: Advises that check valve SG-V044 will not be relocated from Train B motor-driven auxiliary feedwater pump room (AFPR) to Train A turbine-driven AFPR per 810306 commitment.Steam line pipe stresses do not exceed recommendation.

DISTRIBUTION CODE: B001S COPIES RECEIVED:LTR / ENCL / SIZE: /
TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES:Standardized plant. 05000528
Standardized plant. 05000529
Standardized plant. 05000530

	RECIPIENT ID CODE/NAME	COPIES LTTR	COPIES ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR	COPIES ENCL
	NRR/DL/ADL	1	0	NRR LB3 BC	1	0
	NRR LB3 LA	1	0	LICITRA,E. 01	1	1
INTERNAL:	ELD/HDS3	1	0	IE FILE	1	1
	IE/DEPER/EPB 36	3	3	IE/DEPER/IRB 35	1	1
	IE/DEQA/QAB 21	1	1	NRR/DE/AEAB	1	0
	NRR/DE/CEB 11	1	1	NRR/DE/EHEB	1	1
	NRR/DE/EQB 13	2	2	NRR/DE/GB 28	2	2
	NRR/DE/HGEB 30	1	1	NRR/DE/MEB 18	1	1
	NRR/DE/MTEB 17	1	1	NRR/DE/SAB 24	1	1
	NRR/DE/SGEB 25	2	2	NRR/DHFS/HFEB40	1	1
	NRR/DHFS/LQB 32	1	1	NRR/DL/SSPB	1	0
	NRR/DSI/AEB 26	1	1	NRR/DSI/ASB	1	1
	NRR/DSI/CPB 10	1	1	NRR/DSI/CSB 09	1	1
	NRR/DSI/ICSB 16	1	1	NRR/DSI/METB 12	1	1
	NRR/DSI/PSB 19	1	1	NRR/DSI/RAB 22	1	1
	NRR/DSI/RSB 23	1	1	REG FILE 04	1	1
	RGN5	3	3	RM/DDAMI/MIB	1	0
EXTERNAL:	ACRS 41	6	6	BNL(AMDTS ONLY)	1	1
	DMB/DSS (AMDTS)	1	1	FEMA-REP DIV 39	1	1
	LPDR 03	1	1	NRC PDR 02	1	1
	NSIC 05	1	1	NTIS	1	1

TOTAL NUMBER OF COPIES REQUIRED: LTTR 54 ENCL 47

Arizona Public Service Company
P.O. BOX 21666 • PHOENIX, ARIZONA 85036

April 15, 1983
ANPP-23510 - WFQ/RJP

Director of Nuclear Reactor Regulation
Attention: Mr. George Knighton, Chief
Licensing Branch No. 3
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Subject: Palo Verde Nuclear Generating Station (PVNGS) Units 1, 2 and 3
Docket Nos. STN-50-528/529/530
File: 83-056-026; G.1.01.10

Reference: Letter from E. E. Van Brunt, Jr., APS, to H. R. Denton, NRC, dated March 6, 1981.

Dear Mr. Knighton:

The referenced letter provided responses to open items from the PVNGS Auxiliary Feedwater System Independent Design Review, which was held in Phoenix on August 21 and 22, 1981.

Page 2 of the attachment to the Referenced letter states that check valve SG-V044 is being relocated from the Train B pump room to the Train A turbine-driven Auxiliary Feedwater pump room.

We have since evaluated this steam line in accordance with the criteria of Branch Technical Position (BTP) MEB 3-1, B.2.C, and found that the pipe stresses do not exceed the $0.4(1.2S_h t+S_A)$ recommendation at any point in the Train B motor-driven Auxiliary Feedwater pump room. We have also evaluated this pipe in accordance with Appendix A of BTP APCSB3-1 and do not consider it to be a high-energy or moderate-energy line.

Based on these evaluations the necessary requirements are met without moving this check valve. Therefore, we are changing our previous commitment, and the present design will not be changed.

Very truly yours,

E. E. Van Brunt

E. E. Van Brunt, Jr.
APS Vice President,
Nuclear Projects
ANPP Project Director

B001

EEVB/RJP/sp

cc: E. A. Licitra A. C. Gehr G. Wermiel (NRC)