REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8410230313 DOC.DATE: 84/10/18 NOTARIZED: YES DOCKET #
FACIL:STN-50-528 Palo Verde Nuclear Station, Unit 1, Arizona Publi 05000528
STN-50-529 Palo Verde Nuclear Station, Unit 2, Arizona Publi 05000529
STN-50-530 Palo Verde Nuclear Station, Unit 3, Arizona Publi 05000530

AUTH.NAME AUTHOR AFFILIATION
VAN BRUNT,E.E. Arizona Public Service Co.
RECIP.NAME RECIPIENT AFFILIATION
KNIGHTON,G. Licensing Branch 3

SUBJECT: Forwards proposed FSAR change to Section 1.8 re exception to Reg Guide 1.83, "Inservice Insp of PWR Steam Generator Tubes," to perform baseline insp prior to field hydrostatic test.

DISTRIBUTION CODE: B001D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 5
TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES:Standardized plant. 05000528
Standardized plant. 05000529
Standardized plant. 05000530

	RECIPIENT ID CODE/NAME	COPIES LTTR	COPIES ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR	COPIES ENCL
	NRR/DL/ADL	1	0	NRR LB3 BC	1	0
	NRR LB3 LA	1	0	LICITRA,E 01	1	1
INTERNAL:	ADM/LFMB	1	0	ELD/HDS3	1	0
	IE FILE	1	1	IE/DEPER/EPB 36	3	3
	IE/DEPER/IRB 35	1	1	IE/DQASIP/QAB21	1	1
	NRR ROE,M.L.	1	1	NRR/DE/AEAB	1	0
	NRR/DE/CEB 11	1	1	NRR/DE/EHEB	1	1
	NRR/DE/EQB 13	2	2	NRR/DE/GB 28	2	2
	NRR/DE/MEB 18	1	1	NRR/DE/MTEB 17	1	1
	NRR/DE/SAB 24	1	1	NRR/DE/SGEB 25	1	1
	NRR/DHFS/HFEB40	1	1	NRR/DHFS/LQB 32	1	1
	NRR/DHFS/PSRB	1	1	NRR/DL/SSPB	1	0
	NRR/DSI/AEB 26	1	1	NRR/DSI/ASB	1	1
	NRR/DSI/CPB 10	1	1	NRR/DSI/CSB 09	1	1
	NRR/DSI/ICSB 16	1	1	NRR/DSI/METB 12	1	1
	NRR/DSI/PSB 19	1	1	NRR/DSI/RAB 22	1	1
	NRR/DSI/RSB 23	1	1	REG FILE 04	1	1
	RGN5	3	3	RM/DDAMI/MIB	1	0
EXTERNAL:	ACRS 41	6	6	BNL(AMDTS ONLY)	1	1
	DMB/DSS (AMDTS)	1	1	FEMA-REP DIV 39	1	1
	LPDR 03	1	1	NRC PDR 02	1	1
	NSIC 05	1	1	NTIS	1	1

TOTAL NUMBER OF COPIES REQUIRED: LTTR 55 ENCL 47

Arizona Public Service Company

Director of Nuclear Reactor Regulation
Attention: Mr. George Knighton, Chief
Licensing Branch No. 3
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

October 18, 1984
ANPP-30889 TFQ/JYM

Subject: Palo Verde Nuclear Generating Station (PVNGS)
Units 1, 2 and 3
Docket Nos. STN-50-528/529/530
Exception to R. G. 1.83
File: 84-056-026; G.1.01.10

Dear Mr. Knighton:

Attached is a proposed FSAR change to Section 1.8 concerning an exception to Regulatory Guide 1.83, "Inservice Inspection of Pressurized Water Reactor Steam Generator Tubes."

The exception is to perform a base line inspection prior to the field hydrostatic test in lieu of after field hydrostatic testing.

If you have any questions on this matter, please contact me.

Very truly yours,

E. E. Van Brunt

E. E. Van Brunt, Jr.
APS Vice President
Nuclear Production
ANPP Project Director

EEVBJr/JYM/bg
cc:
E. A. Licitra w/a
A. C. Gehr w/a
R. Zimmerman w/a

B001
1/1

ANPP-30889

STATE OF ARIZONA)
) ss.
COUNTY OF MARICOPA)

I, Edwin E. Van Brunt, Jr., represent that I am Vice President, Nuclear Production of Arizona Public Service Company, that the foregoing document has been signed by me on behalf of Arizona Public Service Company with full authority to do so, that I have read such document and know its contents, and that to the best of my knowledge and belief, the statements made therein are true.

Edwin E. Van Brunt

Edwin E. Van Brunt, Jr.

Sworn to before me this 17th day of October, 1984.

Nora E. Meador
Notary Public

My Commission Expires:
My Commission Expires April 6, 1987

bcc:
E. E. Van Brunt
D. B. Karner
A. C. Rogers
W. E. Ide
W. F. Quinn
T. F. Quan
M. F. Hodge
S. R. Frost
LCTS Coordinator
T. G. Woods
K. W. Gross
J. E. Kirby
J. M. Allen
J. R. Bynum
D. R. Canady
O. J. Zeringue
J. D. Houchen
R. Ferguson
L. Papworth
B. Strickler
B. Simko
W. H. Wilson
W. G. Bingham
D. Keith
S. Shepherd
C. Ferguson
M. Barnoski

All With Attachments

REGULATORY GUIDE 1.83: Inservice Inspection of Pressurized Water Reactor Steam Generator Tubes (Revision 0, June 1974)

RESPONSE

Refer to CESSAR Section 1.8 and to section ~~5.2.4.~~

INSERT A

REGULATORY GUIDE 1.84: Design and Fabrication Code Case Acceptability ASME Section III Division 1 (Revision 15, May 1979)

RESPONSE

11 The position of Regulatory Guide 1.84 is accepted (refer to table 5.2-2).

REGULATORY GUIDE 1.85: Materials Code Case Acceptability ASME Section III Division 1 (Revision 15, May 1979)

RESPONSE

11 The position of Regulatory Guide 1.85 is accepted (refer to table 5.2-3).

REGULATORY GUIDE 1.86: Termination of Operating Licenses for Nuclear Reactors (Revision 0, June 1974)

RESPONSE

The position of Regulatory Guide 1.86 is accepted.

REGULATORY GUIDE 1.87: Construction Criteria for Class 1 Components in Elevated Temperature Reactors (Revision 0, June 1974)

INSERT A

The position of Regulatory Guide 1.83 is accepted (refer to CESSAR Section 1.8 and to section 5.2.4) except that for compliance with Position C.3.a of the regulatory guide, the inspection shall be performed prior to the field hydrostatic test.