

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8412110309 DOC. DATE: 84/12/05 NOTARIZED: NO DOCKET #
 FACIL: STN-50-528 Palo Verde Nuclear Station, Unit 1, Arizona Publ 05000528
 STN-50-529 Palo Verde Nuclear Station, Unit 2, Arizona Publ 05000529
 STN-50-530 Palo Verde Nuclear Station, Unit 3, Arizona Publ 05000530
 AUTH. NAME: AUTHOR AFFILIATION
 VAN BRUNT, E.E. Arizona Public Service Co.
 RECIP. NAME: RECIPIENT AFFILIATION
 KNIGHTON, G.W. Licensing Branch 3

SUBJECT: Advises that to ensure adequate backup fire protection water suppression capability, design will be changed to add valve & piping to isolate secondary suppression hose stations from primary suppression sys. Completion expected by 850401.

DISTRIBUTION CODE: B002D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: Licensing Submittal: Fire Protection

NOTES: Standardized plant. 05000528
 Standardized plant. 05000529
 Standardized plant. 05000530

RECIPIENT		COPIES		RECIPIENT		COPIES	
ID	CODE/NAME	LTTR	ENCL	ID	CODE/NAME	LTTR	ENCL
	NRR LB3 BC	1	1		LICITRA, E	01	1
INTERNAL:	ACRS	10	6		ADM/LFMB		1
	ELD/HDS3		1		IE FILE	07	1
	NRR/DE/CEB	06	2		NRR/DSI/ASB		1
	<u>REG. FILE</u>	04	1		RGNS		1
EXTERNAL:	LPDR	03	1		NRC PDR	02	1
	NSIC	05	1		NTIS		1

TOTAL NUMBER OF COPIES REQUIRED: LTTR 20 ENCL 18



Arizona Public Service Company

ANPP-31335-EEVB/WFQ/DKN
December 5, 1984

Director of Nuclear Reactor Regulation
Attention: Mr. George W. Knighton, Chief
Licensing Branch No. 3
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: Palo Verde Nuclear Generating Station (PVNGS)
Units 1, 2 and 3
Docket Nos. STN-50-528/529/530
Fire Protection Modification and Compensatory Measures
File: 84-056-026; G.1.01.10

Dear Mr. Knighton:

Appendix A to 10CFR50 requires the fire protection system to have adequate capacity and capability. Branch Technical Position APCSB 9.5-1 Appendix A, interprets this to mean that no single failure should disable the primary and secondary suppression system. At the 120- and 140-foot elevations in the Auxiliary Building (Fire Zones 47B, 52D, 56B, 56C, 57I, and 57J), the primary and secondary systems are interconnected and the nearest non-interconnected hose station is in excess of 150 feet away. Accordingly, due to the long hose length necessary to provide backup suppression capability, the intent of the BTP is not met.

To ensure adequate backup fire protection water suppression capability, the PVNGS design will be changed to add a valve and piping that will isolate the secondary suppression hose stations from the primary suppression system at the 120- and 140-foot elevation. In the interim, the fire detection system will be operational and whenever the primary suppression system is not available, backup fire suppression water will be provided from the nearest active hose station in accordance with Technical Specification 3/4.7.11.4. Thus, even in the unlikely event of a piping failure and a fire, suppression capability would be maintained by compensatory measures. This design change is expected to be completed by April 1, 1985.

Please contact William Quinn on my staff should you have questions regarding this request.

Very truly yours,

8412110309 841205
PDR ADOCK 05000528
F PDR

EEVBjr/DKN/no

cc: E.A. Licitra
D.J. Kubicki
P. Qualls
A.C. Gehr
R.P. Zimmerman

E.E. Van Brunt, Jr.
E.E. Van Brunt, Jr.
APS Vice President
Nuclear Production
ANPP Project Director

*Booz
1/0*

