

# REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8504150314 DOC. DATE: 85/04/11 NOTARIZED: YES DOCKET #  
 FACIL: STN-50-528 Palo Verde Nuclear Station, Unit 1, Arizona Public 05000528  
 AUTH. NAME AUTHOR AFFILIATION  
 VAN BRUNT, E.E. Arizona Public Service Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 DENTON, H.R.

SUBJECT: Application for amend to License NPF-34, revising Tech Spec  
 3/4.3.2 to correct containment spray pump response times  
 identified in Item 3e of Table 3.3-5, "ESF Response Times."  
 Expeditious review requested.

DISTRIBUTION CODE: B001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 241  
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES: Standardized plant.  
 OL: 12/31/84

05000528

RECIPIENT		COPIES		RECIPIENT		COPIES	
ID	CODE/NAME	LTTR	ENCL	ID	CODE/NAME	LTTR	ENCL
NRR/DL/ADL		1	0	NRR LB3 BC		1	0
NRR LB3 LA		1	0	LICITRA, E	01	1	1
INTERNAL: ACRS	41	6	6	ADM/LFMB		1	0
ELD/HDS3		1	0	IE FILE		1	1
IE/DEPER/EPB	36	1	1	IE/DQAVT/QAB21		1	1
NRR ROE, M.L		1	1	NRR/DE/AEAB		1	0
NRR/DE/CEB	11	1	1	NRR/DE/EHEB		1	1
NRR/DE/eqB	13	2	2	NRR/DE/GB	28	2	2
NRR/DE/MEB	18	1	1	NRR/DE/MTEB	17	1	1
NRR/DE/SAB	24	1	1	NRR/DE/SGEB	25	1	1
NRR/DHFS/HFEB40		1	1	NRR/DHFS/LQB	32	1	1
NRR/DHFS/PSRB		1	1	NRR/DL/SSPB		1	0
NRR/DSI/AEB	26	1	1	NRR/DSI/ASB		1	1
NRR/DSI/CPB	10	1	1	NRR/DSI/CSB	09	1	1
NRR/DSI/ICSB	16	1	1	NRR/DSI/METB	12	1	1
NRR/DSI/PSB	19	1	1	NRR/DSI/RAB	22	1	1
NRR/DSI/RSB	23	1	1	REG FILE	04	1	1
RGN5		3	3	RM/DOAMI/MIB		1	0
EXTERNAL: BNL (AMDTs ONLY)		1	1	DMB/DSS (AMDTs)		1	1
LPDR	03	1	1	NRC PDR	02	1	1
NSIC	05	1	1	PNL GRUEL, R		1	1

TOTAL NUMBER OF COPIES REQUIRED: LTTR 51 ENCL 43





## Arizona Nuclear Power Project

P.O. BOX 52034 • PHOENIX, ARIZONA 85072-2034

ANPP-32373-EEVB/WFQ

April 11, 1985

Director of Nuclear Regulation  
Mr. Harold R. Denton  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Subject: Palo Verde Nuclear Generating Station (PVNGS)  
Units 1, 2, and 3  
Docket Nos. STN 50-528 (License No. NPF-34)/529/530  
Request for License Technical Specification Correction  
File: 85-056-026; G.1.01.10

Dear Mr. Denton:

The purpose of this letter is to request an emergency Technical Specification change to correct the Containment Spray Pump response times identified in Technical Specification 3/4.3.2, Table 3.3-5, Item 3e, as shown on the attachment. On April 9, 1985 APS identified an error in the calculation of this value which decreased the required response times by six seconds. These times should read:

e. Containment Spray Pump  $\leq 33^*/23^{**}$

This correction is required to make the Technical Specification consistent with the Safety Analysis as previously reviewed by your staff and does not represent a decrease in any margin of safety as described in the Safety Analysis.

This correction has been reviewed by the Plant Review Board and Plant Manager. It was discussed with Mr. G. Knighton et al, on April 10 and 11, 1985 via telecon.

Unit 1 is expected to be ready for initial entry into Mode 4 on or about April 15, 1985. In support of this evolution, you are requested to provide concurrence for this emergency Technical Specification change request as soon as possible. If you have any questions, please contact Joe Bynum at (602) 932-5300, extension 6300.

Very truly yours,

*E E Van Brunt / DBK*  
E. E. Van Brunt, Jr.  
Executive Vice President  
Project Director

8504150314 850411  
PDR ADDCK 05000528 PDR

EEVB/KWG/jdf  
Attachment

cc: E. A. Licitra (w/attachment)  
G. W. Knighton (w/attachment)  
P. R. Zimmerman (w/attachment)  
A. C. Gehr (w/attachment)

Boo/  
1/1

STATE OF ARIZONA     )  
                              ) ss.  
COUNTY OF MARICOPA)

I, Donald Karner, represent that I am Assistant Vice President, Nuclear Production of Arizona Public Service Company, that the foregoing document has been signed by me on behalf of Arizona Public Service Company with full authority to do so, that I have read such document and know its contents, and that to the best of my knowledge and belief, the statements made therein are true.

Donald Karner  
Donald Karner

Sworn to before me this 11<sup>th</sup> day of April, 1985

Louis A. Armstrong  
Notary Public

My Commission Expires:

4-15-88

