

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8604230257 DDC. DATE: 86/04/18 NOTARIZED: NO DOCKET #
 FACIL: STN-50-528 Palo Verde Nuclear Station, Unit 1, Arizona Publi 05000528
 STN-50-529 Palo Verde Nuclear Station, Unit 2, Arizona Publi 05000529
 STN-50-530 Palo Verde Nuclear Station, Unit 3, Arizona Publi 05000530
 AUTH. NAME AUTHOR AFFILIATION
 VAN BRUNT, E. E. Arizona Nuclear Power Project (formerly Arizona Public Serv
 RECIP. NAME RECIPIENT AFFILIATION
 KNIGHTON, G. W. PWR Project Directorate 7

SUBJECT: Provides resolution schedule for masonry wall evaluation.
 Acceptable analysis & performance of addl testing or
 implementation of design mods on masonry wall will be
 provided by 861222.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: OR Submittal: General Distribution

NOTES: Standardized plant. 05000528
 Standardized plant. 05000529
 Standardized plant. 05000530

RECIPIENT		COPIES		RECIPIENT		COPIES	
ID	CODE/NAME	LTTR	ENCL	ID	CODE/NAME	LTTR	ENCL
PWR-B	ADTS	1	0	PWR-B	EB	1	1
PWR-B	PEICSB	2	2	PWR-B	FOB	1	1
PWR-B	PD7 PD 01	5	5	LICITRA, E		1	1
PWR-B	PEICSB	1	1	PWR-B	RSB	1	1
INTERNAL:	ACRS 09	6	6	ADM/LFMB		1	0
	ELD/HDS3	1	0	NRR/DHET/TSCB		1	1
	NRR/ORAS	1	0	REG FILE 04		1	1
	RGN5	1	1				
EXTERNAL:	24X	1	1	EG&G BRUSKE, S		1	1
	LPDR 03	1	1	NRC PDR 02		1	1
	NSIC 05	1	1				

No encls Rec'd

TOTAL NUMBER OF COPIES REQUIRED: LTTR 30 ENCL 26

[illegible]

FILE: OR Subm 447: General Distribution
DISTRIBUTION CODE: 4470 COPIES RECEIVED

6-300000		.fnsfq	baxibrbunqz	10710M
95000000		.fnsfq	baxibrbunqz	
05000000		.fnsfq	baxibrbunqz	

[illegible]



Arizona Nuclear Power Project

P.O. BOX 52034 • PHOENIX, ARIZONA 85072-2034

April 18, 1986

ANPP-36301-EEVB/WFQ/98.05

Director of Nuclear Reactor Regulation
Attention: Mr. George W. Knighton, Project Director
PWR Project Directorate #7
Division of Pressurized Water Reactor Licensing - B
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: Palo Verde Nuclear Generating Station (PVNGS)
Units 1, 2 and 3
Docket Nos. STN 50-528 (License NPF-41)
STN 50-529 (License NPF-46)
STN 50-530

Masonry Walls
File: 86-056-026

Reference: Letter from E. E. Van Brunt, Jr., ANPP, to G. W. Knighton,
NRC, dated April 16, 1986 (ANPP-36153). Subject: Evaluation of
Masonry Walls

Dear Mr. Knighton:

On April 16, 1986, ANPP provided a Masonry Wall Evaluation for your information. Since additional confirmatory items remain regarding the capability of some of these walls, ANPP hereby provides the following resolution schedule:

For Units 1 and 2, ANPP will provide an acceptable analysis or perform additional testing or implement design modifications on the masonry walls by December 22, 1986. For Unit 3, these activities will be completed prior to initial criticality. In the interim, until such time as these activities are accomplished, ANPP will take compensatory measures. Based on use of assumptions provided by NRC, earthquake induced stresses and displacements will remain at or below the appropriate allowable values as long as the ground acceleration does not exceed 0.05g. Therefore for any earthquake registered at the Palo Verde site having accelerations equal to or greater than 0.05g, ANPP will thereafter commence a normal shutdown to mode 3 of the operating units and perform an inspection of the subject masonry block walls and associated safety related attachments. Prior to resuming operations or ceasing the shutdown, ANPP will assure that no functional damage has occurred to those safety related attachments.

Very truly yours,

EE Van Brunt Jr./JH

E. E. Van Brunt, Jr.
Executive Vice President
Project Director

EEVB/WFQ/rw
Attachments

cc: E. A. Licitra
R. P. Zimmerman
A. C. Gehr

8604230257 860418
PDR ADDCK 05000528
P PDR



*A001
1/0* *No Encls
Rec'd*

