

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8703170105 DOC. DATE: 87/03/11 NOTARIZED: NO DOCKET #
 FACIL: STN-50-530 Palo Verde Nuclear Station, Unit 3, Arizona Publi 05000530
 AUTH. NAME AUTHDR AFFILIATION
 HAYNES, J. G. Arizona Nuclear Power Project (formerly Arizona Public Serv
 RECIP. NAME RECIPIENT AFFILIATION
 KNIGHTON, G. W. PWR Project Directorate 7

SUBJECT: Informs that only radiation monitoring equipment required by
 Tech Specs will be tested prior to fuel load due to
 unavailability of parts. List of affected monitors encl.

DISTRIBUTION CODE: B001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES: Standardized plant. M. Davis, NRR: 1Cy. 05000530

RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
	LTTR	ENCL		LTTR	ENCL
PWR-B EB	1	1	PWR-B PEICSB	2	2
PWR-B FQB	1	1	PWR-B PD7 LA	1	1
PWR-B PD7 PD	1	1	LICITRA, E 04	2	2
PWR-B PEICSB	1	1	PWR-B RSB	1	1

INTERNAL: ACRS 41	6	6	ADM/LFMB	1	0
IE FILE	1	1	IE/DEPER/EPB 36	1	1
IE/DGAVT/GAB 21	1	1	NRR BWR ADTS	1	0
NRR PWR-B ADTS	1	0	NRR ROE, M. L	1	1
NRR/DHET/MTB	1	1	OGC/HDS1	1	0
<u>REG FILE</u> 01	1	1	RM/DDAMI/MIB	1	0
EXTERNAL: BNL (AMDTs ONLY)	1	1	DMB/DSS (AMDTs)	1	1
LPDR 03	1	1	NRC PDR 02	1	1
NSIC 05	1	1	PNL GRUEL, R	1	1

NOTES: 1 1

Investigation of system to establish list of affected monitors and
Test Spect will be tested prior to fuel load up to
to determine that only radiation monitoring equipment reported by

TITLE: Proposed Submission
 PSAT: For Amde & Related
 DISTRIBUTION CODE: BOLD
 COPIES RECEIVED: LTR
 ENCL: 1
 SIZE: 1

05000000

[illegible]

1991



Arizona Nuclear Power Project

P.O. BOX 52034 • PHOENIX, ARIZONA 85072-2034

March 11, 1987
161-00062-JGH/JKR

Director of Nuclear Reactor Regulation
Attention: Mr. George W. Knighton, Project Director
PWR Project Directorate #7
Division of Pressurized Water Reactor Licensing - B
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: Palo Verde Nuclear Generating Station (PVNGS)
Unit 3
Docket No. STN 50-530
Radiation Monitoring System (RMS)
File: 87-D-056-026

Reference: Letter dated January 21, 1987, to G. W. Knighton, NRC, from J. G. Haynes, ANPP; (ANPP-39767-JGH/JKR/98/05) Subject: Radiation Monitoring System (RMS).

Dear Mr. Knighton:

The ANPP project goal for the Unit 3 Radiation Monitoring System (RMS) has been to complete all Phase I preoperational testing prior to fuel load. We are working to an augmented schedule and had been progressing firmly towards that goal. However, we have experienced major problems due to the availability of parts.

As a result of these problems, we are forced to adjust our goal. Our schedule now entails the completed testing of only those radiation monitoring equipment required by the Technical Specifications prior to fuel load.

The attachment to this letter lists those monitors that will not be tested prior to fuel load. These monitors will be tested prior to initial criticality. This change does not present a safety concern, and therefore no compensatory measures are required.

Those monitors not required by Technical Specifications and not listed in the in the attachment have been satisfactorily tested.

If you have any further questions, please contact Mr. W. F. Quinn of my staff.

Very truly yours,

J. G. Haynes, Vice President
Nuclear Production Department

JGH/CW/dgd

cc: O. M. De Michele
E. A. Licitra
A. C. Gehr

E. E. Van Brunt, Jr.
R. P. Zimmerman

8703170105 870311
PDR ADOCK 05000530
A PDR

BOO1
1/1

ATTACHMENT

<u>Monitor Number</u>	<u>Description</u>
RU-2	Essential Cooling Water Monitor
RU-7	Auxiliary Steam Condensate Monitor
RU-9	Auxiliary Building Lower Level Vent Monitor
RU-10	Auxiliary Building Upper Level Vent Monitor
RU-14	Radwaste Building Vent Exhaust Monitor
RU-15	Waste Gas Vent Exhaust Monitor
RU-27,28	Waste Solidification Area Monitors
RU-150	Primary Coolant Monitor
RU-204	Process Radiation Monitor
RU-265	Gas Stripper Monitor

