

# REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8712140278 DOC. DATE: 87/11/26 NOTARIZED: NO DOCKET #  
 FACIL: STN-50-530 Palo Verde Nuclear Station, Unit 3, Arizona Publi 05000530  
 AUTH. NAME AUTHOR AFFILIATION  
 VAN BRUNT, E. E. Arizona Nuclear Power Project (formerly Arizona Public Serv  
 RECIP. NAME RECIPIENT AFFILIATION  
 MARTIN, J. B. Region 5, Ofc of the Director

SUBJECT: Certifies that Item 1.a of Attachment 1 re operability of  
 all required sys for initial entry into Mode 1 completed.

DISTRIBUTION CODE: IE01D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1  
 TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response


NOTES: Standardized plant.

05000530

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD5 PD	1	LICITRA, E	2
	DAVIS, M	2		2
INTERNAL:	ACRS	2	AEDD	1
	DEDRO	1	NRR MORISSEAU, D	1
	NRR/DLPQ/PEB	1	NRR/DOEA DIR	1
	NRR/DREP/EPB	1	NRR/DREP/RPB	2
	NRR/DRIS DIR	1	NRR/PMAS/ILRB	1
	DE LIEBERMAN, J	1	OGC/HDS1	1
	REG FILE	1	RES DEPY GI	1
	RGNS FILE 01	1		
EXTERNAL:	LPDR	1	NRC PDR	1
	NSIC	1		
NOTES:		1		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 26 ENCL

0  
26





## Arizona Nuclear Power Project

P.O. BOX 52034 • PHOENIX, ARIZONA 85072-2034

200-00517-EEVB/OJZ

November 26, 1987

RECEIVED  
NRC  
REGION V  
1981 NOV 30 A 10:23

Mr. John B. Martin  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission, Region V  
1450 Maria Lane - Suite 210  
Walnut Creek, California 94596

Ref.: PVNGS Unit 3 Operating License - NPF-65

Dear Mr. Martin:

Subject: Certification of the Operability of All Required Systems  
for Initial Entry Into Mode 1 - Palo Verde Unit 3

File: 87-056-026

As required by Item 1.b of Attachment 1 to the Palo Verde Nuclear Generating Unit 3 Operating License, NPF-65, I am hereby certifying that Item 1.a of Attachment 1 to the license has been completed for the initial entry into Mode 1.

The operability of all systems required for the initial entry into Mode 1 has been demonstrated by successfully meeting the acceptance criteria in the PVNGS Technical Specifications. This has been accomplished by the completion of the applicable surveillance tests or by preoperational testing which verifies meeting the requirements of the Technical Specifications which were performed within the required surveillance interval or by operability as demonstrated for Modes 2, 3, 4, 5, and 6.

Very truly yours,

E. E. Van Brunt, Jr.  
Executive Vice President  
Project Director

EEVB/OJZ/cbh

cc: Gaston Fiorelli  
Art Gehr

8712140278 871126  
PDR ADOCK 05000530  
P PDR

110  
IE-01

