

MARKED UP  
TECHNICAL SPECIFICATION  
PAGES

9710210002 971008  
PDR ADOCK 05000528  
P PDR

2. 71 6 24

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.8.4.8 -----NOTE-----  This Surveillance shall not be performed in  MODE 1, 2, 3, or 4.  -----</p> <p>Verify battery capacity is <math>\geq 80\%</math> (low  specific gravity cells) or <math>\geq 90\%</math> (AT&amp;T) of  the manufacturer's rating when subjected to  a performance discharge test or a modified  performance discharge test. *</p>	<p>60 months</p> <p><u>AND</u></p> <p>12 months when  battery shows  degradation or  has reached 85%  of the expected  life with  capacity  <math>&lt; 100\%</math> of  manufacturer's  rating</p> <p><u>AND</u></p> <p>24 months when  battery has  reached 85% of  the expected  life with  capacity  <math>\geq 100\%</math> of  manufacturer's  rating</p>

\* The requirement to perform SR 3.8.4.8 for the Unit 1 batteries A, B and C is waived until entry into MODE 4 coming out of the ninth refueling outage for Unit 1 (1R09).



**RETYPE**  
**TECHNICAL SPECIFICATION**  
**PAGES**



SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.8.4.8 -----NOTE-----  This Surveillance shall not be performed in  MODE 1, 2, 3, or 4.  -----</p> <p>Verify battery capacity is <math>\geq 80\%</math> (low  specific gravity cells) or <math>\geq 90\%</math> (AT&amp;T) of  the manufacturer's rating when subjected to  a performance discharge test or a modified  performance discharge test. *</p>	<p>60 months</p> <p><u>AND</u></p> <p>12 months when  battery shows  degradation or  has reached 85%  of the expected  life with  capacity  <math>&lt; 100\%</math> of  manufacturer's  rating</p> <p><u>AND</u></p> <p>24 months when  battery has  reached 85% of  the expected  life with  capacity  <math>\geq 100\%</math> of  manufacturer's  rating</p>

\* The requirement to perform SR 3.8.4.8 for the Unit 1 batteries A, B, and C is waived until entry into MODE 4 coming out of the ninth refueling outage for Unit 1 (1R09).

