

# CONTROLLED BY USER

## TABLE 3.6-1 CONTAINMENT ISOLATION VALVES

VALVE NUMBER	PENETRATION NUMBER	FUNCTION	MAXIMUM ACTUATION TIME (SECONDS)
A. CONTAINMENT ISOLATION (CIAS)			
RDA-UV 023	9	Containment radwaste sump pump to LRS holdup tank	30
RDB-UV 024	9	Containment radwaste sump pump to LRS holdup tank	5
RDB-UV 407	9	Containment radwaste sump post-accident sampling system	5
SGB-HV 200 <sup>#</sup>	11	Downcomer feedwater chemical injection	1
SGB-HV 201 <sup>#</sup>	12	Downcomer feedwater chemical injection	1
SIA-UV 708 <sup>#</sup>	23	Containment recirc sump to post-accident sampling system	5
HCB-UV 044	25A	Containment air radioactivity monitor (inlet)	<del>12</del> 1
HCA-UV 045	25A	Containment air radioactivity monitor (inlet)	<del>12</del> 1
HCA-UV 046	25B	Containment air radioactivity monitor (outlet)	<del>12</del> 1
HCB-UV 047	25B	Containment air radioactivity monitor (outlet)	<del>12</del> 1
GAA-UV 002	29	N <sub>2</sub> to steam generator and reactor drain tank	10
GAA-UV 001	30	N <sub>2</sub> to SI tanks	10

#Not Type C Tested

8805180322 880509  
PDR ADOCK 05000528  
P DCD

PALO VERDE - UNIT 1

. 3/4 6-21

# CONTROLLED BY USER

# CONTROLLED BY USER

TABLE 3.6-1

## CONTAINMENT ISOLATION VALVES

VALVE NUMBER	PENETRATION NUMBER	FUNCTION	MAXIMUM ACTUATION TIME (SECONDS)
A. CONTAINMENT ISOLATION (CIAS)			
RDA-UV 023	9	Containment radwaste sump pump to LRS holdup tank	30 <sup>20</sup>
RDB-UV 024	9	Containment radwaste sump pump to LRS holdup tank	5
RDB-UV 407	9	Containment radwaste sump post-accident sampling system	5
SGB-HV 200#	11	Downcomer feedwater chemical injection	1
SGB-HV 201#	12	Downcomer feedwater chemical injection	1
SIA-UV 708#	23	Containment recirc sump to post-accident sampling system	5
HCB-UV 044	25A	Containment air radioactivity monitor (inlet)	<del>1</del> 1
HCA-UV 045	25A	Containment air radioactivity monitor (inlet)	<del>1</del> 1
HCA-UV 046	25B	Containment air radioactivity monitor (outlet)	<del>1</del> 1
HCB-UV 047	25B	Containment air radioactivity monitor (outlet)	<del>1</del> 1
GAA-UV 002	29	N <sub>2</sub> to steam generator and reactor drain tank	10
GAA-UV 001	30	N <sub>2</sub> to SI tanks	10

#Not Type C tested.



# CONTROLLED BY USER

TABLE 3.6-1

## CONTAINMENT ISOLATION VALVES

VALVE NUMBER	PENETRATION NUMBER	FUNCTION	MAXIMUM ACTUATION TIME (SECONDS)
A. CONTAINMENT ISOLATION (CIAS)			
RDA-UV 023	9	Containment radwaste sump pump to LRS holdup tank	30
RDB-UV 024	9	Containment radwaste sump pump to LRS holdup tank	5
RDB-UV 407	9	Containment radwaste sump post-accident sampling system	5
SGB-HV 200#	11	Downcomer feedwater chemical injection	1
SGB-HV 201#	12	Downcomer feedwater chemical injection	1
SIA-UV 708#	23	Containment recirc sump to post-accident sampling system	5
HCB-UV 044	25A	Containment air radioactivity monitor (inlet)	<del>12</del> 1
HCA-UV 045	25A	Containment air radioactivity monitor (inlet)	<del>12</del> 1
HCA-UV 046	25B	Containment air radioactivity monitor (outlet)	<del>12</del> 1
HCB-UV 047	25B	Containment air radioactivity monitor (outlet)	<del>12</del> 1
GAA-UV 002	29	N <sub>2</sub> to steam generator and reactor drain tank	10
GAA-UV 001	30	N <sub>2</sub> to SI tanks	10

#Not Type C tested.

