

KEY PLAN - LEVEL A




NOTES:

1. FOR GENERAL CONDUIT & TAP NOTES, SYMBOLS & DETAILS, SEE DWG. 13-C-ZAC-050.
2. 6" NOMINAL SCH. 80 CARBON STEEL PIPE-FOR INSTALLATION & DETAILS, SEE DWG 13-C-ZCC-027.
3. ALL RACEWAY MONITORS ON THIS DWG WILL BE PREPARED BY SFCA UNLESS OTHERWISE NOTED.
4. RACEWAYS WITH FIRST DIGIT "A,C OR D" ARE SAFETY RELATED (CLASS R).
5. RACEWAYS WITH FIRST DIGIT "N" ARE NON SAFETY RELATED.
6. ALL EMBEDDED CONDUITS ON THIS DWG WILL BE TERMINATED WITH A CONCRETE PLUG TO FINISH. CONCRETE AND PLUGGED UNLESS OTHERWISE N.T.D.
7. FOR EK CORE NEUTRON FLUX MONITORING SYSTEM DETECTORS LOCATIONS CRITERIA, SEE CR CRITERIA NUMBER SYS80 ICE-3106 APPENDIX A
8. TO FACILITATE MODERATELY PRESSURIZING THE CONDUIT WITH DRY AIR OR NITROGEN, A 1" FORGED WELD-ON PORT AND PLUG SHOULD BE PROVIDED AT THE EK-CORE DETECTOR CONDUITS 12" BELOW THE BOTTOM OF THE JUNCTION BOX.
9. ALL JUNCTION BOXES SHALL BE SIZED 8"X8" UNLESS OTHERWISE NOTED.

11. FOR ELECTRONIC REMARKS SPEAKER CONNECTION DETAILS SEE DWG. 11-4 870 CO. 10 FOR INSTRUMENTS EXACT LOCATION SEE DWG. 12 300F-002

12. FOR LOCATION OF RADIOGRAPHIC DEVICES, REFER TO AREA INSTRUMENT LOCATION DWGS. TYP. 147 CONSULT A7 RADIATION DETECTION

 BECHTEL LOS ANGELES	CONTAINMENT BLDG CONDUIT & TRAY PLAN AT EL 80 FT LEVEL A ZCAA,ZCAB			
	ARIZONA NUCLEAR POWER PROJECT PALO VERDE NUCLEAR GENERATING STATION	SCALE 1/4" = 1'-0" BUCH'S SEAL	JOB NO. 18-17	DRAWING NO. 13-E-ZCC-007

