

SHUTDOWNS AND POWER REDUCTIONS
APRIL 1986

DOCKET NO. 50-528
UNIT NAME PVNGS-1
DATE 09/13/88
COMPLETED BY T. J. Bloom
TELEPHONE (602) 371-4187

No.	Date	Type ¹	Duration Hours	Reason ²	Method of Shutting Down Reactor ³	LER No.	System Code ⁴	Component Code ⁵	Cause and Corrective Action to Prevent Recurrence
2	03/07/86	S	720	A	4	1-86-018-00	SJ	PMC	Reactor trip on low S/G level. The unit entered scheduled surveillance test outage.

1	2	3	4
F-Forced S-Scheduled	Reason: A-Equipment Failure (Explain) B-Maintenance or Test C-Refueling D-Regulatory Restriction E-Operator Training & License Examination F-Administrative G-Operational Error H-Other (Explain)	Method: 1-Manual 2-Manual Scram 3-Automatic Scram 4-Continuation from Previous Month 5-Reduction of 20% or Greater in the Past 24 Hours 9-Other-(Explain)	Exhibit F-Instructions for Preparation of the Data Entry Sheets for Licensee Event Report (LER) File (NUREG 0161) 5 Exhibit H-Same Source

8809270354 880919
PDR ADDCK 05000528
R PNU

