

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8907250145 DOC. DATE: 89/07/12 NOTARIZED: YES DOCKET #
 FACIL: STN-50-528 Palo Verde Nuclear Station, Unit 1, Arizona Public 05000528
 STN-50-529 Palo Verde Nuclear Station, Unit 2, Arizona Public 05000529
 STN-50-530 Palo Verde Nuclear Station, Unit 3, Arizona Public 05000530
 AUTH. NAME: CONWAY, W.F. AUTHOR AFFILIATION: Arizona Public Service Co. (formerly Arizona Nuclear Power
 RECIP. NAME: Document Control Branch (Document Control Desk)

SUBJECT: Responds to Generic Ltr 89-08 re erosion/corrosion induced pipe wall thinning.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1
 TITLE: OR Submittal: General Distribution

NOTES: Standardized plant. 05000528
 Standardized plant. 05000529
 Standardized plant. 05000530

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	PD5 LA	1	PD5 PD	1
	CHAN, T	5	DAVIS, M.	5
INTERNAL:	ACRS	6	NRR/DEST/ADS 7E	1
	NRR/DEST/CEB 8H	1	NRR/DEST/ESB 8D	1
	NRR/DEST/ICSB	1	NRR/DEST/MTB 9H	1
	NRR/DEST/RSB 8E	1	NRR/DOEA/TSB 11	1
	NUDOCS-ABSTRACT	1	OC/LEMB	1
	OGC/HDS1	1	REG FILE 01	1
	RES/DSIR/EIB	1		
EXTERNAL:	LPDR	1	NRC PDR	1
	NSIC	1		
NOTES:		1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 34 ENCL 32

1

100-443887-100

Arizona Public Service Company

P.O. BOX 53999 • PHOENIX, ARIZONA 85072-3999

WILLIAM F. CONWAY
EXECUTIVE VICE PRESIDENT
NUCLEAR

161-02090-WFC/JST
July 12, 1989

Docket Nos. STN 50-528/529/530


Document Control Desk
U. S. Nuclear Regulatory Commission
Mail Station P1-37
Washington, D. C. 20555

Dear Sirs:

Subject: Palo Verde Nuclear Generating Station (PVNGS)
Units 1, 2, and 3
Erosion/Corrosion-Induced Pipe Wall Thinning
(Generic Letter 89-08)
File: 89-010-026

This letter forwards the Palo Verde Nuclear Generating Station (PVNGS) response to Generic Letter 89-08 "Erosion/Corrosion-Induced Pipe Wall Thinning." PVNGS has been actively involved in ultrasonic inspection for detection of both single and two-phase erosion/corrosion induced pipe wall thinning since the first refueling outage of Unit 1. Baseline inspections have been performed on all three PVNGS units in accordance with NUMARC guidelines. These inspections have shown no significant occurrence of the flow assisted erosion/corrosion phenomena. PVNGS has utilized the CHEC and CHECMATE computer codes and the output of these codes does not indicate PVNGS will be susceptible to any appreciable wear rates. PVNGS is in the process of formalizing the current inspection program in the form of Administrative and Departmental Control Procedures. This program will be based on the NUMARC and EPRI guidelines with the CHEC and CHECMATE computer codes as the cornerstone. The currently scheduled completion date for approval of the program is December 31, 1989.

Sincerely,



WFC/JST/jle

cc: J. B. Martin
T. L. Chan
A. C. Gehr
T. J. Polich
M. J. Davis

8907250145 890712
PDR ADOCK 05000528
P PDC

*Adol
1/10*

STATE OF ARIZONA)
) ss.
COUNTY OF MARICOPA)

I, W. F. Conway, represent that I am Executive Vice President - Nuclear, that the foregoing document has been signed by me on behalf of Arizona Public Service Company with full authority to do so, that I have read such document and know its contents, and that to the best of my knowledge and belief, the statements made therein are true and correct.

W. F. Conway
W. F. Conway

Sworn to before me this 19 day of July, 1989.

Linda Spill
Notary Public

My Commission Expires:

My Commission Expires June 5, 1992

11/11/11

11/11/11

11/11/11