

SUMMARY OF OPERATING EXPERIENCE FOR THE MONTH
REVISION

DOCKET NO. 50-529
UNIT NAME PVNGS-2
DATE 09/13/89
COMPLETED BY K. F. Porter
TELEPHONE (602) 371-4187

AUGUST 1989

08/01	0000	Unit began month operating in Mode 1, 100% RX Power.
08/04	0823	Turbine trip on a false RX trip signal.
08/06*	0513	Generator synchronized to grid.
08/07	0235	Unit reached 100% RX Power.
08/22	1956	Commenced power reduction to 65% for feedwater pump turbine maintenance.
08/24	1100	Unit back at 100% RX Power.
08/31	2400	Unit ended month in Mode 1, 100% RX Power.

* This date appeared in the August report incorrectly as 07/06