

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9008160090 DOC. DATE: ~~90/07/31~~ NOTARIZED: NO DOCKET #  
 FACIL: STN-50-528 Palo Verde Nuclear Station, Unit 1, Arizona Publi 05000528  
 STN-50-529 Palo Verde Nuclear Station, Unit 2, Arizona Publi 05000529  
 STN-50-530 Palo Verde Nuclear Station, Unit 3, Arizona Publi 05000530

AUTH. NAME AUTHOR AFFILIATION  
 PORTER, K.F. Arizona Public Service Co. (formerly Arizona Nuclear Power  
 LEVINE, J.M. Arizona Public Service Co. (formerly Arizona Nuclear Power  
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating repts for Jul 1990 for Palo Verde Nuclear  
 Generating Station Unots 1,2 & 3. W/ 900814 Dtr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 16  
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES: STANDARDIZED PLANT 05000528  
 Standardized plant. 05000529  
 Standardized plant. 05000530

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD5 LA	3 3	PD5 PD	1 1
PETERSON, S.	1 1	TRAMMELL, C.	1 1
INTERNAL: ACRS	10 10	AEOD/DOA	1 1
AEOD/DSP/TPAB	1 1	IRM TECH ADV	2 2
NRR/DLPQ/LPEB10	1 1	NRR/DOEA/OEAB11	1 1
REG FILE 01	1 1	RGN5	1 1
EXTERNAL: EG&G BRYCE, J.H	3 3	LPDR	1 1
NRC PDR	1 1	NSIC	1 1
NOTES:	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 31 ENCL 31

MR



Arizona Public Service Company

PALO VERDE NUCLEAR GENERATING STATION  
P.O. BOX 52034 • PHOENIX, ARIZONA 85072-2034

254-01069-JML/KFP

August 14, 1990

Docket Nos. STN 50-528/529/530


Document Control Desk  
U. S. Nuclear Regulatory Commission  
Mail Station P1-37  
Washington, D.C. 20555

Subject: Palo Verde Nuclear Generating Station (PVNGS)  
Units 1, 2, and 3  
Monthly Operating Reports for July 1990  
File: 90-024-404

Attached are the Monthly Operating Reports for July 1990 prepared and submitted pursuant to Specification 6.9.1.6 of Appendix A (Technical Specifications) to the Palo Verde Nuclear Generating Station, Units 1, 2, and 3 Operating Licenses. By copy of this letter, we are also forwarding the Monthly Operating Reports to the Regional Administrator of the Region V Office.

If you have any questions, please contact Mr. K. F. Porter, at (602) 340-4187.

Very truly yours,

  
J. M. Levine  
Vice President  
Nuclear Production

JML/KFP  
Attachments

cc: S. Peterson (all w/attachments)  
J. B. Martin  
D. H. Coe  
INPO Records Center

9008160090 900731  
PDR ADOCK 05000528  
R PDC

IE24  
11

91233

# NRC MONTHLY OPERATING REPORT

DOCKET NO. 50-528  
UNIT NAME PVNGS-1  
DATE 08/08/90  
COMPLETED BY K.F. Porter  
TELEPHONE (602) 340-4187

## OPERATING STATUS

1. Unit Name: Palo Verde Nuclear Generating Station, Unit 1
2. Reporting Period: July 1990
3. Licensed Thermal Power (MWt): 3800
4. Nameplate Rating (Gross MWe): 1403
5. Design Electrical Rating (Net MWe): 1270
6. Maximum Dependable Capacity (Gross MWe): 1303
7. Maximum Dependable Capacity (Net MWe): 1221
8. If Changes Occur In Capacity Ratings (Item Numbers 3 Through 7)  
Since Last Report, Give Reasons: N/A

9. Power Level to Which Restricted, If Any (Net MWe): None
10. Reasons For Restrictions, If Any: N/A

	This Month	Yr.-to-Date	Cumulative
11. Hours in Reporting Period	<u>744</u>	<u>5,088</u>	<u>39,504</u>
12. Number of Hours Reactor Was Critical	<u>744.0</u>	<u>881.6</u>	<u>18,143.7</u>
13. Reactor Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
14. Hours Generator On-Line	<u>638.1</u>	<u>638.1</u>	<u>17,465.0</u>
15. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
16. Gross Thermal Energy Generated (MWH)	<u>2,146,547</u>	<u>2,157,372</u>	<u>63,088,593</u>
17. Gross Electrical Energy Generated (MWH)	<u>724,300</u>	<u>724,300</u>	<u>21,887,400</u>
18. Net Electrical Energy Generated (MWH)	<u>675,073</u>	<u>675,073</u>	<u>20,468,263</u>
19. Unit Service Factor	<u>85.8%</u>	<u>12.5%</u>	<u>44.2%</u>
20. Unit Availability Factor	<u>85.8%</u>	<u>12.5%</u>	<u>44.2%</u>
21. Unit Capacity Factor (Using MDC Net)	<u>74.3%</u>	<u>10.9%</u>	<u>42.4%</u>
22. Unit Capacity Factor (Using DER Net)	<u>71.4%</u>	<u>10.4%</u>	<u>40.8%</u>
23. Unit Forced Outage Rate	<u>0.0%</u>	<u>0.0%</u>	<u>27.4 %</u>
24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each): <u>N/A</u>			

25. If Shutdown At End of Report Period, Estimated Date of Start-up:  
N/A

	Forecast	Achieved
INITIAL CRITICALITY	<u>05/85</u>	<u>05/25/85</u>
INITIAL ELECTRICITY	<u>06/85</u>	<u>06/10/85</u>
COMMERCIAL OPERATION	<u>11/85</u>	<u>01/28/86</u>



# AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-528  
UNIT NAME PVNGS-1  
DATE 08/08/90  
COMPLETED BY K.F. Porter  
TELEPHONE (602) 340-4187

MONTH: JULY 1990

## DAY AVERAGE DAILY POWER LEVEL

1	<u>0</u>
2	<u>0</u>
3	<u>0</u>
4	<u>0</u>
5	<u>15</u>
6	<u>124</u>
7	<u>292</u>
8	<u>661</u>
9	<u>823</u>
10	<u>826</u>
11	<u>1010</u>
12	<u>1153</u>
13	<u>1234</u>
14	<u>1234</u>
15	<u>1231</u>
16	<u>1231</u>

## DAY AVERAGE DAILY POWER LEVEL

17	<u>1233</u>
18	<u>1236</u>
19	<u>1233</u>
20	<u>1225</u>
21	<u>1189</u>
22	<u>1235</u>
23	<u>1235</u>
24	<u>1233</u>
25	<u>1235</u>
26	<u>1238</u>
27	<u>1238</u>
28	<u>1236</u>
29	<u>1243</u>
30	<u>1240</u>
31	<u>1238</u>





REFUELING INFORMATION

DOCKET NO. 50-528  
UNIT NAME PVNGS-1  
DATE 08/08/90  
COMPLETED BY K.F. Porter  
TELEPHONE (602) 340-4187

1. Scheduled date for next refueling shutdown.  
02/01/92, 3rd refueling.
2. Scheduled date for restart following refueling.  
04/11/92
3. Will refueling or resumption of operation thereafter require a Technical Specification change or other license amendment?  
To be determined.
4. Scheduled date for submitting proposed licensing action and supporting information.  
To be determined.
5. Important Licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, and new operating procedures.  
To be determined.
6. The number of fuel assemblies.  
a) In the core. 241  
b) In the spent fuel storage pool. 188
7. Licensed spent fuel storage capacity. 1329  
Intended change in spent fuel storage capacity. None
8. Projected date of last refueling that can be discharged to spent fuel storage pool assuming present capacity.  
2004 (18 Month reloads and full core discharge capability).

# SUMMARY OF OPERATING EXPERIENCE FOR THE MONTH

DOCKET NO.	<u>50-528</u>
UNIT NAME	<u>PVNGS-1</u>
DATE	<u>08/08/90</u>
COMPLETED BY	<u>K.F. Porter</u>
TELEPHONE	<u>(602) 340-4187</u>

## July 1990

07/01	00:00	Unit began the month in Mode 1, 2nd Refueling Outage.
07/04	13:21	Generator synchronized to the grid for heat soak prior to overspeed testing.
07/04	17:21	Generator taken off-line for overspeed testing and adjustments.
07/05	13:54	Generator synchronized to the grid marking the end of the 2nd Refueling Outage.
07/12	21:45	Unit reached 100% RX power, post refueling outage power ascension completed.
07/20	20:40	Unit commenced power reduction to 95% for planned valve testing.
07/21	18:15	Unit back at 100% RX power.
07/31	24:00	Unit ended the month in Mode 1, 100% RX power.

# SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO 50-528  
UNIT NAME PVNGS-1  
DATE 08/08/90  
COMPLETED BY K.F. Porter  
TELEPHONE (602) 340-4187

No.	Date	Type <sup>1</sup>	Duration Hours	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	LER No.	System Code <sup>4</sup>	Component Code <sup>5</sup>	Cause and Corrective Action to Prevent Recurrence
89/03	04/08/89	S	85.3	C	4	N/A	N/A	N/A	Continuation of 2nd refueling outage.
90/01	07/04/90	S	20.6	B	9	N/A	N/A	N/A	Planned turbine overspeed testing and adjustments. The reactor remained in Mode 1.

<sup>1</sup>F-Forced  
S-Scheduled

<sup>2</sup>Reason:  
A-Equipment Failure(Explain)  
B-Maintenance or Test  
C-Refueling  
D-Regulatory Restriction  
E-Operator Training & License Examination  
F-Administrative  
G-Operational Error  
H-Other (Explain)

<sup>3</sup>Method:  
1-Manual  
2-Manual Scram  
3-Automatic Scram  
4-Continuation from Previous Month  
5-Reduction of 20% or Greater in the Past 24 Hours  
9-Other-(Explain)

<sup>4</sup>Exhibit F-Instructions  
for Preparation of the Data  
Entry Sheets for Licensee  
Event Report (LER) File  
(NUREG 0161)

<sup>5</sup>Exhibit H-Same Source



# NRC MONTHLY OPERATING REPORT

DOCKET NO.	<u>50-529</u>
UNIT NAME	<u>PVNGS-2</u>
DATE	<u>08/08/90</u>
COMPLETED BY	<u>K.F. Porter</u>
TELEPHONE	<u>(602) 340-4187</u>

## OPERATING STATUS

1. Unit Name: Palo Verde Nuclear Generating Station, Unit 2
2. Reporting Period: July 1990
3. Licensed Thermal Power (MWt): 3800
4. Nameplate Rating (Gross MWe): 1403
5. Design Electrical Rating (Net MWe): 1270
6. Maximum Dependable Capacity (Gross MWe): 1303
7. Maximum Dependable Capacity (Net MWe): 1221
8. If Changes Occur In Capacity Ratings (Item Numbers 3 Through 7)  
Since Last Report, Give Reasons: N/A

9. Power Level to Which Restricted, If Any (Net MWe): None
10. Reasons For Restrictions, If Any: N/A

	This Month	Yr.-to-Date	Cumulative
11. Hours in Reporting Period	<u>744</u>	<u>5,088</u>	<u>33,888</u>
12. Number of Hours Reactor Was Critical	<u>409.2</u>	<u>1,704.2</u>	<u>20,955.3</u>
13. Reactor Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
14. Hours Generator On-Line	<u>309.2</u>	<u>1,604.2</u>	<u>20,351.4</u>
15. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
16. Gross Thermal Energy Generated (MWH)	<u>558,801</u>	<u>5,429,501</u>	<u>74,057,854</u>
17. Gross Electrical Energy Generated (MWH)	<u>173,700</u>	<u>1,886,200</u>	<u>25,856,070</u>
18. Net Electrical Energy Generated (MWH)	<u>132,981</u>	<u>1,746,989</u>	<u>24,129,801</u>
19. Unit Service Factor	<u>41.6%</u>	<u>31.5%</u>	<u>60.1%</u>
20. Unit Availability Factor	<u>41.6%</u>	<u>31.5%</u>	<u>60.1%</u>
21. Unit Capacity Factor (Using MDC Net)	<u>14.6%</u>	<u>28.1%</u>	<u>58.3%</u>
22. Unit Capacity Factor (Using DER Net)	<u>14.1%</u>	<u>27.0%</u>	<u>56.1%</u>
23. Unit Forced Outage Rate	<u>0.0%</u>	<u>0.0%</u>	<u>9.7%</u>
24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each): <u>N/A</u>			

25. If Shutdown At End of Report Period, Estimated Date of Start-up:  
N/A

	Forecast	Achieved
INITIAL CRITICALITY	<u>03/86</u>	<u>04/18/86</u>
INITIAL ELECTRICITY	<u>06/86</u>	<u>05/20/86</u>
COMMERCIAL OPERATION	<u>11/86</u>	<u>09/19/86</u>



# AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-529  
 UNIT NAME PVNGS-2  
 DATE 08/08/90  
 COMPLETED BY K.F. Porter  
 TELEPHONE (602) 340-4187

MONTH: JULY 1990

DAY AVERAGE DAILY POWER LEVEL

1	<u>0</u>
2	<u>0</u>
3	<u>0</u>
4	<u>0</u>
5	<u>0</u>
6	<u>0</u>
7	<u>0</u>
8	<u>0</u>
9	<u>0</u>
10	<u>0</u>
11	<u>0</u>
12	<u>0</u>
13	<u>0</u>
14	<u>0</u>
15	<u>0</u>
16	<u>0</u>

DAY AVERAGE DAILY POWER LEVEL

17	<u>0</u>
18	<u>0</u>
19	<u>82</u>
20	<u>99</u>
21	<u>103</u>
22	<u>352</u>
23	<u>738</u>
24	<u>818</u>
25	<u>804</u>
26	<u>779</u>
27	<u>778</u>
28	<u>625</u>
29	<u>411</u>
30	<u>396</u>
31	<u>409</u>





REFUELING INFORMATION

DOCKET NO. 50-529  
UNIT NAME PVNGS-2  
DATE 08/08/90  
COMPLETED BY K.F. Porter  
TELEPHONE (602) 340-4187

1. Scheduled date for next refueling shutdown.  
10/17/91, 3rd refueling.
2. Scheduled date for restart following refueling.  
12/26/91
3. Will refueling or resumption of operation thereafter require a Technical Specification change or other license amendment?  
To be determined.
4. Scheduled date for submitting proposed licensing action and supporting information.  
To be determined.
5. Important Licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, and new operating procedures.  
To be determined.
6. The number of fuel assemblies.  
a) In the core. 241  
b) In the spent fuel storage pool. 204
7. Licensed spent fuel storage capacity. 1329  
Intended change in spent fuel storage capacity. None
8. Projected date of last refueling that can be discharged to spent fuel storage pool assuming present capacity.  
2004 (18 Month reloads and full core discharge capability).



# SUMMARY OF OPERATING EXPERIENCE FOR THE MONTH

DOCKET NO. 50-529  
UNIT NAME PVNGS-2  
DATE 08/08/90  
COMPLETED BY K.F. Porter  
TELEPHONE (602) 340-4187

## July 1990

07/01	00:00	Unit began the month in Mode 5, 2nd Refueling Outage.
07/02	09:55	Unit entered Mode 4.
07/03	18:07	Unit entered Mode 3.
07/14	22:46	Unit entered Mode 2 for low power physics testing.
07/18	06:20	Unit entered Mode 1.
07/19	00:36	Generator synchronized to grid for heat soak prior to overspeed testing.
07/19	09:13	Generator taken off-line for overspeed testing and adjustments.
07/19	11:26	Generator synchronized to grid marking the end of the 2nd Refueling Outage.
07/25	15:35	Unit commenced power reduction to 65% from 70% for maintenance of feedwater pump "B".
07/28	12:08	Unit commenced power reduction to 40% from 65% for repair of a condenser tube leak.
07/31	24:00	Unit ended the month in Mode 1, 40% RX power.

## SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO 50-529  
 UNIT NAME PVNGS-2  
 DATE 08/08/90  
 COMPLETED BY K.F. Porter  
 TELEPHONE (602) 340-4187

No.	Date	Type <sup>1</sup>	Duration Hours	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	LER No.	System Code <sup>4</sup>	Component Code <sup>5</sup>	Cause and Corrective Action to Prevent Recurrence
90/01	02/23/90	S	432.6	C	4	N/A	N/A	N/A	Continuation of 2nd Refueling Outage.
90/02	07/19/90	S	2.2	B	9	N/A	N/A	N/A	Planned turbine overspeed testing. The reactor remained in Mode 1.
90/03	07/28/90	F	N/A	A	5	N/A	N/A	N/A	Power reduction to 40% for repair of a condenser tube leak.

<sup>1</sup>F-Forced  
S-Scheduled

<sup>2</sup>Reason:  
 A-Equipment Failure(Explain)  
 B-Maintenance or Test  
 C-Refueling  
 D-Regulatory Restriction  
 E-Operator Training & License Examination  
 F-Administrative  
 G-Operational Error  
 H-Other (Explain)

<sup>3</sup>Method:  
 1-Manual  
 2-Manual Scram  
 3-Automatic Scram  
 4-Continuation from Previous Month  
 5-Reduction of 20% or Greater in the Past 24 Hours  
 9-Other-(Explain)

<sup>4</sup>Exhibit F-Instructions  
 for Preparation of the Data  
 Entry Sheets for Licensee  
 Event Report (LER) File  
 (NUREG 0161)

<sup>5</sup>Exhibit H-Same Source



# NRC MONTHLY OPERATING REPORT

DOCKET NO. 50-530  
 UNIT NAME PVNGS-3  
 DATE 08/08/90  
 COMPLETED BY K.F. Porter  
 TELEPHONE (602) 340-4187

## OPERATING STATUS

1. Unit Name: Palo Verde Nuclear Generating Station, Unit 3
2. Reporting Period: July 1990
3. Licensed Thermal Power (MWt): 3800
4. Nameplate Rating (Gross MWe): 1403
5. Design Electrical Rating (Net MWe): 1270
6. Maximum Dependable Capacity (Gross MWe): 1303
7. Maximum Dependable Capacity (Net MWe): 1221
8. If Changes Occur In Capacity Ratings (Item Numbers 3 Through 7)  
 Since Last Report, Give Reasons: N/A

9. Power Level to Which Restricted, If Any (Net MWe): None
10. Reasons For Restrictions, If Any: N/A

	This Month	Yr.-to-Date	Cumulative
11. Hours in Reporting Period	<u>744</u>	<u>5,088</u>	<u>22,464</u>
12. Number of Hours Reactor Was Critical	<u>744.0</u>	<u>4,557.2</u>	<u>13,968.4</u>
13. Reactor Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
14. Hours Generator On-Line	<u>744.0</u>	<u>4,458.7</u>	<u>13,732.7</u>
15. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
16. Gross Thermal Energy Generated (MWH)	<u>2,814,578</u>	<u>15,876,133</u>	<u>50,286,524</u>
17. Gross Electrical Energy Generated (MWH)	<u>982,300</u>	<u>5,565,400</u>	<u>17,633,200</u>
18. Net Electrical Energy Generated (MWH)	<u>929,041</u>	<u>5,220,244</u>	<u>16,583,709</u>
19. Unit Service Factor	<u>100.0%</u>	<u>87.6%</u>	<u>61.1%</u>
20. Unit Availability Factor	<u>100.0%</u>	<u>87.6%</u>	<u>61.1%</u>
21. Unit Capacity Factor (Using MDC Net)	<u>102.3%</u>	<u>84.0%</u>	<u>60.5%</u>
22. Unit Capacity Factor (Using DER Net)	<u>98.3%</u>	<u>80.8%</u>	<u>58.1%</u>
23. Unit Forced Outage Rate	<u>0.0%</u>	<u>12.3%</u>	<u>10.4%</u>
24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each): <u>N/A</u>			

25. If Shutdown At End of Report Period, Estimated Date of Start-up:  
N/A

	Forecast	Achieved
INITIAL CRITICALITY	<u>07/87</u>	<u>10/25/87</u>
INITIAL ELECTRICITY	<u>07/87</u>	<u>11/28/87</u>
COMMERCIAL OPERATION	<u>09/87</u>	<u>01/08/88</u>



# AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-530  
UNIT NAME PVNGS-3  
DATE 08/08/90  
COMPLETED BY K.F. Porter  
TELEPHONE (602) 340-4187

MONTH: JULY 1990

## DAY AVERAGE DAILY POWER LEVEL

1	<u>1250</u>
2	<u>1248</u>
3	<u>1248</u>
4	<u>1250</u>
5	<u>1251</u>
6	<u>1249</u>
7	<u>1223</u>
8	<u>1249</u>
9	<u>1247</u>
10	<u>1247</u>
11	<u>1245</u>
12	<u>1246</u>
13	<u>1245</u>
14	<u>1251</u>
15	<u>1251</u>
16	<u>1248</u>

## DAY AVERAGE DAILY POWER LEVEL

17	<u>1247</u>
18	<u>1248</u>
19	<u>1245</u>
20	<u>1243</u>
21	<u>1249</u>
22	<u>1252</u>
23	<u>1253</u>
24	<u>1249</u>
25	<u>1250</u>
26	<u>1257</u>
27	<u>1258</u>
28	<u>1260</u>
29	<u>1258</u>
30	<u>1256</u>
31	<u>1253</u>





# REFUELING INFORMATION

DOCKET NO. 50-530  
UNIT NAME PVNGS-3  
DATE 08/08/90  
COMPLETED BY K.F. Porter  
TELEPHONE (602) 340-4187

1. Scheduled date for next refueling shutdown.

03/16/91, 2nd refueling.

2. Scheduled date for restart following refueling.

05/25/91

3. Will refueling or resumption of operation thereafter require a Technical Specification change or other license amendment?

To be determined.

4. Scheduled date for submitting proposed licensing action and supporting information.

To be determined.

5. Important Licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, and new operating procedures.

To be determined.

6. The number of fuel assemblies.

a) In the core. 241

b) In the spent fuel storage pool. 104

7. Licensed spent fuel storage capacity. 1329

Intended change in spent fuel storage capacity. None

8. Projected date of last refueling that can be discharged to spent fuel storage pool assuming present capacity.

2005 (18 Month reloads and full core discharge capability).



# SUMMARY OF OPERATING EXPERIENCE FOR THE MONTH

DOCKET NO.	<u>50-530</u>
UNIT NAME	<u>PVNGS-3</u>
DATE	<u>08/08/90</u>
COMPLETED BY	<u>K.F. Porter</u>
TELEPHONE	<u>(602) 340-4187</u>

## July 1990

07/01	00:00	Unit began the month in Mode 1, 100% RX power.
07/07	04:50	Began RX power reduction to 95% for planned valve testing.
07/07	15:05	Unit back at 100% RX power.
07/31	24:00	Unit ended the month in Mode 1, 100% RX power.



# SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO 50-530  
UNIT NAME PVNGS-3  
DATE 08/08/90  
COMPLETED BY K.F. Porter  
TELEPHONE (602) 340-4187

No.	Date	Type <sup>1</sup>	Duration Hours	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	LER No.	System Code <sup>4</sup>	Component Code <sup>5</sup>	Cause and Corrective Action to Prevent Recurrence
-----	------	-------------------	-------------------	---------------------	--	---------	-----------------------------	--------------------------------	---

No outages or power reductions of greater than 20% occurred during the month.

<sup>1</sup>F-Forced  
S-Scheduled

<sup>2</sup>Reason:  
A-Equipment Failure(Explain)  
B-Maintenance or Test  
C-Refueling  
D-Regulatory Restriction  
E-Operator Training & License  
Examination  
F-Administrative  
G-Operational Error  
H-Other (Explain)

<sup>3</sup>Method:  
1-Manual  
2-Manual Scram  
3-Automatic Scram  
4-Continuation from  
Previous Month  
5-Reduction of 20% or  
Greater in the Past  
24 Hours  
9-Other-(Explain)

<sup>4</sup>Exhibit F-Instructions  
for Preparation of the Data  
Entry Sheets for Licensee  
Event Report (LER) File  
(NUREG 0161)

<sup>5</sup>Exhibit H-Same Source