

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9101230321 DOC. DATE: 91/01/16 NOTARIZED: NO DOCKET #
 FACIL: STN-50-528 Palo Verde Nuclear Station, Unit 1, Arizona Publi 05000528
 AUTH. NAME AUTHOR AFFILIATION
 LEVINE, J.M. Arizona Public Service Co. (formerly Arizona Nuclear Power
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Special Rept 1-SR-90-007: on 901221. containment bldg
 atmosphere radiation monitor RU-1 inoperable for more than
 72 h. On 901218, monitor declared inoperable due to high flow
 conditions. Caused by failure of flow totalizer.

DISTRIBUTION CODE: IE22D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
 TITLE: 50.73/50.9 Licensee Event Report (LER), Incident Rpt, etc.

NOTES: STANDARDIZED PLANT

05000528

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD5 LA	1 1	PD5 PD	1 1
	TRAMMELL, C	1 1	TRAMMELL, C.	1 1
INTERNAL:	ACNW	2 2	ACRS	2 2
	AEOD/DOA	1 1	AEOD/DSP/TPAB	1 1
	AEOD/ROAB/DSP	2 2	NRR/DET/ECMB 9H	1 1
	NRR/DET/EMEB 7E	1 1	NRR/DLPQ/LHFB11	1 1
	NRR/DLPQ/LPEB10	1 1	NRR/DOEA/OEAB	1 1
	NRR/DREP/PRPB11	2 2	NRR/DST/SELB 8D	1 1
	NRR/DST/SICB 7E	1 1	NRR/DST/SPLB8D1	1 1
	NRR/DST/SRXB 8E	1 1	REG FILE 02	1 1
	RES/DSIR/EIB	1 1	RGN5 FILE 01	1 1
EXTERNAL:	EG&G BRYCE, J.H	3 3	L ST LOBBY WARD	1 1
	NRC PDR	1 1	NSIC MAYS, G	1 1
	NSIC MURPHY, G.A	1 1	NUDOCS FULL TXT	1 1
NOTES:		1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM PI-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 35 ENCL 35

IA2

Arizona Public Service Company
PALO VERDE NUCLEAR GENERATING STATION
P.O. BOX 52034 • PHOENIX, ARIZONA 85072-2034

JAMES M. LEVINE
VICE PRESIDENT
NUCLEAR PRODUCTION

192-00710-JML/TRB/SBJ
January 16, 1991

U. S. Nuclear Regulatory Commission
Attention: NRC Document Control Desk
Mail Station: P1-37
Washington, D.C. 20555


Dear Sirs:

Subject: Palo Verde Nuclear Generating Station (PVNGS)
Unit 1
Docket No. STN 50-528 (License No. NPF-41)
Special Report 1-SR-90-007
File: 91-020-404

Attached please find Special Report 1-SR-90-006 prepared and submitted pursuant to Technical Specifications 3.3.3.1 ACTION 27 and 6.9.2. This report discusses the Containment Building Atmosphere Radiation Monitor being inoperable for a period greater than 72 hours.

If you have any questions, please contact T. R. Bradish, Compliance Manager, at (602) 393-2521.

Very truly yours,



JML/TRB/SBJ/dmn

Attachment

cc: W. F. Conway (all w/attachment)
J. B. Martin
D. H. Coe
A. C. Gehr
A. H. Gutterman
INPO Records Center

9101230321 910116
PDR ADOCK 05000528
S PDR



PALO VERDE NUCLEAR GENERATING STATION UNIT 1

Radiation Monitor Inoperable

License No. NPF-41

Docket No. 50-528

Special Report 1-SR-90-007

Initial Conditions:

On December 21, 1990 Palo Verde Unit 1 was in Mode 1 (POWER OPERATION) at approximately 100 percent power.

Description of Event:

This Special Report is being submitted pursuant to Technical Specification 3.3.3.1 ACTION 27 and Technical Specification 6.9.2 to report an event in which the Containment Building Atmosphere Radiation Monitor (RU-1) was inoperable for a period greater than 72 hours. The 72 hour period for returning the monitor to service was exceeded at approximately 0830 MST on December 21, 1990.

On December 18, 1990 at approximately 0830 MST, the Containment Building Atmosphere Radiation Monitor (RU-1) was declared inoperable because of high flow conditions. RU-1 continuously monitors the containment atmosphere for particulate and gaseous activity to provide a qualitative indication of an increase in primary coolant system leakage. A portable radiation monitor was installed to continuously sample containment air and grab sampling initiated in accordance with Technical Specifications 3.3.3.1 Action 27.

Cause of Event:

The cause of RU-1 being inoperable was a failure of the flow totalizer. The radiation monitor could not be returned to service within 72 hours due to the time required to obtain replacement parts.

Based on current information, the failure is considered to be an isolated equipment failure. If additional information is developed from the evaluation of the failed flow totalizer, a supplement to the report will be submitted.

Corrective Actions:

The flow totalizer was replaced and the surveillance test was successfully performed. The radiation monitor was declared operable at approximately 1543 MST on December 28, 1990. RU-1 was inoperable for approximately 10 days, 7 hours and 13 minutes.

