

CONTROLLED BY USER

TABLE 3.6-1 (Continued)
CONTAINMENT ISOLATION VALVES

VALVE NUMBER	PENETRATION NUMBER	FUNCTION	MAXIMUM ACTUATION TIME (SECONDS)
E. SAFETY/RELIEF VALVES			
SIA-PSV 151# 23		Containment recirculation sump to containment spray, LPSI and HPSI headers 1A & 1B	N.A.
SIB-PSV 140# 24		Containment recirculation sump to containment spray, LPSI and HPSI headers 2A & 2B	N.A.
SIB-PSV 189# 26		From shutdown cooling RC Loop 2	N.A.*
SIA-PSV 179# 27		From shutdown cooling RC Loop 1	N.A.*
SIE-PSV 474 28		Safety injection drain relief	N.A.

*Valves also covered by Specification 3/4.4.8.3

#Not Type C Tested

9201280007 920114
PDR ADDCK 05000528
P PDR

CONTROLLED BY USER

TABLE 3.6-1 (Continued)

CONTAINMENT ISOLATION VALVES

VALVE NUMBER	PENETRATION NUMBER	FUNCTION	MAXIMUM ACTUATION TIME (SECONDS)
G. REQUIRED OPEN DURING ACCIDENT CONDITIONS			
SID-UV 654#	26	From shutdown cooling RC loop 2	N.A.
SIB-UV 656#	26	From shutdown cooling RC loop 2	N.A.
SIB-HV 690#	26	From shutdown cooling RC loop 2	N.A.
SIC-UV 653#	27	From shutdown cooling RC loop 1	N.A.
SIA-UV 655#	27	From shutdown cooling RC loop 1	N.A.
SIA-HV 691#	27	From shutdown cooling RC loop 1	N.A.
HCC-HV 076#	32A	Containment pressure monitor	N.A.
HPA-HV 007A	35	Containment to hydrogen monitor	N.A.
HPB-HV 008A	36	Containment to hydrogen monitor	N.A.
HPA-HV 007B	38	Hydrogen monitor to containment	N.A.
HPB-HV 008B	39	Hydrogen monitor to containment	N.A.
CHA-HV 524	41	Regenerative heat exchanger to RC loop 2A	N.A.
HCA-HV 074#	54A	Containment pressure monitor	N.A.
HCB-HV 075#	55A	Containment pressure monitor	N.A.
HCD-HV 077#	62A	CB pressure monitor	N.A.
SID-HV 331	67	Long-term recirculation loop 2	N.A.
CHB-HV 255	72	RC pump seal injection water to RCP 1A, 1B, 2A, 2B	N.A.
SIC-HV 321	77	Long-term recirculation loop 1	N.A.
SGA-UV 134#	2	Main steam to auxiliary feedwater turbine	N.A.
SGA-UV 134A#	2	Main steam to auxiliary feedwater turbine bypass	N.A.

#Not Type C tested

CONTROLLED BY USER

TABLE 3.6-1 (Continued)
CONTAINMENT ISOLATION VALVES

VALVE NUMBER	PENETRATION NUMBER	FUNCTION	MAXIMUM ACTUATION TIME (SECONDS)
E. SAFETY/RELIEF VALVES			
SIA-PSV 151#	23	Containment recirculation sump to containment spray, LPSI and HPSI headers 1A & 1B	N.A.
SIB-PSV 140#	24	Containment recirculation sump to containment spray, LPSI and HPSI headers 2A & 2B	N.A.
SIB-PSV 189#	26	From shutdown cooling RC Loop 2	N.A.*
SIA-PSV 179#	27	From shutdown cooling RC Loop 1	N.A.*
SIE-PSV 474	28	Safety injection drain relief	N.A.

*Valves also covered by Specification 3/4.4.8.3.

#Not Type C tested.

FOR INFORMATION ONLY

TABLE 3.6-1 (Continued)

CONTAINMENT ISOLATION VALVES

VALVE NUMBER	PENETRATION NUMBER	FUNCTION	MAXIMUM ACTUATION TIME (SECONDS)
G. REQUIRED OPEN DURING ACCIDENT CONDITIONS			
SID-UV 654#	26	From shutdown cooling RC loop 2	N.A.
SIB-UV 656#	26	From shutdown cooling RC loop 2	N.A.
SIB-HV 690#	26	From shutdown cooling RC loop 2	N.A.
SIC-UV 653#	27	From shutdown cooling RC loop 1	N.A.
SIA-UV 655#	27	From shutdown cooling RC loop 1	N.A.
SIA-HV 691#	27	From shutdown cooling RC loop 1	N.A.
HCC-HV 076#	32A	Containment pressure monitor	N.A.
HPA-HV 007A	35	Containment to hydrogen monitor	N.A.
HPB-HV 008A	36	Containment to hydrogen monitor	N.A.
HPA-HV 007B	38	Hydrogen monitor to containment	N.A.
HPB-HV 008B	39	Hydrogen monitor to containment	N.A.
CHA-HV 524	41	Regenerative heat exchanger to RC loop 2A	N.A.
HCA-HV 074#	54A	Containment pressure monitor	N.A.
HCB-HV 075#	55A	Containment pressure monitor	N.A.
HCD-HV 077#	62A	CB pressure monitor	N.A.
SID-HV 331	67	Long-term recirculation loop 2	N.A.
CHB-HV 255	72	RC pump seal injection water to RCP 1A, 1B 2A, 2B	N.A.
SIC-HV 321	77	Long-term recirculation loop 1	N.A.
SGA-UV 134#	2	Main steam to auxiliary feedwater turbine	N.A.

#Not Type C tested.

TABLE 3.6-1 (Continued)
CONTAINMENT ISOLATION VALVES

VALVE NUMBER	PENETRATION NUMBER	FUNCTION	MAXIMUM ACTUATION TIME (SECONDS)
E. SAFETY/RELIEF VALVES			
SIA-PSV 151#	23	Containment recirculation sump to containment spray, LPSI and HPSI headers 1A & 1B	N.A.
SIB-PSV 140#	24	Containment recirculation sump to containment spray, LPSI and HPSI headers 2A & 2B	N.A.
SIB-PSV 189#	26	From shutdown cooling RC Loop 2	N.A.*
SIA-PSV 179#	27	From shutdown cooling RC Loop 1	N.A.*
SIE-PSV 474	28	Safety injection drain relief	N.A.

*Valves also covered by Specification 3/4.4.8.3.

#Not Type C tested.

TABLE 3.6-1 (Continued)
CONTAINMENT ISOLATION VALVES

VALVE NUMBER	PENETRATION NUMBER	FUNCTION	MAXIMUM ACTUATION TIME (SECONDS)
G. REQUIRED OPEN DURING ACCIDENT CONDITIONS			
SID-UV 654#	26	From shutdown cooling RC loop 2	N.A.
SIB-UV 656#	26	From shutdown cooling RC loop 2	N.A.
SIB-HV 690#	26	From shutdown cooling RC loop 2	N.A.
SIC-UV 653#	27	From shutdown cooling RC loop 1	N.A.
SIA-UV 655#	27	From shutdown cooling RC loop 1	N.A.
SIA-HV 691#	27	From shutdown cooling RC loop 1	N.A.
HCC-HV 076#	32A	Containment pressure monitor	N.A.
HPA-HV 007A	35	Containment to hydrogen monitor	N.A.
HPB-HV 008A	36	Containment to hydrogen monitor	N.A.
HPA-HV 007B	38	Hydrogen monitor to containment	N.A.
HPB-HV 008B	39	Hydrogen monitor to containment	N.A.
CHA-HV 524	41	Regenerative heat exchanger to RC loop 2A	N.A.
HCA-HV 074#	54A	Containment pressure monitor	N.A.
HCB-HV 075#	55A	Containment pressure monitor	N.A.
HCD-HV 077#	62A	CB pressure monitor	N.A.
SID-HV 331	67	Long-term recirculation loop 2	N.A.
CHB-HV 255	72	RC pump seal injection water to RCP 1A, 1B 2A, 2B	N.A.
SIC-HV 321	77	Long-term recirculation loop 1	N.A.
SGA-UV 134#	2	Main steam to auxiliary feedwater turbine	N.A.

#Not Type C tested.

