

ENCLOSURE 3

**REVISED PAGE FOR THE UNIT 3
DECEMBER 1992 MONTHLY OPERATING REPORT**

9302190056 930212
PDR ADDCK 05000528
R PDR

NRC MONTHLY OPERATING REPORT

REVISED

DOCKET NO. 50-530
 UNIT NAME PVNGS-3
 DATE 01/08/93
 COMPLETED BY B. S. Ecklund
 TELEPHONE (602) 340-4068

OPERATING STATUS

1. Unit Name: Palo Verde Nuclear Generating Station, Unit 3
2. Reporting Period: December 1992
3. Licensed Thermal Power (MWt): 3800
4. Nameplate Rating (Gross MWe): 1403
5. Design Electrical Rating (Net MWe): 1270
6. Maximum Dependable Capacity (Gross MWe): 1303
7. Maximum Dependable Capacity (Net MWe): 1221
8. If Changes Occur In Capacity Ratings (Item Numbers 3 Through 7)
 Since Last Report, Give Reasons: N/A
9. Power Level to Which Restricted, If Any (Net MWe): None
10. Reasons For Restrictions, If Any: N/A

	UNIT 3 GENERATING STATISTICS	This Month	Yr. -to-Date	Cumulative
11.	Hours In Reporting Period	744	8,784	43,680
12.	Hours Reactor was Critical	744.0	7,010.0	31,007.7
13.	Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14.	Hours Generator was On-Line	744.0	6,924.8	30,524.2
15.	Unit Reserve Shutdown Hours	0.0	0.0	0.0
16.	Gross Thermal Energy Generated (MWH)	2,825,029	25,505,596	112,017,005
17.	Gross Electrical Energy Generated (MWH)	994,600	8,909,100	39,227,800
18.	Net Electrical Energy Generated (MWH)	942,531	8,385,395	36,903,320
19.	Unit Service Factor (%)	100.0%	78.8%	69.9%
20.	Unit Availability Factor (%)	100.0%	78.8%	69.9%
21.	Unit Capacity Factor (Using MDC Net)	103.8%	78.2%	69.2%
22.	Unit Capacity Factor (Using DER Net)	99.8%	75.2%	66.5%
23.	Unit Forced Outage Rate (%)	0.0%	3.3%	8.0%

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each): N/A

25. If Shutdown At End of Report Period, Estimated Date of Start-up: N/A

	Forecast	Achieved
INITIAL CRITICALITY	<u>07/87</u>	<u>10/25/87</u>
INITIAL ELECTRICITY	<u>07/87</u>	<u>11/28/87</u>
COMMERCIAL OPERATION	<u>09/87</u>	<u>01/08/88</u>

