

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8401250260 DOC.DATE: 84/01/19 NOTARIAL NO: NO DOCKET #
 FACIL:50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH.NAME AUTHOR AFFILIATION
 MAIER,J.E. Rochester Gas & Electric Corp.
 RECIP.NAME RECIPIENT AFFILIATION
 DENTON,H.R. Office of Nuclear Reactor Regulation, Director

SUBJECT: Forwards application for amend to License DPR-18, reducing
 requirement for low pressurizer water level from 12 to 10.6%
 & changing P-10 permissive from 10 to 8% power.


DISTRIBUTION CODE: A001S COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 1+9
 TITLE: OR Submittal: General Distribution

NOTES:NRR/DL/SEP 1cy.

05000244

	RECIPIENT ID CODE/NAME		COPIES LTTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTTR ENCL
	NRR ORB5 BC 01		7 7				
INTERNAL:	ELD/HDS4		1 0		NRR/DE/MTEB		1 1
	NRR/DL DIR		1 1		NRR/DL/ORAB		1 0
	NRR/DSI/METB		1 1		NRR/DSI/RAB		1 1
	REG FILE 04		1 1		RGN1		1 1
EXTERNAL:	ACRS 09		6 6		LPDR 03		1 1
	NRC PDR 02		1 1		NSIC 05		1 1
	NTIS		1 1				
NOTES:			1 1				

TOTAL NUMBER OF COPIES REQUIRED: LTTR 26 ENCL 24



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

JOHN E. MAIER
Vice President

TELEPHONE
AREA CODE 716 546-2700

January 19, 1984

Mr. Harold R. Denton
Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Re: Rochester Gas and Electric Corporation,
R.E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Mr. Denton:

Enclosed are:

1. Three (3) originals and nineteen (19) copies of an Application for Amendment to Operating License to amend Appendix A of that license to reduce the requirement for low pressurizer water level from 12 to 10.6% and change the P-10 permissive from 10% to 8% power.
2. Forty (40) copies of documents designated Attachments A B and C which set forth the requested change in Technical Specifications, its safety evaluation, and the basis for determining that the change does not involve a significant hazards consideration; and
3. Since this change supplements a previous proposal, no fee is required.

Very truly yours,

John E. Maier
John E. Maier

Enclosures

xc: Mr. Jay Dunkleberger,
New York State Energy Office

*A001
11*

8401250260	840119
PDR ADOCK 05000244	
P	PDR



11/11/77

11/11/77

11/11/77

11/11/77

11/11/77

11/11/77

11/11/77

11/11/77

11/11/77