

ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001

TELEPHONE
AREA CODE 716 546-2700

GINNA STATION

April 18, 1990


US Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Monthly Report for March, 1990
Operating Status Information
R. E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1, attached herewith is the monthly operating status report for Ginna Station for the month of March, 1990.

Very truly yours,


Robert C. Mecredy
Division Manager
Nuclear Production

RCM/eeh

Attachments

cc: Mr. Thomas T. Martin NRC (1)

9004230556 900331
PDR ADOCK 05000244
R PDC

1E24
11

OPERATING DATA REPORT

DOCKET NO. 50-244DATE April 18, 1990

COMPLETED BY

Robert E. Dodge
Robert E. DodgeTELEPHONE (315) 524-4446 ext. 396OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: MARCH 1990
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electrical Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes: The unit was shutdown on March 23 for Annual Refueling and Maintenance. It remained shutdown at the end of the report period.

9. Power Level to Which Restricted, If Any (Net MWe): _____
10. Reasons For Restrictions, If Any: _____

	This Month	Yr.-to-Date	Cumulative
11. Hours In Report Period	<u>744</u>	<u>2,160.0</u>	<u>178,746.45</u>
12. Number of Hours Reactor Was Critical	<u>546.07</u>	<u>1,962.07</u>	<u>140,308.21</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>1,687.55 *</u>
14. Hours Generator On-Line	<u>545.5</u>	<u>1,961.5</u>	<u>137,802.88</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>8.5 *</u>
16. Gross Thermal Energy Generated (MWH)	<u>808,550</u>	<u>2,926,224</u>	<u>194,548,674</u>
17. Gross Electrical Energy Generated (MWH)	<u>274,719</u>	<u>987,813</u>	<u>64,021,158</u>
18. Net Electrical Energy Generated (MWH)	<u>261,454</u>	<u>940,207</u>	<u>60,758,120</u>
19. Unit Service Factor	<u>73.32</u>	<u>90.81</u>	<u>77.27</u>
20. Unit Availability Factor	<u>73.32</u>	<u>90.81</u>	<u>77.27</u>
21. Unit Capacity Factor (Using MDC Net)	<u>74.77</u>	<u>92.61</u>	<u>73.81</u>
22. Unit Capacity Factor (Using DER Net)	<u>74.77</u>	<u>92.61</u>	<u>73.81</u>
23. Unit Forced Outage Rate	<u>0</u>	<u>0</u>	<u>6.27</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

25. If Shut Down At End Of Report Period, Estimated Date of Startup:

26. Units In Test Status (Prior to Commercial Operation):

Forecast

Achieved

INITIAL CRITICALITY
INITIAL ELECTRICITY
COMMERCIAL OPERATION

*CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-244
 UNIT R.E. Ginna Nuclear Power Plant
 DATE April 18, 1990
 COMPLETED BY Robert E. Dodge
 Robert E. Dodge

TELEPHONE 1 (315) 524-4446 ext. 396

MONTH March, 1990

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1. 484
 2. 484
 3. 484
 4. 484
 5. 484
 6. 484
 7. 484
 8. 484
 9. 484
 10. 484
 11. 484
 12. 483
 13. 484
 14. 484
 15. 483
 16. 483

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17. 483
 18. 483
 19. 482
 20. 482
 21. 482
 22. 475
 23. 265
 24. -10
 25. - 9
 26. - 8
 27. - 4
 28. - 4
 29. - 4
 30. - 4
 31. - 4

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH MARCH 1990

DOCKET NO. 50-244
 UNIT NAME: R.E. GINNA NUCLEAR POWER PLANT
 DATE April 18, 1990
 COMPLETED BY Robert E. Dodge
 TELEPHONE 315-524-4446 x-396
Ginna Station

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
90-1	3/23/90	S		C	1		-	-	The unit was shutdown for Annual Refueling and Maintenance Outage. The unit remained shutdown at the end of the report period.

1
 F: Forced
 S: Scheduled

2
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

3
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

4
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5
 Exhibit 1 - Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE April 18, 1990
COMPLETED BY Robert E. Dodge
TELEPHONE 1 (315) 524-4446 ext. 396

MONTH March, 1990

The unit was shutdown for the Annual Refueling and Maintenance Outage. The unit remained shutdown at the end of the report period.

