

ENCLOSURE 2

REVISED PAGE FOR THE UNIT 2
AUGUST 1993 MONTHLY OPERATING REPORT

9310190220 931013
PDR ADCK 0500052B
R PDR

D

NRC MONTHLY OPERATING REPORT

REVISED

DOCKET NO. 50-529
UNIT NAME PVNGS-2
DATE 09/10/93
COMPLETED BY B.S.Ecklund
TELEPHONE (602) 340-4068

OPERATING STATUS

1. Unit Name: Palo Verde Nuclear Generating Station, Unit 2
2. Reporting Period: August 1993
3. Licensed Thermal Power (MWt): 3800
4. Nameplate Rating (Gross MWe): 1403
5. Design Electrical Rating (Net MWe): 1270
6. Maximum Dependable Capacity (Gross MWe): 1303
7. Maximum Dependable Capacity (Net MWe): 1221
8. If Changes Occur In Capacity Ratings (Item Numbers 3 Through 7)
Since Last Report, Give Reasons: N/A
9. Power Level to Which Restricted, If Any (Net MWe): None
10. Reasons For Restrictions, If Any: N/A

	Unit 2 Generating Statistics	This Month	Yr. to Date	Cumulative
11.	Hours in Reporting Period	744	5,832	60,936
12.	Hours Reactor was Critical	94.7	1,827.5	41,652.9
13.	Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14.	Hours Generator was On-Line	5.7	1,738.5	40,795.1
15.	Unit Reserve Shutdown Hours	0.0	0.0	0.0
16.	Gross Thermal Energy Generated (MWH)	21,067	6,579,013	150,615,969
17.	Gross Electrical Energy Generated (MWH)	900	2,277,400	52,443,470
18.	Net Electrical Energy Generated (MWH)	0	2,131,321	49,126,040
19.	Unit Service Factor (%)	0.8%	29.8%	66.9%
20.	Unit Availability Factor (%)	0.8%	29.8%	66.9%
21.	Unit Capacity Factor (Using MDC Net)	0.0%	29.9%	66.0%
22.	Unit Capacity Factor (Using DER Net)	0.0%	28.8%	63.5%
23.	Unit Forced Outage Rate (%)	0.0%	6.2%	6.4%

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each): Refueling outage, March 20, 1993. 80 days. Outage extension to repair SG tubes.
25. If Shutdown At End of Report Period, Estimated Date of Start-up: 09/01/93

INITIAL CRITICALITY
INITIAL ELECTRICITY
COMMERCIAL OPERATION

Forecast
03/86
06/86
11/86

Achieved
04/18/86
05/20/86
09/19/86

