

ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9312030122 DOC. DATE: 93/11/22 NOTARIZED: NO DOCKET #
 FACIL: STN-5Q-528 Palo Verde Nuclear Station, Unit 1, Arizona Publi 05000528
 AUTH. NAME AUTHOR AFFILIATION
 LEVINE, J. M. Arizona Public Service Co. (formerly Arizona Nuclear Power
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards Special Rept 1-SR-93-005 re number of steam generator tubes plugged during ISI activities. Insp resulted in 56 tubes plugged in Steam Generator 1 & 126 plugged in Steam Generator 2.

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
 TITLE: OR Submittal: Inservice/Testing/Relief from ASME Code

NOTES: STANDARDIZED PLANT

05000528

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL		RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	
	PDV LA	1	0	PDV PD	1	1
	HOLIAN, B	2	2	TRAN, L	2	2
INTERNAL:	ACRS	6	6	AEOD/DSP/ROAB	1	1
	NRR/DE/EMEB	1	1	NRR/EMCB	1	1
	NUDOCS-ABSTRACT	1	1	OG/L-EDCB	1	0
	OGC/HDS1	1	0	<u>REG FILE</u> 01	1	1
	RES/DSIR/EIB	1	1			
EXTERNAL:	EG&G BROWN, B	1	1	EG&G RANSOME, C	1	1
	NRC PDR	1	1	NSIC	1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 24 ENCL 21

9312030122 931122
PDR ADOCK 05000528
Q PDR

Arizona Public Service Company
PALO VERDE NUCLEAR GENERATING STATION
P.O. BOX 52034 • PHOENIX, ARIZONA 85072-2034

192-00869-JML/BAG/RJR
November 22, 1993

JAMES M. LEVINE
VICE PRESIDENT
NUCLEAR PRODUCTION

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Mail Station P1-37
Washington, D.C. 20555

Dear Sirs:


Subject: Palo Verde Nuclear Generating Station (PVNGS)
Unit 1
Docket No. STN 50-528 (License No. NPF-41)
Special Report 1-SR-93-005
File: 93-020-404

Enclosed please find Special Report 1-SR-93-005 prepared and submitted pursuant to Technical Specification (TS) Surveillance Requirement 4.4.4.5.a and TS 6.9.2. This report discusses steam generator tube plugging in Unit 1. A copy of this Special Report is being forwarded to the Regional Administrator, NRC Region V.

If you have any questions, please contact Burton A. Grabo, Supervisor, Nuclear Regulatory Affairs, at (602) 393-6492.

Sincerely,

300036



JML/TRB/RJR/rv

Enclosure

cc: W. F. Conway (all with attachment)
B. H. Faulkenberry
J. A. Sloan
INPO Records Center

AD47
4672

PALO VERDE NUCLEAR GENERATING STATION UNIT 1

STEAM GENERATOR TUBE PLUGGING

License No. NPF-41

Docket No. 50-528

Special Report 1-SR-93-005

This Special Report is being provided pursuant to Palo Verde Unit 1 Technical Specification (TS) Surveillance Requirement 4.4.4.5.a and TS 6.9.2 to report the number of steam generator tubes plugged as a result of inservice inspection activities. On November 12, 1993, Unit 1 was in Mode 5 (COLD SHUTDOWN) during a refueling outage when inservice inspection of both steam generators was completed. The inspection resulted in the plugging of fifty-six (56) tubes in Steam Generator No. 1 and one hundred twenty-six (126) tubes in Steam Generator No. 2.

Pursuant to TS 4.4.4.5.b, the complete results of the steam generator tube inservice inspection will be submitted by November 12, 1994.

