

PRIORITY 1

ACCELERATED RIDS PROCESSING

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9506020170 DOC. DATE: 95/05/24 NOTARIZED: NO DOCKET #
 FACIL: STN-50-528 Palo Verde Nuclear Station, Unit 1, Arizona Publi 05000528
 STN-50-529 Palo Verde Nuclear Station, Unit 2, Arizona Publi 05000529
 STN-50-530 Palo Verde Nuclear Station, Unit 3, Arizona Publi 05000530

AUTH. NAME AUTHOR AFFILIATION
 STEWART, W.L. Arizona Public Service Co. (formerly Arizona Nuclear Power
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Provides suppl to proposed amend to TS section 3/4.3.2
 which would clarify settings for undervoltage relay trip
 values for Class 1E 4.16kV electrical buses by modifying
 Tables 3.3-4 & 3.3-5 of Section 3/4.3.2.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR / ENCL 0 SIZE: 2
 TITLE: OR Submittal: General Distribution

NOTES: STANDARDIZED PLANT 05000528
 Standardized plant. 05000529
 Standardized plant. 05000530

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD4-2 LA	1	PD4-2 PD	1
	HOLIAN, B	1	TRAN, L	1
	THOMAS, C	1		
INTERNAL:	ACRS	6	<u>FILE CENTER 01</u>	1
	NRR/DE/EMCB	1	NRR/DRCH/HICB	1
	NRR/DSSA/SPLB	1	NRR/DSSA/SRXB	1
	NUDOCS-ABSTRACT	1	OGC/HDS2	1
EXTERNAL:	NOAC	1	NRC PDR	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL
 DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 20 ENCL 0

P
R
I
O
R
I
T
Y

D
O
C
U
M
E
N
T

100

Arizona Public Service Company
P.O. BOX 53999 • PHOENIX, ARIZONA 85072-3999

WILLIAM L. STEWART
EXECUTIVE VICE PRESIDENT
NUCLEAR

102-03367-WLS/AKK/DRL
May 24, 1995

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-37
Washington, DC 20555-0001

Reference: APS Letter 102-02772-WFC/RAB/GEC to NRC, dated December 30, 1993,
Proposed Amendment to Technical Specification Section 3/4.3.2

Dear Sirs:

Subject: Palo Verde Nuclear Generating Station (PVNGS)
Units 1, 2, and 3
Docket Nos. STN 50-528/529/530
Supplement to Proposed Amendment to Technical Specification
Section 3/4.3.2

Pursuant to 10 CFR 50.90, Arizona Public Service Company (APS) submitted the above reference to request amendments to Facility Operating Licenses NPF-41, NPF-51, and NPF-74 for PVNGS Units 1, 2, and 3. The requested amendment would clarify the settings for undervoltage relay trip values for the Class 1E 4.16 kV electrical buses by modifying Tables 3.3-4 and 3.3-5 of Section 3/4.3.2, and by adding Figure 3.3-1.

During its review, the NRC asked APS to provide an upper tolerance for the setting of the degraded voltage relays. APS is preparing an additional submittal which provides a response to a sustained degraded switchyard voltage. This submittal will include calculated upper and lower setpoint tolerances around the nominal value of 3744 volts for the degraded voltage relays. Therefore, APS is withdrawing the degraded voltage relay setting values provided in the above reference (i.e., changes to line VIII(B) of Table 3.3-4 and the change to line 11 of Table 3.3-5). The remainder of the revisions in the reference are unchanged and should be processed accordingly.

By copy of this letter, the Arizona Radiation Regulatory Agency is being notified of this change to the referenced Technical Specification amendment request pursuant to 10 CFR 50.91(b)(1).

020015

9506020170 950524
PDR ADDCK 05000528
P PDR

ADD 1/0

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Supplement to Proposed Amendment to TS Section 3/4.3.2
Page 2

Should you have any questions, please contact Scott A. Bauer at (602) 393-5978.

Sincerely,

A handwritten signature in black ink, appearing to read 'S. A. Bauer', written in a cursive style.

WLS/AKK/DRL/rv

cc: L. J. Callan
K. E. Perkins
B. E. Holian
K. E. Johnston
A. V. Godwin (ARRA)

