

**ENCLOSURE 2**

**REVISED PAGE FOR THE MAY 1995  
UNIT 2 MONTHLY OPERATING REPORT**

9507190338 950713  
PDR ADOCK 05000528  
R PDR

# NRC MONTHLY OPERATING REPORT

## REVISED

DOCKET NO. 50-529  
 UNIT NAME PVNGS-2  
 DATE 06/08/95  
 COMPLETED BY J. D. Fulton  
 TELEPHONE (602) 393-5277

### OPERATING STATUS

1. Unit Name: Palo Verde Nuclear Generating Station, Unit 2
2. Reporting Period: May 1995
3. Licensed Thermal Power (MWt): 3800
4. Nameplate Rating (Gross MWe): 1403
5. Design Electrical Rating (Net MWe): 1270
6. Maximum Dependable Capacity (Gross MWe): 1303
7. Maximum Dependable Capacity (Net MWe): 1221
8. If Changes Occur In Capacity Ratings (Item Numbers 3 Through 7)  
 Since Last Report, Give Reasons: N/A
9. Power Level to Which Restricted, If Any (Net MWe): None
10. Reasons For Restrictions, If Any: N/A

	Unit 2 Generating Statistics	This Month	Yr. to Date	Cumulative
11.	Hours in Reporting Period	744	3,624	76,248
12.	Hours Reactor was Critical	744.0	2,371.1	53,022.8
13.	Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14.	Hours Generator was On-Line	744.0	2,323.5	51,924.4
15.	Unit Reserve Shutdown Hours	0.0	0.0	0.0
16.	Gross Thermal Energy Generated (MWH)	2,742,603	8,485,231	188,729,138
17.	Gross Electrical Energy Generated (MWH)	948,600	2,931,500	65,662,970
18.	Net Electrical Energy Generated (MWH)	894,373	2,741,858	61,435,753
19.	Unit Service Factor (%)	100.0%	64.1%	68.1%
20.	Unit Availability Factor (%)	100.0%	64.1%	68.1%
21.	Unit Capacity Factor (Using MDC Net)	98.5%	62.0%	66.0%
22.	Unit Capacity Factor (Using DER Net)	94.7%	59.6%	63.4%
23.	Unit Forced Outage Rate (%)	0.0%	0.0%	5.8%

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each): N/A

25. If Shutdown At End of Report Period, Estimated Date of Start-up: N/A

	Forecast	Achieved
INITIAL CRITICALITY	<u>03/86</u>	<u>04/18/86</u>
INITIAL ELECTRICITY	<u>06/86</u>	<u>05/20/86</u>
COMMERCIAL OPERATION	<u>11/86</u>	<u>09/19/86</u>

