

**Revised Page
for April 1996**

(9608200100 960813
PDR ADCK 05000528
R PDR)

NRC MONTHLY OPERATING REPORT

CORRECTED COPY

DOCKET NO. 50-528
 UNIT NAME PVNGS-1
 DATE 7/23/96
 COMPLETED BY J. D. Fulton
 TELEPHONE (602) 393-5277

OPERATING STATUS

1. Unit Name: Palo Verde Nuclear Generating Station, Unit 1
2. Reporting Period: April 1996
3. Licensed Thermal Power (MWt): 3800
4. Nameplate Rating (Gross MWe): 1403
5. Design Electrical Rating (Net MWe): 1249
6. Maximum Dependable Capacity (Gross MWe): 1299
7. Maximum Dependable Capacity (Net MWe): 1227
8. If Changes Occur In Capacity Ratings (Item Numbers 3 Through 7)
 Since Last Report, Give Reasons: N/A
9. Power Level to Which Restricted, If Any (Net MWe): None
10. Reasons For Restrictions, If Any: N/A

	Unit 1 Generating Statistics	This Month	Yr. to Date	Cumulative
11.	Hours in Reporting Period	720	2,904	89,904
12.	Hours Reactor was Critical	364.1	2,448.1	60,411.1
13.	Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14.	Hours Generator was On-Line	363.4	2,378.1	59,281.2
15.	Unit Reserve Shutdown Hours	0.0	0.0	0.0
16.	Gross Thermal Energy Generated (MWH)	1,373,041	8,986,110	214,522,314
17.	Gross Electrical Energy Generated (MWH)	472,900	3,090,200	74,200,700
18.	Net Electrical Energy Generated (MWH)	444,198	2,906,111	69,663,832
19.	Unit Service Factor (%)	50.5%	81.9%	65.9%
20.	Unit Availability Factor (%)	50.5%	81.9%	65.9%
21.	Unit Capacity Factor (Using MDC Net)	49.7%	81.4%	63.5%
22.	Unit Capacity Factor (Using DER Net)	48.8%	80.0%	61.0%
23.	Unit Forced Outage Rate (%)	0.0%	6.6%	12.0%

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each): 6th Refueling outage is scheduled for 9/7/96 through 10/27/96 (50 days).
25. If Shutdown At End of Report Period, Estimated Date of Start-up: N/A

INITIAL CRITICALITY	Forecast	Achieved
INITIAL ELECTRICITY	<u>05/85</u>	<u>05/25/85</u>
COMMERCIAL OPERATION	<u>06/85</u>	<u>06/10/85</u>
	<u>12/85</u>	<u>01/28/86</u>

