

**Enclosure 2  
Revised Page  
March 1996  
Monthly Operating Report**

( 9610160442 961009  
PDR ADOCK 05000528  
R PDR )



# NRC MONTHLY OPERATING REPORT

CORRECTED COPY

DOCKET NO. 50-529  
 UNIT NAME PVNGS-2  
 DATE 4/11/96  
 COMPLETED BY J. D. Fulton  
 TELEPHONE (602) 393-5277

## OPERATING STATUS

1. Unit Name: Palo Verde Nuclear Generating Station, Unit 2
2. Reporting Period: March 1996
3. Licensed Thermal Power (MWt): 3800
4. Nameplate Rating (Gross MWe): 1403
5. Design Electrical Rating (Net MWe): 1249
6. Maximum Dependable Capacity (Gross MWe): 1299
7. Maximum Dependable Capacity (Net MWe): 1227
8. If Changes Occur In Capacity Ratings (Item Numbers 3 Through 7)  
 Since Last Report, Give Reasons: N/A
9. Power Level to Which Restricted, If Any (Net MWe): None
10. Reasons For Restrictions, If Any: N/A

Unit 2 Generating Statistics		This Month	Yr. to Date	Cumulative
11.	Hours in Reporting Period	744	2,184	83,568
12.	Hours Reactor was Critical	360.1	1,771.9	59,907.0
13.	Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14.	Hours Generator was On-Line	360.1	1,747.1	58,769.3
15.	Unit Reserve Shutdown Hours	0.0	0.0	0.0
16.	Gross Thermal Energy Generated (MWH)	1,299,310	6,502,203	214,529,816
17.	Gross Electrical Energy Generated (MWH)	453,200	2,261,700	74,591,170
18.	Net Electrical Energy Generated (MWH)	428,480	2,142,955	69,907,706
19.	Unit Service Factor (%)	48.4%	80.0%	70.3%
20.	Unit Availability Factor (%)	48.4%	80.0%	70.3%
21.	Unit Capacity Factor (Using MDC Net)	46.5%	79.8%	68.5%
22.	Unit Capacity Factor (Using DER Net)	45.7%	78.4%	65.9%
23.	Unit Forced Outage Rate (%)	0.0%	2.9%	5.3%

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each): N/A
25. If Shutdown At End of Report Period, Estimated Date of Start-up: N/A

	Forecast	Achieved
INITIAL CRITICALITY	<u>03/86</u>	<u>04/18/86</u>
INITIAL ELECTRICITY	<u>06/86</u>	<u>05/20/86</u>
COMMERCIAL OPERATION	<u>12/86</u>	<u>09/19/86</u>

